

Enforcement Orders Signed January 21, 2014

City of Cotulla, Docket No. GUD 10230

City of Cotulla Distribution System (System ID No. 710177), Cotulla, La Salle County, Texas

Rules violated:

49 CFR §192.721(a):

Distribution mains were not patrolled as often as necessary to observe conditions affecting public safety.

49 CFR §192.805(b):

The operator did not ensure that pipeline personnel were qualified to perform covered tasks as required in the written qualification program.

Date violations began: May 12, 2010

Date of compliance: October 15, 2013

Penalty paid: \$3,750.00