

## Agreed Order Signed August 6, 2013

Sandpiper Cove Apartments  
Docket No. GUD 10236

Company ID 4673, Galveston, Galveston County, Texas  
System ID 562032

Rule(s) violated:

The level of cathodic protection for the pipe system(s) listed below did not meet one or more of the criteria specified in Appendix D, Code of Federal Regulations.	Requirement: 49 CFR 192.463(a)
---	--------------------------------

Date violations began: 1/30/2012

Penalty paid: \$2,500