

## Agreed Order Signed October 22, 2013

SILVERCREEK APARTMENT PARTNERS

GUD 10145

SYSTEM ID 160716/RANDALL COUNTY, TEXAS

### VIOLATIONS CITED:

The listed valve(s) which may be necessary for the safe operation of the distribution system, was not checked and serviced at intervals not exceeding 15-months, but at least once each calendar year.	Requirement: 49 CFR 192.747(a)
--	--------------------------------

### VIOLATION NOTES:

Section Valve	Emergency Valves	Valves located at the master meters, and at riser inlet to each building.	The operator had no records that would demonstrate that emergency key valves were maintained per the minimum requirements according to 49 CFR 192-747. This alleged violation was assessed in the previous evaluation on 11/23/2010 (#103422) and there were no records that were able to demonstrate that corrections were made to bring about compliance.
------------------	---------------------	---	---

Date violations began: January 25, 2012

Date of compliance: October 22, 2013

Penalty Paid: \$500.00