

CHECK LIST FOR STATIONARY LPG INSTALLATION PROPOSALS

Application received: Date _____

Installation File Name _____

Installer's License No. _____ Qualified Installer YES NO Expires _____

Filing Fee Rec'd \$50 PCN _____ Resub. Fee Rec'd \$30 PCN _____

Type of Installation: _____

Aggregate WC of **current** storage _____ Number of tank(s) to be installed _____

Size of tank(s) to be installed _____ Total WC upon completion _____

Container Information complete YES NO

Mfg's Name: Tank 1 _____, Tank 2 _____, Tank 3 _____

Serial No.: Tank 1 _____, Tank 2 _____, Tank 3 _____

Water Capacity: Tank 1 _____, Tank 2 _____, Tank 3 _____

Year Built: Tank 1 _____, Tank 2 _____, Tank 3 _____

Working Press: Tank 1 _____, Tank 2 _____, Tank 3 _____

Container(s) to be installed: NEW USED BOTH

Information needed to verify container status: Mfg Data Rpt. Form 23 Form 8

Received: Date: _____

Distance from proposed container(s) to: (check if distance listed meets requirement)

Nearest Highway or Public Street _____'

Bulkhead _____' (10') 9.143(d)(4)

Electrical Transmission Line _____' (6') 6.4.5.12

Nearest Building _____' Table 6.3.1 _____'

Other type fuel container (gasoline) _____' (20') 6.4.5.5

Adjacent LPG Container _____' Table 6.3.1 _____'

Property Line – N _____' S _____' E _____' W _____' Table 6.3.1 _____'

NOTIFICATION STATUS (9.102) Applicable YES NO

Certified Survey Plat (**with 500' radius marked**) Rec'd: Date _____

Real property owners listed on survey plat or separate list indicating property owned rec'd?

YES NO Date _____

LPG Form 500a(s) rec'd: Date _____

Number of **real** property owners: _____ Number of owners **properly** notified: _____

Certified mail receipts rec'd: Date _____

Latest date notification sent: _____

Property owner's (18 day) Response deadline: _____

RENOTIFICATION INFORMATION (if required) Applicable YES NO

Certified mail receipts rec'd: Date _____

Green return receipts cards rec'd: Date _____

Latest date notification rec'd: _____

Property owner's (18 day) Response deadline: _____

Number of objections rec'd _____ Number of owners with **valid** objections _____

Valid objection reasons stated: _____

INSTALLATION SITE PLAN (check if distance listed meets requirement)

Site plan submitted?

Container location indicated?

Location & distances to Bulkhead: Listed? Distance _____' 9.143(d)(4) – 10'

Container to Elec. Tran. Lines: Listed? Distance _____' 6.4.5.12 – 6'

Container to other type fuel containers: Listed? Distance _____' 6.4.5.5 – 20'

Container to bldg's & structures: Listed? Distance _____' Table 6.3.1 – _____' ←↓

Container to property lines: Listed? N _____' S _____' E _____' W _____'

Location & distances to Remote ESV: Listed? Distance _____' 9.143(e) – _____ - 100'

Container to Roadway ROW: Listed? Distance _____'

Container to Hwy ROW: Listed? Distance _____'

Container to Railroad: Listed? Distance _____'

Container to Pipeline: Listed? Distance _____'

Route of vehicular traffic around container: Listed?

Location & distances of any electrically operated material handling equipment (pumps, compressors, etc) :

Listed? Distance _____' Table 6.3.9 – 10' (For non-explosion proof/source of ignition)

Adjacent Container's in Multi-container installation: Listed? Distance _____' Table 6.3.1 _____'

Does the installation include a transfer system? YES NO *If the point of transfer of containers located outdoors in stationary installations is not located at the container, it shall be located in accordance with Table 6.5.3 Point of transfer is defined as The location where connections and disconnection are made or where LP-gas is vented to the atmosphere in the course of transfer operations. (3.3.54)*

If Yes, then the following apply per Table 6.5.3:

Is the location of the point of transfer shown, including distance from BH/container? YES NO

Buildings with fire-resistive walls: Distance _____' (10')*

Buildings with other than fire-resistive walls: Distance _____' (25')*

Building wall openings or pits at or below point of transfer: Distance _____' (25')*

Line of adjoining property that can be built upon: (25')*

N _____' S _____' E _____' W _____'

Outdoor places of public assembly: Distance _____' (50')*

Public Ways (streets, thoroughfares, sidewalks): Distance _____' (25'* or 10' for vehicle fuel dispensers)

Driveway: Distance _____' (5') *Does not include vehicle fuel dispensers*

Railroad track centerlines: Distance _____' (25')

Containers other than those being filled: Distance _____' (10')

Flammable & Class II combustible liquid dispensers: Distance _____' (10') See NFPA 30

Flammable & Class II combustible liquid containers: Distance _____' (20')

**See 6.5.4.4 The distances shall be reduced by ½ where the system incorporates the provisions of low emission transfers in 6.26.5 – for unground or mounded containers only (9.403)*

Lease agreement required: YES NO Date: _____

For new facility locations – is facility accessed from a public hwy under jurisdiction of DOT? YES NO

If yes, then has a statement or permit from DOT been provided? YES NO Date: _____

Is the installation a Site Built Subdivision or does the piping to be installed leave the property? YES NO

If YES, then the installation must comply with CFR 192.1 (Pipeline Safety Rules). The name of the pipeline installer should be obtained and given to Pipeline Safety to verify the items in 192.1 are covered.

Unusual topographical or geographical features? _____

Other activities, features, or safety concerns? _____

Review of Submitted Application (deficiencies noted & listed below):

Action Taken: _____

Current Status of Proposal: _____