



CITY OF LODI

PUBLIC WORKS DEPARTMENT

Water Valve Installation Materials List

All Water Valves & Materials shall be Class 150B with 2" square operating nuts, open left (clockwise to close) and shall conform to AWWA Standard C-504 for Rubber Seated Butterfly Valves and City of Lodi Construction Specs 6-7602.

AWWA Approved Valves:

- Mueller RS and Butterfly
- M+H/Clow/Kennedy RS and Butterfly
- American Darling RS Gate valves
- Waterous RS Gate valve
- AVK RS Gate valves

Sheet 2 of 2

Dr.	No.	Date	Revision	Appr.	Approved By:	Date	STD PLAN
KT					<i>F. Wally Sandelin</i> F. Wally Sandelin City Engineer R.C.E. 39895	12/28/00	402
Ch.	WS						
Date		12/00					