



# CITY OF LODI

PUBLIC WORKS DEPARTMENT

## Double Check Valve Assembly Materials List

Size	Vertical Clearance min / max		Box or Vault / Lid (See Note 3) (min)
1"	8"	18"	Christy B40 or Bes C40W Box/ Christy B40-61D or Bes 61D75
1-1/2"	10"	20"	Christy B48 or Bes C48W Box/ Christy B48-62D or Bes 62D85
2"	10"	20"	Christy B48 or Bes C48W Box/ Christy B48-62D or Bes 62D85
3"	16"	30"	4'x4' / Split, hinged lid } Christy B52 or Bes C52W box/ 4'x4' / similar to Forni- } Christy or Bes 62D90 7'x5' / HAL-Lucero 7'x5' / Assembly
4"	20"	36"	
6"	24"	40"	
8"	30"	48"	

Sheet 2 of 2

Dr. KT	No.	Date	Revision	Appr.	Approved By: <i>F. Wally Sandelin</i>	12/28/00	STD PLAN
Ch. WS					F. Wally Sandelin City Engineer R.C.E. 39895	Date	<b>411</b>
Date 12/00							