



# CITY OF LODI

PUBLIC WORKS DEPARTMENT

## 1-1/2" & 2" Water Service Materials List

Fitting (a)	Size	Basic Feature	Inlet Connection	Outlet Connection	Manufacturer's Nos.
Saddles 1	1-1/2" & 2"	For C1-AC & Ductile Iron Pipe  Ductile Iron Double Strap Saddle  <u>No Single Strap Saddles</u>		IPT	Rockwell 313 Apac 102 Other manufacturers with similar designs o.k.
Saddles	1-1/2" & 2"	For C900 Pipe		IPT	Romac 101S Mueller H1349 with 1P thread
Corp. Stop 2	1-1/2"	Oriseal or Ball Valve	Saddle IPT 1-1/2" 1-1/2" IPT	1-1/2" PJ CTS	All PJ must have inserts 1-1/2" J1935 with insert J2805 1-1/2" FB1100 with insert 54 1-1/2" Mueller H15023 with insert 506139
Corp. Stop	1-1/2"	Oriseal or Ball valve	1-1/2" Saddle IPT 1-1/2" IPT	1-1/2" IPT	All PJ must have inserts 1-1/2" FB500 with C14-66 FIPT CTS PJ adapter with Insert 1-1/2" J1943, J2607 FIPT Adapter CTS with Insert 1-1/2" Mueller H9969 with H15451 CTS Adapter with Insert 506139
Corp. Stop	2"	Oriseal or Ball Valve	2" Saddle IPT 2" IPT	2" PJ CTS	All PJ must have inserts 2" J1935 with insert J2805 2" FB1100 with insert 55 2" Mueller H15023 with insert 506141
Corp. Stop	2"	Oriseal or Ball Valve	2" IPT	2" IPT	All PJ must have inserts 2" FB 500 with C14-77 IPT CTS Adapter with Insert 2" J1943 with J2607 with Insert 2" Mueller 9969 with H15451 CTS Adapter with insert 506141

Sheet 2 of 4

Dr. KT	No.	Date	Revision	Appr.	Approved By:	STD PLAN	
Ch. WS	1	9/03	ADDED END CAP		 F. Wally Sandelin City Engineer R.C.E. 39895	<b>412</b>	
Date	2	2/04	REVISED PAGE 4				2/2/05
12/00	3	2/05	REVISED PAGE 1				Date