



CITY OF LODI

PUBLIC WORKS DEPARTMENT

1-1/2" & 2" Water Service Materials List

Fitting (a)	Size	Basic Feature	Inlet Connection	Outlet Connection	Manufacturer's Nos.
Service Box 9	1-1/2"	All Lids to read Water Holes in Lids for touch read Probe will be required if a meter is to be installed			Christy B36 or Bes C36W Box Christy B36D or Bes D70 Lid (Flush Fit foot Traffic, Grass Areas) Christy FI36D (Foot Traffic, Grass Areas, Flush fit) Christy B36-61D 1/4" Steel Checker Plate (Driveways, Sidewalks) Christy B1730 Full Vehicular Traffic Box
	2"	All Lids to read Water Holes in Lids for touch read Probe will be required if a meter is to be installed			Christy B40 or Bes C40W Box Christy B40-61D of Bes 61D75 Lid 1/4" Steel Plate Christy B24x36 Full Vehicular Traffic Box
90° PJ Elbow			1-1/2" OR 2" PJ CTS	1-1/2" OR 2" PJ CTS	1-1/2" Ford L44-46 with Insert Jones 1-1/2" J2611 with Insert 2" Ford L44-77 1-1/2", 2" Mueller H-15526 with Insert
90° Elbow 10			1-1/2" OR 2"	1-1/2" OR 2"	PVC

a. Alternate Fittings must be approved by the City Engineer.

Dr. KT	No.	Date	Revision	Appr.	Approved By:	 F. Wally Sandelin City Engineer R.C.E. 39895	2/2/05 Date	STD PLAN	
Ch. WS	1	9/03	ADDED END CAP		 F. Wally Sandelin City Engineer R.C.E. 39895			2/2/05 Date	<h1>412</h1>
Date 12/00	2	2/04	ADDED PVC 90 ELBOW						
	3	2/05	REVISED PAGE 1						