Bay Area Air Quality Management District

939 Ellis Street San Francisco, CA 94109 (415) 771-6000

Proposed

MAJOR FACILITY REVIEW PERMIT

Issued To: City of Santa Rosa Wastewater Treatment Facility #A1403

> **Facility Address:** 4300 Llano Road Santa Rosa CA 95407

> Mailing Address: 4300 Llano Road Santa Rosa CA 95407

Responsible Official Miles Ferris, Dir. Of Utilities

Facility Contact Scott StinebaughDean Paige, ManagerEnvironmental Compliance Officer (707) 543-33503375

(707) 543-3350

Type of Facility:Municipal Wastewater
Treatment Facility
(Publicly Owned Treatment Works)Primary SIC:4952Product:Treated Municipal Wastewater

BAAQMD Engineering Division Contact Randy Frazier, P.E.

ISSUED BY THE BAY AREA AIR QUALITY MANAGEMENT DISTRICT

Jack P. Broadbent, Executive Officer/Air Pollution Control Officer

Date

TABLE OF CONTENTS

I.	STANDARD CONDITIONS	3
II.	EQUIPMENT LIST	7
III.	GENERAL APPLICABLE REQUIREMENTS	9
IV.	SOURCE-SPECIFIC APPLICABLE REQUIREMENTS	11
V.	SCHEDULE OF COMPLIANCE	22
VI.	PERMIT CONDITIONS	22
	A. SOURCE SPECIFIC PERMIT CONDITIONS	22
VII.	APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS	33
VIII.	TEST METHODS	40
IX.	GLOSSARY	42

I. STANDARD CONDITIONS

A. Administrative Requirements

The permit holder shall comply with all applicable requirements in the following regulations: **BAAQMD** Regulation 1 - General Provisions and Definitions (as amended by the District Board on 5/2/01): SIP Regulation 1 - General Provisions and Definitions (as approved by EPA through 8/27/99); BAAOMD Regulation 2, Rule 1 - Permits, General Requirements (as amended by the District Board on 8/1/01); SIP Regulation 2, Rule 1 - Permits, General Requirements (as approved by EPA through 2/25/99); BAAOMD Regulation 2, Rule 2 - Permits, New Source Review (as amended by the District Board on 5/17/00); SIP Regulation 2, Rule 2 - Permits, New Source Review and Prevention of Significant Deterioration (as approved by EPA through 2/25/99); BAAQMD Regulation 2, Rule 4 - Permits, Emissions Banking (as amended by the District Board on 5/17/00); SIP Regulation 2, Rule 4 - Permits, Emissions Banking (as approved by EPA through 2/25/99); and BAAOMD Regulation 2. Rule 6 - Permits. Major Facility Review (as amended by the District Board on 5/2/01).

B. Conditions to Implement Regulation 2, Rule 6, Major Facility Review

- 1. This Major Facility Review Permit <u>was issued on [___] and expires on [when</u> issued, enter 5th anniversary of issue date]. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than [when issued, enter date 6 months prior to permit expiration date] and no earlier than [when issued, enter date 12 months prior to expiration date]. **If a complete application for renewal has not been submitted in accordance with this deadline, the facility may not operate after** [when issued, enter 5th anniversary of issue date]. (Regulation 2-6-307, 404.2, & 409.6; MOP Volume II, Part 3, §4.2)
- 2. The permit holder shall comply with all conditions of this permit. The permit consists of this document and all appendices. Any non-compliance with the terms and conditions of this permit will constitute a violation of the law and will be grounds for enforcement action; permit termination, revocation and re-issuance, or modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP Volume II, Part 3, §4.11)
- 3. In the event any enforcement action is brought as a result of a violation of any term or condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or condition shall not be a defense to such enforcement action. (MOP

I. Standard Conditions

Volume II, Part 3, §4.11)

- 4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)
- 5. The filing of a request by the facility for a permit modification, revocation and reissuance, or termination, or <u>the filing</u> of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
- 6. This permit does not convey any property rights of any sort, or any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
- 7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
- 8. Any records required to be maintained pursuant to this permit which the permittee considers to contain proprietary or trade secret information shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District's Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
- 9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B Public Information, Confidentiality of Business Information. (40 CFR Part 2)
- 10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions <u>or the potential to emit</u> for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)
- 11. The responsible official shall certify all documents submitted by the facility pursuant to the major facility review permit. The certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. The certifications shall be signed by a responsible official for the facility. (MOP Volume II, Part 3, §4.11)

C. Requirement to Pay Fees

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

I. Standard Conditions

D. Inspection and Entry

Access to Facility: The permit holder shall provide reasonable access to the facility and equipment which is subject to this permit to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

E. Records

- 1. <u>The permit holder must provide any information, records, and reports requested or specified by the APCO. (Regulation 1-441, Regulation 2-6-409.4)</u>
- 2. Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of creation of the record. (Regulation 2-6-501, Regulation 3; MOP Volume II, Part 3, §4.7)

F. Monitoring Reports

Reports of all required monitoring must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. The first reporting period for this permit shall be [date of issuance] to [six months later]. The report shall be submitted by [one month after end of reporting period]. Subsequent reports shall be for the following periods: [1st through 30th or 31st] and [1st through 30th or 31st], and are due on the last day of the month after the end of the reporting period. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions. The reports shall be sent to the following address:

Director of Compliance and Enforcement
Bay Area Air Quality Management District
939 Ellis Street
San Francisco, CA 94109
Attn: Title V Reports
*

(Regulation 2-6-502, Regulation 3; MOP Volume II, Part 3, §4.7)

G. Compliance Certification

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification period will be 1st to 30th or 31st. The certification shall be submitted by 30th or 31st of each year. The certification must list each applicable requirement, the compliance status, whether compliance was continuous or intermittent, the method used to determine compliance, and any other specific information required by the permit. The permit holder may satisfy this requirement through submittal of District-generated Compliance Certification forms. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification shall be sent to the

I. Standard Conditions

Environmental Protection Agency at the following address:

Director of the Air Division USEPA, Region IX 75 Hawthorne Street San Francisco, CA 94105 Attention: Air-3

(MOP Volume II, Part 3, §4.5 and 4.15)

H. Emergency Provisions

- 1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)
- 2. The permit holder may seek relief from enforcement action for a violation of any of the terms and conditions of this permit eaused by conditions beyond the permit holder's reasonable control by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The Hearing Board will determine after notice and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. Any variance granted by the Hearing Board from any term or condition of this permit which lasts longer than 90 days will be subject to EPA approval. (MOP Volume II, Part 3, §4.8)
- 3. Notwithstanding the foregoing, The granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement-unless the Major Facility Review Permit has been modified pursuant to Regulation 2, Rule 6. (MOP Volume II, Part 3, §4.8)

I. Severability

In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

J. Miscellaneous Conditions

1. <u>The maximum capacity for each source as shown in Table II-A is the maximum allowable capacity.</u> Exceedance of the maximum allowable capacity for any source is a violation of Regulation 2, Rule 1, Section 301. (Regulation 2-1-301)

II. EQUIPMENT LIST

Table II A - Permitted Sources

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. <u>The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.</u>

		1	1	1
S-#	Description	Make or Type	Model	Capacity
S-3	Compost BayFacil, 31E3 sq ft	<u>N/A</u>	Custom	36,500 tons<u>31,000 sq ft</u>
S-4	Stockpiles/Finished Compost & Yard Waste	<u>N/A</u>	Custom	36,500 tons
S-5	Trommel Screens, Portable	<u>N/A</u>	Custom	36,500 tons
S-17	Irrigation Ponds <u>Reclaimed Water</u> Pond C, 216 MM Gal Cap	<u>N/A</u>	Custom	60-216 MM gal /day capacity
S-18	Irrigation PondsReclaimed Water Pond D, 358 MM Gal Cap	<u>N/A</u>	Custom	37-<u>358</u> MM gal/day capacity
S-28	Hot water Boilers (2) (digester gas, natural gas)	Cleaver Brooks	CB-125	8.4 MM Btu/hr <u>each</u>
S-29	Internal Combustion lean burn engine #1 (digester gas, natural gas)	Waukesha	L7042G0	750 h.p. before 6/15/97 1160 h.p . after 6/15/97
S-30	Internal Combustion lean burn engine #2 (digester gas, natural gas)	Waukesha	L7042G0	750 h.p. before 6/15/97 1160 h.p. after 6/15/97
S-31	Internal Combustion lean burn engine #3 (digester gas, natural gas)	Waukesha	L7042G0	750 h.p. before 6/15/97 1160 h.p <u>HP</u> . after 6/15/97
<u>S-32</u>	Waste Recycle Grinder, Diesel Fired	John Deere	<u>375JD</u>	<u>375 HP</u>
<u>S-33</u>	Emergency Standby Generator #1, Diesel Fired	<u>Caterpillar</u>	<u>3516</u>	<u>2836 HP, 2000 KW</u>
<u>S-34</u>	Emergency Standby Generator #2, Diesel Fired	<u>Caterpillar</u>	3516	2836 HP, 2000 KW
<u>S-35</u>	Internal Combustion lean burn engine #4 (digester gas, natural gas)	<u>Waukesha</u>	L7042GL	<u>1160 HP, 800 KW</u>
<u>S-36</u>	Diesel Engine Compressor, portable	John Deere	<u>300</u>	<u>70 HP</u>
<u>S-37</u>	Diesel Engine Pump, portable	<u>Deutz</u>	<u>F4L912144</u> 132	<u>51 HP</u>
S-38	Diesel Engine Pump, portable	Deutz	F4L912	51 HP
S-100	Municipal Wastewater Treatment Plant	Custom	<u>N/A</u>	20-21.3 MM gal/day calendar month average, dry weather 42 MM gal/day, calendar month average, wet weather
S-110	Preliminary Treatment <u>: Aeration +</u> Settling + Flotation	Custom	Custom	20 <u>42</u> MM gal/day
S-120	Primary Treatment: Sedimentation +	Custom	Custom	20-42_MM gal/day

II. Equipment List (continued)

Table II A - Permitted Sources Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.					
S-#	Description	Make or Type	Model	Capacity	
	Flotation				
S-130	Flow Equalization <u>; 2 Tanks, 6.4 MM</u> gal each	Custom	Custom	<u>20-42 MM gal/day</u>	
S-140	Secondary Treatment <u>, 2 Equalization</u> Basins, 4 Aeration Basins	Custom	Custom	20_42 MM gal/day	
S-150	Secondary Clarifiers: 5 Clarifiers	Custom	Custom	<u>20-42 MM gal/day</u>	
S-160	Tertiary Treatment, 14 Filter Cells	Custom	Custom	20-<u>42</u> MM gal/day	
S-170	Disinfection, UV Light Treatment	Custom	Custom	20-<u>42</u> MM gal/day	
S-180	Sludge Handling Processes <u>, 4 Belt</u> Filter Presses	Custom	Custom	20- <u>42</u> MM gal/day	
S-190	Anaerobic Digestors Digesters; 4 Digesters	Custom	<u>Custom</u>	M gal/day	

Table II B – Abatement Devices

A-#	Description	Source(s)	Applicable	Operating	Required
		Controlled	Requirement	Parameters	Efficiency
A-1	Biofilter 50,000 sq. ft	S-3, S-4,	7-300	None Listed	90%
		S-5			
<u>A-35</u>	Digester Gas Flare	<u>S-190</u>	BAAQMD	None Listed	<u>N/A</u>
			<u>Reg. 1-301</u>		

III. GENERAL APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements will not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit.

The dates in parenthesis in the Title column identify the versions of the regulations being cited and are, as applicable:

- 1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors
- 2. Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full language of SIP requirements is on the EPA Region 9 website. The address is http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Ba y+Area+Air+Quality+Management+District-Agency-Wide+Provisions

The address is included in Appendix A of this permit.

NOTE:

There are differences between the current BAAQMD rules and the versions of the rules in the SIP. All sources must comply with both versions of the rule until US EPA has reviewed and approved the District's revision of the regulation.

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	Description of Requirement	(Y/N)
BAAQMD Regulation 1	General Provisions and Definitions (11/3/93)	Ν
SIP Regulation 1	General Provisions and Definitions (11/10/82)	Y
BAAQMD Regulation 4	Air Pollution Episode Plan (3/20/91)	Ν
SIP Regulation 4	Air Pollution Episode Plan (8/06/90)	Y
BAAQMD Regulation 5	Open Burning (11/2/94)	Ν
SIP Regulation 5	Open Burning (5/3/84)	Y
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)	Ν

Table IIIGenerally Applicable Requirements

III. General Applicable Requirements

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	Description of Requirement	(Y/N)
SIP Regulation 6	Particulate Matter and Visible Emissions (5/3/84)	Y
BAAQMD Regulation 7	Odorous Substances (3/17/82)	Ν
BAAQMD Regulation 8, Rule 1	Organic Compounds - General Provisions (6/15/94)	Y
SIP Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (11/16/83)	Y
BAAQMD Regulation 8, Rule 4	Organic Compounds-General Solvent and Surface Coating Operations (12/20/95)	Y
BAAQMD Regulation 8, Rule 16	Organic Compounds-Solvent Cleaning Operation (12/20/95)	Y
BAAQMD Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (12/20/95)	
SIP Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (3/22/95)	Y
BAAQMD Regulation 8, Rule 51	Organic Compounds - Adhesive and Sealant Products (12/20/95)	Ν
BAAQMD Regulation 9, Rule 1	Inorganic Gaseous Pollutants-Sulfur Dioxide (3/15/95)	Ν
SIP Regulation 9, Rule 1	Inorganic Gaseous Pollutants - Sulfur Dioxide (5/3/84)	Y
BAAQMD Regulation 9, Rule 2	Inorganic Gaseous Pollutants-Hydrogen Sulfide (3/17/82)	Ν
BAAQMD Regulation 11, Rule 2	Hazardous Pollutants - Asbestos Demolition, Renovation and Manufacturing (12/4/91)	Y
BAAQMD Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (7/11/90)	
SIP Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (9/2/81)	Y

Table IIIGenerally Applicable Requirements

IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parenthesis in the Title column identify the versions of the regulations being cited and are, as applicable:

- 1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board
- 2. Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit condition cited is included in Section VI, Permit Conditions, of this permit. <u>The full language of SIP requirements is on the EPA Region 9 website at:</u> <u>http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions.1.The address is included in Appendix A of this permit. All other text may be found in the regulations themselves.</u>

Table IV – ASource-specific Applicable Requirements

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-301	Ringelmann Number 1 Limitation	Ν	
6-401	Appearance of Emissions	Y	
<u>SIP</u>	PROVISIONS NO LONGER IN CURRENT RULE		
Regulation 6	Particulate Matter and Visible Emissions (6/16/83)		
6-301	Ringelmann Number 1 Limitation (9/5/79)	Υ^{1}	
BAAQMD	Odorous Substances (3/17/82)	Ν	
Regulation 7			
7-303	Limit on Odorous Compounds	Ν	
BAAQMD	Organic Compounds-Miscellaneous Operation (6/15/94)		
Regulation 8,			
Rule 2			
<u>8-2-301</u>	Miscellaneous Operations Standards	<u>Y</u>	
BAAQMD			
Condition			

S-3 Compost bay, S-4 Stockpiles, S-5 Screens

Table IV – ASource-specific Applicable Requirements

S-3 COMPOST BAY, S-4 STOCKPILES, S-5 SCREENS

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
#12848	Description of Requirement		Dutt
Part 1	Ringelmann limit (basis: BACT, 1-301)	Y	
<u>Part 2</u>	Biofilter source test requirement (Basis: Reg 7)	N	
Part 3	Throughput limit (basis: cumulative increase)	Y	
Part 4	Minimize Particulate Emissions (basis: 6-301)	Y	
<u>Part 5</u>	Minimum processing time (basis: Reg 7)	<u>N</u>	
Part 6	Odor Limitation (basis: 7-301)	Ν	
Part 7	Daily Record Keeping of usage (basis: cumulative increase)	Y	

Table IV - BSource-specific Applicable Requirements

S-17, S-18 IRRIGATION RECLAIMED WATER PONDS DIGESTORS

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Organic Compounds-Miscellaneous Operation (6/15/94)	Y	
Regulation 8,			
Rule 2			
8-2-301	Miscellaneous Operations	Y	

<u>Table IV - C</u> <u>Source-specific Applicable Requirements</u>

S-28 HOT WATER BOILERS (2), BURNING NATURAL AND DIGESTER GAS

<u>Applicable</u> <u>Requirement</u>	Regulation Title or Description of Requirement	<u>Federally</u> <u>Enforceable</u> <u>(Y/N)</u>	<u>Future</u> <u>Effective</u> <u>Date</u>
BAAQMD	Particulate and Visible Emissions (12/19/90))		
Regulation 6			
<u>6-301</u>	Ringelmann No. 1 Limitation	<u>Y</u>	
<u>6-305</u>	Visible Particulates	<u>Y</u>	
<u>6-310</u>	Particulate Weight Limitation	Y	
<u>6-310.3</u>	Particulate Concentration Correction to 6% Oxygen, Dry	Y	

<u>Table IV - C</u> <u>Source-specific Applicable Requirements</u>

S-28 HOT WATER BOILERS (2), BURNING NATURAL AND DIGESTER GAS

		<u>Federally</u>	<u>Future</u>
<u>Applicable</u>	Regulation Title or	Enforceable	Effective Data
Requirement BAAOMD	<u>Description of Requirement</u> Organic Compounds-Miscellaneous Operation (6/15/94)	<u>(Y/N)</u>	<u>Date</u>
BAAQNID Regulation 8,	Organic Compounds-Miscenaneous Operation (0/15/94)		
Rule 2			
8-2-301	Miscellaneous Operations Standards	Y	
BAAQMD			
Regulation 9,	Inorganic Gaseous Pollutants - Sulfur Dioxide (3/15/95)		
Rule 1			
9-1-301	Limitations on Ground Level Concentrations	<u>Y</u>	
9-1-302	General Emission Limitations	<u>Y</u>	
BAAQMD	Inorganic Gaseous Pollutants-NOx and CO from Industrial,		
Regulation 9	and Commercial Boilers, Steam Generators, and Process		
Rule 7	Heaters(9/15/93)		
9-7-111	Limited Exemption, Low Fuel Usage	<u>NY</u>	
9-7-304	Low Fuel Usage Requirements	<u>NY</u>	
9-7-304.1	Oxygen concentration limit	<u>NY</u>	
9-7-304.2	Tuning requirement	<u>NY</u>	
9-7-304.3	Emission limits	<u>NY</u>	
BAAQMD			
Condition			
<u>#1541</u>			
<u>Part 1</u>	Allowable fuel type (Basis: Cumulative Increase)	<u>Y</u>	
<u>Part 2</u>	Thermal Capacity limitation (Basis: Cumulative Increase)	<u>Y</u>	
Part 3	Annual tune-up requirement (Basis: 9-7-304.2)	<u>Y</u>	
Part 4	Recordkeeping (Basis: 2-6-501)	<u>Y</u>	

Table IV - DSource-specific Applicable RequirementsS-29, S-30, S-31 INTERNAL COMBUSTION ENGINES AT 1160750 HPH-P.

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Organic Compounds-Miscellaneous Operation (6/15/94)		
Regulation 8,			
Rule 2			
8-2-301	Miscellaneous Operations Standards	<u>Y</u>	
BAAQMD	NOx and CO requirements for Stationary Internal Combustion	N	
Regulation 9	Engines (1/20/93)		
Rule 8			
9-8-301	Emission Limits - Fossil Derived Fuel Gas	<u>NY</u>	
9-8-301.2	NOx Emission Limit for Lean Burn Engines	<u>NY</u>	
9-8-301.3	CO Emission Limit for Lean Burn Engines	<u>NY</u>	
9-8-302	Emission Limits - Waste Derived Fuel Gas	<u>NY</u>	
9-8-302.1	NOx Emission Limit for Lean Burn Engines	<u>NY</u>	
9-8-302.3	CO Emission Limit for Lean Burn Engines	N <u>Y</u>	
BAAQMD	Operating Limit (basis: cumulative increase)	¥	
Condition	(Permit Condition effective until 6/15/97)		
# 2612			
BAAQMD	(Permit Condition effective after 6/15/97)		6/15/97
Condition			
#11031			
Part 1	NOx Limit (basis: Regulation 9-8-302.1, cumulative increase)	¥	6/15/97
Part 2	Startup Test - (basis: Regulation 9-8-501)	N	6/15/97
Part 3	Periodic Monitoring for NOx (basis: Regulation 2-6-409.2)	¥	6/15/97
Part 4	Records (basis: cumulative increase, BAAQMD Regulation	¥	6/15/97
	2-6-501)		
BAAQMD			
Condition			
<u>18867</u>			
<u>Part 1</u>	NOx Limit (Basis: Reg 9-8-301.2, 302.1)	<u>Y</u>	<u>6/15/97</u>
Part 2	CO Limit (Basis: Reg 9-8-301.3, 302.1)	<u>Y</u>	<u>6/15/97</u>
Part 3	Flowmeters Required (basis: 1-441, Cumulative Increase)	<u>Y</u>	<u>5/15/97</u>
Part 4	Periodic Monitoring for NOx, CO (basis: Reg 2-6-309.2409.2)	<u>Y</u>	<u>5/15/97</u>
Part 5	Records (basis: Reg 2-6-409.2501)	Y	5/15/97

<u>Table IV-E</u> <u>Source-specific Applicable Requirements</u>

S-32 -WASTE RECYCLE GRINDER, DIESEL FIRED

		Federally	<u>Future</u>
<u>Applicable</u>	Regulation Title or	<u>Enforceable</u>	Effective
<u>Requirement</u>	Description of Requirement	<u>(Y/N)</u>	<u>Date</u>
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
<u>6-301</u>	Ringelmann No. 1 Limitation	<u>¥</u>	
<u>6-303</u>	Ringelmann No. 2 Limitation		
<u>6-303.1</u>	Internal combustion engines below 1500 cubic inches displacement	<u>Y</u>	
	or standby engines		
<u>6-305</u>	Visible Particulates	<u>Y</u>	
<u>6-310</u>	Particulate Weight Limitation	<u>Y</u>	
<u>6-401</u>	Appearance of Emissions	<u>Y</u>	
BAAQMD	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
Regulation			
<u>9, Rule 1</u>			
<u>9-1-301</u>	Limitations on Ground Level Concentrations	<u>Y</u>	
<u>9-1-302</u>	General Emission limitations	$\underline{\mathbf{Y}}$	
<u>9-1-304</u>	Fuel Burning (Liquid and Solid Fuels)	<u>Y</u>	
BAAQMD		<u>N</u>	
Condition			
<u>#17392</u>			
Part 1	Diesel Throughput Limitation (Basis: Cumulative Increase)	<u>Y</u>	
Part 2	Diesel Sulfur Specification (Basis: Cumulative Increase, Reg 9-1-	<u>Y</u>	
	<u>304)</u>		
Part 3	Hours of Operation (Basis: Cumulative Increase)	Y	
Part 4	Recordkeeping (Basis: Reg 1-441)	<u>Y</u>	
Part 5	Visible Emissions Limitations (Basis: Reg 6-301)	Y	

<u>Table IV-F</u> <u>Source-specific Applicable Requirements</u>

S-33 STANDBY ENGINE/GENERATOR #5, DIESEL FIRED S-34 STANDBY ENGINE/GENERATOR #6, DIESEL FIRED

		Federally	Future
<u>Applicable</u>	Regulation Title or	Enforceable	<u>Effective</u>
<u>Requirement</u>	Description of Requirement	<u>(Y/N)</u>	<u>Date</u>
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
<u>Regulation 6</u>			
<u>6-301</u>	Ringelmann No. 1 Limitation	<u>Y</u>	
<u>6-305</u>	Visible Particulates	<u>Y</u>	
<u>6-310</u>	Particulate Weight Limitation	<u>Y</u>	
<u>6-401</u>	Appearance of Emissions	<u>Y</u>	
BAAQMD	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
Regulation			
<u>9, Rule 1</u>			
<u>9-1-301</u>	Limitations on Ground Level Concentrations	<u>Y</u>	
<u>9-1-304</u>	Fuel Burning (Liquid and Solid Fuels)	<u>Y</u>	
BAAQMD	Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon		
Regulation 9,	Monoxide from Stationary Internal Combustion Engines		
<u>Rule 8</u>	<u>(8/1/01)</u>		
<u>9-8-110.4</u>	Exemption from 9-8 Standards, Emergency Standby Engines	<u>N</u>	
<u>9-8-331</u>	Hours of Operation, Essential Public Service Standby Engines	<u>N</u>	
BAAQMD			
BAAQMD Condition			
Condition	Hours of Operation (Bbasis: Regulation 9-8-331, CA CCR 893115)	<u>Y</u>	
<u>Condition</u> <u>#18856</u>	<u>Hours of Operation (Bbasis: Regulation 9-8-331, CA CCR δ93115)</u> Definition: Emergency Operation (basis: Regulation 9-8-231)	<u> </u>	
<u>Condition</u> <u>#18856</u> part 1			
Condition #18856 part 1 part 2	Definition: Emergency Operation (basis: Regulation 9-8-231)	<u>Y</u>	
Condition #18856 part 1 part 2	Definition: Emergency Operation (basis: Regulation 9-8-231) Definition: Reliability-Related Operation	<u>Y</u>	

<u>Table IV -</u> G <u>Source-specific Applicable Requirements</u>

S-35 INTERNAL COMBUSTION ENGINE, 1160 HP.

Applicable	Regulation Title or	<u>Federally</u> Enforceable	<u>Future</u> Effective
Requirement	Description of Requirement	<u>(Y/N)</u>	Date
BAAQMD		<u> </u>	
Regulation 6			
6-301	Ringelmann No. 1 Limitation	Y	
6-305	Visible Particulates	<u>Y</u>	
<u>6-310</u>	Particulate Weight Limitation	<u>Y</u>	
6-310.3	Particulate concentration corrected to 6% oxygen, dry basis	<u>Y</u>	
<u>6-401</u>	Appearance of Emissions	<u>Y</u>	
BAAQMD	Organic Compounds-Miscellaneous Operation (6/15/94)		
Regulation 8,			
Rule 2			
<u>8-2-301</u>	Miscellaneous Operations Standards	<u>Y</u>	
BAAQMD			
Regulation 9,	Inorganic Gaseous Pollutants - Sulfur Dioxide (3/15/95)		
<u>Rule 1</u>			
<u>9-1-301</u>	Limitations on Ground Level Concentrations	<u>Y</u>	
<u>9-1-302</u>	General Emission Limitations	<u>Y</u>	
<u>9-1-304</u>	Fuel Burning (Liquid and Solid Fuels)	<u>Y</u>	
BAAQMD	NOx and CO requirements for Stationary Internal Combustion		
Regulation 9	Engines (1/20/93)		
Rule 8			
<u>9-8-301</u>	Emission Limits - Fossil Derived Fuel Gas	<u>Y</u>	
<u>9-8-301.2</u>	NOx Emission Limit for Lean Burn Engines	<u>Y</u>	
<u>9-8-301.3</u>	CO Emission Limit for Lean Burn Engines	<u>Y</u>	
<u>9-8-302</u>	Emission Limits - Waste Derived Fuel Gas	<u>Y</u>	
<u>9-8-302.1</u>	NOx Emission Limit for Lean Burn Engines	<u>Y</u>	
9-8-302.3	CO Emission Limit for Lean Burn Engines	<u>Y</u>	
BAAQMD			
<u>Condition</u> <u>19750</u>			
<u>Part 1</u>	Allowable Fuel: Digester Gas and/or Natural Gas with Diesel Pilot (Cumulative Increase)	<u>¥</u>	
Part 2	Thermal Capacity Limitation (Cumulative Increase)	<u>Y</u>	

<u>Table IV -</u> G <u>Source-specific Applicable Requirements</u>

S-35 INTERNAL COMBUSTION ENGINE, 1160 HP.

		Federally	<u>Future</u>
<u>Applicable</u>	Regulation Title or	Enforceable	Effective
<u>Requirement</u>	Description of Requirement	<u>(Y/N)</u>	Date
Part 3	NOx Limits (BACT)	<u>Y</u>	
Part 4	CO Limits (BACT)	<u>Y</u>	
Part 5	Records (basis: Reg 2-6-501)	<u>Y</u>	
Part 6	Flowmeters Required (basis: Reg 1-441, Cumulative Increase)	<u>Y</u>	
Part 7	Initial Performance Test (basis: Reg 2-6-409.2)	<u>Y</u>	
<u>Part 8</u>	Annual Performance Test Requirement (basis: Reg 1-441)	<u>Y</u>	
Part 9	Recordkeeping (basis: Reg 2-6-409.2)	<u>Y</u>	

<u>Table IV-H</u> <u>Source-specific Applicable Requirements</u>

<u>S-36 Diesel Engine Compressor, Portable, John Deere, 70 HP</u> <u>S-37 Diesel Engine Pump, Portable, Deutz, 51 HP</u> <u>S-38 Diesel Engine Pump, Deutz, 51 HP</u>

		Federally	<u>Future</u>
<u>Applicable</u>	Regulation Title or	Enforceable	Effective
<u>Requirement</u>	Description of Requirement	<u>(Y/N)</u>	<u>Date</u>
BAAQMD	<u>Permits – General Requirements (8/1/2001)</u>		
Regulation 2			
<u>1-220.1</u>	Portable Equipment; Single Site Time Limit	<u>Y</u>	
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
<u>6-303</u>	Ringelmann No. 2 Limitation	<u>Y</u>	
<u>6-305</u>	Visible Particulates	Y	
<u>6-310</u>	Particulate Weight Limitation	<u>Y</u>	
<u>6-401</u>	Appearance of Emissions	<u>Y</u>	
BAAQMD	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
<u>Regulation</u>			
<u>9, Rule 1</u>			
<u>9-1-301</u>	Limitations on Ground Level Concentrations	<u>Y</u>	
<u>9-1-304</u>	Fuel Burning (Liquid and Solid Fuels)	<u>Y</u>	
BAAQMD	Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon		

<u>Table IV-</u>H <u>Source-specific Applicable Requirements</u>

S-36 DIESEL ENGINE COMPRESSOR, PORTABLE, JOHN DEERE, 70 HP S-37 DIESEL ENGINE PUMP, PORTABLE, DEUTZ, 51 HP S-38 DIESEL ENGINE PUMP, DEUTZ, 51 HP

<u>Applicable</u> <u>Requirement</u>	Regulation Title or Description of Requirement	<u>Federally</u> <u>Enforceable</u> <u>(Y/N)</u>	<u>Future</u> <u>Effective</u> <u>Date</u>
BAAQMD	<u>Permits – General Requirements (8/1/2001)</u>		
Regulation 2 Regulation 9,	Monoxide from Stationary Internal Combustion Engines		
Rule 8	(8/1/01)		
9-8-110.4	Exemption from 9-8-301, 302, 502 Standards, Emergency Standby Engines	N	
<u>9-8-330</u>	Hours of Operation, Emergency Standby Engines	<u>N</u>	
<u>9-8-331</u>	Hours of Operation, Essential Public Service Standby Engines	N	
<u>9-8-530</u>	Monitoring and Recordkeeping, Emergency Standby Engines	<u>N</u>	
BAAQMD Condition #19192			
<u>Part 1</u>	Eligibility Requirements (2-1-220)	<u>Y</u>	
Part 2	Single Site Operating Hours - Limitation (2-1-220)	<u>Y</u>	
Part 3	Noncompliance Reporting (2-1-403)	<u>Y</u>	
Part 4	Limitations on Diesel Fuel Sulfur Content (9-1-304)	<u>Y</u>	
Part 5	Opacity Limitation (6-301, 302)	<u>Y</u>	
Part 6	Public Nuisance (1-301)	<u>Y</u>	
Part 7	Limitation in Operation Near School (2-1-412)	<u>Y</u>	
Part 8	<u>Recordkeeping (1-441, 9-8-530)</u>	<u>Y</u>	

Table IV-IESource-specific Applicable Requirements

S-100 WASTEWATER TREATMENT PLANT

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Organic Compounds-Miscellaneous Operation (6/15/94)	Y	
Regulation 8,			

Table IV-IE Source-specific Applicable Requirements

S-100 WASTEWATER TREATMENT PLANT

Rule 2			
8-2-301	Miscellaneous Operations	Y	
BAAQMD	Odor Abatement (basis: Reg. 7-1-102)	Ν	
Condition			
#947			
Part 1	Wastewater Throughput (Cumulative Increase)	<u>Y</u>	
Part 2	Consequences of odor complaints (1-301; Public Nuisance)	<u>Y</u>	
Part 3	Recordkeeping (2-6-409.2)	Y	

<u>Table IV-J</u> <u>Source-specific Applicable Requirements</u>

<u>S-110 Pre- Treatment</u>, S-120 PRIMARY TREATMENT, <u>S-130 Flow Equalization, S-140 Secondary Treatment</u>, <u>S-150 Secondary Clarifiers, S-160 Tertiary Treatment</u> <u>S-170 Disinfection, S-180 Sludge Handling Processes</u>

		Federally	<u>Future</u>
<u>Applicable</u>	Regulation Title or	Enforceable	<u>Effective</u>
<u>Requirement</u>	Description of Requirement	<u>(Y/N)</u>	<u>Date</u>
BAAQMD	Organic Compounds-Miscellaneous Operation (6/15/94)	<u>Y</u>	
Regulation 8,			
Rule 2			
<u>8-2-301</u>	Miscellaneous Operations	<u>Y</u>	
BAAQMD	Odor Abatement (basis: Reg. 7-1-102)	<u>N</u>	
Condition			
<u>#947</u>			
Part 1	Wastewater Throughput (Cumulative Increase)	<u>Y</u>	
Part 2	Consequences of odor complaints (1-301; Public Nuisance)	<u>Y</u>	
Part 3	Recordkeeping (2-6-409.2)	<u>Y</u>	

Table IV-<u>H</u>F Source-specific Applicable Requirements S-130 FLOW EQUALIZATION

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Organic Compounds-Miscellancous Operation (6/15/94)	¥	
Regulation 8,			
Rule 2			
8-2-301	Miscellaneous Operations	¥	
BAAQMD	Odor Abatement (basis: Reg. 7-1-102)	N	
Condition			
#784			

<u>Table IV-</u>4K <u>Source-specific Applicable Requirements</u>

S-190 ANAEROBIC DIGESTERS

<u>Applicable</u> <u>Requirement</u>	<u>Regulation Title or</u> <u>Description of Requirement</u>	<u>Federally</u> <u>Enforceable</u> <u>(Y/N)</u>	<u>Future</u> <u>Effective</u> <u>Date</u>
BAAQMD Regulation 8, Rule 2	Organic Compounds-Miscellaneous Operation (6/15/94)	Ϋ́	
<u>8-2-301</u>	Miscellaneous Operations	<u>Y</u>	
BAAQMD Regulation 9, Rule 2	Inorganic Gaseous Pollutants- Hydrogen Sulfide (10/6/99)		
<u>9-2-301</u> BAAQMD Cond 18871	H2S ground-level concentration limitations	<u>N</u>	
Part 1	Primary Abatement of Digester Gas (Basis: Reg 1-301)	<u>Y</u>	
Part 2	Secondary Abatement of Digester Gas (Basis: Cumulative Increase)	<u>Y</u>	
Part 3	Digester Gas Sulfide ppm Limit (Basis: Reg 9-1)	<u>Y</u>	
Part 4	Weekly Sulfide Content Monitoring/Recording (Basis: Reg 9-1-302)	<u>Y</u>	

V. SCHEDULE OF COMPLIANCE

The permit holder shall comply with all applicable requirements cited in this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit on a timely basis.

The permit holder shall continue to comply with all applicable requirements cited in Parts III and IV of this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit.

VI. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

A. Source Specific Permit Conditions

*Condition #784

For S-130 Flow Equalization

1. If the District receives more than five confirmed complaints in a week, the City of Santa Rosa WWTP shall take immediate action to abate the odor (Basis: BAAQMD Reg. 7-102).

*Condition #947

For S-100 Wastewater Treatment Plant

- 1. If the District receives more than five confirmed complaints in a week, the City of Santa Rosa WWTP shall take immediate action to abate the odor (Basis: BAAQMD Reg. 7-102). Flowrate
- Total wastewater flow shall not exceed 21.3 million gallons per day on acalendar month average during dry weather periods or 42 million gallons perday on a calendar month average during wet weather periods. For thepurposes of this limit, wet weather is defined as the months from Octoberthrough May. [Basis: Cumulative Increase]
- 2. If the District receives more than five confirmed complaints in a week, the City of Santa Rosa WWTP shall take immediate action to abate the odors. Nuisance

In the event that a public nuisance odor source is identified at this facility, the

Permit Holder shall employ all measures, practices, or modifications necessary to abate the nuisance. [Basis: Regulation 1-301]

- 3. Records
- <u>To demonstrate compliance with Part 1, above, the Permit Holder shall maintain the</u> <u>following records: [Basis: Regulation 2-6-409.2]</u>
- a. Daily and monthly (calendar basis) records of the quantity of wastewater processed at this source.
- b. Monthly records shall be totaled for each consecutive 12-month period.
- c. All records shall be retained onsite for five years from the date of entry, and made available for inspection by District staff upon request.
- d. These recordkeeping requirements do not replace the recordkeeping requirements contained in any applicable District Regulations.

*Condition #1541

For S-28 Hot Water Boilers

- If the District receives more than five confirmed complaints in a week, the City of Santa Rosa WWTP shall take immediate action to abate the odor. (Basis: BAAQMD Reg 7-102) S-28 Boilers may be fired on any combination of sewage sludge digester gas or natural gas. (Basis: Cumulative Increase)
- 2. Throughput

Total fuel usage at S-28 boilers shall not exceed 73.58 MM Btu/yr per boiler, gross heating basis. (Basis: Cumulative Increase)

- 3. The Permit Holder shall perform a regular inspection and tune-up of the combustion section of both boilers to ensure the proper air-to-fuel ratio is being used to maximize efficiency and minimize the production of nitrogen oxides and carbon monoxide, following the procedures of Regulation 9 Rule 7, Section 604 (CARB BARCT Tune Up Procedures). The time interval between boiler tune-ups shall not exceed 12 months. (Basis: Regulation 9-7-304.2)
- 4. Recordkeeping
 - To demonstrate compliance with parts 1,2 and 3, above, the Permit Holder of hot water boilers S-28 shall document the operation and tune ups by keeping the following records:

- a. Total monthly records of operation including hours of operation and quantities and type of fuel fired.
- b. Time and date of the tune up and the identity of the qualified technician.
- c. Stack gas oxygen concentrations (ppm dry) and carbon monoxide concentrations (ppm dry) before and after any adjustments are made.

The records associated with the above requirements shall be maintained for a period of at least 5 years from the date of the inspection or test and be available for review by District personnel upon request. (Basis: Reg 2-6-501)

Condition #2612

For S-29, 30, 31 Internal Combustion Engines Condition effective until 6/15/97

1. Only one of the three engines shall be operated at any given time (Basis: Cumulative Increase).

Condition #11031

For Sources S-29, S-30 and S-31 Condition effective after 6/15/97

- 1. Emissions of NOx from this source shall not exceed 140 ppmv as corrected to 15% oxygen, dry basis. (basis: Regulation 9-8-302.1, cumulative increase)
- 2. Within 30 days after start-up, The City of Santa Rosa shall conduct a performance test in accordance with the District test procedures to demonstrate compliance with condition number 1. Written notice of the test shall be provided to the District 10 days prior to the test so that an observer from the District be present. (basis: Regulation 9-8-501)
- 3. City of Santa Rosa shall ensure that an annual performance test is conducted in accordance with the District test procedures to demonstrate compliance with the NOx limits. City of Santa Rosa may submit an alternative monitoring plan to the District for approval. If the alternative monitoring plan is approved, the plan shall supercede the annual source test requirement. Approvals shall be processed using the permit modification procedure contained in Regulation 2, Rule 6. (Basis: Regulation 2-6-409.2)
- 4. Effective upon effective date of approval of Regulation 9, Rule 8 into the California State Implementation Plan by EPA: City of Santa Rosa shall ensure that an annual performance test is conducted in accordance with the District test procedures to demonstrate compliance with

the CO limits. City of Santa Rosa may submit an alternative monitoring plan to the District for approval. If the alternative monitoring plan is approved, the plan shall supercede the annual source test requirement. Approvals shall be processed using the permit modification procedure contained in Regulation 2, Rule 6. (Basis: Regulation 2-6-409.2)

5. A District approved engine log shall be maintained to record the hours of operation, amount of digester gas and natural gas combusted to produce the power. This log shall be maintained for a period of at least five years and shall be made available to District personnel upon request. (basis: cumulative increase, BAAQMD Regulation 2-6-501)

Condition #12848

For S-3 Composting Bay, S-4 Stockpiles, S-5 Screens, A-1 Biofilter

- 1. Visible particulate emissions from this source shall not exceed Ringelmann 0.5 or result in fallout on adjacent property in such quantities to cause a public nuisance per Regulation 1-301. (Basis: BACT, Regulation 1-301)
- *2. The facility shall conduct a District approved source test on A-1 Biofilter within 60 days of start-up to ensure that this facility is in compliance with Regulation 7, Section 303 for the following compounds: (Basis: Regulation 7)
 - a Dimethylsulfide (CH3)2S
 - b. Mercaptans, calculated as methylmercaptan CH3SH
 - c. Ammonia NH3

The samples shall be collected as prescribed in the Manual of Procedures, Volume IV and submitted to the District.

- 3. Throughput of sludge and yard waste mixture shall not exceed 36,500 tons in any consecutive 12 month period. (Basis: cumulative increase)
- 4. For the compost that is stockpiled, both in the curing pile and storage piles, water shall be added manually as needed to reduce particulates. (Basis: Regulation 6-301)
- *5. The stockpile of shredded screen yard waste (i.e., green tree trimmings, green leaves, brushes) shall be processed no later than 5 days from the time they are received to prevent wood decomposition and odors. (Basis: Reg. 7)
- *6. If the facility receives 2 or more Violation Notices from the District for "Public

Nuisance" in any consecutive 12 month period, the owner/operator of this facility shall submit to the District within 30 days, an application to modify the Permit to Operate to include the following control measures as applicable or any other that the District deems necessary and appropriate. (Basis: Reg. 7)

- a. Reduce holding time of yard waste from 5 days to 3 days.
- b. Replace biofilter media with new material if it no longer is effective and decomposition has set it, or increase the biofilters thickness so that no odors are detected.
- In order to demonstrate compliance with the above conditions, the operator of sources S-3, S-4 and S-5 shall maintain the following records in a District approved log. These records shall be kept on facility and made available for District inspection for a period of five years from the date that the record was made. (Basis: Cumulative Increase, BAAQMD Regulation 2-6-501)
 - a. Daily throughput of sludge/yard waste material being processed, summarized on a monthly basis.
 - b. Cubic yards of stockpiled yard waste received in stockpiled area and removed for processing during a 5 day time period.
 - c. Daily hours of operation, summarized on a monthly basis.

Condition 17392

For Source S-32 Waste Recycle Grinder, Turbo Diesel Powered, 375 HP

- 1.The total amount of diesel fuel burned in S-32 recycle grinder diesel engine
shall not exceed 2,448 gallons during any consecutive 12 month period.
[Basis: Cumulative Increase]
- 2. S-32 recycle grinder diesel engine shall not burn diesel fuel having a sulfur content greater than 500 ppm (wt basis). [Basis: Cumulative Increase]
- 3. S-32 recycle grinder diesel engine operation shall not exceed 3 hours in any calendar day. [Basis: Cumulative Increase]
- 4. Daily records shall be maintained, in a District approved logbook, of the diesel fuel usage and engine hours of operation. The logbook shall be kept onsite and made available to District Staff upon request. [Basis: Reg 1-441]
- 5. Visible particulate emissions from this operation shall not exceed a Ringelmann 1.0 during any consecutive three minutes in any hour. [Basis: 6-

<u>301]</u>

Condition # 18856 For S-33 and S-34 Emergency Standby Gensets

1. Hours of Operation

The emergency standby engine generators S-33 and S-34 shall only be operated to mitigate emergency conditions or for reliability-related activities. Operation for reliability-related activities shall not exceed 20 hours in any calendar year per engine. Operation while mitigating emergency conditions is unlimited. (Basis: Reg 9-8-331)

- 2. Emergency Conditions is defined as any of the following: (Basis: Reg 9-8-231)
- a. Loss of regular natural gas supply.
- b. Failure of regular power supply.
- c. Flood mitigation.
- d. Sewage overflow mitigation.
- e. Fire.
- f. Failure of a primary motor, but only for such time as needed to repair or replace the primary motor.
- 3. Reliability-related activities is defined as any of the following: (Basis: Reg <u>9-8-232)</u>
- a. Operation of an emergency standby engine to test its ability to perform for an emergency use, or

b. Operation of an emergency standby engine during maintenance of a primary motor.

- 4. Each of the emergency standby engines shall be equipped with either a) a nonresettable totalizing meter that measures and records the hours of operation for the engine, or b) a non-resettable fuel usage meter. (Basis: Reg 9-8-530)
- 5. The emergency standby generators S-33 and S-34 shall only be fired on diesel fuel with a sulfur content not to exceed 0.5% by weight. (Basis: Reg 9-1-304)

To demonstrate compliance with the above sulfur limit, the Permit Holder shall secure and maintain onsite, for at least 5 years, one of the following

records: (Basis: Reg 2-6-409.2, 2-6-501)

- <u>a.</u> A written statement, as applicable, received from the diesel fuel
 <u>supplier(s) certifying that the diesel fuel purchased from the supplier does</u>
 <u>not exceed 0.5% by weight or meets the sulfur limitations for CARB</u>
 <u>Vehicular Diesel Fuel as specified in 13 CCR, Section 2281, California</u>
 <u>Code of Regulations, or</u>
- b. A vendor certification of sulfur content, or
- c. Fuel test results showing the sulfur content from a District-approved test.
- 6. Records
- The following monthly records shall be maintained in a District-approved log for at least 2 years and shall be made available for District inspection upon request. (Basis: Reg 9-8-530, 1-441)
- a. Total hours of operation.
- b. Hours of operation under emergency conditions and a description of the nature of each emergency condition.
- c. Monitoring Records noted in Part 4, above.
- d. Diesel sulfur records required in Part 5, above.

Condition 18867

For Sources S-29, S-30 and S-31

Condition effective after 6/15/97

- 1. Emissions of NOx from this source shall not exceed 140 ppmv as corrected to 15% oxygen, dry basis. (basis: BAAQMD 9-8-301.2, 302.1, cumulative increase)
- Within 30 days after start-up, The City of Santa Rosa shall conduct a
 performance test in accordance with the District test procedures to
 demonstrate compliance with condition number 1. Written notice of the test
 shall be provided to the District 10 days prior to the test so that an observer
 from the District be present. (basis: Regulation 9-8-501)Emissions of CO
 from this source shall not exceed 2000 ppmv as corrected to 15% oxygen, dry
 basis. (Basis: BAAQMD 9-8-301.3, 302.3)
- 3. City of Santa Rosa shall ensure that an annual performance test is conducted in accordance with the District test procedures to demonstrate compliance with the NOx limits. City of Santa Rosa may submit an alternative monitoring plan to the District for approval. If the alternative monitoring plan

is approved, the plan shall supercede the annual source test requirement. Approvals shall be processed using the permit modification procedure contained in Regulation 2, Rule 6. (Basis: Regulation 2-6-409.2)District approved flowmeters shall be installed on each engine, to measure the respective digester gas and natural gas flow. These flowmeters shall be installed prior to any operation and maintained in good working order. (Basis: BAAQMD 1-441, cumulative increase)

- 4. Effective upon effective date of approval of Regulation 9, Rule 8 into the California State Implementation Plan by EPA: City of Santa Rosa shall ensure that an annual performance test is conducted in accordance with the District test procedures to demonstrate compliance with the <u>NOx and CO</u> limits. City of Santa Rosa may submit an alternative monitoring plan to the District for approval. If the alternative monitoring plan is approved, the plan shall supersede the annual source test requirement. Approvals shall be processed using the permit modification procedure contained in Regulation 2, Rule 6. (Basis: BAAQMD 2-6-409.2)
- A District approved engine log shall be maintained to record the hours of operation, amount of digester gas and natural gas combusted to produce the power. This log shall be maintained for a period of at least five years and shall be made available to District personnel upon request. (basisBasis: BAAQMD 2-6-501, ceumulative cumulative increaseincrease)

Condition # 18871

For S-190 Anaerobic Digesters

- 1. Emissions from S-190 shall be abated at all times by combustion at any or all of the following sources: S-28, S-29, S-30, and S-31 except as specified in Part 2. (Basis: BAAQMD 1-301)
- 2. Emissions from S-190 shall be abated by A-35 only when equipment failure or other emergencies require the flaring of digester gas. (Basis: Cumulative Increase)
- 3. Digester gas total sulfur content shall not exceed 1500 ppm. (Basis: BAAQMD 9-1)
- 4. To demonstrate compliance with this standard the permit holder shall monitor and record the sulfur content of the digester gas at a frequency of at least once every calendar week. If the permit holder can demonstrate 3 months of digester gas sulfur results lower than 1000 ppm the monitoring frequency for

sulfur analysis may be reduced to at least once every calendar month. (Basis: BAAQMD 9-1-302)

Condition 19192 for sources S-36, S-37, and S-38

- S-36 Portable Compressor: Diesel Engine, Make: John Deere, Model: 300 Series, Rated Horsepower: 70 HP.
- S-37 Portable Pump: Diesel Engine, Make: Deutz, Model: F4L 912 1441-32, Rated Horsepower: 51 HP.
- S-38 Portable Pump: Diesel Engine, Make: Deutz, Model: F4L912, Rated Horsepower: 51 HP.

Portable Equipment Requirements

- 1. This mobile equipment shall operate at all times in conformance with the eligibility requirements set forth in BAAQMD Regulation 2-1-220 for portable equipment. [Basis: BAAQMD 2-1-220]
- 2. If this portable equipment remains at any fixed location in the Bay Area Air Basin for more than 12 months, the portable permit will automatically revert to a conventional permanent location BAAQMD permit and will lose its portability. [Basis: BAAQMD 2-1-220.10]
- 3. Any loss of portability per part 2, above, shall be reported to the Director of the Compliance and Enforcement Division no later than 30 days after the loss of its portability. [Basis: BAAQMD 2-1-404]

Regulatory Compliance Requirement

- 4. S-36, S-37, and S-38 shall only fire diesel fuel containing less than 0.5% by weight sulfur. [Basis: BAAQMD 9-1-304]
 - To demonstrate compliance with the above sulfur limit, the Permit Holder shall secure and maintain onsite, for at least 5 years, one of the following records: [Basis: Regulations 2-6-409.2, 2-6-501]
- a. A written statement, as applicable, received from the diesel fuel
 supplier(s) certifying that the diesel fuel purchased from the supplier does
 not exceed 0.5% by weight or meets the sulfur limitations for CARB
 Vehicular Diesel Fuel as specified in 13 CCR, Section 2281, California
 Code of Regulations, or

- b. A vendor certification of sulfur content, or
- c. Fuel test results showing the sulfur content from a District-approved test.
- 5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour that is as dark or darker than Ringelmann #1 or equivalent to 20% opacity. [Basis: BAAQMD <u>6-301, 302]</u>
- 6. Operation of S-36, S-37, and S-38 shall not create emissions in sufficient quantities as to cause a public nuisance under Regulation 1-301. [Basis: BAAQMD 1-301]
- 7. S-36, S-37, and S-38 shall not be operated for longer than 72 consecutive hours within 1,000 feet of a school. To operate for longer than 72 consecutive hours within 1,000 feet of a school, the Permit Holder must submit an application to the District so that proper notification of the intended operation can be made known to the affected public in advance of any usage of the equipment. [Basis: BAAQMD 2-1-412]

Recordkeeping Requirements

- 8. The following records shall be kept in a District-approved logbook and retained for a period of at least five years following the date of entry. The log shall be kept with the equipment and made available to District staff upon request. [Basis: BAAQMD 1-441]
 - a. Weekly hours of operation or fuel usage for S-36, S-37, and S-38.b. Hours of operation or fuel usage shall be totaled on a monthly basis

Condition 19750

For source S-35, Cogen Engine #4, 1160 BHP, 800 KW

- 1.
 This engine shall be fired on digester gas and/or natural gas only.

 [Basis: Cumulative Increase]
- 2. Thermal Capacity Limitation: Total thermal input shall not exceed 56,772 MM Btu in any 12 month period. [Basis: Cumulative Increase]
- 3. NOx emissions, calculated an NO2, shall not exceed 95 ppm at 15 percent oxygen, or 0.35 lb/MM Btu fuel input [Basis: BACT, Cumulative Increase]
- 4. CO emissions shall not exceed 410 ppm at 15 percent oxygen, or 0.94 lb/MM

Btu fuel input. [Basis: BACT, Cumulative Increase]

- 5. NMHC emissions, calculated as methane, shall not exceed 270 ppm at 15 percent oxygen, or 0.35 lb/MM Btu duel input. [Basis: BACT, Cumulative Increase]
- 6. District approved flowmeters shall be installed on this engine to measure the respective digester gas and natural gas flow. These flowmeters shall be installed prior to any operation and maintained in good working order. [Basis: Cumulative Increase]
- 7. To demonstrate compliance with the limits specified in Parts 3, 4, and 5, above, the permit holder shall conduct a District-approved performance test within 60 days of startup. [Basis: BAAQMD 2-6-409.2]
- 8. City of Santa Rosa shall ensure that an annual performance test is conducted on this engine in accordance with District-approved test procedures to demonstrate ongoing compliance with the NOx, CO and NMHC limits specified in Parts 3, 4, and 5, above.
 [Basis: BAAQMD 1-441]
- <u>9.</u> To determine compliance with the above Parts, the Permit Holder shall maintain the following records and provide all of the data necessary to evaluate compliance with the above conditions, including the following information: [Basis: Regulation 2-6-409.2]
 - a. Monthly records of the quantity of digester gas and natural gas burned at this source.
 - b. Monthly records of the total thermal input in BTU.
 - c. All records shall be retained onsite for five years from the date of entry, and made available for inspection by District staff upon request.
 - d. These recordkeeping requirements do not replace the recordkeeping requirements contained in any applicable District Regulation.

VII. APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency column indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown <u>using the following codes</u>: annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

Table VII-A Applicable Limits and Compliance Monitoring Requirements S-3 COMPOST BAY, S-4 STOCKPILES, S-5 SCREENS

			Future		Monitoring	Monitoring		
Type of	Citation of	FE	Effective		Requirement	Frequency	Monitoring	
<u>Limit</u>	<u>Limit</u>	Y/N	Date	<u>Limit</u>	Citation	(P/C/N)	Туре	
TSP	BAAQMD	Ν		Ringelmann No. 1		Ν		
	6-301							
	BAAQMD	¥		0.15 grain/dsef		N		
	6-310			@ 6% O2				
	BAAQMD	Y		Ringelmann No. 1		Ν		
	Cond							
	#12848,							
	Part 1							

Table VII - B

Applicable Limits and Compliance Monitoring Requirements S-17, S-18 Irrigation <u>Reclaimed Water</u> Ponds, S-100 Wastewater Treatment Plant, S-110 Preliminary Treatment, S-120 Primary Treatment, S-130 Flow Equalization, S-140 Secondary Treatment, S-150 Secondary Clarifiers, S-160 Tertiary Treatment, S-170 Disinfection, S-180 Sludge Handling, S-190 Anaerobic Digestors

Type of	Citation of	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
Limit	Limit	Y/N	Date	Limit	Citation	(P/C/N)	Туре
VOC	BAAQMD	Y		15 lb/day & 300 ppm	Ν	Ν	
	8-2-301			total carbon on dry basis			

Table VII-C
Applicable Limits and Compliance Monitoring Requirements
S-28 Hot Water Boilers

<u>Type of</u>	<u>Citation of</u> <u>Limit</u>	<u>FE</u> <u>Y/</u>	<u>Future</u> <u>Effective</u> <u>Date</u>	<u>Limit</u>	<u>Monitoring</u> <u>Requirement</u> <u>Citation</u>	<u>Monitoring</u> <u>Frequency</u> <u>(P/C/N)</u>	<u>Monitoring</u> <u>Type</u>
<u>Limit</u> <u>SO2</u>	BAAQMD Regulation 9-1-301	<u>N</u> <u>Y</u>		GLC of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours	None	N	
	BAAQMD Regulation <u>9-1-302</u>	Y		<u>300 ppm (dry)</u>	None	<u>N</u>	
<u>Opacity</u>	<u>BAAQMD</u> <u>6-301</u>	<u>Y</u>		<u>> Ringelmann 1.0 for</u> <u>no more than 3 min in</u> <u>any hour</u>	<u>N</u>	<u>N</u>	
<u>PM</u>	BAAQMD <u>6-310</u>	<u>Y</u>		<u>0.15 gr/dscf at 6%</u> <u>Oxygen</u>	<u>N</u>	<u>N</u>	
<u>Organic</u> <u>Compounds</u>	BAAQMD <u>8-2-301</u>	<u>Y</u>		>15 lb/day or >300 ppm total carbon <u>concentration</u>	N	N	

Table VII-CDApplicable Limits and Compliance Monitoring Requirements
S-29, S-30, S-31 I.C. ENGINES

			Future		Monitoring	Monitoring	
Type of	Citation of	FE	Effective		Requirement	Frequency	Monitoring
<u>Limit</u>	<u>Limit</u>	Y/N	Date	<u>Limit</u>	Citation	(P/C/N)	Туре
NOx	BAAQMD	Ν		NOx<140 ppmv corrected	condition	P/A^2	source test
	9-8-301.2			to 15% oxygen, dry basis	Condition		or alternate
					# 11031 ,		monitoring
					<u>18867</u>		plan ²
					part <u>1</u> 3 ²		
NOx	BAAQMD	Ν		NOx<140 ppmv corrected	condition	P/A^2	source test
	9-8-302.1			to 15% oxygen, dry basis	Condition		or alternate
					# 11031 ,		monitoring

Table VII-CDApplicable Limits and Compliance Monitoring Requirements
S-29, S-30, S-31 I.C. ENGINES

Type of	Citation of	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
Limit	Limit	Y/N	Date	<u>Limit</u>	Citation	(P/C/N)	Туре
					<u>18867</u>		plan ²
					part <u>31</u> ²		
	Condition	Y		NOx<140 ppmv corrected	condition	P/A	source test
	11031			to 15% oxygen, dry basis	Condition		or alternate
	<u>18867,</u> part				# 11031 ,		monitoring
	1				<u>18867</u>		plan
					part <u>31</u>		
CO	BAAQMD	Ν		CO<2000 ppmv corrected	condition	P/A ²	source test
	9-8-301.3			to 15% oxygen, dry basis	Condition		or alternate
					# 11031		monitoring
					<u>18867</u> ,		plan ²
					part $4^2 \underline{2^2}$		
CO	BAAQMD	Ν		CO<2000 ppmv corrected	Condition	P/A ²	source test
	9-8-302.3			to 15% oxygen, dry basis	# 11031		or alternate
					<u>18867</u> ,		monitoring
					part <u>2</u> 4 ²		plan ²
<u>CO</u>	Condition	<u>Y</u>		CO<2000 ppmv corrected	Condition #	$\underline{P/A^2}$	source test
	<u>18867, part</u>			to 15% oxygen, dry basis	<u>18867,</u>		or alternate
	<u>2</u>				part 2^2		monitoring
							<u>plan</u>

²-This condition will become effective after Regulation 9, Rule 8 is approved into the California SIP.

Table VII-CE Applicable Limits and Compliance Monitoring Requirements S-32 WASTE RECYCLER GRINDER

			Future		Monitoring	Monitoring	
Type of	Citation of	FE	Effective		Requirement	Frequency	Monitoring
<u>Limit</u>	<u>Limit</u>	Y/N	Date	Limit	Citation	(P/C/N)	Туре
Fuel Input	BAAQMD	Y		<u>2,448 gal in any</u>	BAAQMD	<u>P/D</u>	Records
	Cond			consecutive 12 month	Cond 17392,		
	<u>17392,</u>			period	Part 4		
	Part 1						

			Future		Monitoring	Monitoring	
Type of	Citation of	FE	Effective		Requirement	Frequency	Monitoring
<u>Limit</u>	<u>Limit</u>	Y/N	Date	<u>Limit</u>	Citation	(P/C/N)	Туре
TSP	<u>6-301</u>	N		Ringelmann No. 1		<u>N</u>	
	BAAQMD	<u>Y</u>		0.15 grain/dscf		<u>N</u>	
	<u>6-310</u>			<u>@ 6% O2</u>			
Diesel	BAAQMD	Y		500 ppm	BAAQMD	<u>N</u>	
Sulfur	Cond				Cond <u>17392</u>		
	<u>17392</u>				Part 2		
	Part 2						

Table VII-CE Applicable Limits and Compliance Monitoring Requirements S-32 WASTE RECYCLER GRINDER

<u>Table VII-G</u> <u>Applicable Limits and Compliance Monitoring Requirements</u> <u>S-33, Standby Engine/Generator #1, Diesel Fired, 2000 KW</u> <u>S-34, Standby Engine/Generator #2, Diesel Fired, 2000 KW</u>

Type of	Citation of		<u>Future</u>		<u>Monitoring</u>	<u>Monitoring</u>	Monitoring
<u>Limit</u>	Limit	FE	Effective	<u>Limit</u>	<u>Requirement</u>	<u>Frequency</u>	<u>Type</u>
		Y/N	<u>Date</u>		<u>Citation</u>	<u>(P/C/N)</u>	
<u>Hrs of</u>	CA CCR	N	<u>1/1/06</u>	20 hours/calendar year	CA CCR	<u>P/E</u>	Records
Operation	Section				Section 93115,		
	<u>93115</u>				BAAQMD		
					Cond 18856,		
					Part 5		
Diesel	BAAQMD	N		0.5% by weight		N	
<u>Sulfur</u>	<u>9-1-304</u>						
<u>Content</u>							
Diesel	BAAQMD	Y		0.5% by weight	BAAQMD	<u>P/E</u>	Records
<u>Sulfur</u>	Condition				Condition		
Content	<u>18856,</u>				<u>18856,</u>		
	<u>part 5.</u>				Part 5		
FP	BAAQMD	Y		<u>0.15 gr/dscf</u>		N	
	<u>6-310</u>						
Opacity	BAAQMD	Y		Ringelmann 2.0 for no		N	
	<u>6-303</u>			more than 3 minutes in			
				any hour			

	Applical			al Compliance Mo al Combustion En			
<u>Type of</u> <u>Limit</u>	<u>Citation of</u> <u>Limit</u>	<u>FE</u> <u>Y/</u> <u>N</u>	<u>Future</u> <u>Effective</u> <u>Date</u>	<u>Limit</u>	<u>Monitoring</u> <u>Requirement</u> <u>Citation</u>	<u>Monitoring</u> <u>Frequency</u> (<u>P/C/N)</u>	<u>Monitoring</u> <u>Type</u>
<u>NOx</u>	BAAQMD Regulation 9-8-302.1	<u>Y</u>		<u>140 ppmv</u> @ 15% O2, dry	BAAQMD Cond 19750, part 8	<u>P/A</u>	source test
	BAAQMD Condition 19750, part 3	Y		<u>95 ppm @ 15% O2, or</u> <u>0.25 lb/MM Btu fuel</u>	BAAQMD Cond 19750, part 8	<u>P/A</u>	source test
<u>CO</u>	BAAQMD Regulation 9-8-302.3	Y		<u>2000 ppmv</u> @ 15% O2, dry	BAAQMD Cond 19750, part 8	<u>P/A</u>	source test
	<u>BAAQMD</u> <u>Cond</u> <u>19750, part</u> <u>4</u>	Y		410 ppm @ 15 % O2 or 0.94 lb/MM btu fuel	<u>BAAQMD</u> <u>Cond 19750,</u> <u>part 8</u>	<u>P/A</u>	source test
<u>SO2</u>	BAAQMD Regulation <u>9-1-301</u>	Y		GLC of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours	None	<u>N</u>	
	BAAQMD Regulation <u>9-1-302</u>	Y		<u>300 ppm (dry)</u>	None	<u>N</u>	
<u>NMHC</u>	<u>BAAQMD</u> <u>Cond</u> <u>19750.</u> <u>part 5</u>	Y		270 ppm @ 15% Oxygen or 0.35 Ib/MM Btu Fuel Input	BAAQMD Cond 19750, part 8	<u>P/A</u>	source test
	BAAQMD <u>8-2-301</u>	Y		>15 lb/day or >300 ppm total carbon concentration	<u>None</u>	<u>N</u>	
<u>Opacity</u>	<u>BAAQMD</u> <u>6-301</u>	Y		<u>> Ringelmann 1.0 for</u> <u>no more than 3 min in</u> <u>any hour</u>	None	<u>N</u>	
<u>FP</u>	BAAQMD <u>6-310</u>	<u>Y</u>		<u>0.15 gr/dscf</u>	None	<u>N</u>	
<u>Thermal</u> Throughput	BAAQMD Condition	<u>Y</u>		56,772 MM Btu in any 12 month period	<u>BAAQMD</u> Cond 19750,	<u>P/D</u>	<u>Records</u>

<u>Table VII-C</u> <u>Applicable Limits and Compliance Monitoring Requirements</u> S-35 Internal Combustion Engine, 1160 HP

Table VII-CApplicable Limits and Compliance Monitoring RequirementsS-35 Internal Combustion Engine, 1160 HP

<u>Type of</u> <u>Limit</u>	<u>Citation of</u> <u>Limit</u>	<u>FE</u> <u>Y/</u> <u>N</u>	<u>Future</u> <u>Effective</u> <u>Date</u>	<u>Limit</u>	<u>Monitoring</u> <u>Requirement</u> <u>Citation</u>	Monitoring <u>Frequency</u> (P/C/N)	<u>Monitoring</u> <u>Type</u>
	<u>19750</u> part 2				<u>part 9</u>		

Table VII-FApplicable Limits and Compliance Monitoring RequirementsS-36, Portable Compressor, Diesel Fired, 70 HPS-37 Portable Pump, Diesel Fired, 51 HPS-38 Portable Pump, Diesel Fired, 51 HP

<u>Type of</u>	Citation of	EE	<u>Future</u>	T **4	<u>Monitoring</u>	<u>Monitoring</u>	<u>Monitoring</u>
<u>Limit</u>	<u>Limit</u>	<u>FE</u> <u>Y/N</u>	<u>Effective</u> Date	<u>Limit</u>	<u>Requirement</u> Citation	<u>Frequency</u> (P/C/N)	<u>Type</u>
Hours of	BAAQMD	Y		72 consecutive hours	BAAQMD	<u>P/W</u>	Records
Operation	Cond			(unless permit is	Cond 19192.		
within	<u>19192,</u>			granted for more time)	<u>parts 8a, 8b</u>		
<u>1000 ft of</u>	part 7						
<u>School</u>							
<u>Diesel</u>	BAAQMD	N		0.5% by weight	BAAQMD	<u>P/E</u>	Records
<u>Sulfur</u>	<u>9-1-304</u>				Condition		
<u>Content</u>					<u>19192,</u>		
					Part 4		
Diesel	BAAQMD	Y		0.5% by weight	BAAQMD	<u>P/E</u>	Records
<u>Sulfur</u>	Condition				Condition		
Content	<u>19192,</u>				<u>19192,</u>		
	<u>part 4.</u>				Part 4		
<u>Opacity</u>	BAAQMD	Y		>Ringelmann 2.0 for		<u>N</u>	
	<u>6-303</u>			no more than 3 min in			
				any hour			
FP	BAAQMD	Y		<u>0.15 gr/dscf</u>		<u>N</u>	
	<u>6-310</u>						

Table VII-DApplicable Limits and Compliance Monitoring RequirementsS-100 WASTEWATER TREATMENT PLANTS-110 PRELIMINARY TREATMENTS-120 PRIMARY TREATMENTS-130 FLOW EQUALIZATIONS-130 FLOW EQUALIZATIONS-140 SECONDARY TREATMENTS-150 SECONDARY CLARIFIERSS-160 TERTIARY TREATMENTS-170 DISINFECTIONS-180 SLUDGE HANDLING PROCESSESS-190 ANAEROBIC DIGESTERS

<u>Type of</u>	Citation of	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
<u>Limit</u>	<u>Limit</u>	Y/N	Date	Limit	Citation	(P/C/N)	Туре
VOC	BAAQMD	Y		Emissions may not exceed		Ν	
	8-2-301			300 ppm total carbon, dry,			
				and 15 lb/day/source			

Table VII-D Applicable Limits and Compliance Monitoring Requirements

S-190 ANAEROBIC DIGESTERS

-			<u>Future</u>		Monitoring	<u>Monitoring</u>	
<u>Type of</u>	Citation of	<u>FE</u>	Effective		<u>Requirement</u>	<u>Frequency</u>	<u>Monitoring</u>
<u>Limit</u>	<u>Limit</u>	<u>Y/N</u>	Date	<u>Limit</u>	Citation	<u>(P/C/N)</u>	<u>Type</u>
VOC	BAAQMD	Y		Emissions may not exceed	<u>N</u>	Ν	<u>N</u>
	8-2-301			300 ppm total carbon, dry,			
				and 15 lb/day/source			
<u>Sulfide</u>	BAAQMD	N		<u>1500 ppm</u>	BAAQMD	<u>P/W</u>	Testing
	Cond 18871				Cond 18871		
					Part 4		

VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally referenced in Section 600 <u>et seq.</u> of the regulation. The following table indicates only the test methods associated with the emission limits referenced in Section VII, Applicable Emission Limits & Compliance Monitoring Requirements, of this permit.

Table VIII Test Methods

Applicable		
Requirement	Description of Requirement	Acceptable Test Methods
BAAQMD	Ringelmann No. 1 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
6-301		
SIP	Ringelmann No. 1 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
6-301		
BAAQMD	Ringelmann No. 2 Limitation	Manual of Procedures, Volume I, Evaluation of Visible Emissions
<u>6-303</u>		
BAAQMD	Particulate Weight Limitation	Manual of Procedures, Volume IV, ST-15, Particulates Sampling
6-310	_	
BAAQMD	Limit on Odorous Compounds	Manual of Procedures, Volume IV, ST-1, ST-8,
7-303		ST-11, ST-16, ST-22, Sampling of Odorous Compounds
BAAQMD	Miscellaneous Operations	Manual of Procedures, Volume IV, ST-7, Non-Methane Organic
8-2-301		Carbon Sampling or
		EPA Method 25 or 25A.
BAAQMD	General Emission Limitation	Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide,
9-1-302		Continuous Sampling, or
		ST-19B, Total Sulfur Oxides Integrated Sample
BAAQMD	Fossil Derived Fuel Gas, NOx	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen,
9-8-301.2	Limits for Lean Burn Engines	Continuous Sampling Limit on Odorous Compounds and
		ST-14, Oxygen, Continuous Sampling
BAAQMD	Fossil Derived Fuel Gas, CO	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide,
9-8-301.3	Limits	Continuous Sampling and
		ST-14, Oxygen, Continuous Sampling
BAAQMD	Waste Derived Fuel Gas NOx	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen,
9-8-302.1	Limits for Lean Burn Engines	Continuous Sampling Limit on Odorous Compounds and
		ST-14, Oxygen, Continuous Sampling
BAAQMD	Waste Derived Fuel Gas CO	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide,
9-8-302.3	Limits	Continuous Sampling and
		ST-14, Oxygen, Continuous Sampling
BAAQMD	NOx Limit	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen,
Cond #		Continuous Sampling Limit on Odorous Compounds and ST-14,
11031<u>18867</u>,		Oxygen, Continuous Sampling
Part 1		
BAAQMD	CO Limits	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide,
Cond #		Continuous Sampling and
<u>18867, part 2</u>		ST-14, Oxygen, Continuous Sampling

VII. Permit Conditions (continued)

Table VIIITest Methods

BAAQMD	Ringelmann limit	Manual of Procedures, Volume I, Evaluation of Visible Emissions
Cond #		
12848, Part 1		

IX. GLOSSARY

ACT

Federal Clean Air Act

BAAQMD

Bay Area Air Quality Management District

BACT Best Available Control Technology

Basis

The underlying authority which allows the District to impose requirements.

CAA The federal Clean Air Act

CAAQS California Ambient Air Quality Standards

CEQA California Environmental Quality Act

CFR

The Code of Federal Regulations. 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

СО

Carbon Monoxide

Cumulative Increase

The sum of permitted emissions from each new or modified source since a specified date pursuant to BAAQMD Rule 2-1-403, Permit Conditions (as amended by the District Board on 7/17/91) and SIP Rule 2-1-403, Permit Conditions (as approved by EPA on 6/23/95). Used to determine whether threshold-based requirements are triggered.

District

The Bay Area Air Quality Management District

EPA

The federal Environmental Protection Agency.

Excluded

Not subject to any District regulations.

Federally Enforceable, FE

All limitations and conditions which are enforceable by the Administrator of the EPA including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60 (NSPS), Part 61 (NESHAPs), Part 63 (MACT), and Part 72 (Permits Regulation, Acid Rain), including limitations and conditions contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

FP

Filterable Particulate as measured by BAAQMD Method ST-15, Particulate.

HAP

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by $\underline{40}$ CFR Part 63.

Major Facility

A facility with potential emissions of: (1) at least 100 tons per year of regulated air pollutants, (2) at least 10 tons per year of any single hazardous air pollutant, and/or (3) at least 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity of hazardous air pollutants as determined by the EPA administrator.

MFR

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Federal Clean Air Act and implemented by District Regulation 2, Rule 6.

MOP

The District's Manual of Procedures.

NAAQS

National Ambient Air Quality Standards

NESHAPS

National Emission Standards for Hazardous Air Pollutants. <u>Contained</u> in 40 CFR Parts 61 and 63

NMHC

Non-methane Hydrocarbons (Same as NMOC)

<u>NMOC</u>

Non-methane Organic Compounds (Same as NMHC)

NOx

Oxides of nitrogen.

NSPS

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Federal Clean Air Act, and implemented by 40 CFR Part 60 and District Regulation 10.

VIII. Glossary (continued)

NSR

New Source Review. A federal program for pre-construction review and permitting of new and modified sources of pollutants <u>for which criteria have been established in accordance with</u> <u>Section 108 of the Federal Clean Air Act</u>. Mandated by Title I of the Federal Clean Air Act and implemented by 40 CFR Parts 51 and 52 and District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

Offset Requirement

A New Source Review requirement to provide federally enforceable emission offsets for the emissions from a new or modified source and any pre-existing cumulative increase minus any on site contemporaneous emission reduction credits. Applies to emissions of POC, NOx, PM10, and SO2.

Phase II Acid Rain Facility

A facility that generates electricity for sale through fossil-fuel combustion <u>and is not exempted</u> by 40 CFR 72 from Titles IV and V of the Clean Air Act.

POC

Precursor Organic Compounds

PM

Total Particulate Matter

PM10

Particulate matter with aerodynamic equivalent diameter of less than or equal to 10 microns

PSD

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of those air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

SO2

Sulfur dioxide

THC

Total Hydrocarbons (NMHC + Methane)

Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

VIII. Glossary (continued)

<u>TOC</u>

Total Organic Compounds (NMOC + Methane, Same as THC)

<u>TPH</u>

Total Petroleum Hydrocarbons

TRMP

Toxic Risk Management Plan

<u>TSP</u>

Total Suspended Particulate

VOC

Volatile Organic Compounds

Units of Measure:

bhp	=	brake-horsepower
btu	=	British Thermal Unit
cfm	=	cubic feet per minute
g	=	grams
gal	=	gallon
gpm	=	gallons per minute
hp	=	horsepower
hr	=	hour
lb	=	pound
in	=	inches
max	=	maximum
m^2	=	square meter
min	=	minute
mm	=	million
ppmv	=	parts per million, by volume
ppmw	=	parts per million, by weight
psia	=	pounds per square inch, absolute
psig	=	pounds per square inch, gauge
scfm	=	standard cubic feet per minute
yr	=	year