September 29, 2004

Ms. Deborah Jordan
Director, Air Management Division
United States Environmental Protection Agency
75 Hawthorne Street
San Francisco, CA 94105

ALAMEDA COUNTY

Roberta Cooper Scott Haggerty (Chairperson) Nate Miley Shelia Young

Dear Ms. Jordan:

CONTRA COSTA COUNTY

Mark DeSaulnier Erling Horn Mark Ross Gayle Uilkema (Secretary) This is to advise you that the Bay Area Air Quality Management District is issuing a significant revision to the Major Facility Review Permit for Delta Energy Center, LLC (Facility #B2095).

Plant Name Application Engineer City County B2095 Delta Energy Center, LLC 8341 D. Jang Pittsburg Contra Costa

MARIN COUNTY Harold C. Brown, Jr.

NAPA COUNTY Brad Wagenknecht

SAN FRANCISCO COUNTY Chris Daly Jake McGoldrick Gavin Newsom The District proposed a significant permit revision for this facility on July 9, 2004. This revision resulted in no emission increases. The following changes were included in the proposed permit.

 The fuel sulfur content limit was increased from 0.25 gr/100 scf to 1.0 gr/100 scf and the hourly and daily SO₂ mass emission limits were deleted, while maintaining the frequency of monitoring for the annual SO₂ mass emissions and to determine Acid Rain permit SO₂ allowances.

SAN MATEO COUNTY

Jerry Hill Marland Townsend (Vice-Chairperson)

SANTA CLARA COUNTY

The requirements for EPA review of the proposed significant revisions to a Major Facility Review Permit for the facility identified above have been completed. No comments on this proposed significant revision were received from the EPA or the facility. The District has made the following additional administrative revisions to the proposed permit.

Erin Garner

Liz Kniss
Patrick Kwok
Julia Miller

• Permit conditions governing the commissioning period for the facility have been deleted since the period ended in 2001.

SOLANO COUNTY John F. Silva The District has decided to issue the revised permit.

SONOMA COUNTY

Tim Smith Pamela Torliatt Enclosed is a copy of the final revised permit. If you have any questions regarding this permit, please call Dennis Jang, Air Quality Engineer, at (415) 749-4707.

Jack P. Broadbent EXECUTIVE OFFICER/APCO

Jack P. Broadbent Executive Officer / APCO

Sincerely yours,

Enclosures: **JPB**:BFB:dti

H:\PUB_DATA\TITLEV\PERMIT\SIGNIFICANT\ISSUE\04September\B2095SignificantIssuance.doc