

January 29, 2007

Ms. Deborah Jordan
Director, Air Management Division
United States Environmental Protection Agency
75 Hawthorne Street
San Francisco, CA 94105

Dear Ms. Jordan:

This to advise you that the Bay Area Air Quality Management District is issuing a significant revision to the Major Facility Review Permit for the following facility.

Facility	Facility Name	Application	Permit Engineer	City	County
B4414	Creed Energy Center, LLC	11000	A. Chiu	Suisun City	Solano

ALAMEDA COUNTY
Tom Bates
Scott Haggerty
Janet Lockhart
Nate Miley

The main purpose of the proposed significant revision (Application # 11000) is to change permit conditions that have been revised under NSR application 11001. The proposed permit condition changes include the following:

CONTRA COSTA COUNTY
John Gioia
Mark Ross
(Chair)
Michael Shimansky
Gayle B. Uilkema

1. Amend the definition of "hour" to "clock hour" since the facility's continuous emission monitors operate on a clock hour basis.
2. Condition #20136, part 18.2: Revise the ammonia slip monitoring language to agree with standard language in other Calpine power plant permits. The revised language will allow the use of a District-approved calculation method to monitor ammonia slip. This is not a relaxation of monitoring, but replaces the original calculation method that was inaccurate.

MARIN COUNTY
Harold C. Brown, Jr.

NAPA COUNTY
Brad Wagenknecht

3. Condition #18102, part 24: Change the required source test frequency for the gas turbine from annual to every 8000 hours of gas turbine operation or once every 3 years, whichever comes first. This is a relaxation of monitoring and therefore is considered a significant revision pursuant to Regulation 2-6-226.3.

SAN FRANCISCO COUNTY
Chris Daly
Jake McGoldrick
Gavin Newsom

The public comment period ended on December 4, 2006. The EPA comment period ended on December 21, 2006. No comments on this proposed significant revision were received from the public, EPA, or the facility.

SAN MATEO COUNTY
Jerry Hill
(Vice-Chair)
Carol Klatt

The District has decided to issue the revised permit incorporating the proposed significant revision. Enclosed is a copy of the final revised permit. If you have any questions regarding this permit, please call Barry Young, Air Quality Engineering Manager, at: (415) 749-4721.

SANTA CLARA COUNTY
Erin Garner
Yoriko Kishimoto
Liz Kniss
Patrick Kwok

Sincerely yours,

SOLANO COUNTY
John F. Silva

SONOMA COUNTY
Tim Smith
Pamela Torliatt
(Secretary)

Jack P. Broadbent
Executive Officer/Air Pollution Control Officer

Enclosures:

Jack P. Broadbent
EXECUTIVE OFFICER/APCO

JPB:BFB:DTJ