Bay Area Air Quality Management District

939 Ellis Street San Francisco, CA 94109 (415) 771-6000

Final

MAJOR FACILITY REVIEW PERMIT

Issued To: Central Contra Costa Sanitary District Facility # A0907

> Facility Address: 5019 Imhoff Place Martinez, CA 94553-4392

Mailing Address: 5019 Imhoff Place Martinez, CA 94553-4392

Responsible Official James M. Kelly Director of Operations (925) 229-7386 Facility Contact Doug Craig Treatment Plant Operations Division Manager (925) 229-7284

Type of Facility:	Municipal Wastewater
	Treatment Facility
Primary SIC:	4952
Product:	Treated Municipal Wastewater

BAAQMD Engineering Division Contact Randy Frazier, P.E.

ISSUED BY THE BAY AREA AIR QUALITY MANAGEMENT DISTRICT

<u>Signed by Peter Hess for Jack P. Broadbent</u> Jack P. Broadbent, Executive Officer/Air Pollution Control Officer December 11, 2006 Date

TABLE OF CONTENTS

I.	STANDARD CONDITIONS
II.	EQUIPMENT7
III.	GENERAL APPLICABLE REQUIREMENTS 11
IV.	SOURCE-SPECIFIC APPLICABLE REQUIREMENTS
V.	SCHEDULE OF COMPLIANCE
VI.	PERMIT CONDITIONS
VII.	APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS53
VIII	TEST METHODS
IX.	PERMIT SHIELD70
X.	REVISION HISTORY
XI.	GLOSSARY

I. STANDARD CONDITIONS

A. Administrative Requirements

The permit holder shall comply with all applicable requirements in the following regulations: **BAAQMD** Regulation 1 - General Provisions and Definitions (as amended by the District Board on 5/2/01); SIP Regulation 1 - General Provisions and Definitions (as approved by EPA through 8/27/99); BAAQMD Regulation 2, Rule 1 - Permits, General Requirements (as amended by the District Board on 8/1/01); SIP Regulation 2, Rule 1 - Permits, General Requirements (as approved by EPA through 2/25/99); BAAOMD Regulation 2, Rule 2 - Permits, New Source Review (as amended by the District Board on 5/17/00); SIP Regulation 2, Rule 2 - Permits, New Source Review and Prevention of Significant Deterioration (as approved by EPA through 2/25/99); BAAQMD Regulation 2, Rule 4 - Permits, Emissions Banking (as amended by the District Board on 5/17/00); and SIP Regulation 2, Rule 4 - Permits, Emissions Banking (as approved by EPA through 2/25/99). BAAQMD Regulation 2, Rule 6 - Permits, Major Facility Review (as amended by the District Board on 5/2/01).

B. Conditions to Implement Regulation 2, Rule 6, Major Facility Review

- 1. This Major Facility Review Permit was issued on December 11, 2006 and expires on December 10, 2011. The permit holder shall submit a complete application for renewal of this Major Facility Review Permit no later than June 10, 2011 and no earlier than December 10, 2010. If a complete application for renewal has not been submitted in accordance with this deadline, the facility may not operate after December 10, 2011. (Regulation 2-6-307, 404.2, & 409.6; MOP Volume II, Part 3, §4.2)
- 2. The permit holder shall comply with all conditions of this permit. The permit consists of this document and all appendices. Any non-compliance with the terms and conditions of this permit will constitute a violation of the law and will be grounds for enforcement action; permit termination, revocation and re-issuance, or modification; or denial of a permit renewal application. (Regulation 2-6-307; MOP Volume II, Part 3, 4.11)
- 3. In the event any enforcement action is brought as a result of a violation of any term or condition of this permit, the fact that it would have been necessary for the permittee to halt or reduce the permitted activity in order to maintain compliance with such term or condition shall not be a defense to such enforcement action. (MOP Volume II, Part 3, §4.11)
- 4. This permit may be modified, revoked, reopened and reissued, or terminated for cause. (Regulation 2-6-307, 409.8, 415; MOP Volume II, Part 3, §4.11)
- 5. The filing of a request by the facility for a permit modification, revocation and re-

issuance, or termination, or the filing of a notification of planned changes or anticipated non-compliance does not stay the applicability of any permit condition. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)

- 6. This permit does not convey any property rights of any sort, or any exclusive privilege. (Regulation 2-6-409.7; MOP Volume II, Part 3, §4.11)
- 7. The permit holder shall supply within 30 days any information that the District requests in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. (Regulation 1-441, Regulation 2-6-409.4 & 501; MOP Volume II, Part 3, §4.11)
- 8. Any records required to be maintained pursuant to this permit which the permittee considers to contain proprietary or trade secret information shall be prominently designated as such. Copies of any such proprietary or trade secret information which are provided to the District shall be maintained by the District in a locked confidential file, provided, however, that requests from the public for the review of any such information shall be handled in accordance with the District's procedures set forth in Section 11 of the District's Administrative Code. (Regulation 2-6-419; MOP Volume II, Part 3, §4.11)
- 9. Proprietary or trade secret information provided to EPA will be subject to the requirements of 40 CFR Part 2, Subpart B Public Information, Confidentiality of Business Information. (40 CFR Part 2)
- 10. The emissions inventory submitted with the application for this Major Facility Review Permit is an estimate of actual emissions or the potential to emit for the time period stated and is included only as one means of determining applicable requirements for emission sources. It does not establish, or constitute a basis for establishing, any new emission limitations. (MOP Volume II, Part 3, §4.11)
- 11. The responsible official shall certify all documents submitted by the facility pursuant to the major facility review permit. The certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. The certifications shall be signed by a responsible official for the facility. (MOP Volume II, Part 3, §4.11)

C. Requirement to Pay Fees

The permit holder shall pay annual fees in accordance with District Regulation 3, including Schedule P. (Regulation 2-6-402 & 409.13, Regulation 3; MOP Volume II, Part 3, §4.12)

D. Inspection and Entry

Access to Facility: The permit holder shall provide reasonable access to the facility and equipment which is subject to this permit to the APCO and/or to his or her designee. (Regulation 1-440, Regulation 2-6-409.3; MOP Volume II, Part 3, §4.14)

E. Records

- 1. The permit holder must provide any information, records, and reports requested or specified by the APCO. (Regulation 1-441, Regulation 2-6-409.4)
- 2. Notwithstanding the specific wording in any requirement, all records for federally enforceable requirements shall be maintained for at least five years from the date of creation of the record. (Regulation 2-6-501, Regulation 3; MOP Volume II, Part 3, §4.7)

F. Monitoring Reports

Reports of all required monitoring must be submitted to the District at least once every six months, except where an applicable requirement specifies more frequent reporting. Reports shall be submitted for the following periods: July 1st through December 31st and January 1st through June 30th, and are due on the last day of the month after the end of the reporting period. All instances of non-compliance shall be clearly identified in these reports. The reports shall be certified by the responsible official as true, accurate, and complete. In addition, all instances of non-compliance with the permit shall be reported in writing to the District's Compliance and Enforcement Division within 10 calendar days of the discovery of the incident. Within 30 calendar days of the discovery of any incident of non-compliance, the facility shall submit a written report including the probable cause of non-compliance and any corrective or preventative actions. The reports shall be sent to the following address:

Director of Compliance and Enforcement Bay Area Air Quality Management District 939 Ellis Street San Francisco, CA 94109 Attn: Title V Reports

(Regulation 2-6-502, Regulation 3; MOP Volume II, Part 3, §4.7)

G. Compliance Certification

Compliance certifications shall be submitted annually by the responsible official of this facility to the Bay Area Air Quality Management District and to the Environmental Protection Agency. The certification period will be January 1st to December 31st. The certification shall be submitted by January 31st of each year. The certification must list each applicable requirement, the compliance status, whether compliance was continuous or intermittent, the method used to determine compliance, and any other specific information required by the permit. The permit holder may satisfy this requirement through submittal of District-generated Compliance Certification forms. The certification should be directed to the District's Compliance and Enforcement Division at the address above, and a copy of the certification shall be sent to the Environmental Protection Agency at the following address:

Director of the Air Division USEPA, Region IX 75 Hawthorne Street San Francisco, CA 94105 Attention: Air-3

(MOP Volume II, Part 3, §4.5 and 4.15)

H. Emergency Provisions

1. The permit holder may seek relief from enforcement action in the event of a breakdown, as defined by Regulation 1-208 of the District's Rules and Regulations, by following the procedures contained in Regulations 1-431 and 1-432. The District will thereafter determine whether breakdown relief will be granted in accordance with Regulation 1-433. (MOP Volume II, Part 3, §4.8)

- 2. The permit holder may seek relief from enforcement action for a violation of any of the terms and conditions of this permit by applying to the District's Hearing Board for a variance pursuant to Health and Safety Code Section 42350. The Hearing Board will determine after notice and hearing whether variance relief should be granted in accordance with the procedures and standards set forth in Health and Safety Code Section 42350 et seq. -(MOP Volume II, Part 3, §4.8)
- 3. The granting by the District of breakdown relief or the issuance by the Hearing Board of a variance will not provide relief from federal enforcement. (MOP Volume II, Part 3, §4.8)

I. Severability

In the event that any provision of this permit is invalidated by a court or tribunal of competent jurisdiction, or by the Administrator of the EPA, all remaining portions of the permit shall remain in full force and effect. (Regulation 2-6-409.5; MOP Volume II, Part 3, §4.10)

J. Miscellaneous Conditions

1. The maximum capacity for each source as shown in Table II-A is the maximum allowable capacity. Exceedance of the maximum allowable capacity for any source is a violation of Regulation 2, Rule 1, Section 301. (Regulation 2-1-301)

II. EQUIPMENT

Table II A - Permitted Sources

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

S-#	Description	Make or Type	Model	Capacity
S-7	Boiler 1, Auxiliary Steam, (natural gas, landfill gas, distillate oil) ME 74129	Cleaver-Brooks	CB700	28 MM Btu/hr
S-8	Boiler 2, Auxiliary Steam, (natural gas, landfill gas, distillate oil) ME 74140	Cleaver-Brooks	CB700	28 MM Btu/hr
S-9	Incinerator #1, (sewage sludge, landfill gas, natural gas)	BSP Multiple Rotary Hearth	Custom	60 dry ton/day 27 MM Btu/hr max
S-10	Incinerator #2, (sewage sludge, landfill gas, natural gas)	BSP Multiple Rotary Hearth	Custom	60 dry ton/day 27 MM Btu/hr max
S-11	Lime Storage Silo # 1 w/Pneumatic Loading System	Custom	SEMCO	0.2 ton/hr
S-13	Lime Storage Silo #2 w/Pneumatic Loading System	Custom	SEMCO	0.2 ton/hr
S-15	Lime Storage Silo #3 w/Pneumatic Loading System	Custom	SEMCO	0.2 ton/hr
S-22	Lime Storage Silo #4 w/Pneumatic Loading System	Custom	SEMCO	0.2 ton/hr
S-24	Centrifuges & Cake Hoppers, four units	Sharples	PM75000b	3.0 dry ton/hr
S-25	Gasoline Dispensing Facility (G6368), 1 nozzle	Custom	N/A	1000 gallon tank
S-100	Wastewater Treatment Plant - Fugitive Emissions	Secondary Activated Sludge	N/A	11.9 MM gal/hr
S-110	Preliminary Treatment; Influent Structure: Influent Pumping, Bar Screens, Grinders	Custom	N/A	11.9 MM gal/hr
S-120	Primary Treatment, Aerated Grit Chamber (covered), 4 Primary Sedimentation Tanks; Effluent Channel - Aerated Section - Primary Sediment to Aeration Basin Units	Custom	N/A	11.9 MM gal/hr
S-130	Flow Equalization (equivalent to wastewater holding ponds)	Custom	N/A	11.9 MM gal/hr

Table II A - Permitted Sources

Each of the following sources has been issued a permit to operate pursuant to the requirements of BAAQMD Regulation 2, Permits. The capacities in this table are the maximum allowable capacities for each source, pursuant to Standard Condition I.J and Regulation 2-1-301.

S-#	Description	Make or Type	Model	Capacity
S-140	Secondary Treatment; Two Aerated Effluent Channel - Non-aerated Section - Primary Sediment to Aeration Basin Units	Custom	N/A	11.9 MM gal/hr
S-150	Secondary Clarifiers; Aerated Effluent Channel - Aeration Basins to Secondary Clarifiers	Custom	N/A	11.9 MM gal/hr
S-160	Tertiary Treatment; four gravity filtration units/gravity filtration forebay	Custom	N/A	11.9 MM gal/hr
S-170	Disinfection; Aerated Effluent Channel - Secondary Clarifiers to Ultraviolet Disinfection	Custom	N/A	11.9 MM gal/hr
S-180	Sludge Handling Processes; Three Dissolved Air Flotation Units, Four Centrifuges, Two Sludge Blending Tank	Custom	Roots Blower Calgon Filter	3.0 dry ton/hr
S-182	Ash Conveying System	Custom	Frame	0.6 dry ton/hr
S-188	Cogeneration Turbine with Heat Recovery Steam Generator (natural gas)	Solar Centaur	T-4700	49.5 MM Btu/Hr HHV; 3500 kW
S-189	Emergency Standby Generator #1, Diesel Fired	Detroit Diesel	DDC1635	2500 HP
S-190	Emergency Standby Generator #2, Diesel Fired	Detroit Diesel	DDC1635	2500 HP
S-191	Portable Standby Generator, Diesel	Caterpillar	3054	80 HP
S-194	Portable Pump, Diesel	Deutz	F4L912	95 HP

A-#	Description	Source(s) Controlled	Applicable Requirement	Operating Parameters	Limit or Efficiency
A-1	Dry Cyclone Scrubber, Multiple	S-9	BAAQMD Reg	none listed	N/A
	Units (12" dia), American		10; NSPS O, 40		
	Standard Series 348		CFR 60.152 (a)(1)		
			& (a)(2)		
A-2	Wet Scrubber, Krebs	S-9	BAAQMD Reg	pressure drop	N/A
	Medwa/Elbair		10; NSPS O, 40	shall not drop	
			CFR 60.152 (a)(1)	below 5.9	
			& (a)(2)	inches of water	
				for more than	
				15 min in any	
				hour	
A-3	Dry Cyclone Scrubber	S-10	BAAQMD Reg	none listed	N/A
			10; NSPS O, 40		
			CFR 60.152 (a)(1)		
			& (a)(2)		
A-4	Wet Scrubber, Krebs	S-10	BAAQMD Reg	pressure drop	N/A
	Medwa/Elbair		10; NSPS O, 40	shall not drop	
			CFR 60.152 (a)(1)	below 4.7	
			& (a)(2)	inches of water	
				for more than	
				15 min in any	
				hour	
A-7	Lime Storage Bin Vent Filter	S-11, S-13, S-	BAAQMD	none listed	0.15 gr/dscf
		15, S-22	6-301, 6-310		
A-14	Packed Tower #1, Ceilcote	S-24, S-180	BAAQMD 7-102	none listed	N/A
A-15	Packed Tower #2, Ceilcote	S-24, S-180	BAAQMD 7-102	none listed	N/A
A-23	Quad Mist Odor Control Scrubber	S-110	BAAQMD	none listed	N/A
			7-102		
A-24	Quad Mist Odor Control Scrubber	S-110	BAAQMD	none listed	N/A
			7-102		
A-120	Calvert Mist Odor Control	S-120	BAAQMD	none listed	N/A
	Scrubber		7-102		
A-186	Filter Baghouses	S-182	BAAQMD	none listed	N/A
			6-301, 6-310		
A-187	Biofilter Odor Control System	S-180	BAAQMD 7-102	none listed	N/A
A-191	Cyclone, Premier	S-182	BAAQMD	none listed	N/A
			6-301, 6-310		

Table II B - Abatement Devices

		Source(s)	Applicable	Operating	Limit or
A- #	Description	Controlled	Requirement	Parameters	Efficiency
A-192	Filter Baghouse, Supervac	S-182	BAAQMD	none listed	N/A
			6-301, 6-310		
A-196	Filter Baghouse	S-182	BAAQMD	none listed	N/A
			6-301, 6-310		

Table II B - Abatement Devices

III. GENERAL APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. These requirements apply in a general manner to the facility and/or to sources exempt from the requirement to obtain a District Permit to Operate. The District has determined that these requirements would not be violated under normal, routine operations, and that no additional periodic monitoring or reporting to demonstrate compliance is warranted. In cases where a requirement, in addition to being generally applicable, is also specifically applicable to one or more sources, the requirement and the source are also included in Section IV, Source-Specific Applicable Requirements, of this permit.

The dates in parenthesis in the Title column identify the versions of the regulations being cited and are, as applicable:

- 1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors.
- 2. Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date.

The full language of SIP requirements is on EPA Region 9's website. The address is: http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&c at=Bay+Area+Air+Quality+Management+District-Agency-Wide+Provisions

NOTE:

There are differences between the current BAAQMD rule and the version of the rule in the SIP. All sources must comply with both versions of the rule until US EPA has reviewed and approved the District's revision of the regulation.

		Federally
Applicable	Regulation Title or	Enforceable
Requirement	Description of Requirement	(Y/N)
BAAQMD Regulation 1	General Provisions and Definitions (11/3/93)	Ν
SIP Regulation 1	General Provisions and Definitions (11/10/82)	Y
BAAQMD Regulation 4	Air Pollution Episode Plan (3/20/91)	Ν
SIP Regulation 4	Air Pollution Episode Plan (8/06/90)	Y
BAAQMD Regulation 5	Open Burning (11/2/94)	Ν
SIP Regulation 5	Open Burning (5/3/84)	Y
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)	Ν
SIP Regulation 6	Particulate Matter and Visible Emissions (5/3/84)	Y
BAAQMD Regulation 7	Odorous Substances (3/17/82)	N

Table IIIGenerally Applicable Requirements

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)
BAAQMD Regulation 8, Rule 1	Organic Compounds - General Provisions (6/15/94)	Y
BAAQMD Regulation 8, Rule 2	Organic Compounds - Miscellaneous Operations (6/15/94)	Y
BAAQMD Regulation 8, Rule 3	Organic Compounds - Architectural Coatings (11/21/01)	Y
BAAQMD Regulation 8, Rule 4	Organic Compounds-General Solvent and Surface Coating Operations (12/20/95)	Y
BAAQMD Regulation 8, Rule 16	Organic Compounds-Solvent Cleaning Operation (12/20/95)	Y
BAAQMD Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (12/20/95)	N
SIP Regulation 8, Rule 49	Organic Compounds - Aerosol Paint Products (3/22/95)	Y
BAAQMD Regulation 8, Rule 51	Organic Compounds - Adhesive and Sealant Products (12/20/95)	Ν
BAAQMD Regulation 9, Rule 1	Inorganic Gaseous Pollutants - Sulfur Dioxide (6/8/99)	Y
SIP Regulation 9, Rule 1	Inorganic Gaseous Pollutants - Sulfur Dioxide (5/3/84)	Y
BAAQMD Regulation 9, Rule 2	Inorganic Gaseous Pollutants – Hydrogen Sulfide (10/6/99)	Ν
BAAQMD Regulation 11, Rule 2	Hazardous Pollutants - Asbestos Demolition, Renovation and Manufacturing (12/4/91)	Y
BAAQMD Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (7/11/90)	Y
SIP Regulation 12, Rule 4	Miscellaneous Standards of Performance - Sandblasting (9/2/81)	Y

Table IIIGenerally Applicable Requirements

IV. SOURCE-SPECIFIC APPLICABLE REQUIREMENTS

The permit holder shall comply with all applicable requirements, including those specified in the BAAQMD and SIP Rules and Regulations and other federal requirements cited below. The requirements cited in the following tables apply in a specific manner to the indicated source(s).

The dates in parenthesis in the Title column identify the versions of the regulations being cited and are, as applicable:

- 1. BAAQMD regulation(s): The date(s) of adoption or most recent amendment of the regulation by the District Board of Directors.
- 2 Any federal requirement, including a version of a District regulation that has been approved into the SIP: The most recent date of EPA approval of any portion of the rule, encompassing all actions on the rule through that date

The full text of each permit condition cited is included in Section VI, Permit Conditions, of this permit. The full language of SIP requirements is on EPA Region 9's website. The address is: http://yosemite.epa.gov/r9/r9sips.nsf/Agency?ReadForm&count=500&state=California&cat=Ba y+Area+Air+Quality+Management+District-Agency-Wide+Provisions

All other text may be found in the regulations themselves.

Table IV - A Source-specific Applicable Requirements S-7, Auxiliary Boiler, Multi-Fuel S-8, Auxiliary Boiler, Multi-Fuel

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective or Expiration Date
BAAQMD	General Provisions and Definitions (5/2/01)		
Regulation 1			
1-107	Combination of Emissions	Y	
1-523	Parametric Monitoring and Recordkeeping Procedures	Ν	
1-523.1	Reporting requirement for periods of inoperation > 24 hours	Y	
1-523.2	Limit on duration of inoperation	Y	
1-523.3	Reporting requirement for violations of any applicable limits	Ν	
1-523.4	Records of inoperation, tests, calibrations, adjustments, & maintenance	Y	
1-523.5	Maintenance and calibration	Ν	

Table IV - A Source-specific Applicable Requirements S-7, Auxiliary Boiler, Multi-Fuel S-8, Auxiliary Boiler, Multi-Fuel

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective or Expiration Date
SIP	General Provisions and Definitions (6/28/99)		
Regulation 1			
1-523	Parametric Monitoring and Recordkeeping Procedures	Y^1	
1-523.3	Reports of Violations	Y^1	
1-523.5	Maintenance and calibration	Y^1	
BAAQMD	Particulate Matter and Visible Emissions		
Regulation 6	(12/19/90)		
6-301	Ringelmann Number 1 Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-310.3	Heat Transfer Operations	Y	
6-401	Appearance of Emissions	Y	
BAAQMD	Organic Compounds - Solid Waste Disposal Sites		
Regulation 8	(10/06/99)		
Rule 34			
8-34-113	Limited Exemption, Inspection and Maintenance	Y	
8-34-113.1	Emission Minimization Requirement	Y	
8-34-113.2	Shutdown Time Limitation	Y	
8-34-113.3	Recordkeeping Requirement	Y	
8-34-301	Landfill Gas Collection/Emission Control Requirements	Y	
8-34-301.1	Continuous Operation	Y	
8-34-301.2	Collection and Control System Leak Limitations	Y	
8-34-301.4	Emission Control System Limits	Y	
8-34-412	Annual Compliance Demonstration Test	Y	
8-34-413	Annual Performance Test Report	Y	
8-34-501	Operating Records	Y	
8-34-501.2	Records of emission control system downtime	Y	

Table IV - A Source-specific Applicable Requirements S-7, Auxiliary Boiler, Multi-Fuel S-8, Auxiliary Boiler, Multi-Fuel

			Future
		To Jose Ha	Effective
Applicable	Regulation Title or	Federally Enforceable	or Expiration
Requirement	Description of Requirement	(Y/N)	Date
8-34-501.4	Testing records	Y	Dutt
8-34-501.6	Leaks	Y	
8-34-501.10	Continuous gas flow records	Y	
8-34-501.11	Records of key emission control system operating parameters	Y	
8-34-501.12	Records retention for 5 years	Y	
8-34-503	Landfill gas collection and emission control system leak testing	Y	
8-34-504	Portable hydrocarbon detector	Y	
8-34-508	Gas Flow Meter	Y	
8-34-509	Key emission control system operating parameters	Y	
8-34-601	Determination of Emissions	Y	
8-34-602	Inspection Procedures	Y	
BAAQMD	Inorganic Gaseous Pollutants - Sulfur Dioxide		
Regulation 9	(3/15/95)		
Rule 1			
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-302	General Emission Limitation	Y	
9-1-304	Fuel Burning (Liquid & Solid Fuels)	Y	
BAAQMD	Inorganic Gaseous Pollutants – Hydrogen Sulfide		
Regulation 9	(10/6/99)		
Rule 2			
9-2-301	Limitations on Hydrogen Sulfide Emissions	N	
BAAQMD	Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon		
Regulation 9,	Monoxide from Industrial, Institutional, and Commercial Boilers,		
Rule 7	Steam Generators, and Process Heaters (9/15/93)		
9-7-301	Emission Limits - Gaseous Fuel	Y	
9-7-301.1	NOx	Y	
9-7-301.2	СО	Y	
9-7-302	Emission Limits – Non-Gaseous Fuel	Y	
9-7-302.1	NOx	Y	

Table IV - A Source-specific Applicable Requirements S-7, Auxiliary Boiler, Multi-Fuel S-8, Auxiliary Boiler, Multi-Fuel

Applicable	Regulation Title or	Federally Enforceable	Future Effective or Expiration
Requirement	Description of Requirement	(Y/N)	Date
9-7-302.2	СО	Y	
9-7-305	Emission Limits - Non Gaseous Fuel Natural Gas Curtailment; NOx & CO Limits	Y	
9-7-306	Emission Limits - Non-Gaseous Fuel - Equipment Testing; NOx and CO Limits	Y	
9-7-403	Initial Demonstration of Compliance	Y	
9-7-503	Records	Y	
9-7-603	Compliance Determination	Y	
BAAQMD			
Condition #21422			
part 1	Firing rate limitations (Cumulative Increase)	Y	
part 2	Exhaust gas SO2 emission limitations/monitoring & recordkeeping (BAAQMD 9-1-302, 2-6-501)	Y	
part 3	Exhaust gas NOx emission limitations – gaseous fuels firing (BAAQMD 9-7-301.1)	Y	
part 4	Exhaust gas NOx emission limitations – distillate oil fuels firing (BAAQMD 9-7-302.1)	Y	
part 5	Exhaust gas CO emission limitations (BAAQMD 9-7-301.2, 302.2)	Y	
part 6	Distillate oil sulfur content specification (Cumulative Increase)	Y	
part 7	Ongoing compliance source tests (Cumulative Increase)	Y	
part 8	Landfill gas – organic destruction efficiency, annual compliance demonstration source test, first pass boiler temperature limitation (BAAQMD 8-301.4)	Y	
part 9	Recordkeeping (Cumulative Increase, BAAQMD 9-1-304)	Y	
part 9a	Monthly fuel consumption records (Cumulative Increase)	Y	
part 9b	Monthly records - distillate oil sulfur content (BAAQMD 9-1-304)	Y	
part 9c	Monthly records – to be totaled for preceding 12 months (Cumulative Increase)	Y	
part 9d	Rolling 3 clock-hour average first pass boiler temperature records	Y	

Table IV - A Source-specific Applicable Requirements S-7, Auxiliary Boiler, Multi-Fuel S-8, Auxiliary Boiler, Multi-Fuel

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective or Expiration Date
	(BAAQMD 8-34-501.11)		
part 9e	Records retention (Cumulative Increase)	Y	

Table IV - B

Source-specific Applicable Requirements S-9 – FURNACE 1, SEWAGE SLUDGE (INCINERATOR) S-10 – FURNACE 2, SEWAGE SLUDGE (INCINERATOR)

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective or Expiration Date
BAAQMD			
Regulation 1	General Provisions and Definitions (10/7/98)		
1-107	Combination of Emissions	Y	
1-522	Continuous Emission Monitoring and Recordkeeping Procedures	Y	
BAAQMD Regulation 6	Particulate Matter and Visible Emissions (12/19/90)	Y	
6-301	Ringelmann No. 1 Limitation	Y	
6-302	Opacity Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-310.1	Incineration or Salvage Operations	Y	
6-311	General Operations	Y	
6-401	Appearance of Emissions	Y	
BAAQMD	Organic Compounds - Solid Waste Disposal Sites		
Regulation 8	(10/06/99)		
Rule 34			
8-34-113	Limited Exemption, Inspection and Maintenance	Y	

Table IV - BSource-specific Applicable RequirementsS-9 – FURNACE 1, SEWAGE SLUDGE (INCINERATOR)S-10 – FURNACE 2, SEWAGE SLUDGE (INCINERATOR)

Applicable	Regulation Title or	Federally Enforceable	Future Effective or Expiration
Requirement	Description of Requirement	(Y/N)	Date
8-34-113.1	Emission Minimization Requirement	Y	
8-34-113.2	Shutdown Time Limitation	Y	
8-34-113.3	Recordkeeping Requirement	Y	
8-34-301	Landfill Gas Collection/Emission Control Requirements	Y	
8-34-301.1	Continuous Operation	Y	
8-34-301.2	Collection and Control System Leak Limitations	Y	
8-34-301.4	Emission Control System Limits	Y	
8-34-412	Annual Compliance Demonstration Test	Y	
8-34-413	Annual Performance Test Report	Y	
8-34-501	Operating Records	Y	
8-34-501.2	Records of emission control system downtime	Y	
8-34-501.4	Testing records	Y	
8-34-501.6	Leaks	Y	
8-34-501.10	Continuous gas flow records	Y	
8-34-501.11	Records of key emission control system operating parameters	Y	
8-34-501.12	Records retention for 5 years	Y	
8-34-503	Landfill Gas Collection and Emission Control System Leak Testing	Y	
8-34-504	Portable Hydrocarbon Detector	Y	
8-34-508	Gas Flow Meter	Y	
8-34-509	Key emission control system operating parameters	Y	
8-34-601	Determination of Emissions	Y	
8-34-602	Inspection Procedures	Y	
BAAQMD	Inorganic Gaseous Pollutants – Sulfur Dioxide		
Regulation 9	(3/15/95)		
Rule 1			
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-304	Fuel Burning (Liquid & Solid Fuels)	Y	
9-1-502	Emission Monitoring Requirements	Y	
BAAQMD	Inorganic Gaseous Pollutants – Hydrogen Sulfide		
Regulation 9	(10/6/99)		

Table IV - BSource-specific Applicable RequirementsS-9 – FURNACE 1, SEWAGE SLUDGE (INCINERATOR)S-10 – FURNACE 2, SEWAGE SLUDGE (INCINERATOR)

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective or Expiration Date
Rule 2			
9-2-301	Limitations on Hydrogen Sulfide Emissions	N	
BAAQMD	Hazardous Pollutants - Lead (3/17/82)		
Regulation 11,			
Rule 1			
11-1-301	Daily Limitation	Y	
11-1-302	Ground Level Concentration Limit Without Background	Y	
BAAQMD	Hazardous Pollutants - Beryllium (3/17/82)		
Regulation 11,			
Rule 3			
11-3-301	Emission Limitation – Beryllium	Ν	
11-3-302	Burning Beryllium by Incineration	Ν	
BAAQMD	Hazardous Pollutants - Mercury		
Regulation 11,			
Rule 5			
11-5-302	Emissions from Sludge Incineration Plants	Ν	
BAAQMD	Continuous Emission Monitoring Policy and Procedures (1/20/82)	Y	
Manual of			
Procedures,			
Volume V			
40 CFR 60	Standards of Performance for New Stationary Sources (12/23/71)	Y	
Subpart A	General Provisions	Y	
60.4(b)	Reports to EPA and District	Y	
60.7	Notification and Recordkeeping	Y	
60.8	Performance Tests	Y	
60.9	Availability of Information	Y	
60.11	Compliance with standards and maintenance requirements	Y	
60.12	Circumvention	Y	
60.13(a)	Monitoring requirements	Y	
60.13(b)	Installation prior to performance tests	Y	

Table IV - BSource-specific Applicable RequirementsS-9 – FURNACE 1, SEWAGE SLUDGE (INCINERATOR)S-10 – FURNACE 2, SEWAGE SLUDGE (INCINERATOR)

		Federally	Future Effective or
Applicable	Regulation Title or	Enforceable	Expiration
Requirement	Description of Requirement	(Y/N)	Date
60.13(c)	COMS data for compliance with opacity standard	Y	
60.13(e)	Continuous operation	Y	
60.13(g)	Combined effluents	Y	
60.13(h)	Reduction of data	Y	
60.13(i)	Alternative monitoring	Y	
60.19	General notification and reporting requirements	Y	
NSPS - 40	Standards of Performance for Sewage Treatment Plants		
CFR 60			
Subpart O			
60.152(a)(1)	Particulate Emission Standards	Y	
60.152(a)(2)	Opacity Standards	Y	
60.153	Monitoring of Operations	Y	
60.153(a)(1)	Install and operate sludge flow measurement device	Y	
60.153(a)(2)	Access to well-mixed sludge sample	Y	
60.153(a)(3)	Install and operate sludge weighing device	Y	
60.153(b)(1)	Install and operate gas scrubber pressure drop monitor	Y	
60.153(b)(2)	Install and operate exhaust gas O2 content	Y	
60.153(b)(3)	Install and operate hearth temp measurement device(s)	Y	
60.153(b)(4)	Install and operate fuel flow device(s)	Y	
60.153(b)(5)	Sample sludge feed daily	Y	
60.153(c)(1)	Records – gas scrubber pressure drop	Y	
60.153(c)(2)	Records – exhaust gas O2 content	Y	
60.153(c)(3)	Records – sludge charge rate	Y	
60.155(a)	Reports – Semi-annual	Y	
60.155(a)(1)	Reports – Scrubber Pressure Drop	Y	
60.155(a)(2)	Reports – Exhaust Gas Oxygen Content	Y	
60.155(b)	Reports – Exhaust Gas Oxygen Content – O2 over performance test	Y	
CO 155(1)(1)	level	17	
60.155(b)(1)	Reports – Scrubber Pressure Drop	Y	
60.155(b)(2)	Reports – Exhaust Gas Oxygen Content	Y	

Table IV - BSource-specific Applicable RequirementsS-9 – FURNACE 1, SEWAGE SLUDGE (INCINERATOR)S-10 – FURNACE 2, SEWAGE SLUDGE (INCINERATOR)

			Future Effective
		Federally	or
Applicable	Regulation Title or	Enforceable	Expiration
Requirement	Description of Requirement	(Y/N)	Date
60.155(b)(3)	Reports – Hearth Temperatures	Y	
60.155(b)(4)	Reports – Sludge Charge Rate	Y	
60.155(b)(5)	Reports – Incinerator Fuel Use	Y	
60.155(b)(6)	Reports – Moisture & Volatile Solids	Y	
NSPS	Performance Specifications		
Appendix B			
Performance	Specifications and test procedures for opacity continuous emission	Y	
Specification 1	monitoring systems in stationary sources		
40 CFR 61	National Emission Standard for Beryllium		
Subpart C			
61.32	Beryllium Emissions not to exceed 10 g Be/24 hr period	Y	
61.33(a)	Stack Sampling-required methods	Y	
61.33(b)	Stack sampling – Notification of Administrator	Y	
61.33(c)	Source test sampling periods	Y	
61.33(d)	Sampling analysis instructions	Y	
61.33(e)	Retention of emission test reports	Y	
40 CFR 61	National Emission Standard for Mercury		
Subpart E			
61.52(b)	Mercury Emission Standard	Y	
61.53(d)(1)	Stack sampling required	Y	
61.53(d)(2)	Method 101A instructions	Y	
61.53(d)(3)	Stack sampling - Notification of Administrator	Y	
61.53(d)(4)	Source test sampling periods	Y	
61.53(d)(5)	Sampling analysis instruction	Y	
61.53(d)(6)	Retention of emission test reports	Y	
61.54(a)	Alternate compliance demonstration – Sludge Sampling	Y	
61.54(a)(1,2)	Sludge test timing	Y	
61.54(b)	Administrator notification of sludge test	Y	
61.54 (c)	Sludge sampling instructions	Y	
61.54 (d)	Mercury emissions calculation method	Y	

Table IV - BSource-specific Applicable RequirementsS-9 – FURNACE 1, SEWAGE SLUDGE (INCINERATOR)S-10 – FURNACE 2, SEWAGE SLUDGE (INCINERATOR)

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective or Expiration Date
61.54 (e)	No operational changes allowed	Y	
61.54 (f)	Timing of sludge mercury analysis	Y	
61.54 (g)	Retention of mercury emission data	Y	
BAAQMD			
Cond #21423			
part 1	Solid fuel to be derived from CCCSD only (Cumulative Increase)	Y	
part 2	Solid fuel throughput (Cumulative Increase)	Y	
Part 3	Particulate emissions (mass/throughput) limitation (40 CFR 60.152(a)(1), NSPS)	Y	
part 4	Particulate emissions (exhaust grain loading) limitation (SIP 6-310)	Y	
part 5	Visible emissions limitation – opacity (40 CFR 60.152(a)(2), (SIP 6-401)	Y	
part 6	Beryllium emissions limitation (BAAQMD 11-3-301)	Y	
part 7	Total mercury emissions limitation (BAAQMD 11-5-302, 40 CFR 61.52)	Y	
part 8	Mercury emissions enhanced monitoring trigger criteria (40 CFR 61.55(a))	Y	
part 9	Lead emissions limitation (BAAQMD 11-1)	Y	
part 10	Ongoing compliance source test requirements (BAAQMD 2-6-501)	Y	
part 10a	Sewage sludge sampling/analysis (40 CFR 60.154)	Y	
part 10b	Incinerator exhaust sampling/analysis (40 CFR 60.154(d)(3))	Y	
part 10c	Incinerator exhaust metals sampling/testing (40 CFR 60.154(d)(3)(I))	Y	
part 11	Ongoing emissions monitoring – SO2 limits (BAAQMD 9-1-304)	Y	
Part 12	Organic emissions abatement efficiency – Landfill Gas Combustion, annual compliance demonstration source test, Hearth 1 temperature limitation (BAAQMD 8-34-301.4)	Y	
part 13	Ongoing Monitoring – NSPS Requirements (40 CFR 60.153)	Y	

Table IV - BSource-specific Applicable RequirementsS-9 – FURNACE 1, SEWAGE SLUDGE (INCINERATOR)S-10 – FURNACE 2, SEWAGE SLUDGE (INCINERATOR)

			Future Effective
		Federally	or
Applicable	Regulation Title or	Enforceable	Expiration
Requirement	Description of Requirement	(Y/N)	Date
part 13a	Feed flowrate monitoring (40 CFR 60.153(a)(1))	Y	
part 13b	Wet scrubber pressure drop monitoring (40 CFR 60.153(b)(1))	Y	
part 13c	Incinerator oxygen content monitoring (40 CFR 60.153(b)(2))	Y	
part 13d	Incinerator temperature profile monitoring (40 CFR 60.153(b)(3))	Y	
part 13e	Incinerator fuel flow monitoring (40 CFR 60.153(b)(4))	Y	
part 13f	Sewage incinerator feed sampling/analysis (40 CFR 60.153(b)(5))	Y	
part 13g	Daily records - solids feed to incinerator (Cumulative Increase)	Y	
part 13h	Records retention (Cumulative Increase)	Y	
part 14	Reporting Requirements(40 CFR 60.155)	Y	
part 14a	Average scrubber pressure drop less than compliance test setpoints (40 CFR 60.155(a)(1)(i) & (ii))	Y	
part 14b	Average oxygen content (40 CFR 60.155(a)(2))	Y	
part 14c	Recent reports as requested by APCO (40 CFR 60.155(a)(3), (4), (5), (6))	Y	

Table IV - C

Source-specific Applicable Requirements

- S-11 LIME STORAGE SILO W/PNEUMATIC LOADING SYSTEM
- S-13 LIME STORAGE SILO W/PNEUMATIC LOADING SYSTEM
- S-15 Lime Storage Silo w/Pneumatic Loading System
- S-22 Lime Storage Silo w/Pneumatic Loading System

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Particulate Matter and Visible Emissions		
Regulation 6	(12/19/90)		
6-301	Ringelmann Number 1 Limitation	Y	
6-305	Visible Particles	Y	

Table IV - CSource-specific Applicable RequirementsS-11 - LIME STORAGE SILO W/PNEUMATIC LOADING SYSTEMS-13 - LIME STORAGE SILO W/PNEUMATIC LOADING SYSTEMS-15 - LIME STORAGE SILO W/PNEUMATIC LOADING SYSTEMS-22 - LIME STORAGE SILO W/PNEUMATIC LOADING SYSTEM

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
6-310	Particulate Weight Limitation	Y	
6-311	General Operations	Y	
6-401	Appearance of Emissions	Y	
BAAQMD Cond 16692			
Part 1	Abatement Requirement (basis: Regulation 2-1-403)	Y	
Part 2	Visible Emissions Monitoring (basis: Regulation 2-6-501)	Y	
Part 3	Visible Emissions Monitoring Records (basis: Regulation 2-6-501)	Y	

Table IV - DSource-specific Applicable RequirementsS-24 – CENTRIFUGES AND CAKE HOPPERS

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Particulate Matter and Visible Emissions		
Regulation 6	(12/19/90)		
6-301	Ringelmann Number 1 Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-311	General Operations	Y	
6-401	Appearance of Emissions	Y	
BAAQMD	Inorganic Gaseous Pollutants – Hydrogen Sulfide		
Regulation 9	(10/6/99)		
Rule 2			
9-2-301	Limitations on Hydrogen Sulfide Emissions	Ν	
BAAQMD			
Cond 1716			
part 1	Stack Outlet - H2S Concentration Limits (Reg 1-301; Public Nuisance)	Ν	

Table IV - DSource-specific Applicable RequirementsS-24 – CENTRIFUGES AND CAKE HOPPERS

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
part 2	Consequences of odor complaints (Reg 1-301; Public Nuisance)	Ν	
part 3	Use of Abatement Equipment Required during S-24 Operation (Reg 1- 301; Public Nuisance)	Ν	

Table IV – ESource-specific Applicable RequirementsS-25 (G6368) GASOLINE DISPENSING FACILITY

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD	Organic Compounds - Gasoline Dispensing Facilities (11/06/02)		
Regulation 8			
Rule 7			
8-7-301	Phase I Requirements	Y	
8-7-113	Tank Gauging and Inspection Exemption	Y	
8-7-114	Stationary Tank Testing Exemption	Y	
8-7-116	Periodic Testing Requirements Exemption	N	
8-7-301	Phase I Requirements	Y	
8-7-301.1	Requirement for Transfers into Stationary Tanks, Cargo Tanks, and Mobile Refuelers	Y	
8-7-301.2	Carb Certification Requirements	Y	
8-7-301.3	Submerged Fill Pipes Requirement	Y	
8-7-301.5	Maintenance and Operating Requirement	Y	
8-7-301.6	Leak-Free and Vapor-Tight Requirement for Components	Y	
8-7-301.7	Fitting Requirements for Vapor Return Line	Y	
8-7-301.8	Coaxial Phase I Systems Certified by CARB prior to January 1, 1994 may not be installed on New or Modified Systems	Y	
8-7-301.9	Anti-rotational Coupler or Swivel Adapter Required	Y	
8-7-301.10	Vapor Recovery Efficiency Requirements for New and Modified Systems	Y	
8-7-301.12	Spill Box Drain Valve Limitation	Y	
8-7-301.13	Annual Vapor Tightness Test Requirement	N	

Table IV – ESource-specific Applicable RequirementsS-25 (G6368) GASOLINE DISPENSING FACILITY

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
8-7-302	Phase II Requirements	Y	
8-7-302.1	Requirement for Transfers into Motor Vehicle Fuel Tanks	Y	
8-7-302.2	Maintenance Requirements	Y	
8-7-302.3	Proper Operation and Free of Defects Requirements	Ν	
8-7-302.4	Repair Time Limit for Defective Components	N	
8-7-302.5	Leak-Free and Vapor-Tight Requirement for Components	Y	
8-7-302.6	Requirements for Bellows Nozzles	Y	
8-7-302.7	Requirements for Vapor Recovery Nozzles on Balance Systems	Y	
8-7-302.8	Minimum Liquid Removal Rate	Y	
8-7-302.9	Coaxial Hose Requirement	Y	
8-7-302.10	Construction Materials Specifications	Ν	
8-7-302.12	Liquid Retain Limitation	N	
8-7-302.13	Nozzle Spitting Limitation	N	
8-7-302.14	Annual Back Pressure Test Requirements for Balance Systems	N	
8-7-302.15	Annual Testing Requirements for Vacuum Assist Systems	N	
8-7-303	Topping Off	Y	
8-7-304	Certification Requirements	Y	
8-7-306	Prohibition of Use	N	
8-7-307	Posting of Operating Instructions	Y	
8-7-308	Operating Practices	Y	
8-7-309	Contingent Vapor Recovery Requirements	Y	
8-7-313	Requirements for New or Modified Phase II Installations	Y	
8-7-314	Hold Open Latch Requirements	Y	
8-7-316	Pressure Vacuum Valve Requirements, Aboveground Storage Tanks and Vaulted Below Grade Storage Tanks	Y	
8-7-401	Equipment Installation and Modification	Y	
8-7-406	Testing Requirements, New and Modified Installations	Y	
8-7-407	Periodic Testing Requirements	N	
8-7-408	Periodic Testing Notification and Submission Requirements	N	
8-7-501	Burden of Proof	Y	
8-7-502	Right of Access	Y	

Table IV – ESource-specific Applicable RequirementsS-25 (G6368) GASOLINE DISPENSING FACILITY

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
8-7-503	Recordkeeping Requirements	Y	
8-7-503.1	Gasoline Throughput Records	Y	
8-7-503.2	Maintenance Records	Y	
8-7-503.3	Records Retention Time	N	
SIP	Organic Compounds, Gasoline Dispensing Facilities (7/25/2001)		
Regulation 8,			
Rule 7			
8-7-302.3	Proper Operation and Free of Defects Requirements	Y ¹	
8-7-302.4	Repair Time Limit for Defective Components	Y ¹	
8-7-302.10	Construction Materials Specifications	Y ¹	
8-7-302.12	Liquid Retain Limitation	Y ¹	
8-7-302.13	Nozzle Spitting Limitation	Y ¹	
8-7-306	Prohibition of Use	Y ¹	
8-7-503.3	Records Retention Time	Y ¹	
BAAQMD			
Cond 7523			
part 1	Gasoline throughput (Toxic Risk Management Policy)	Ν	
part 2	Gasoline throughput monitoring (Toxic Risk Management Policy)	Ν	

Table IV - FSource-specific Applicable RequirementsS-100 - MUNICIPAL WASTEWATER TREATMENT PLANT

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD			
Cond 193			
Part 1	Wastewater Throughput (Cumulative Increase)	Y	
Part 2	Consequences of odor complaints (1-301; Public Nuisance)	Y	
Part 3	Recordkeeping (2-6-409.2)	Y	

Table IV - GSource-specific Applicable RequirementsS-110- PRELIMINARY TREATMENT

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD			
Cond 7124			
part 1	Abatement of Odorous Emissions Required (Reg 1-301; Public Nuisance)	Ν	
part 2	Consequences of Odorous Emissions (Reg 1-301; Public Nuisance)	Ν	

Table IV - HSource-specific Applicable RequirementsS-120 – PRIMARY TREATMENT

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD			
Cond 7046			
part 1	Abatement of Malodorous Compounds by A-120 Required (Reg 1-301;	Ν	
	Public Nuisance)		

Table IV - ISource-specific Applicable RequirementsS-180 – SLUDGE HANDLING PROCESSES

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD Cond 13082			
part 1	Abatement of Odorous Emissions Required (Reg 1-301; Public Nuisance)	Ν	
part 2	Use of Abatement Equipment Required during S-180 Operation (Reg 1- 301; Public Nuisance)	Ν	

Table IV - JSource-specific Applicable RequirementsS-182 – ASH CONVEYING SYSTEM

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective Date
BAAQMD	Particulate Matter and Visible Emissions		
Regulation 6	(12/19/90)		
6-301	Ringelmann Number 1 Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particulate Weight Limitation	Y	
6-311	General Operations	Y	
6-401	Appearance of Emissions	Y	
BAAQMD			
Cond			
#21425			
part 1	Particulate Emissions to be Abated (Cumulative Increase)	Y	
part 2	Maintenance (Cumulative Increase)	Y	
part 3	Manufacturer's Specifications (Cumulative Increase)	Y	
part 4	Continuous Monitoring for Particulate Emissions (Regulation 2-6-503)	Y	
Part 5	Daily Visual Inspection of exhaust stacks and abatement system	Y	
part 6	Records of Leak gauge alarm events, Leak gauge instrument maintenance (Regulation 2-6-501)	Y	

Table IV - KSource-specific Applicable RequirementsS-188 – COGENERATION TURBINE, 3500 KW,NATURAL GAS FIRED

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective or Expiration Date
BAAQMD Regulation 1	General Provisions and Definitions (10/7/98)		
8			
1-107	Combination of Emissions	Y	
BAAQMD			
Regulation 6	Particulate Matter and Visible Emissions (12/19/90)		

Table IV - KSource-specific Applicable RequirementsS-188 – COGENERATION TURBINE, 3500 kW,NATURAL GAS FIRED

Applicable Requirement	Regulation Title or Description of Requirement	Federally Enforceable (Y/N)	Future Effective or Expiration Date
6-301	Ringelmann No. 1 Limitation	Y	
6-305	Visible Particles	Y	
6-310	Particle Weight Limitation	Y	
BAAQMD Regulation 9 Rule 1	Inorganic Gaseous Pollutants - Sulfur Dioxide (3/15/95)		
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-302	General Emission Limitation	Y	
BAAQMD Regulation 9, Rule 9	Inorganic Gaseous Pollutants - Nitrogen Oxides from Stationary Gas Turbines (9/21/94)		
9-9-113	Exemption - Inspection/Maintenance	Y	
9-9-114	Exemption - Startup/Shutdown	Y	
9-9-301	Emission Limits - General	Y	
9-9-301.1	Emission Limits - Turbines below 10.0 MW	Y	
NSPS Part	Standards of Performance for New Stationary Sources (12/23/71)	Y	
60			
Subpart A 60.7	Notification and record keeping	Y	
60.8(a)	Performance Tests	Y	
60.9	Availability of Information	Y	
60.11(a)	Compliance with standards and maintenance requirements	Y	
60.12	Circumvention	Y	
60.13	Monitoring Requirements	Y	
NSPS	Standards of Performance for Stationary Gas Turbines (1/27/82)		
Subpart GG			
60.332 (a)(1)	Performance Standard, NOx	Y	
60.333	Performance Standards, SO2	Y	
60.333 (b)	Fuel Sulfur Limit	Y	
60.334(a)	Water-to-fuel monitoring (if water injection used for NOx control)	Y	
60.334	Monitoring Requirements	Y	
60.334 (b)	Fuel Sulfur and Nitrogen Content	Y	

Table IV - KSource-specific Applicable RequirementsS-188 – COGENERATION TURBINE, 3500 kW,NATURAL GAS FIRED

Applicable	Regulation Title or	Federally Enforceable	Future Effective or Expiration
Requirement	Description of Requirement	(Y/N)	Date
60.334 (c)	Excess Emissions	Y	
60.335	Test Methods and Procedures	Y	
BAAQMD Cond 21485			
part 1a	Fuel Type (Cumulative Increase)	Y	
part 1b	Throughput Limitations (Cumulative Increase)	Y	
part 1c	Requirement for PUC quality natural gas	Y	
part 2	NOx emission limitations- Stack Gas Concentration (Reg 9-9-301.1)	Y	
part 3	NOx limit – clock hour average (40 CFR 60.332)	Y	
part 4	NOx Emission limitations - Daily Total (Cumulative Increase)	Y	
part 5	NOx Emission Limitations - Annual Total (Cumulative Increase)	Y	
part 6	CO Emission Limitations - Daily Total (Cumulative Increase)	Y	
part 7	CO Emission Limitations - Annual Total (Cumulative Increase)	Y	
part 8	SO2 Emission Limitations (40 CFR 60 Subpart GG)	Y	
part 9	Initial Compliance Source Test (Cumulative Increase)	Y	
part 10	Sampling Ports Required (Cumulative Increase)	Y	
part 11	Continuous emission monitoring (Cumulative Increase)	Y	
part 12	Records - daily usage of natural gas (Cumulative Increase)	Y	
part 3	NOx limit (40 CFR 60.332)	Y	
part 13	Monitoring for NSPS NOx limit, fuel input limit (40 CFR 60.334(c)(1), Cumulative Increase)	Y	
part 14	SO2 limit and monitoring (Reg 9-1-302)	Y	
part 15	Start-up Grace Period (Reg 9-9-114)	Y	
part 16	Shutdown Grace Period (Reg 9-9-114)	Y	

1 This section has been removed from BAAQMD Regulations because it has been superseded. Nevertheless, the source must comply with this regulation until US EPA has reviewed and approved (or disapproved) the District's revision of the regulation.

Table IV-LSource-specific Applicable RequirementsS-189 Emergency Standby Generator #1, Detroit Diesel, 2500 BHP

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-303	Ringelmann No. 2 Limitation	Y	
6-305	Visible Particulates	Y	
6-310	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	
BAAQMD Regulation 9, Rule 1	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-304	Fuel Burning (Liquid and Solid Fuels)	Y	
BAAQMD	Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon		
Regulation 9,	Monoxide from Stationary Internal Combustion Engines		
Rule 8	(1/20/93)		
9-8-110.4	Exemption from 9-8-301, 302, 502 Standards, Emergency Standby Engines	N	
9-8-330	Hours of Operation, Emergency Standby Engines	N	
9-8-331	Hours of Operation, Essential Public Service Standby Engines	N	
9-8-530	Monitoring and Recordkeeping, Emergency Standby Engines	Ν	
Section	Airborne Toxic Control Measure for Stationary Compression		
93115, title 17, CCR	Ignition Engines		
Part (e)(1)(A)	Fuel Requirements	Y	
Part (e)(2)(B)3.a. II. iii.	PM Emission Standards & Maximum Hours of Operation for Maintenance and Testing	Y	1-1-08
Part (e)(2)(B)3.b.I.	Applicable Emissions Standards for HC, NOx, NMHC+NOx, and CO	Y	1-1-08
Part (e)(4)(A)2.	Schedule for Reporting Information Required in Part (e)(4)(A)3.	Y	1-1-08
Part (e)(4)(A)3.	Engine Information Submittal Requirements	Y	
Part (e)(4)(A)4.	Reporting of Control Strategy Used to Achieve Compliance	Y	

Table IV-L Source-specific Applicable Requirements S-189 Emergency Standby Generator #1, Detroit Diesel, 2500 BHP

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
Part (e)(4)(D)2.	Submittal of Emissions or Operational Data	Y	1-1-08
Part (e)(4)(G)1.	Monitoring Equipment	Y	
Part (e)(4)(G)3.	Additional Monitoring Equipment Requirement	Y	
Part (e)(4)(I)1.	Monthly Log: Data Required	Y	
Part (e)(4)(I)2.	Data Log Retention	Y	
Part (g)(2)	Tiered Compliance Schedule	Y	1-1-08
BAAQMD Condition #19290			
Part 1	Hours of Operation (9-8-331)	Y	
Part 2	Definition of Emergency Conditions (9-8-231)	Y	
Part 3	Definition of Reliability-Related Activities (9-8-232)	Y	
Part 4	Monitoring (9-8-530)	Y	
Part 5	Recordkeeping (1-441, 9-8-530)	Y	

Table IV-MSource-specific Applicable RequirementsS-190 Emergency Standby Generator #2, Detroit Diesel, 2500 BHP

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-303	Ringelmann No. 2 Limitation	Y	
6-305	Visible Particulates	Y	

Table IV-MSource-specific Applicable RequirementsS-190 Emergency Standby Generator #2, Detroit Diesel, 2500 BHP

Applicable	Regulation Title or	Federally Enforceable	Future Effective
Requirement	Description of Requirement	(Y/N)	Date
6-310	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	
BAAQMD Regulation	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
9, Rule 1			
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-304	Fuel Burning (Liquid and Solid Fuels)	Y	
BAAQMD	Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon		
Regulation 9, Rule 8	Monoxide from Stationary Internal Combustion Engines (1/20/93)		
9-8-110.4	Exemption from 9-8-301, 302, 502 Standards, Emergency Standby Engines	Ν	
9-8-330	Hours of Operation, Emergency Standby Engines	N	
9-8-331	Hours of Operation, Essential Public Service Standby Engines	N	
9-8-530	Monitoring and Recordkeeping, Emergency Standby Engines	N	
Section	Airborne Toxic Control Measure for Stationary Compression		
93115, title 17, CCR	Ignition Engines		
Part (e)(1)(A)	Fuel Requirements	Y	
Part (e)(2)(B)3.a. II. iii.	PM Emission Standards & Maximum Hours of Operation for Maintenance and Testing	Y	1-1-09
Part (e)(2)(B)3.b.I.	Applicable Emissions Standards for HC, NOx, NMHC+NOx, and CO	Y	1-1-09
Part (e)(4)(A)2.	Schedule for Reporting Information Required in Part (e)(4)(A)3.	Y	
Part (e)(4)(A)3.	Engine Information Submittal Requirements	Y	
Part (e)(4)(A)4.	Reporting of Control Strategy Used to Achieve Compliance	Y	
Part (e)(4)(D)2.	Submittal of Emissions or Operational Data	Y	1-1-09
Part (e)(4)(G)1.	Monitoring Equipment	Y	

Table IV-M Source-specific Applicable Requirements S-190 Emergency Standby Generator #2, Detroit Diesel, 2500 BHP

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
Part	Additional Monitoring Equipment Requirement	Y	
(e)(4)(G)3.			
Part	Monthly Log: Data Required	Y	
(e)(4)(I)1.			
Part	Data Log Retention	Y	
(e)(4)(I)2.			
Part	Tiered Compliance Schedule	Y	1-1-09
(g)(2)			
BAAQMD			
Condition			
#19290			
Part 1	Hours of Operation (9-8-331)	Y	
Part 2	Definition of Emergency Conditions (9-8-231)	Y	
Part 3	Definition of Reliability-Related Activities (9-8-232)	Y	
Part 4	Monitoring (9-8-530)	Y	
Part 5	Recordkeeping (1-441, 9-8-530)	Y	

Table IV-N

Source-specific Applicable Requirements S-191 Emergency Generator, Portable, Caterpillar 3056, 80 hp, Diesel S-194 Emergency Pump, Portable, Deutz F4L912, 94 hp, Diesel

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
BAAQMD	Permits – General Requirements (8/1/2001)		
Regulation 2			
1-220.1	Portable Equipment; Single Site Time Limit	Y	
BAAQMD	Particulate Matter and Visible Emissions (12/19/90)		
Regulation 6			
6-303	Ringelmann No. 2 Limitation	Y	
6-305	Visible Particulates	Y	

Table IV-NSource-specific Applicable RequirementsS-191 Emergency Generator, Portable, Caterpillar 3056, 80 HP, DieselS-194 Emergency Pump, Portable, Deutz F4L912, 94 HP, Diesel

		Federally	Future
Applicable	Regulation Title or	Enforceable	Effective
Requirement	Description of Requirement	(Y/N)	Date
6-310	Particulate Weight Limitation	Y	
6-401	Appearance of Emissions	Y	
BAAQMD	Inorganic Gaseous Pollutants, Sulfur Dioxide (3/15/95)		
Regulation			
9, Rule 1			
9-1-301	Limitations on Ground Level Concentrations	Y	
9-1-304	Fuel Burning (Liquid and Solid Fuels)	Y	
BAAQMD	Inorganic Gaseous Pollutants - Nitrogen Oxides and Carbon		
Regulation 9,	Monoxide from Stationary Internal Combustion Engines		
Rule 8	(1/20/93)		
9-8-110.4	Exemption from 9-8-301, 302, 502 Standards, Emergency Standby	Ν	
	Engines		
9-8-330	Hours of Operation, Emergency Standby Engines	Ν	
9-8-331	Hours of Operation, Essential Public Service Standby Engines	Ν	
9-8-530	Monitoring and Recordkeeping, Emergency Standby Engines	Ν	
BAAQMD			
Condition			
#19291			
Part 1	Eligibility Requirements (2-1-220)	Y	
Part 2	Single Site Operating Hours - Limitation (2-1-220)	Y	
Part 3	Opacity Limitation (6-301)	Y	
Part 4	Public Nuisance (1-301)	Y	
Part 5	Limitation on Operation Near School (2-1-412)	Y	
Part 6	Recordkeeping (1-441)	Y	
Part 7	Reporting (1-441)	Y	
Part 8	Year End Operating Summary (1-441)	Y	

V. SCHEDULE OF COMPLIANCE

The permit holder shall comply with all applicable requirements cited in this permit. The permit holder shall also comply with applicable requirements that become effective during the term of this permit.

VI. PERMIT CONDITIONS

Any condition that is preceded by an asterisk is not federally enforceable.

Condition 193

For: S-100, Wastewater Treatment Plant

1. Flowrate

Total wastewater flow shall not exceed 53.8 million gallons per day on a calendar month average during dry weather periods or 140 million gallons per day on a calendar month average during wet weather periods. For the purposes of this limit, wet weather is defined as the months from October through May. [Basis: Cumulative Increase]

2. Nuisance

In the event that a public nuisance odor source is identified at this facility, the Permit Holder shall employ all measures, practices, or modifications necessary to abate the nuisance. [Basis: Regulation 1-301]

3. Records

To demonstrate compliance with Part 1, above, the Permit Holder shall maintain the following records: [Basis: Regulation 2-6-409.2]

- a. Daily and monthly (calendar basis) records of the quantity of wastewater processed at this source.
- b. Monthly records shall be totaled for each consecutive 12-month period.
- c. All records shall be retained onsite for five years from the date of entry.

Condition 1716

For: S-24, Centrifuges and Cake Hoppers

- *1. H₂S concentration at the stack outlet of A-14 or A-15 shall not exceed 1.50 ppm, by volume. (Basis: BAAQMD Regulation 1-301)
- *2. If the District receives ten or more confirmed odor complaints within a 90 day period, Central Contra Costa Sanitary District shall install an area monitoring system for H_2S as described in Regulation 1-510 and comply with Regulation 9 Rule 2 Sections 9-2-301 and 9-2-501. This area monitoring system shall be installed and operating within 6 months from the date the tenth odor complaint is confirmed. (Basis: BAAQMD Regulation 1-301)
- *3. S-24 shall not be operated unless abated by A-14 or A-15 packed tower. (Basis: BAAQMD Regulation 1-301)

Condition 7046

For: S-120, Primary Treatment

*1. The pre-aeration tank area and adjacent wastewater distribution channels at S-120 shall be enclosed and gaseous emissions from these portions of S-120 shall be abated by A-120 at all times that malodorous compounds are present at S-120. (Basis: BAAQMD Regulation 1-301)

Condition 21425

For: S-182, Ash Conveying System

- All particulate emissions at S-182 shall be abated by either Baghouse A-186, Baghouse A-196, or Cyclone A-191/Baghouse A-192. (Basis: Cumulative Increase)
- A-186 Baghouse Filters, A-196 Baghouse Filters, and A-191 Cyclone/A-192 Baghouse System shall all be properly maintained and kept in good working order. (Basis: Cumulative Increase)
- 3. A-186 Baghouse Filters, A-196 Baghouse Filters, and A-191 Cyclone/A-192 Baghouse System shall all be operated according to and within manufacturer's operating specifications. (Basis: Cumulative Increase)
- 4. Particulate emissions control systems A-186 Baghouse Filters, A-196 Baghouse Filters, and A-191 Cyclone/A-192 Baghouse System, shall be monitored continuously for particulate emissions by the use of a Mikro-

Charge LeakGauge or equivalent instrument with a setpoint to detect particulate emissions and activate an operator alarm. In the event of an alarm indicating a filter system leak, the Permit Holder shall take all corrective action necessary to minimize emissions and to make the needed repairs. The Mikro-Charge LeakGauge system shall be properly maintained and operated as per Manufacturer recommendations. [Basis: BAAQMD 2-6-503]

- 5. The exhaust stacks from particulate emissions abatement system A-186, A-196, and A-191/A-192 shall be visually checked and the observation recorded in a District-approved log at a frequency of at least one time per day during daylight hours either by using the remote control rooftop video camera or by a personal rooftop inspection of the exhaust stacks by the plant operator. An observation of a visible emission would constitute an abatement system leak, requiring immediate action to minimize further leakage and to make the necessary repairs. (Basis: BAAQMD 2-6-501)
- 6. The Permit Holder shall keep records of all Mikro-Charge LeakGauge alarm events, visible emissions checks including the operator performing the check, and all maintenance performed on A-186 Baghouse Filters, A-196 Baghouse Filters, and A-191 Cyclone/A-192 Baghouse System, and the Mikro-Charge LeakGauge Instrument system. The records shall be retained for five (5) years and shall be made available to District personnel upon request. [Basis: BAAQMD 2-6-501]

Condition 7124

For: S-110, Preliminary Treatment

- *1. Odorous emissions from S-110 shall be abated by A-23 and A-24 at all times that malodorous compounds are present at S-110. (Basis: BAAQMD Regulation 1-301)
- *2. S-110 shall not emit odorous emissions in such quantities that cause a public nuisance per Regulation 1-301. (Basis: BAAQMD Regulation 1-301)

Condition 7523

For: S-25, Non Retail Gasoline Dispensing Facility

- *1. Pursuant to BAAQMD Toxic Section Policy, this facility's annual gasoline throughput shall not exceed 400,000 gallons in any consecutive 12 month period. (Basis: BAAQMD Toxic Section Policy/Toxic Risk)
- *2. In order to demonstrate compliance with the above condition, Central Contra Costa Sanitary District shall maintain the following records and provide all of the data necessary to evaluate compliance with the above condition, including the following information:

Monthly gasoline throughput (gallons/month)

All records shall be retained on-site for five years, from the date of entry, and made available for inspection by District staff upon request. These recordkeeping requirements shall not replace the recordkeeping requirements contained in any applicable District Regulations. (Basis: Toxic Section Policy/Toxic Risk)

Condition 13082

For: S-180, Sludge Handling - Dissolved Air Flotation (DAF) thickeners

- *1. Each of the three dissolved air floatation (DAF) units at S-180 shall be equipped and operated with a District approved cover and ducting in place to route emissions from the DAF units to A-187 for abatement. (Basis: BAAQMD Regulation 1-301)
- *2. Malodorous gaseous emissions from each of the three dissolved air floatation units (DAF) units at S-180 shall be routed to and abated at all times that these portions of S-180 are sources of malodorous emissions. (Basis: BAAQMD Regulation 1-301)

Condition 19290

For: S-189: Emergency Standby Generator #1: Diesel Engine, Make: Detroit, Model: DDC1635, Rated Horsepower: 2500 HPS-190: Emergency Standby Generator: #2 Diesel Engine, Make: Detroit, Model: DDC1635, Rated Horsepower: 2500 HP

*1. Hours of Operation: The emergency standby engines (S-189, S-190) shall only be operated to mitigate emergency conditions or for reliabilityrelated activities. Operation for reliability-related activities shall not exceed 200 hours in any calendar year for S-189 and S-190. Operation while mitigating emergency conditions is unlimited for both S-189 and S-190. [Basis: Reg 9-8-331]

- *2. "Emergency Conditions" is defined as any of the following: [Basis: Reg 9-8-231]
 - a. Loss of regular natural gas supply.
 - b. Failure of regular electric power supply.
 - c. Flood mitigation.
 - d. Sewage overflow mitigation.
 - e. Fire.

f. Failure of a primary motor, but only for such time as needed to repair or replace the primary motor.

*3. "Reliability-related activities" is defined as any of the following: [Basis: Reg 9-8-232]

a. Operation of an emergency standby engine to test its ability to perform for an emergency use, or

b. Operation of an emergency standby engine during maintenance of a primary motor.

*4. The emergency standby engine shall be equipped with either: [Basis: Reg. 9-8-530]

a. a non-resettable totalizing meter that measures and records the hours of operation for the engine, or

- b. a non-resettable fuel usage meter.
- *5. Records: The following monthly records shall be maintained in a Districtapproved log for at least 2 years and shall be made available for District inspection upon request: [Basis: Reg. 9-8-530, 1-441]
 - a. Hours of operation (total).
 - b. Hours of operation (emergency).
 - c. For each emergency, the nature of the emergency condition.

Condition 19291

For:

- S-191 Portable Standby Generator: Diesel Engine, Make: Caterpillar, Model: 3054, Rated Horsepower: 80 HP.
- S-194 Portable Standby Pump: Diesel Engine, Make: Deutz, Model: F4L912, Rated Horsepower: 95 HP (2300 RPM).

Portable Equipment Requirements

1. This mobile equipment shall operate at all times in conformance with the eligibility requirements set forth in BAAQMD Regulation 2-1-220 for portable equipment. [Basis: Reg 2-1-220]

2. If the portable equipment remains at any fixed location in the Bay Area Air Basin for more than 12 months, the portable permit will automatically revert to a conventional permanent location BAAQMD permit and will lose its portability. [Basis: Reg. 2-1-220.1]

Regulatory Compliance Requirements

- 3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour that is as dark or darker than Ringelmann 1 or equivalent to 20% opacity. [Basis: 6-301]
- 4. Operation of Sources S-191 and S-194 shall not emit pollutant emissions in sufficient quantities as to cause a public nuisance under Regulation 1-301. [Basis: Reg. 1-301]
- 5. S-191 and S-194 shall not be operated for longer than 72 consecutive hours within 1,000 feet of a school. To operate for longer than 72 consecutive hours within 1,000 feet of a school, the Permit Holder must submit an application to the District so that proper notification of your intended operation can be made known to the affected public in advance of any continued usage of the equipment. [Basis: Reg 2-1-114.2.3, 2-1-403, 2-1-412]

Recordkeeping Requirements

6. The following records shall be kept in a District approved logbook and retained for a period of at least five years following the date of entry. The log shall be kept with the equipment and made available to District staff upon request. [Basis: Reg 1-441]

a. Weekly hours of operation or fuel usage for S-191 and S-194.

b. Hours of operation or fuel usage shall be totaled on a monthly basis.

Reporting Requirements

7. The Permit Holder shall notify the District, in writing, at least 3 days in advance, of the new location in which they plan to operate for longer than 72 consecutive hours. The notification shall include [Basis: Reg 1-441]

a. A brief description of the general nature of the operation.

b. The estimated duration of the operation at this site.

c. The name and phone number of a contact person where the equipment will be operated.

8. Within 30 days after the end of every calendar year, the Permit Holder shall provide a year-end summary showing the following information: [Basis: Reg 1-441]

a. The location(s) at which the equipment was operated for more than 72 consecutive hours including the dates operated at each location.b. The total hours of operation or fuel used by S-191 and S-194 for the previous 12 months.

Condition 21485

For: S-188: Natural Gas Fired Turbine Generator with HRSG; Solar Model Centaur T-4700, 3500 KW; Maximum Firing Capacity - 49.5 MMBtu/hr (HHV).

- 1a. S-188 shall be fired only on natural gas. (Basis: Cumulative Increase)
- 1b. The S-188 firing rate shall not exceed 1188 MMBtu/day (HHV). (Basis: Cumulative Increase)
- 1c. All natural gas burned at S-188 shall be PUC quality gas. (basis: 2-1-403)
- 2. NOx emissions from S-188 shall not exceed 42 ppmv, dry, at 15% oxygen based on a three clock hour average. (Basis: Reg 9-9-301.1))
- 3. NOx emissions from S-188 shall not exceed 154 ppmv, dry, at 15% oxygen based on a clock-hour average. (Basis: 40 CFR 60.332)
- 4. NOx emissions from S-188 shall not exceed 118 pounds in any rolling consecutive 24 hour period. (Basis: Cumulative Increase)
- 5. NOx emissions from S-188 shall not exceed 19.824 tons in any rolling 365 consecutive day period. (Basis: Cumulative Increase)
- 6. CO emissions from S-188 shall not exceed 157 pounds each rolling consecutive 24 hour period. (Basis: Cumulative Increase)
- 7. CO emissions from S-188 shall not exceed 26.376 tons in any rolling 365 consecutive day period. (Basis: Cumulative Increase)
- 8. Exhaust gas emissions shall not exceed 150 ppm SO2, dry, at 15% O2. The Permit Holder shall use the sulfur content of the gaseous fuels in conjunction with a material balance to calculate the exhaust gas sulfur dioxide concentration. The Permit Holder shall calculate and record the sulfur dioxide concentration at least 1 time every calendar quarter. (Basis: 40 CFR Part 60 Subpart GG)

- 9. To demonstrate compliance with conditions 6 and 7 above, the Permit Holder shall perform a-compliance source test at a frequency of at least 1 time every 60 months after the most recent source test. Source test results shall be kept onsite and made available to the BAAQMD staff upon request. (Basis: Cumulative Increase)
- 10. The stack at S-188 shall be equipped with BAAQMD approved source testing ports to allow for the suitable sampling and testing of process flue gas emissions from S-188. (Basis: Cumulative Increase)
- 11. The Permit Holder shall operate a BAAQMD approved emission monitoring and recording system for S-188 to continuously assure compliance with conditions 2, 4, and 5, above. Recording made to comply with this condition shall be retained for at least five years from date of last entry. This log shall be kept on-site and made available to the BAAQMD staff upon request. (Basis: Cumulative Increase, BAAQMD Regulation 2-6-501, 9-9-301.1)
- 12. The daily usage of natural gas at S-188, as measured at a BAAQMD approved fuel meter dedicated solely to this sources, shall be recorded daily in cubic feet (or thousands of cubic feet) in a BAAQMD approved log. This log shall be retained for at least five years from date of last entry. This log shall be kept on-site and made available to the BAAQMD staff upon request. (Basis: Cumulative Increase, BAAQMD Regulation 2-6-501)
- 13. In order to show compliance with parts 1b and 14, the Permit Holder shall operate a USEPA approved fuel flow monitor and water injection flow monitor and calculate the water-to-fuel ratio on a clock-hour basis and the heat input on a daily basis. (Basis 40 CFR 60.334(c)(1))
- Exhaust gas emissions shall not exceed 300 SO₂ ppmv, dry. CCCSD shall use the sulfur content of the fuels in conjunction with a material balance to calculate the exhaust gas sulfur dioxide concentrations. (Basis: BAAQMD 9-1-302)
- 15. During the start-up of S-188, this source shall be granted a start-up grace period during which S-188 need not meet the emission limit indicated in part 2, and part 3, above. All other conditions imposed on S-188 shall remain in effect and enforceable. This start-up grace period shall begin once fuel is first combusted at S-188 and shall end not more than three hours later. NOx emissions during this start-up grace period shall not be included in the cumulative NOx emissions of any rolling consecutive 24-hour period. During subsequent additional start-ups of S-188 within a single 24 consecutive hour period, there shall be no start-up grace period and all conditions imposed on S-188 shall be in effect and enforceable. Each start-

up shall be recorded in a District-approved log which shall be retained for at least five years from the date of last entry, be kept on site, and made available to the District upon request. (Basis: BAAQMD 9-9-114)

16. During the shutdown of S-188, this source shall be granted a shutdown grace period during which S-188 need not meet the emission limit indicated in part 2, and part 3, above. All other conditions imposed on S-188 shall remain in effect and enforceable. This shutdown grace period shall be defined as the last hour of operation of S-188 preceding the time that all fuel combustion at S-188 has ceased. NOx emissions during this start-up grace period shall not be included in the cumulative NOx emissions of any rolling consecutive 24-hour period. Not more than one such grace period may occur in any 24 consecutive hour period. During additional shutdowns of S-188 within a single 24 consecutive hour period, there shall be no shutdown grace period and all conditions imposed on S-188 shall remain in effect and enforceable. Each shutdown shall be recorded in a District-approved log which shall be retained for at least five years from the date of last entry, be kept on site, and made available to the District upon request. (Basis: BAAQMD 9-9-114)

Condition # 21422

For: S-7, Auxiliary Steam Boiler 1, and S-8, Auxiliary Steam Boiler 2; Both Boiler Specifications as follows: Cleaver Brooks, CB700, Maximum Firing Capacity: 28 MM Btu/hr (HHV) with High Turn Down Multi-fuel Burners and Cleaver Brooks induced Flue Gas Recirculation System

- 1. S-7 Boiler and S-8 Boiler shall be fired at a rate not to exceed 28 MM Btu/hr (HHV) per boiler. (Basis: Cumulative Increase)
- 2. Exhaust gas emissions shall not exceed 300 ppm, dry SO2. The Permit Holder shall use the sulfur content of the fuels in conjunction with a material balance to calculate the exhaust gas sulfur dioxide concentration. The Permit Holder shall calculate and record the resulting sulfur dioxide concentration at least 1 time every calendar quarter. (Basis: BAAQMD 9-1-302).

The Permit Holder shall monitor and record the sulfur content of the landfill gas at a frequency of at least one time every calendar month when burning landfill gas. (BAAQMD 2-6-501)

- Emissions of nitrogen oxides (NOx) shall not exceed 30 ppmv (@ 3 percent O2, dry) when firing gaseous fuels. (Basis: BAAQMD Regulation 9-7-301.1)
- 4. Emissions of nitrogen oxides (NOx) shall not exceed 40 ppmv (@ 3 percent

O2, dry) when firing distillate oil. (Basis: BAAQMD Regulation 9-7-302.1)

- 5. Emissions of carbon monoxide (CO) shall not exceed 400 ppmv @ 3 percent O2, dry. (Basis: BAAQMD Regulation 9-7-301.2, 9-7-302.2)
- 6. The distillate oil sulfur content shall not exceed 0.5 percent by weight. (Basis: BAAQMD 9-1-304)
- 7. To demonstrate ongoing compliance with parts 3, 4, and 5 above, the Permit Holder shall perform compliance source test at a frequency of at least 1 time every 60 months after the previous source test. Compliance source tests shall be conducted in accordance with District Manual of Procedures. Source test results shall be kept onsite and made available to the BAAQMD staff upon request. (Basis: Cumulative Increase)
- 8. While burning landfill gas, NMOC emissions shall be abated by at least 98% by weight across S-7 and S-8 auxiliary boiler(s), or the exhaust emissions of NMOC shall be less than 120 ppm by volume, dry basis, expressed as methane, corrected to 3% oxygen. BAAQMD 8-34-301.4)

To demonstrate ongoing compliance with this requirement the Permit Holder shall perform a pre-approved annual source test in accordance with the District Manual of Procedures. The annual source test shall be conducted not less than 9 months nor more than 12 months after the most recent compliance source test. (Basis: BAAQMD 8-34-412)

To ensure ongoing compliance with the above NMOC destruction efficiency, the Permit Holder shall maintain the rolling 3 clock-hour average first pass boiler temperature of S-7 and S-8 at 770 degrees F or greater when burning landfill gas. While burning landfill gas, the Permit Holder shall continuously monitor the first pass temperatures of S-7 and S-8 and shall calculate and record the rolling 3 clock-hour average temperatures in a District-approved log. (Basis: BAAQMD 8-34-509)

If a source test demonstrates compliance with all applicable requirements at a different minimum first pass temperature, the APCO may revise the above temperature limit, in accordance with the procedures identified in Regulation 2-6-414 or 2-6-415 based on the following criteria. The minimum first pass temperature for S-7 and S-8 shall be equal to the average first pass temperature measured during a complying source test (NMHC and CO emission limits were met) minus 50 degrees F. (Basis: 40 CFR 60.758(c)(1)(i)

9. The Permit Holder shall maintain the following records and provide all of the

data necessary to demonstrate compliance with the above conditions, including the following information:

- a. Monthly records of the quantity of natural gas, landfill gas, and distillate oil (gal) burned at this source.
- b. Monthly records of the distillate oil sulfur content certification.
- c. Monthly records shall be totaled for each consecutive 12-month period.
- d. Records of the rolling 3 clock-hour average first pass boiler temperatures.
- e. All records shall be retained onsite for five years from the date of entry, and made available for inspection by District staff upon request. These recordkeeping requirements shall not replace the recordkeeping requirements contained in any applicable District Regulations. (Basis: Cumulative Increase, BAAQMD 9-1-304)

Condition # 21423

For: S-9, Furnace 1, and S-10, Furnace 2, Sewage Sludge Incinerators, BSP Multiple Rotary Hearth, 27 MM Btu/hr Max Heat Input

- 1. Solid fuel shall be solids derived from CCCSD sewage operations only. (Basis: Cumulative Increase)
- 2. S-9 and S-10 combined solid fuel throughput shall not exceed 120 ton/day and 20,000 ton in any consecutive 12 month period (Basis: Cumulative Increase)
- 3. Particulate emissions shall not exceed 0.65 gram per kilogram of dry sludge input (1.3 lb/ton dry sludge input) (Basis: 40 CFR 60.152(a)(1), NSPS).
- 4. Particulate emissions shall not exceed 343 mg/dscm (0.15 grain per dscf) of exhaust gas volume. The actual measured concentration of particulate matter in the exhaust gas shall be corrected to the concentration which the same quantity of particulate matter would constitute in the exhaust gas minus water vapor corrected to standard conditions, containing 12% CO2 by volume, and as if no auxiliary fuel had been used (Basis: BAAQMD 6-310).
- 5. Visible emissions shall not exceed 20 percent opacity as detected by an opacity sensing device for a period or periods aggregating more than three minutes in any hour). To comply with this part the Permit Holder shall

install and maintain a District-approved opacity sensing continuous emission monitor (CEM). (Basis: BAAQMD 6-401, 40 CFR 60.152(a)(2)

- 6. Total combined beryllium emissions from S-9 and S-10 are not to exceed 10 grams in any 24 hr period. Unless a waiver is obtained by the APCO (according to 40 CFR 60.13) the Permit Holder is to demonstrate compliance according to EPA Method 104 of Appendix B of 40 CFR 61.33. (Basis: BAAQMD 11-3-301)
- 7. Total combined mercury emissions from S-9 and S-10 are not to exceed 3200 gram per 24 hour period.. Compliance with this section may be demonstrated by performing an EPA Method 105 (Mercury in Wastewater Treatment Plant Sewage Sludge) test or an equivalent test as pre-approved by the APCO. (Basis: BAAQMD 11-5-302, 40 CFR 61.52)
- 8. If mercury emissions exceed 1600 gram per 24 hour period, the Permit Holder shall monitor mercury emissions from S-9 and S-10 at a frequency of at least once every 12 months. (Basis: 40 CFR 61.55(a))
- 9. Lead emissions are not to exceed 15 lb/day per furnace (Basis: BAAQMD 11, Rule 1).
- 10. To demonstrate compliance with parts 4 through 9, above, and with Regulation 6-311, the Permit Holder shall perform a District-approved compliance source test within 180 days of furnace startup and ongoing source tests at a frequency of at least once every 60 months of furnace operation following the previous source test. Note: Source tests performed prior to issuance of the Title V permit may be used to demonstrate initial compliance as long as District-approved sampling and analysis methods were used. Source tests to demonstrate compliance with 40 CFR part 503 may also be used to demonstrate compliance as long as District-approved sampling and analysis methods were used and approved by the APCO. Source test results shall be submitted to the APCO within 60 days of analytical completion. (Basis: BAAQMD 2-6-501)
 - a. Sewage Sludge sampling: Sewage sludge sampling shall be performed as noted in condition 13(f) below. The Permit Holder shall use Method 209F to determine dry sludge content, Method 104 for beryllium, Method 12 for lead, and Method 105 for mercury. (Basis: 40 CFR 60.154)
 - b. Exhaust particulate testing: Three composite exhaust samples shall be collected according to EPA Method 5 and analyzed for particulate mass. (Basis: 40 CFR 60.154 (d)(3)).

- c. Exhaust metals testing: Three composite exhaust samples shall be collected according to EPA Method 5. Two of the samples shall be analyzed by neutron activation for arsenic, cadmium, chromium, copper, nickel, selenium and zinc; and one sample shall be analyzed according to Method 104 (or Method 103) and Method 12, respectively, for beryllium and lead. (Basis: 40 CFR 60.154(d)(3)(i).
- 11. Ongoing Emissions Sulfur Dioxide: Exhaust gas emissions shall not exceed 300 ppm, dry SO2. (Basis: BAAQMD 9-1-304)

To demonstrate compliance with this requirement the Permit Holder shall perform a District-approved source test at a frequency of at least one time every calendar year. Source tests shall be conducted using BAAQMD Method ST-19A (or an approved equivalent method) according to a preapproved source test protocol. Results shall be submitted to the APCO within 60 days of analytical completion. (Basis: BAAQMD 9-1-304)

12. NMOC emissions shall be abated by at least 98% by weight across S-9 and S-10 or the concentration shall be less than 120 ppmv, dry NMOC, expressed as methane corrected to 3% oxygen when firing landfill gas. To demonstrate that each furnace complies with this requirement, the Permit Holder shall perform a District-approved initial source test within 60 days of S-9 or S-10 furnace startup, and ongoing source tests at a frequency of not less than 9 months nor greater than 12 months of furnace operation after the most recent compliance source test. Source test protocols shall be prepared and pre-approved by the APCO prior to performing any source tests.

To ensure compliance with the above NMOC abatement or emission standard, the Permit Holder shall maintain the rolling 3 clock-hour average temperature of Hearth 1 at 1,000 degrees F or greater. The Permit Holder shall calculate and record the rolling 3 clock-hour average temperatures in a District-approved log. (Basis: 40CFR 60.158(c)(1)(i))

If a source test demonstrates compliance with all applicable requirements at a different minimum hearth 1 temperature, the APCO may revise the above temperature limit, in accordance with the procedures identified in Regulation 2-6-414 or 2-6-415 based on the following criteria. The minimum hearth 1 temperature for S-9 and S-10 shall be equal to the average hearth 1 temperature measured during a complying source test (NMHC emission limit was met) minus 50 degrees F. (Basis: 40 CFR 60.758(c)(1)(i))

13. Ongoing Monitoring: To demonstrate compliance with the above parts and as required by the New Source Performance Standard (NSPS) for sewage treatment plants the Permit Holder shall:

- a. Install, calibrate, maintain and operate a flow measuring device, which can be used to determine either the mass or volume of sludge charged to the furnace. The sludge flow measurement device shall be certified by the manufacturer to have an accuracy of plus or minus 5% over its operating range. The flow measurement device shall be operated continuously and data recorded during all periods of operation of the furnace. (Basis: 40 CFR 60.153(a)(1))
- b. Install, calibrate, maintain and operate a monitoring device that continuously measures and records the pressure drop of the gas flow through the wet scrubber. Where a combination of wet scrubbers is used in series, the pressure drop of the gas flow through the combined system shall be continuously monitored. The device used to monitor scrubber pressure drop shall be certified by the manufacturer to be accurate within plus or minus 1 inch water gauge and shall be calibrated on an annual basis in accordance with manufacturer's instructions. (Basis: 40 CFR 60.153(b)(1))
- c. Install, calibrate, maintain and operate a monitoring device that continuously measures and records the oxygen content of the furnace exhaust gases. The oxygen monitor shall be located upstream of any rabble shaft cooling air inlet in the furnace exhaust gas stream, fan, ambient air recirculation damper, or any other source of dilution air. The oxygen monitoring device shall be certified by the manufacturer to have a relative accuracy of plus or minus 5 percent over its operating range and shall be calibrated according to method(s) prescribed by the manufacturer at least once each 24-hour operating period. (Basis: 40 CFR 60.153(b)(2))
- d. Install, calibrate, maintain and operate temperature measuring devices at every hearth in the multiple hearth furnaces. A minimum of one thermocouple shall be installed in each hearth in the cooling and drying zones, and a minimum of two thermocouples shall be installed in each hearth in the combustion zone. Each temperature measuring device shall be certified by the manufacturer to have an accuracy of plus or minus 5 percent over its operating range. The temperature monitoring devices shall be operated continuously and data recorded during all periods of operation of the furnace. (Basis: 40 CFR 60.153(b)(3))
- e. Install, calibrate, maintain and operate a device for measuring the fuel flow to the furnace. The flow measuring device shall be certified by the manufacturer to have an accuracy of plus or minus 5 percent over its operating range. The fuel flow device(s) shall be operated continuous

and data recorded during all periods of operation of the furnace. (Basis: 40 CFR 60.153(b)(4))

- f. Collect and analyze a grab sample of the sludge fed to the furnace once per day. The dry sludge content and the volatile solids content shall be determined in accordance with the method specified in 40 CFR 60.154 c (2). (Basis: 40 CFR 60.153(b)(5))
- g. In order to demonstrate compliance with part 2, above, the Permit Holder shall maintain daily records of total solid fuel throughput (ton/day) to S-9 and S-10 sewage sludge furnaces. (Basis: Cumulative Increase)
- h. All records shall be retained onsite for a period of at least 5 years and made available to the APCO upon request. (Basis: Cumulative Increase)
- 14. Reporting: As required by the New Source Performance Standard (NSPS) and NESHAPs for Beryllium and Mercury, the Permit Holder shall submit to the Administrator and the APCO semi-annually a report in writing which contains the following (Basis: 40 CFR 60.155):
 - a. A record of average wet scrubber pressure drop measurements for each period of 15 minutes duration or more, when feeding sludge to the furnace, when the pressure drop of the scrubber was less than the following limits. (Basis: 40 CFR 60.155(a)(1)).
 - 1. S-9 (Furnace 1) Wet Scrubber A-2: 5.9 inches W.C.
 - 2. S-10 (Furnace 2) Wet Scrubber A-4: 4.7 inches W.C.
 - b. A record of average oxygen content in the incinerator exhaust gas (prior to dilution) for each period of 1-hour duration or more that the oxygen content exceeds 10 percent. (Basis: 40 CFR 60.155(a)(2)).
 - c. Any recent reports as appropriate or as requested by the APCO. (Basis: 40 CFR 60.155(a)(3), (4), (5), (6))

Condition #16692

For: S-11, S-13, S-15, S-22, Lime Storage Silos with Pneumatic Loading System

 Particulate matter emissions during lime storage silo S-11, S-13, S-15, or S-22 operation shall be controlled by A-7, Lime Storage Bin Vent Filter FR55315. [Basis: Regulation 2-1-403]

- 2. A-7 Lime Storage Bin Vent Filter FR55315, shall be checked for visible emissions on a quarterly basis when in use. The visible emissions check shall take place while the equipment is operating and during daylight hours. If any visible emissions are detected, the operator shall take corrective action, and check for visible emissions during the next loading event. If no visible emissions are detected, the operator shall continue to check for visible emissions every quarter. [Basis: Regulation 2-6-501]
- 3. The operator shall keep records of all visible emissions checks, the person performing the check, and all maintenance performed on A-7 Lime Storage Bin Vent Filter FR55315. The records shall be retained for five (5) years and shall be made available to District personnel upon request. [Basis: Regulation 2-6-501]

VII. APPLICABLE LIMITS & COMPLIANCE MONITORING REQUIREMENTS

This section has been included to summarize the applicable emission limits contained in Section IV, Source-Specific Applicable Requirements, of this permit. The following tables show the relationship between each emission limit and the associated compliance monitoring provisions, if any. The monitoring frequency column indicates whether periodic (P) or continuous (C) monitoring is required. For periodic monitoring, the frequency of the monitoring has also been shown using the following codes: annual (A), quarterly (Q), monthly (M), weekly (W), daily (D), or on an event basis (E). No monitoring (N) has been required if the current applicable rule or regulation does not require monitoring, and the operation is unlikely to deviate from the applicable emission limit based upon the nature of the operation.

Table VII - AApplicable Limits and Compliance Monitoring RequirementsS-7 Auxiliary Boiler, Multi-FuelS-8 Auxiliary Boiler, Multi-Fuel

True of	Emission Limit	FE	Future Effective		Monitoring	Monitoring	Monitoring
Type of limit	Citation	ге Y/N	Date	Emission Limit	Requirement Citation	Frequency (P/C/N)	Monitoring Type
NOx		Y	Date			P/once	source test
NOX	BAAQMD	1		30 ppmv	BAAQMD	- /	source test
	9-7-301.1			@ 3% O2, dry	Condition	every 60	
	(Gaseous				#21422,	months	
	Fuels)				part 7		
	BAAQMD	Y		40 ppmv	BAAQMD	P/once	source test
	9-7-302.1			@3% O2, dry	Condition	every 60	
	(Non-				#21422,	months	
	Gaseous				part 7		
	Fuels)						
	BAAQMD	Y		150 ppmv @ 3% O2, dry	BAAQMD	P/E	Records
	9-7-305.1				9-7-503.2		
	BAAQMD	Y		150 ppmv @ 3% O2, dry	BAAQMD	P/E	Records
	9-7-306.1				9-7-503.2		
СО	BAAQMD	Y		400 ppmv @ 3% O2, dry	BAAQMD	P/once	source test
	9-7-301.2				Condition	every 60	
	(Gaseous				#21422,	months	
	Fuels)				part 7		

Table VII - AApplicable Limits and Compliance Monitoring RequirementsS-7 Auxiliary Boiler, Multi-FuelS-8 Auxiliary Boiler, Multi-Fuel

Type of limit	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
СО	BAAQMD 9- 7-302.2 (Non- Gaseous Fuels)	Y		400 ppmv @ 3% O2, dry		Ν	
	BAAQMD 9-7-305.2	Y		400 ppmv @ 3% O2, dry	BAAQMD 9-7-503.2	P/E	Records
	BAAQMD 9-7-306.2	Y		400 ppmv @ 3% O2, dry	BAAQMD 9-7-503.3	P/E	Records
SOx	BAAQMD 9-1-301	N		GLC of 0.5 ppm for 3 min or 0.25 ppm for 60 min or 0.05 ppm for 24 hours		Ν	
	BAAQMD 9-1-302	Y		300 ppm (dry)	BAAQMD Condition #21422, part 2	P/Q	Fuel Sulfur Analysis based calculation
	BAAQMD 9-1-304	Y		Sulfur content of fuel (<0.5% by wt)	BAAQMD Condition #21422, part 9b	P/M	Fuel Sulfur Analysis
	BAAQMD Condition #21422, part 2	Y		300 ppm (dry)	BAAQMD Condition #21422, part 2	P/ Q	Fuel Sulfur Analysis based calculation
SOx	BAAQMD Condition #21422, part 6	Y		Sulfur content of fuel (<0.5% by wt)	BAAQMD Condition #21422, part 9b	P/M	Fuel Sulfur Analysis
TSP	BAAQMD 6-301	Y		Ringelmann No. 1		Ν	
	BAAQMD 6-310	Y		0.15 grains/dscf @ 6% O ₂		Ν	
Organics	BAAQMD,	Ν		Emission Reduction: 98%	BAAQMD,	С	temperature

Table VII - AApplicable Limits and Compliance Monitoring RequirementsS-7 Auxiliary Boiler, Multi-FuelS-8 Auxiliary Boiler, Multi-Fuel

Type of limit	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
& CH ₄	Cond			by weight or concentration	Cond		monitor and
	21422,			less than 120 ppmvd	21422,		recorder
	part 8			NMOC, as methane @ 3% O2	part 8		
	BAAQMD	N		Max Leakage:	BAAQMD	P/Q	Leak
	8-34-301.2			1000 ppmv (as CH ₄)	8-39-503	- / 2	Testing
	BAAQMD	N		Emission Reduction: 98%	8-34-507	С	temperature
	8-34-301.4			by weight or concentration			monitor and
				less than 120 ppmvd			recorder
				NMOC, as methane and at			
				3% O2			
	BAAQMD	N		Emission Reduction: 98%	8-34-508	С	gas flow
	8-34-301.4			by weight or concentration			meter
				less than 120 ppmvd			
				NMOC, as methane and at			
				3% O2			
Organics	BAAQMD	Ν		Emission Reduction: 98%	8-34-412	P/A	source test
& CH ₄	8-34-301.4			by weight or concentration			
				less than 120 ppmvd			
				NMOC, as methane and at			
				3% O2			
Organics	BAAQMD	Y		Max Leakage:	BAAQMD	P/Q	Leak
& CH ₄	8-34-301. 1 2			1000 ppmv (as CH ₄)	8-39-503		Testing
Heat	BAAQMD	Y		Not to exceed 28	BAAQMD	P/M	Records
input	Condition			MMBtu/hr	Condition		
	21422, part 1				21422 part 9a		
Boiler	BAAQMD	Y		770 degrees F or greater,	BAAQMD	С	Records
Temp	Condition			when burning landfill gas	Condition		
	21422, part 8				21422, part 8		

Table VII -BApplicable Limits and Compliance Monitoring RequirementsS-9, Furnace 1, Sewage Sludge (Incinerator)S-10, Furnace 2, Sewage Sludge (Incinerator)

-	Emission		Future		Monitoring	Monitoring	
Туре	Limit	FE	Effective		Requirement	Frequency	Monitoring
of limit	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре
SOx	BAAQMD	Y		GLC of 0.5 ppm for		Ν	
	9-1-301			3 min or 0.25 ppm			
				for 60 min or 0.05			
				ppm for 24 hours			
	BAAQMD	Y		300 ppm (dry)	BAAQMD	P/A	source test
	9-1-304				Condition		
					#21423 part 11		
TSP	BAAQMD	Y		Ringelmann No. 1		Ν	
	6-301						
	BAAQMD	Y		20% opacity for no	BAAQMD	С	COM
	6-302			more than 3 min in	6-501		
				any hour			
	BAAQMD	Y		0.15 grains/dscf	BAAQMD	P/once per	Exhaust
	6-310.1			@ 12% CO ₂ and as	Condition	permit term	sample &
				if no auxiliary fuel	#21423, part 10		analysis
				is used			
	Regulation	Y		4.10P ^{0.67} lb/hr,	BAAQMD	P/once per	Exhaust
	6-311			where P is process	Condition	permit term	sample &
				weight, ton/hr	#21423, part 10		analysis
	BAAQMD	Y		343 mg	40 CFR 60.154	P/once per	Exhaust
	Condition			particulate/dscm of	(d)(3)	permit term	sample &
	21423, part 4			exhaust gas volume			analysis
	40 CFR	Y		0.65 g particulate	40 CFR	С	Sludge flow
	60.152(a)			matter/kg dry	60.153(a)(1)		meter
	(1),			sludge			
	BAAQMD						
	Condition						
	21423, part 3						
TSP	40 CFR	Y		0.65 g particulate	40 CFR	С	Sludge
	60.152(a) (1)			matter/kg dry	60.153(a)(3)		weighing
				sludge			

Table VII -BApplicable Limits and Compliance Monitoring RequirementsS-9, Furnace 1, Sewage Sludge (Incinerator)S-10, Furnace 2, Sewage Sludge (Incinerator)

Type of limit	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
TSP	40 CFR	Y		0.65 g particulate	40 CFR	С	Pressure drop
	60.152(a) (1)			matter/kg dry	60.153(b)(1),		meter
				sludge (pressure	BAAQMD		
				drop shall not drop	Condition 21423,		
				below individual	parts 13b and 14a		
				furnace scrubber			
				pressure setpoints			
				for > 15 min in any			
				hour)			
	40 CFR	Y		0.65 g particulate	40 CFR	С	O2 Meter
	60.152(a) (1)			matter/kg dry	60.153(b)(2),		
				sludge (oxygen	BAAQMD		
				content shall not	Condition 21423,		
				exceed 10%)	parts 13c and 14b		
	40 CFR	Y		0.65 g particulate	40 CFR	С	Temperature
	60.152(a)			matter/kg dry	60.153(b)(3)		monitoring
	(1)			sludge			
	40 CFR	Y		0.65 g particulate	40 CFR	С	Fuel flow
	60.152(a)			matter/kg dry	60.153(b)(4)		meter
	(1)			sludge			
	40 CFR	Y		0.65 g particulate	40 CFR	P/D	Sludge sample
	60.152 (1)			matter/kg dry	60.153(b)(5)		and analysis
				sludge			
TSP	40 CFR	Y		20% Opacity or	40 CFR	С	СОМ
	60.152(a) (2),			greater	60.154		
	BAAQMD						
	Condition						
	21423 Part 5						
NMOC	BAAQMD	Ν		Emission	BAAQMD	С	temperature
	Condition			Reduction: 98% by	Condition		monitor and
	21423, Part			weight or	21423, part 12		recorder
	12			concentration less			
				than 120 ppmvd			

Table VII -BApplicable Limits and Compliance Monitoring RequirementsS-9, Furnace 1, Sewage Sludge (Incinerator)S-10, Furnace 2, Sewage Sludge (Incinerator)

Type of limit	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
				NMOC, as methane			
				and at 3% O2			
CH_4	BAAQMD	Y		Max Leakage:	BAAQMD	P/Q	leak
	8-34-301.2			1000 ppmv (as	8-34-503		monitoring
				CH ₄)			
NMOC	BAAQMD	Ν		Emission	8-34-507	С	temperature
	8-34-301.4			Reduction: 98% by			monitor and
				weight or			recorder
				concentration less			
				than 120 ppmvd			
				NMOC, as methane			
				and at 3% O2			
NMOC	BAAQMD	Ν		Emission	8-34-508	С	gas flow meter
	8-34-301.4			Reduction: 98% by			
				weight or			
				concentration less			
				than 120 ppmvd			
				NMOC, as methane			
				and at 3% O2			
NMOC	BAAQMD	Ν		Emission	8-34-412	P/A	source test
	8-34-301.4			Reduction: 98% by			
				weight or			
				concentration less			
				than 120 ppmvd			
				NMOC, as methane			
				and at 3% O2			
H_2S	BAAQMD	Ν		24 Hour Standard:		Ν	
	9-2-301			GLC not to exceed			
				0.06 ppm ave over			
				3 min and 0.03 ppm			
				ave over 60 min			
Lead	BAAQMD	Y		15 lb/day	BAAQMD	P/once per	Sludge
	11-1-301,				Condition	permit term	Analysis,

Table VII -BApplicable Limits and Compliance Monitoring RequirementsS-9, Furnace 1, Sewage Sludge (Incinerator)S-10, Furnace 2, Sewage Sludge (Incinerator)

Type of limit	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
	BAAQMD Condition 21423, Part 9				21423, part 10		Exhaust Source Test
	BAAQMD 11-1-302	Y		Max GLC (w/o background): 1.0 microgram/cu m (24 hr ave)		Ν	
Be	BAAQMD 11-3-301, BAAQMD Condition 21423, part 6	N		10 g/ 24 hr	BAAQMD Condition 21423, part 10	P/once per permit term	Sludge Analysis, Exhaust Source Test
	40 CFR Part 61.32	Y		10 g/ 24 hr	BAAQMD Condition 21423 <u>,</u> part 10	P/ once per permit term	Sludge Analysis, Exhaust Source Test
Hg	BAAQMD 11-5-302, Condition 21423, Part 7	N		3200 g/24 hr	BAAQMD Condition 21423, parts 7, 8, 10	P/once per permit term	Sludge Analysis, Exhaust Source Test
	40 CFR Part 61.52 (b)	Y		3.2 kg/24 hr	40 CFR Part 61.53	P/once per permit term	Sludge Analysis, Exhaust Source Test
Solid Fuel Feed Rate	Permit Condition 21423, Part 2	Y		120 ton sludge (dry)/day	Permit Condition 21423, Part 13a	P/C	flow measuring device
	Permit Condition 21423, Part 2	Y		20,000 ton sludge (dry)/consecutive 12-month period	Permit Condition 21423, Part 13a	P/C	flow measuring device
Hearth- 1 Min	Permit Condition	Y		1,000 degrees F, rolling 3 clock-hour	Permit Condition # 21423, Part 13d	С	Temperature Measurement

Table VII -BApplicable Limits and Compliance Monitoring RequirementsS-9, Furnace 1, Sewage Sludge (Incinerator)S-10, Furnace 2, Sewage Sludge (Incinerator)

Type of limit	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Temp	21423,			average			
	Part 12						

Table VII - C

Applicable Limits and Compliance Monitoring Requirements S-11 Lime Storage Silo w/Pneumatic Loading System S-13 Lime Storage Silo w/Pneumatic Loading System S-15 Lime Storage Silo w/Pneumatic Loading System S-22 Lime Storage Silo w/Pneumatic Loading System

Type of	Emission Limit	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
limit	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре
TSP	BAAQMD	Y		Ringelmann No. 1	BAAQMD	P/Q	visible
	6-301				Cond# 16692,		emissions
					part 2		check
	BAAQMD	Y		0.15 grains/dscf	BAAQMD	P/Q	visible
	6-310				Cond# 16692,		emissions
					part 2		check
	BAAQMD	Y		4.10P ^{0.67} lb/hr, where	BAAQMD	P/Q	visible
	6-311			P is process weight,	Cond# 16692,		emissions
				ton/hr	part 2		check

	Applic	able 1	Limits an	d Compliance Mo	onitoring Re	quirements	5							
	S-24 Centrifuges and Cake Hoppers													
	Emission		Future		Monitoring	Monitoring								
Type of	Limit	FE	Effective		Requirement	Frequency	Monitoring							
limit	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре							
TSP	BAAQMD	Y		Ringelmann No. 1		Ν								
	6-301													
	BAAQMD	Y		0.15 grains/dscf		Ν								
	6-310													
	BAAQMD	Y		4.10P ^{0.67} lb/hr, where		Ν								
	6-311			P is process weight,										
				ton/hr										
H_2S	BAAQMD	Ν		1.5 ppmv		Ν								
	Condition													
	1716,													
	Part 1													

Table VII - D

Table VII - E **Applicable Limits and Compliance Monitoring Requirements** S-25 Gasoline Dispensing Facility

Type of limit	Emission Limit Citation	FE Y/N	Future Effective Date	Emission Limit	Monitoring Requirement Citation	Monitoring Frequency (P/C/N)	Monitoring Type
Gasoline	Condition	N		400,000 gallons	Condition	P/M	Records
Throughput	7523,				7523		
	Part 1				Part 2		

Table VII - FApplicable Limits and Compliance Monitoring RequirementsS-180 Sludge Handling Processes

Type of	Emission Limit	FE	Future Effective		Monitoring Requirement	Monitoring Frequency	Monitoring
limit	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре
TSP	BAAQMD	Y		Ringelmann No. 1		Ν	
	6-301						
	BAAQMD	Y		0.15 grains/dscf		Ν	
	6-310						
	BAAQMD	Y		4.10P ^{0.67} lb/hr, where		Ν	
	6-311			P is process weight,			
				ton/hr			

Table VII - GApplicable Limits and Compliance Monitoring RequirementsS-182 Ash Conveying System

True of	Emission	FE	Future		Monitoring	Monitoring	Monitoring
Type of limit	Limit Citation	FE Y/N	Effective Date	Emission Limit	Requirement Citation	Frequency (P/C/N)	Monitoring Type
TSP	BAAQMD	Y		Ringelmann No. 1	BAAQMD	С	Mikro-Charge
	6-301				Cond# 21425,		LeakGauge
					part 4		Particulate
							Monitor/Alarm
	BAAQMD	Y		Ringelmann No. 1	BAAQMD	P/D	Operator
	6-301				Cond# 21425,		Visual Stack
					part 5		Inspection
	BAAQMD	Y		0.15 grains/dscf	BAAQMD	С	Mikro-Charge
	6-310				Cond# 21425,		LeakGauge
					part 4		Particulate
							Monitor/Alarm
	BAAQMD	Y		0.15 grains/dscf	BAAQMD	P/D	Operator
	6-310				Cond# 21425,		Visual Stack
					part 5		Inspection
TSP	BAAQMD	Y		$4.10P^{0.67}$ lb/hr, where	BAAQMD	С	Mikro-Charge
	6-311			P is process weight,	Cond# 21425,		LeakGauge

Table VII - GApplicable Limits and Compliance Monitoring Requirements
S-182 Ash Conveying System

	Emission		Future		Monitoring	Monitoring	
Type of	Limit	FE	Effective		Requirement	Frequency	Monitoring
limit	Citation	Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре
				ton/hr	part 4		Particulate
							Monitor/Alarm
	BAAQMD	Y		4.10P ^{0.67} lb/hr, where	BAAQMD	P/D	Operator
	6-311			P is process weight,	Cond# 21425,		Visual Stack
				ton/hr	part 5		Inspection

Table VII - HApplicable Limits and Compliance Monitoring RequirementsS-188 Natural Gas Fired Turbine Generator with HRSG

	Emission		Future		Monitoring	Monitoring	
Type of	Limit Citation	FE	Effective		Requirement	Frequency	Monitoring
limit		Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре
NOx	BAAQMD	Y		42 ppmv, dry @ 15%	BAAQMD	С	CEM
	9-9-301.1			O ₂ , 3-hr average	Cond #21485		
					part 11		
	40 CFR Part	Y		154 ppm (dry basis) @	BAAQMD	С	water-to-
	60.332			15% O2 on a clock-	Cond #21485		fuel
				hour basis	part 13		monitoring
NOx	40 CFR Part	Y		154 ppm (dry basis) @	Nitrogen	Ν	
	60.332			15% O2 on a clock-	content		
				hour basis	monitoring per		
					40 CFR		
					60.334(a)		
					subsumed by		
					BAAQMD		
					condition		
					#21485, part		
					11. See Permit		
					Shield.		
NOx	BAAQMD	Y		42 ppmv, dry @ 15%	BAAQMD	С	CEM
	Condition			O ₂ , 3-hr average	9-9-501,		

Table VII - HApplicable Limits and Compliance Monitoring RequirementsS-188 Natural Gas Fired Turbine Generator with HRSG

	Emission		Future		Monitoring	Monitoring	
Type of	Limit Citation	FE	Effective		Requirement	Frequency	Monitoring
limit		Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре
	21485, part #2				BAAQMD		
					cond #21485		
					part 11		
	BAAQMD	Y		118 lb/day	BAAQMD	С	CEM
	Condition				cond #21485		
	#21485, part 4				part 11		
	BAAQMD	Y		19.824 ton/rolling 365	BAAQMD	С	CEM
	Condition			day period	cond #21485		
	#21485, part 5				part 11		
CO	BAAQMD	Y		157 lb/24 hour	BAAQMD	P/once	source test
	Condition				cond #21485	every 60	
	#21485, part 6				part 9	months	
	BAAQMD	Y		26.376 tons/rolling 365	BAAQMD	P/once	source test
	Condition			day period	cond #21485	every 60	
	#21485, part 7				part 9	months	
SO2	BAAQMD	Y		GLC 0.5 ppm		Ν	
	9-1-301			(3 min ave)			
				0.25 ppm			
				(60 min ave)			
				0.05 ppm (24 hr ave)			
	BAAQMD	Ν		Maximum exhaust		Ν	
	9-1-302			stream conc - 300 ppm			
	NSPS Subpart	Y		0.8 % sulfur in fuel by	Fuel sulfur	Ν	
	GG, 60.333 (b)			weight	monitoring		
				(natural gas)	requirement		
					subsumed by		
					BAAQMD		
					condition		
					#21485, part		
					1c. See Permit		
					Shield.		
SO2	BAAQMD	Y		Maximum exhaust	BAAQMD	P/Q	Fuel Sulfur
	Condition			stream conc – 150 ppm	Condition		Analysis
	21485, part #8			@ 15% O2	21485 part 8		based

Table VII - HApplicable Limits and Compliance Monitoring RequirementsS-188 Natural Gas Fired Turbine Generator with HRSG

	Emission		Future		Monitoring	Monitoring	
Type of	Limit Citation	FE	Effective		Requirement	Frequency	Monitoring
limit		Y/N	Date	Emission Limit	Citation	(P/C/N)	Туре
							calculation
TSP	BAAQMD	Y		Ringelmann No. 1		Ν	
	6-301						
	BAAQMD	Y		0.15 grains/dscf		Ν	
	6-310.3			@ 6% O ₂			
Fuel	BAAQMD	Y		< 1188 MMBtu/day	BAAQMD	P/D	records
usage	Condition			(HHV) on any fuel	Condition		
	# <u>21485</u> , part				#21485		
	#1b				part 12		

VIII. TEST METHODS

The test methods associated with the emission limit of a District regulation are generally referenced in Section 600 et seq of the regulation. The following table indicates only the test methods associated with the emission limits referenced in Section VII, Applicable Emission Limits & Compliance Monitoring Requirements, of this permit.

Applicable Requirement **Description of Requirement** Acceptable Test Methods BAAQMD Ringelmann No. 1 Limitation Manual of Procedures, Volume I, Evaluation of Visible 6-301 Emissions BAAOMD Particulate Weight Limitation Manual of Procedures, Volume IV, ST-15, Particulates 6-310 Sampling BAAQMD Manual of Procedures, Volume IV, ST-15, Particulates General Operations 6-311 Sampling BAAQMD Manual of Procedures, Volume IV, ST-7 or EPA Method 25 or Performance Standard - Total 8-2-301 Carbon Hydrocarbon Emissions 25A BAAQMD Performance Standard - Landfill Manual of Procedures Volume IV, ST-7, or EPA Method 25 or 8-34-301.4 Gas Collection/Destruction 25A Efficiency BAAQMD General Emission Limitation Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide, 9-1-302 Continuous Sampling, or ST-19B, Total Sulfur Oxides Integrated Sample BAAQMD Fuel Burning Sulfur Limitations Manual of Procedures, Volume III, Method 10, Determination of 9-1-304 Sulfur in Fuel Oil BAAOMD Performance Standard, NOx, Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, 9-7-301.1 Limits Continuous Sampling and ST-14, Oxygen, Continuous Sampling BAAQMD Performance Standard, CO Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, 9-7-301.2 Limits Continuous Sampling and ST-14, Oxygen, Continuous Sampling BAAQMD Performance Standard, NOx, Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, 9-7-302.1 Limits Continuous Sampling, ST-14, Oxygen, Continuous Sampling BAAQMD Performance Standard, CO Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, 9-7-302.2 Limits Continuous Sampling and ST-14, Oxygen, Continuous Sampling

Table VIII Test Methods

VIII. Test Methods

Part 61.32

Part 61.52

BAAQMD

40 CFR

Beryllium Emissions

Mercury Emissions

Performance Standard - Daily

Performance Standard - H2S

Test Methods				
Applicable Requirement	Description of Requirement	Acceptable Test Methods		
BAAQMD 9-7-305.1	Performance Standard, NOx, Limits	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling		
BAAQMD 9-7-305.2	Performance Standard, CO Limits	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling		
BAAQMD 9-7-306.1	Performance Standard, NOx, Limits	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling		
BAAQMD 9-7-306.2	Performance Standard, CO Limits	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide, Continuous Sampling and ST-14, Oxygen, Continuous Sampling		
BAAQMD 9-9-301	Performance Standard, NOx Limits	Manual of Procedures, Volume IV, ST-13A, Oxides of Nitrogen, Continuous Sampling and ST-14, Oxygen, Continuous Sampling		
BAAQMD 11-1-301	Performance Standard - Daily Lead Emission Limit	Manual of Procedures, Volume IV, ST-9, Lead Sampling		
BAAQMD 11-3-301	Performance Standard - Daily Beryllium Emission	Manual of Procedures, Volume IV, ST-2 or EPA-104, Beryllium Sampling		
BAAQMD 11-5-302	Performance Standard - Daily Mercury Emissions	Manual of Procedures, Volume IV, ST-10, Mercury Sampling		
40 CFR 60.332(a)(1)	Performance Standard, NOx Emissions from Stationary Gas Turbines	EPA Method 20, Continuous Emission Monitoring – Nitrogen Oxides		
40 CFR 60.333	Performance Standard, SOx Emissions, ppm	EPA Method 20, Determination of Nitrogen Oxides, Sulfur Dioxide, and Diluent Emissions from Stationary Gas Turbines		
40 CFR 60.152(a)(1)	Performance Standard, Particulate Emission Rate Limitation	EPA Method 5, Determination of Particulate Matter Emissions		
40 CFR 60.152(a)(2)	Visible Emissions Limitation - 20 % Opacity	EPA Method 9 Continuous Opacity Monitoring & 40 CFR 60.11 (Monitoring Requirements – Opacity)		
40 CFR	Performance Standard - Daily	EPA Method 104, Determination of Beryllium Emissions from		

Table VIIITest Methods

Revision Date: December 11, 2006

EPA Method 101, Determination of Mercury Emissions from

Manual of Procedures, Volume IV, ST-28, Hydrogen Sulfide,

Stationary Sources

Sewage Sludge Incinerators

VIII. Test Methods

Table VIII		
Test Methods		

Applicable		
Requirement	Description of Requirement	Acceptable Test Methods
Condition 1716,	Concentration - Stack Outlet	Integrated Sampling
Part 1		
BAAQMD	NOx Limits	Manual of Procedures, Volume IV, ST-13A, Oxides of
Cond. #21485,		Nitrogen, Continuous Sampling and ST-14, Oxygen,
Part 2		Continuous Sampling
BAAQMD	NOx Limits	Manual of Procedures, Volume IV, ST-13A, Oxides of
Cond. #21485,		Nitrogen, Continuous Sampling and ST-14, Oxygen,
Part 4		Continuous Sampling
BAAQMD	NOx Limits	Manual of Procedures, Volume IV, ST-13A, Oxides of
Cond. #21485,		Nitrogen, Continuous Sampling and ST-14, Oxygen,
Part 5		Continuous Sampling
BAAQMD	CO Limits	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide,
Cond. #21485,		Continuous Sampling and ST-14, Oxygen, Continuous
Part 6		Sampling
BAAQMD	CO Limits	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide,
Cond. #21485,		Continuous Sampling and ST-14, Oxygen, Continuous
Part 7		Sampling
BAAQMD	NOX Limit	Manual of Procedures, Volume IV, ST-13A, Oxides of
Condition		Nitrogen, Continuous Sampling and ST-14, Oxygen,
#21422, Part 3		Continuous Sampling
BAAQMD	NOX Limit	Manual of Procedures, Volume IV, ST-13A, Oxides of
Condition		Nitrogen, Continuous Sampling and ST-14, Oxygen,
#21422, Part 4		Continuous Sampling
BAAQMD	CO Limit	Manual of Procedures, Volume IV, ST-6, Carbon Monoxide,
Condition		Continuous Sampling and ST-14, Oxygen, Continuous
#21422, Part 5		Sampling
BAAQMD	Sulfur Content of distillate oil	Manual of Procedures, Volume III, Method 10, Determination
Condition		of Sulfur in Fuel Oils.
21422, Part 6		
BAAQMD	VOC Abatement Efficiency	Manual of Procedures, Volume IV, ST-7, "Organic
Condition		Compounds" or EPA Method 25 "Determination of Total
21422, Part 8		Gaseous Nonmethane Organic Emissions as Carbon" or 25A
		"Determination of Total Gaseous Organic Concentration Using
		a Flame Ionization Analyzer"
BAAQMD	Particulate Limit	EPA Method 5, Determination of Particulate Matter Emissions
Condition		

VIII. Test Methods

Table VIII Test Methods

Applicable		
Requirement	Description of Requirement	Acceptable Test Methods
#21423, Part 3		
BAAQMD	Opacity Limit	EPA Method 9 Continuous Opacity Monitoring & 40 CFR
Condition		60.11 (Monitoring Requirements – Opacity)
#21423, Part 4		
BAAQMD	Beryllium Limit	Manual of Procedures, Volume IV, ST-2 or EPA-104,
Condition		Beryllium Sampling
#21423, Part 6		
BAAQMD	Mercury Limit	Manual of Procedures, Volume IV, ST-10, Mercury Sampling
Condition		
#21423, Part 7		
BAAQMD	Lead Limit	Manual of Procedures, Volume IV, ST-9, Lead Sampling
Condition		
#21423, Part 9		
BAAQMD	Sulfur dioxide testing	Manual of Procedures, Volume IV, ST-19A, Sulfur Dioxide,
Condition		Continuous Sampling, or
#21423, Part 11		ST-19B, Total Sulfur Oxides Integrated Sample
BAAQMD	VOC Abatement Requirement	Manual of Procedures, Volume IV, ST-7, "Organic
Condition		Compounds" or EPA Method 25 "Determination of Total
#21423, Part 12		Gaseous Nonmethane Organic Emissions as Carbon" or 25A
		"Determination of Total Gaseous Organic Concentration Using
		a Flame Ionization Analyzer"

IX. PERMIT SHIELD

A. SUBSUMED REQUIREMENTS

Pursuant to District Regulations 2-6-233.2 and 2-6-409.12, as of the date this permit is issued, the federally enforceable monitoring, recordkeeping, and reporting requirements cited in the following table for the source or group of sources identified at the top of the table[s] are subsumed by the monitoring, recordkeeping, and reporting for more stringent requirements or by a "hybrid" monitoring scheme. The District has determined that compliance with the requirements listed below and elsewhere in this permit will assure compliance with the substantive requirements of the subsumed monitoring requirements. Enforcement actions and litigation may not be initiated against the source or group of sources covered by this shield based on the subsumed monitoring requirements cited.

Table IX-AS-188 Natural Gas & Landfill Gas Fired Turbine Generator with HRSG

Subsumed			
Requirement		Streamlined	
Citation	Title or Description	Requirements	Title or Description
NSPS	Standards of Performance for		
Subpart GG	Stationary Gas Turbines		
60.334 (b)(2)	Fuel Sulfur monitoring (natural	BAAQMD	Requirement for use of PUC quality
	gas)	Condition	natural gas
		#21485, part lc	
60.334 (b)(2)	Fuel Nitrogen Content monitoring	BAAQMD	Requirement for CEM monitoring of
		Condition	NOx for BAAQMD 9-9-301.1 limit
		#21485, part 11	

X. REVISION HISTORY

Title V Permit Issuance (Application #25827):	January 7, 2000		
 Administrative Amendment (no application): Correction of typographical error, capacity of S-7 and S-8, Boilers, was corrected from 22 MMbtu/hr to 28 MMbtu/hr 	May 17, 2000		
 Minor Revision (Application 5738): Numerous minor corrections/clarifications of permit conditions for S-7,8, 9, 10, 182, 188 Revise monitoring frequency on landfill gas sulfide as allowed by condition. Remove landfill gas destruction requirements with expired requirements. Revise conditions for S-7 and S-8 to establish operating parameter (temp) to ensure compliance with Reg 8-34 LFG destruction efficiency. Revise conditions for S-9 and S-10 to establish operating parameter (temp) to ensure compliance with Reg 8-34 LFG destruction efficiency. Revise conditions for S-9 and S-10 to establish scrubber operating parameter (pressure drop setpoints) to ensure compliance with 40 CFR 60.155(a)(1) for particulate control. Revise conditions for S-182 ash loading system dust collection devices—allowing for improved monitoring of the collection system operation. Revise conditions for S-188 Gas Turbine: Remove all references to any requirements for burning landfill gas. 	November 15, 2004		
 Title V Permit Renewal (Application 10118): Added diesel engine sources permitted under loss of exemption AN 4717. Modified permit conditions for existing permitted diesel engine sources to comply with Stationary Diesel ATCM. 	December 11, 2006		
• Modified permit conditions (clarification/correction or to add monitoring requirements) for sources S-			

100, S-7 and S-8, S-9 and S-10, and S-188.

XI. GLOSSARY

BAAQMD

Bay Area Air Quality Management District

BACT

Best Available Control Technology

Basis

The underlying authority which allows the District to impose requirements.

CAA The federal Clean Air Act

CAAQS California Ambient Air Quality Standards

CEQA

California Environmental Quality Act

CFR

The Code of Federal Regulations. 40 CFR contains the implementing regulations for federal environmental statutes such as the Clean Air Act. Parts 50-99 of 40 CFR contain the requirements for air pollution programs.

СО

Carbon Monoxide

Cumulative Increase

The sum of permitted emissions from each new or modified source since a specified date pursuant to BAAQMD Rule 2-1-403, Permit Conditions (as amended by the District Board on 7/17/91) and SIP Rule 2-1-403, Permit Conditions (as approved by EPA on 6/23/95). Used to determine whether threshold-based requirements are triggered.

District

The Bay Area Air Quality Management District

EPA

The federal Environmental Protection Agency.

Excluded

Not subject to any District Regulations.

FE, Federally Enforceable

All limitations and conditions which are enforceable by the Administrator of the EPA

including those requirements developed pursuant to 40 CFR Part 51, subpart I (NSR), Part 52.21 (PSD), Part 60, (NSPS), Part 61, (NESHAPs), Part 63 (HAP), and Part 72 (Permits Regulation, Acid Rain), and also including limitations and conditions contained in operating permits issued under an EPA-approved program that has been incorporated into the SIP.

FP

Filterable Particulate as measured by BAAQMD Method ST-15, Particulate.

HAP

Hazardous Air Pollutant. Any pollutant listed pursuant to Section 112(b) of the Act. Also refers to the program mandated by Title I, Section 112, of the Act and implemented by 40 CFR Part 63.

Major Facility

A facility with potential emissions of regulated air pollutants greater than or equal to 100 tons per year, greater than or equal to 10 tons per year of any single hazardous air pollutant, and/or greater than or equal to 25 tons per year of any combination of hazardous air pollutants, or such lesser quantity as determined by the EPA administrator.

MFR

Major Facility Review. The District's term for the federal operating permit program mandated by Title V of the Act and implemented by District Regulation 2, Rule 6.

MOP

The District's Manual of Procedures.

NAAQS

National Ambient Air Quality Standards

NESHAPs

National Emission Standards for Hazardous Air Pollutants. Contained in 40 CFR Parts 61 and 63.

NMHC

Non-methane Hydrocarbons (Same as NMOC)

NMOC

Non-methane Organic Compounds (Same as NMHC)

NOx

Oxides of nitrogen.

NSPS

Standards of Performance for New Stationary Sources. Federal standards for emissions from new stationary sources. Mandated by Title I, Section 111 of the Act, and implemented by both 40 CFR Part 60 and District Regulation 10.

NSR

New Source Review. A federal program for pre-construction review and permitting of new and modified sources of air pollutants for which criteria have been established in accordance with Section 108 of the Federal Clean Air Act. -Mandated by Title I of the Federal Clean Air Act and implemented by 40 CFR Parts 51 and 52 and District Regulation 2, Rule 2. (Note: There are additional NSR requirements mandated by the California Clean Air Act.)

Offset Requirement

A New Source Review requirement to provide federally enforceable emission offsets for the emissions from a new or modified source. Applies to emissions of POC, NOx, PM10, and SO2.

Phase II Acid Rain Facility

A facility that generates electricity for sale through fossil-fuel combustion and is not exempted by 40 CFR 72 from Title IV and V of the Clean Air Act.

POC

Precursor Organic Compounds

PM

Particulate Matter

PM10

Particulate matter with aerodynamic equivalent diameter of less than or equal to 10 microns

PSD

Prevention of Significant Deterioration. A federal program for permitting new and modified sources of air pollutants for which the District is classified "attainment" of the National Air Ambient Quality Standards. Mandated by Title I of the Act and implemented by both 40 CFR Part 52 and District Regulation 2, Rule 2.

SIP

State Implementation Plan. State and District programs and regulations approved by EPA and developed in order to attain the National Air Ambient Quality Standards. Mandated by Title I of the Act.

SO2

Sulfur dioxide

THC

Total Hydrocarbons (NMHC + Methane)

Title V

Title V of the federal Clean Air Act. Requires a federally enforceable operating permit program for major and certain other facilities.

TOC

Total Organic Compounds (NMOC + Methane, Same as THC)

TPH

Total Petroleum Hydrocarbons

TRMP

Toxic Risk Management Plan

TSP

Total Suspended Particulate

VOC

Volatile Organic Compounds

Units of Measure:

bhp	=	brake-horsepower
btu	=	British Thermal Unit
cfm	=	cubic feet per minute
g	=	grams
gal	=	gallon
gpm	. =	gallons per minute
hp	=	horsepower
hr	=	hour
lb	=	pound
in	=	inches
max	=	maximum
m^2	=	square meter
min	=	minute
mm	=	million
ppm	v =	parts per million, by volume
ppm	w =	parts per million, by weight
psia	=	pounds per square inch, absolute
psig	=	pounds per square inch, gauge
scfn	n =	standard cubic feet per minute
yr	=	year