

X22A SAFETY CHECKLIST			BROOKHAVEN NATIONAL LABORATORY NATIONAL SYNCHROTRON LIGHT SOURCE
Rev: B	Effective:5/24/07	Page 1 of 1	Number: LS-SCL-0048
Reviewed by: Thomas McDonald		Reviewed by:	Approved by: J. Aloï

Original signatures on file.

The only official copy of this file is the one on-line in the NSLS Quality Assurance website. Before using a printed copy, verify that it is the most current version by checking the document effective date on the NSLS QA website.

- 1. Valid Padlock Index and log, no locks open.
- 2. Exclusion Zone (EZ #1) between Isolation Valve and Bremsstrahlung shield (BS #1)
- 3. Bremsstrahlung shield (BS #1) in place and banded see photo 1.
- 4. Lead shield on Be window 1A downstream of BS #1.
- 5. Lead shield on mask tank.
- 6. Lead shield on bellows between Mask Tank and Mirror Tank.
- 7. Lead shield on mirror tank.
- 8. Exclusion Zone (EZ #2) upstream of Bremsstrahlung shield (BS #2). Lead shield on bellows and Be window 2A, upstream of Bremsstrahlung shield (BS #2) (under Exclusion Zone (EZ #2))
- 9. Bremsstrahlung shield (BS # 2) in place and banded see photo 2.
- 10. Exclusion Zone (EZ #3) upstream of Bremsstrahlung shield (BS #3).
- 11. Bremsstrahlung shield (BS # 3) in place and banded see photo 3.
- 12. Lead shield skirt and leaded glass on Viewport above ion pump.
- 13. Lead shield on bellows upstream of monochromator tank.
- 14. Lead shield skirt and leaded glass on Viewport on monochromator tank.
- 15. Exclusion Zone (EZ #4) between Monochromator tank and Bremsstrahlung shield (BS # 4).
- 16. Beam-stop banded.

OPCO / Beamline Staff: _____ Date: _____

USER SYSTEM CHECKS

- A. Check monochromator purge log and pressure gauge. Pressure should read positive 1 to 3 psi. If not, notify Bill at x2377, or Scott at x7110.

Beamline Rep.: _____ Date: _____