

<b>OCRWM</b>	<b>DESIGN CALCULATION OR ANALYSIS COVER SHEET</b>		1. QA: NA 2. Page 1 of 40					
3. System Subsurface HVAC		4. Document Identifier 800-HYC-VU00-00300-000-00A						
5. Title Subsurface Radon Exposure Calculation								
6. Group Nuclear Engineering								
7. Document Status Designation <input checked="" type="checkbox"/> Preliminary <input type="checkbox"/> Final <input type="checkbox"/> Cancelled								
8. Notes/Comments This document supercedes CAL-SSM-NU-000003 REV 00.								
Attachments				Total Number of Pages				
See Section 9								
<b>RECORD OF REVISIONS</b>								
9. No.	10. Reason For Revision	11. Total # of Pgs.	12. Last Pg. #	13. Originator (Print/Sign/Date)	14. Checker (Print/Sign/Date)	15. QER (Print/Sign/Date)	16. Approved/Accepted (Print/Sign)	17. Date
00A	Initial Issue	43	II-1	YuChien Yuan <i>YuChien Yuan</i> 12/1/03	John Wang <i>John Wang</i> 11/25/03	N/A	John Schmitt <i>John Schmitt</i> 12/1/03	12/1/03

## CONTENTS

	<b>Page</b>
1. PURPOSE.....	4
2. QUALITY ASSURANCE.....	4
3. METHOD.....	4
4. ASSUMPTIONS.....	5
4.1 RADON FLUX ESTIMATIONS.....	5
4.1.1 Uniform Rock Strata.....	5
4.1.2 Ventilation Effect.....	5
4.1.3 Temperature Effect.....	7
4.2 VENTILATION FLOW.....	8
5. USE OF COMPUTER SOFTWARE.....	8
6. CALCULATION.....	8
6.1 RADON AND ITS PROGENY CONCENTRATIONS.....	8
6.1.1 Working Level.....	10
6.1.2 Equivalent Radius for Non-Circular Drifts.....	11
6.2 INPUT PARAMETERS.....	11
6.2.1 Radiological Parameters.....	11
6.2.2 Repository Layout and Airflow Parameters.....	11
6.2.3 Deposition Velocity.....	12
6.2.4 Radon Flux.....	12
6.3 CONCENTRATION CALCULATION.....	13
6.3.1 Calculation Output.....	29
6.4 RELEASE CALCULATION.....	37
7. RESULTS.....	37
7.1 RADON AND WORKING LEVEL CENTRATIONS.....	37
7.2 COMPLIANCE WITH APPLICABLE LIMITS.....	37
8. REERENCES.....	39
9. ATTACHMENTS.....	40
ATTACHMENT I. DESCRIPTION OF CALCULATION WORKSHEETS.....	I-1
ATTACHMENT II. LISTING OF ELECTRONIC FILE IN CD CONTAINING RADON EXPOSURE CALCULATIONS.....	II-1

## FIGURES

	<b>Page</b>
1. Radon Decay Chain .....	4
2. Average Radon Flux in Exploratory Studies Facility Main versus Differential Pressure .....	7
3. Subsurface Ventilation System Layout.....	13

## TABLES

	<b>Page</b>
1. Average Radon Flux vs. Pressure Differential .....	6
2. Radiological Input Parameters .....	11
3. Repository Layout Input Parameters .....	14
4. Concentration Calculation Outputs.....	29
5. Comparison of Predicted Air Concentrations with 29 CFR 1910.1096 Limits .....	38
6. List of Attachments.....	40
I-1 Input Parameters and Equations Used for Worksheet.....	I-1
I-2 Description of Calculation Worksheet .....	I-2
II-1. Worksheet Names and Properties in the Attachment II Compact Disk.....	II-1

## 1. PURPOSE

The purpose of this calculation is to evaluate potential radon exposure to workers to support the License Application design effort of the subsurface ventilation system of the repository. The scope of this calculation is to provide estimates of radon exposure to workers based on the ventilation airflow networks described in *Ventilation Network Model Calculation* (BSC 2003a). The subsurface facility workers may be exposed to elevated airborne radon and its short-lived decay products. The ventilation system of the repository must be designed to control, to an acceptable degree or limit, the concentration of radon and its decay products (Minwalla 2003, p. 202).


The technical basis for calculating radon exposure was previously established in *Subsurface Radon Calculations* (CRWMS M&O 2000). This report updates the calculation by using the subsurface design layout for License Application presented in *Underground Layout Configuration* (BSC 2003b). The calculated radon exposure values for the subsurface facilities, therefore, supercede that described in CRWMS M&O (2000).

## 2. QUALITY ASSURANCE

This technical product was prepared in accordance with AP-3.12Q, *Design Calculations and Analyses*. In accordance with *Q-List* (BSC 2003c, p. A-7), both the subsurface emplacement and development ventilation systems are designated as ‘not important to waste isolation’ and ‘not important to safety’ and the safety category is non-SC (BSC 2003c, p. A-7). Therefore, this calculation is not subject to the requirements of *Quality Assurance Requirements and Description* (DOE 2003).

## 3. METHOD

Radon (Rn-222), produced by decay of radium-226 (Ra-226) in underground rocks, migrates through rock and emanates continuously from repository surfaces into all air spaces. After emanation, it is carried along in ventilation currents and decays to produce the solid short-lived decay progeny polonium-218 (Po-218), lead-214 (Pb-214) and bismuth-214 (Bi-214) (Figure 1).



Source: Kocher 1981, p. 63.

Figure 1. Radon Decay Chain

Once in the repository air, Rn-222 remains entrained until the air is discharged aboveground. During the construction and operation of the repository, subsurface workers are exposed to airborne radon and their short-lived decay products. In underground facilities, the concentration of radon and its decay products, in the absence of adequate control measures, can reach relatively high values. Exposure of personnel in underground facilities is maintained within the

recommended limits primarily by mechanical ventilation in combination with other protective techniques.

In this document, the calculation of radon concentration and working levels within the subsurface drifts are based on the repository layout presented in *Underground Layout Configuration*. (BSC 2003b) and the calculation models described in *Subsurface Radon Calculations* (CRWMS M&O 2000). The ventilation airflow and airway pressure distributions are based on data provided in *Ventilation Network Model Calculation* (BSC 2003a, Attachment D).

#### 4. ASSUMPTIONS

The following assumptions have been made in order to calculate radon and the decay progeny concentrations given in Section 6.

##### 4.1 RADON FLUX ESTIMATIONS

It is assumed that rock strata are uniform throughout each drift segment, and the average rate of radon release or annual average radon flux can be approximated by a linear relationship with differential pressure (Figure 2) generated by ventilation flow. It is also assumed that radon flux in the heated emplacement drifts is proportional to the 1.75 power of average rock temperature.

###### 4.1.1 Uniform Rock Strata

The assumption of the uniform rock strata throughout each drift segment for flux calculation is used to average the heterogeneity effect of rock strata. For the main drifts, the attenuation of radon flux by concrete liners, if present, is neglected for conservatism. This assumption is used in Section 6.3 for concentration calculation.

###### 4.1.2 Ventilation Effect

The pressure differentials created by barometric pressure changes and ventilation conditions of the Exploratory Studies Facility (ESF) have been found to induce significant movement of rock gas and the respective transport of radon within the rocks in *Subsurface Radon Flux Calculation* (BSC 2003d, p. 16). The average radon flux from the rock surfaces was estimated in BSC (2003d, p. 14) using radon concentration measurements made at 3900 m and 5035 m within the ESF. The average radon fluxes for ventilation using one fan and two fans (with average velocities of 1.59 m/s and 2.70 m/s, respectively) are shown in Table 1. The flux values indicate that under the ESF negative pressure (suction) system higher airflow generates higher radon flux. The negative pressure system means a repository in which the air pressure underground is negative during venting with respect to the ambient air pressure on the surface. A 70 percent increase in ventilation airflow resulted in about a 50 percent increase in radon flux.

Table 1. Average Radon Flux vs. Pressure Differential

ESF Operation	Average Airflow velocity <sup>a</sup> (m/s)	Flux <sup>a</sup> (pCi/m <sup>2</sup> -s)	Pressure Differential <sup>b</sup> (mbar)
Two Fans	2.70	21	-2.51
One Fan	1.59	14	-0.73

Sources: <sup>a</sup>BSC 2003d, p. 14.

<sup>b</sup>The section below.

To estimate the ventilation-induced pressure effect on radon flux, differential pressures at 4,468 m [(3,900 m + 5035 m)/2] in the ESF Main, with one fan and two fans in operation, are calculated. The differential pressures are calculated using the data and formulas described in *Pressure Distribution in the ESF for One and Two Fan Operation* (BSC 2003e, Sections 4, 5, and 6).

The differential pressures are calculated by determining the frictional pressure loss from the surface to the underground locations. The following calculations determine the differential pressure between the ESF Main at 4468 m and the surface.

Length of the drift from the Enhanced Characterization of the Repository Block (ECRB) to ESF Main at 4468m = 4468m – 1992m or 2476m (8123 ft) (Source of 1992 m: BSC 2003e, 6.3.1).

Equivalent length of drift to account for shock losses = 10% of actual airway length or 1,040.7 ft (BSC 2003e, Section 6.3.1).

Average cross sectional area = 411.07 ft<sup>2</sup> (BSC 2003e, Section 6.3.1).

Average perimeter of the drift = 78.54 ft (BSC 2003e, Section 6.3.1).

Average airflow in ECRB duct = 101.5 kcfm (BSC 2003e, Section 6.2)

Resistance of drift section North Portal to ECRB = 0.00782 PU (BSC 2003e, Section 6.3.1)

Friction factor used for the resistance calculation is  $50 \times 10^{-10}$  lbfmin<sup>2</sup>/ft<sup>4</sup> (BSC 2003e, Section 6.3.1).

Resistance of drift section ECRB to ESF Main 4468m (BSC 2003e, Eq. 1, Section 6.3.1) =

$$50 \times 8123 \times 1.1 \times 78.54 / (52 \times 411.07)^3 = 0.00971 \text{ PU}$$

(1) For Air Velocity in Main Drift = 1.59 m/s (313 ft/min)

Main Drift Airflow = 313 x 411.07/1000 = 129 kcfm

Pressure Differential ( $\Delta P_1$ ) between surface and ESF Main at 4468 (BSC 2003e, Eq. 2, Section 6.4)

$$\Delta P_1 = 0.00782 \times (101.5 + 129)^2 + 0.00971 \times 129^2 = 575 \text{ m.in.w.g. or } 1.43 \text{ mbar}$$

(2) For Air Velocity in Main Drift = 2.70 m/s (531 ft/min)

Main Drift Airflow = 531 x 411.07/1000 = 218 kcfm

Pressure Differential ( $\Delta P_2$ ) between surface and ESF Main at 4468 (BSC 2003e, Eq. 2, Section 6.4)

$$\Delta P_2 = 0.00782 \times (101.5 + 218)^2 + 0.00971 \times 218^2 = 1264 \text{ m.in.w.g. or } 3.15 \text{ mbar.}$$

A correlation between the pressure differential ( $\Delta P$ ) and radon flux (F) was constructed assuming F is linearly depending on  $\Delta P$ . The correlation equation is shown as follows:


$$F (\Delta P) = 1.71 - 6.70 (\Delta P) \tag{Eq. 1}$$

where

- $F(\Delta P)$  = average radon flux ( $\text{pCi}/\text{m}^2\text{-s}$ ) at pressure differential  $\Delta P$
- $\Delta P$  = pressure differential (mbar) =  $P_d - P_a$
- $P_d$  = air pressure underground during ventilating
- $P_a$  = ambient air pressure at the surface

Figure 2 graphically shows the correlation between radon flux and pressure differential generated by ventilation airflow. In applying Equation 1,  $\Delta P$  is limited to values equal to or less than zero for conservatism.

This assumption is used in Section 6.2.4 for flux calculations.



Source: Equation 1.

Figure 2. Average Radon Flux in Exploratory Studies Facility Main versus Differential Pressure

#### 4.1.3 Temperature Effect

The basis for assuming radon flux is proportional to the 1.75 power of average rock temperature of the emplacement drifts was derived based on the relationship between temperature ( $T$ ) and the gas diffusion coefficients (CRWMS M&O 2000, p. 10). The radon flux at rock temperature  $T$  is calculated by applying a temperature adjusting factor  $f(T)$  to the flux value as follows (CRWMS M&O 2000, p. 10):

$$f(T) = \frac{F(T)}{F(T_r)} = \left( \frac{T_e}{T_r} \right)^{1.75} = 1.21 \quad (\text{Eq. 2})$$

where

$f(T)$  = radon flux temperature factor at rock temperature  $T$   
 $F(T)$  = radon flux at average rock temperature  $T$  (pCi/m<sup>2</sup>-s)  
 $F(Tr)$  = radon flux at average rock temperature  $Tr$  (pCi/m<sup>2</sup>-s)  
 $T_e$   
= average emplacement drift rock absolute temperature, (329 °K, CRWMS M&O 2000, p. 10)  
 $Tr$   
= reference absolute temperature, (296 °K, CRWMS M&O 2000, p. 10)

This assumption is used in Section 5.2.4 to account for temperature effect on radon flux from the emplacement drifts.

## 4.2 VENTILATION FLOW

The airflow is assumed to be at a steady state.

The steady state assumption is valid for repository operation under normal conditions when the ventilation is maintained at a constant airflow rate. This assumption is used in Section 6.1 for concentration modeling and calculation.

## 5. USE OF COMPUTER SOFTWARE

The Microsoft Excel 97 spreadsheet program was used to perform the calculations as documented in Section 6 of this document. The user-defined formulas, input, and results are documented in sufficient detail in Section 6 to allow for independent duplication of the various computations without recourse to the originator. This software is considered exempt from the requirements of AP-SI.1Q, *Software Management*.

## 6. CALCULATION

### 6.1 RADON AND ITS PROGENY CONCENTRATIONS

The mass balance equations for radon and its decay products in a segment of the repository with respect to time resulting from airflow velocity of  $v$  and radon exhalation flux of  $F$  from the repository walls are (CRWMS M&O 2000, pp. 11 and 13):

$$\frac{\partial C_0}{\partial t} = -v \frac{\partial C_0}{\partial x} + 2 \frac{F}{R} - \lambda_0 C_0 \quad (\text{Eq. 3})$$

$$\frac{\partial C_i}{\partial t} = -v \frac{\partial C_i}{\partial x} - 2 \frac{V_d C_i}{R} - \lambda_i C_i + \lambda_i C_{i-1} \quad (i = 1, 2, 3) \quad (\text{Eq. 4})$$



where

- $C_0$  = radon concentration in repository air (pCi/m<sup>3</sup>)
- $C_i$  = ith radon progeny concentration in repository air (pCi/m<sup>3</sup>)
- $C_1$  = Po-218 concentration in repository air (pCi/m<sup>3</sup>)
- $C_2$  = Pb-214 concentration in repository air (pCi/m<sup>3</sup>)
- $C_3$  = Bi-214 concentration in repository air (pCi/m<sup>3</sup>)
- $F$  = average radon flux (pCi/m<sup>2</sup>/s)
- $\lambda_0$  = radon decay constant (s<sup>-1</sup>)
- $\lambda_i$  = ith radon progeny decay constant (s<sup>-1</sup>) = 0.693/T<sub>i</sub>
- $T_i$  = ith radon progeny decay half-life (s)
- $R$  = drift radius (m)
- $v$  = airflow velocity (m/s)
- $V_d$  = deposition velocity of radon progeny (m/s).

The solutions of Equations 3 and 4, assuming steady conditions (Assumption 4.2), for a location  $x$ , using the boundary conditions that the radon and its progeny concentrations at an upstream location  $x_1$  are known, are given by (CRWMS M&O 2000, pp. 14 through 17):

$$C_0(x) = A_0 + A_{00} e^{-a_0 x} \quad (\text{Eq. 5})$$

$$C_1(x) = A_1 + A_{10} e^{-a_0 x} + A_{11} e^{-d_1 x} \quad (\text{Eq. 6})$$

$$C_2(x) = A_2 + A_{20} e^{-a_0 x} + A_{21} e^{-d_1 x} + A_{22} e^{-d_2 x} \quad (\text{Eq. 7})$$

$$C_3(x) = A_3 + A_{30} e^{-a_0 x} + A_{31} e^{-d_1 x} + A_{32} e^{-d_2 x} + A_{33} e^{-d_3 x} \quad (\text{Eq. 8})$$

where

$$A_0 = \frac{2F}{R\lambda_0} \quad (\text{Eq. 9})$$

$$A_1 = \frac{a_1}{d_1} A_0 \quad (\text{Eq. 10})$$

$$A_{00} = C_0(x_1) - A_0 \quad (\text{Eq. 11})$$

$$A_{10} = \frac{a_1 A_{00}}{d_1 - d_0} \quad (\text{Eq. 12})$$

$$A_{11} = C_1(x_1) - A_1 - A_{10} \quad (\text{Eq. 13})$$

$$A_2 = \frac{a_2}{d_2} A_1 \quad (\text{Eq. 14})$$

$$A_{20} = \frac{a_2 A_{10}}{d_2 - d_0} \quad (\text{Eq. 15})$$

$$A_{21} = \frac{a_2 A_{11}}{d_2 - d_1} \quad (\text{Eq. 16})$$

$$A_{22} = C_2(x_1) - A_2 - A_{20} - A_{21} \quad (\text{Eq. 17})$$

$$A_3 = \frac{a_3}{d_3} A_2 \quad (\text{Eq. 18})$$

$$A_{30} = \frac{a_3 A_{20}}{d_3 - d_0} \quad (\text{Eq. 19})$$

$$A_{31} = \frac{a_3 A_{21}}{d_3 - d_1} \quad (\text{Eq. 20})$$

$$A_{32} = \frac{a_3 A_{22}}{d_3 - d_2} \quad (\text{Eq. 21})$$

$$A_{33} = C_3(x_1) - A_3 - A_{30} - A_{31} - A_{32} \quad (\text{Eq. 22})$$

$$a_0 = \frac{\lambda_0}{v}; a_1 = \frac{\lambda_1}{v}; a_2 = \frac{\lambda_2}{v}; a_3 = \frac{\lambda_3}{v} \quad (\text{Eq. 23})$$

$$d_0 = a_0; d_1 = a_1 + \frac{2V_d}{vR}; d_2 = a_2 + \frac{2V_d}{vR}; d_3 = a_3 + \frac{2V_d}{vR} \quad (\text{Eq. 24})$$

where

$C_0(x)$  = radon concentration at x (pCi/m<sup>3</sup>)  
 $C_i(x)$  = ith radon progeny concentration at x (pCi/m<sup>3</sup>)

### 6.1.1 Working Level

The working level (WL) value for an atmosphere containing a mixture of radon progeny can be calculated by (CRWMS M&O 2000, p.17):

$$WL = 1.06 \times 10^{-6} C_1 + 5.13 \times 10^{-6} C_2 + 3.81 \times 10^{-6} C_3 \quad (\text{Eq. 25})$$

where  $C_1$ ,  $C_2$ , and  $C_3$  represent the individual concentrations of Po-218, Pb-214, and Bi-214, respectively, in units of pCi/m<sup>3</sup>. The previous equation is used for calculating the WL using the radon progeny concentrations in the air.

### 6.1.2 Equivalent Radius for Non-Circular Drifts

The concentrations of radon and its progeny in a non-circular shaped segment of a drift can be calculated by substituting the drift radius  $R = \frac{2A}{p}$  in Equations 5 through 24 (CRWMS M&O 2000, p. 15 & p. 16), where A is the drift cross-section area (m<sup>2</sup>) and p is the drift rock wall perimeter (m).

For a circular drift with radius r and airflow cross section area  $A = \pi r^2$ , the equivalent radius R is:

$$R = \frac{2A}{p} = \frac{2\pi r^2}{2\pi r} = r$$

## 6.2 INPUT PARAMETERS

This section identifies and documents calculation inputs and sources of input that are used in this document.

### 6.2.1 Radiological Parameters

The radiological parameters or radiological decay half-lives used in calculations made in this section are listed in Table 2. These decay half-lives are taken from Kocher (1981, p. 63) and are well-established scientific facts.

Table 2. Radiological Input Parameters

Nuclide	Decay Half-life <sup>a</sup>	Decay Half-life (sec)
Rn-222	3.82 d	3.30E+05
Po-218	3.05 m	1.83E+02
Pb-214	26.8 m	1.61E+03
Bi-214	19.9 m	1.19E+03

Source: <sup>a</sup>Kocher 1981, p. 63.

### 6.2.2 Repository Layout and Airflow Parameters

The input parameters for repository layout and ventilation network are taken from *Ventilation Network Model Calculation* (BSC 2003a, Attachment D) and are provided in Table 3. The input parameters include node numbers, branch number and description, length, cross-sectional area, perimeter, repository airflow distribution, and airway frictional pressure drop. The ventilation

schematic with node numbers is detailed in *Ventilation Network Model Calculation* (BSC 2003a, Attachment A) and is not repeated in this document. The repository layout and airflow parameters were developed based on *Underground Layout Configuration* (BSC 2003b). Figure 3 shows the subsurface ventilation system layout including repository shaft locations (BSC 2003b, Figure 10).

### 6.2.3 Deposition Velocity

The input parameter of the deposition velocity for radon progeny is 0.0 m/s or no deposition. The use of zero deposition is a conservative approach in calculating radon progeny concentrations or working levels.


### 6.2.4 Radon Flux

The equation used to calculate input radon flux is Equation 26:

$$F(\Delta P) = [1.71 - 6.70(\Delta P)] f(T_e), \text{ (for } \Delta P < 0) \quad (\text{Eq. 26})$$

$$F(\Delta P) = 1.71 f(T_e), \text{ (for } \Delta P \geq 0) \quad (\text{Eq. 26a})$$

The derivation of the previous equation is described in Section 4.1.3. For heated drifts (e.g., emplacement drift, emplacement vent raise, exhaust main drift, and exhaust shaft) the temperature factor  $f(T_e)$  is assumed to be 1.21 (see Section 4.1.3). For all other types of drifts,  $f(T_e)$  is 1.0 since there will be no heat sources.



Source: BSC 2003b, Fig. 10

Figure 3. Subsurface Ventilation System Layout

### 6.3 CONCENTRATION CALCULATION

Average radon and working level concentrations were calculated using equations described in Section 6.1. Excel spreadsheet files used for concentration calculations are provided in Attachment II. Attachment I provides formulas used in the spreadsheet calculations.

Table 3 defines the repository layout input parameters used in concentration calculations. The ventilation airflow network input parameters including airflow rates and pressure differentials are also provided in Table 3. The output results of the calculations are summarized in Section 6.3.1 (Table 4).

Table 3. Repository Layout Input Parameters

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
1	7621	7620	14	371	-10.95	185	Exhaust Raise #1
2	1010	1011	24	97	-5.35	15	Turnout 1 Panel 1
3	1020	1021	24	97	-5.28	15	Turnout 2 Panel 1
4	1030	1031	24	97	-5.23	15	Turnout 3 Panel 1
5	1040	1041	24	97	-5.22	15	Turnout 4 Panel 1
6	1050	1051	24	97	-5.21	15	Turnout 5 Panel 1
7	1060	1061	24	97	-5.21	15	Turnout 6 Panel 1
8	1070	1071	24	97	-5.23	15	Turnout 7 Panel 1
9	1080	1081	24	97	-5.28	15	Turnout 8 Panel 1
10	1011	1013	28	494	-8.06	15	Empl 1 Drift Panel 1
11	1021	1022	28	595	-8.02	15	Empl 2 Drift Panel 1
12	1031	1032	28	597	-7.97	15	Empl 3 Drift Panel 1
13	1041	1042	28	597	-7.96	15	Empl 4 Drift Panel 1
14	1051	1052	28	591	-7.97	15	Empl 5 Drift Panel 1
15	1061	1062	28	544	-8.00	15	Empl 6 Drift Panel 1
16	1071	1072	28	451	-8.07	15	Empl 7 Drift Panel 1
17	1081	1082	28	355	-8.22	15	Empl 8 Drift Panel 1
18	1012	7621	17	14	-8.19	79	5x5 exhaust raise access
19	7622	7621	17	23	-8.15	105	5x5 exhaust raise access
20	7110	7111	26	378	-1.18	410	Intake Shaft #1
21	7210	7211	26	350	-1.04	399	Intake Shaft #2
22	7211	7213	29	107	-2.13	205	8x8.5 shaft access
23	7211	3020	29	381	-2.20	194	8x8.5 shaft access
24	7213	7214	29	244	-2.31	205	8x8.5 shaft access
25	7121	7120	25	438	-9.19	383	Exhaust Shaft #1
26	7125	7121	29	247	-7.97	192	8x8.5 south access
27	7127	7121	29	251	-7.96	192	8x8.5 north access
28	7222	7220	25	428	-11.35	383	Exhaust Shaft #2
29	7224	7221	29	118	-9.76	191	8x8.5 west access
30	7225	7221	29	106	-9.76	187	8x8.5 east access
31	7223	7222	0	0	-6.28	6	8x8.5 shaft access
32	7011	7010	25	398	-10.18	393	ECRB Exhaust Shaft
33	7229	4102	24	69	-7.80	44	lead-in drift
34	3010	3011	24	122	-5.22	15	Turnout 1 Panel 3
35	3020	3021	24	122	-5.10	15	Turnout 2 Panel 3
36	3030	3031	24	122	-5.05	15	Turnout 3 Panel 3
37	3040	3041	24	122	-5.02	15	Turnout 4 Panel 3
38	3050	3051	24	122	-5.01	15	Turnout 5 Panel 3
39	3060	3061	24	122	-5.00	15	Turnout 6 Panel 3
40	3070	3071	24	122	-5.03	15	Turnout 7 Panel 3

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
41	3080	3081	24	122	-5.10	15	Turnout 8 Panel 3
42	3090	3091	24	118	-5.15	15	Turnout 9 Panel 3
43	3100	3101	24	96	-5.20	15	Turnout 10 Panel 3
44	3110	3111	24	97	-5.23	15	Turnout 11 Panel 3
45	3120	3121	24	97	-5.26	15	Turnout 12 Panel 3
46	3130	3131	24	97	-5.28	15	Turnout 13 Panel 3
47	3140	3141	24	97	-5.28	15	Turnout 14 Panel 3
48	3150	3151	24	97	-5.27	15	Turnout 15 Panel 3
49	3160	3161	24	97	-5.26	15	Turnout 16 Panel 3
50	3170	3171	24	97	-5.25	15	Turnout 17 Panel 3
51	3180	3181	24	97	-5.24	15	Turnout 18 Panel 3
52	3190	3191	24	97	-5.24	15	Turnout 19 Panel 3
53	3200	3201	24	97	-5.24	15	Turnout 20 Panel 3
54	3210	3211	24	97	-5.24	15	Turnout 21 Panel 3
55	3220	3221	24	97	-5.22	15	Turnout 22 Panel 3
56	3015	3016	24	123	-5.63	15	Turnout 1 Panel 3
57	3025	3026	24	123	-5.59	15	Turnout 2 Panel 3
58	3035	3036	24	123	-5.55	15	Turnout 3 Panel 3
59	3045	3046	24	123	-5.61	15	Turnout 4 Panel 3
60	3055	3056	24	123	-5.65	15	Turnout 5 Panel 3
61	3065	3066	24	120	-5.68	15	Turnout 6 Panel 3
62	3075	3076	24	97	-5.70	15	Turnout 7 Panel 3
63	3085	3086	24	97	-5.72	15	Turnout 8 Panel 3
64	3095	3096	24	97	-5.74	15	Turnout 9 Panel 3
65	3105	3106	24	97	-5.75	15	Turnout 10 Panel 3
66	3115	3116	24	97	-5.76	15	Turnout 11 Panel 3
67	3125	3126	24	97	-5.77	15	Turnout 12 Panel 3
68	3135	3136	24	97	-5.78	15	Turnout 13 Panel 3
69	3145	3146	24	97	-5.79	15	Turnout 14 Panel 3
70	3155	3156	24	97	-5.82	15	Turnout 15 Panel 3
71	3165	3166	24	97	-5.85	15	Turnout 16 Panel 3
72	3175	3176	24	97	-5.90	15	Turnout 17 Panel 3
73	3185	3186	24	97	-5.95	15	Turnout 18 Panel 3
74	3195	3196	24	97	-5.98	15	Turnout 19 Panel 3
75	3011	3012	28	617	-8.22	15	Empl Drift 1 Panel 3
76	3021	3022	28	617	-7.99	15	Empl Drift 2 Panel 3
77	3031	3032	28	617	-7.84	15	Empl Drift 3 Panel 3
78	3041	3042	28	617	-7.74	15	Empl Drift 4 Panel 3
79	3051	3052	28	617	-7.69	15	Empl Drift 5 Panel 3
80	3061	3062	28	617	-7.67	15	Empl Drift 6 Panel 3
81	3071	3072	28	617	-7.66	15	Empl Drift 7 Panel 3
82	3081	3082	28	617	-7.66	15	Empl Drift 8 Panel 3

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
83	3091	3092	28	620	-7.67	15	Empl Drift 9 Panel 3
84	3101	3102	28	622	-7.70	15	Empl Drift 10 Panel 3
85	3111	3112	28	622	-7.72	15	Empl Drift 11 Panel 3
86	3121	3122	28	622	-7.74	15	Empl Drift 12 Panel 3
87	3131	3132	28	622	-7.77	15	Empl Drift 13 Panel 3
88	3141	3142	28	622	-7.77	15	Empl Drift 14 Panel 3
89	3151	3152	28	622	-7.76	15	Empl Drift 15 Panel 3
90	3161	3162	28	622	-7.75	15	Empl Drift 16 Panel 3
91	3171	3172	28	622	-7.74	15	Empl Drift 17 Panel 3
92	3181	3182	28	622	-7.74	15	Empl Drift 18 Panel 3
93	3191	3192	28	622	-7.74	15	Empl Drift 19 Panel 3
94	3201	3202	28	622	-7.74	15	Empl Drift 20 Panel 3
95	3211	3212	28	622	-7.75	15	Empl Drift 21 Panel 3
96	3221	3222	28	622	-7.76	15	Empl Drift 22 Panel 3
97	3016	3017	28	757	-8.97	15	Empl Drift 1 Panel 3
98	3026	3027	28	799	-8.87	15	Empl Drift 2 Panel 3
99	3036	3037	28	810	-8.80	15	Empl Drift 3 Panel 3
100	3046	3047	28	794	-8.75	15	Empl Drift 4 Panel 3
101	3056	3057	28	787	-8.72	15	Empl Drift 5 Panel 3
102	3066	3067	28	782	-8.70	15	Empl Drift 6 Panel 3
103	3076	3077	28	764	-8.69	15	Empl Drift 7 Panel 3
104	3086	3087	28	714	-8.70	15	Empl Drift 8 Panel 3
105	3096	3097	28	664	-8.70	15	Empl Drift 9 Panel 3
106	3106	3107	28	615	-8.71	15	Empl Drift 10 Panel 3
107	3116	3117	28	565	-8.72	15	Empl Drift 11 Panel 3
108	3126	3127	28	515	-8.74	15	Empl Drift 12 Panel 3
109	3136	3137	28	479	-8.77	15	Empl Drift 13 Panel 3
110	3146	3147	28	464	-8.81	15	Empl Drift 14 Panel 3
111	3156	3157	28	448	-8.86	15	Empl Drift 15 Panel 3
112	3166	3167	28	432	-8.94	15	Empl Drift 16 Panel 3
113	3176	3177	28	417	-9.04	15	Empl Drift 17 Panel 3
114	3186	3187	28	401	-9.17	15	Empl Drift 18 Panel 3
115	3196	3197	28	385	-9.28	15	Empl Drift 19 Panel 3
116	7128	7127	29	24	-7.88	91	8x8.5 exhaust connection
117	7124	7125	29	24	-7.88	92	8x8.5 exhaust connection
118	4010	4011	24	123	-6.19	15	Turnout 1 Panel 4
119	4020	4021	24	123	-6.11	15	Turnout 2 Panel 4
120	4030	4031	24	123	-6.07	15	Turnout 3 Panel 4
121	4040	4041	24	123	-6.04	15	Turnout 4 Panel 4
122	4050	4051	24	123	-6.04	15	Turnout 5 Panel 4
123	4060	4061	24	123	-6.04	15	Turnout 6 Panel 4
124	4070	4071	24	123	-6.05	15	Turnout 7 Panel 4

Source: BSC 2003a, Attachment D and Attachment 2 of this document.



Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
125	4080	4081	24	123	-6.06	15	Turnout 8 Panel 4
126	4090	4091	24	103	-6.06	15	Turnout 9 Panel 4
127	4100	4101	24	97	-6.08	15	Turnout 10 Panel 4
128	4110	4111	24	97	-6.09	15	Turnout 11 Panel 4
129	4120	4121	24	97	-6.11	15	Turnout 12 Panel 4
130	4130	4131	24	97	-6.12	15	Turnout 13 Panel 4
131	4140	4141	24	97	-6.12	15	Turnout 14 Panel 4
132	4150	4151	24	97	-6.11	15	Turnout 15 Panel 4
133	4160	4161	24	97	-6.10	15	Turnout 16 Panel 4
134	4170	4171	24	97	-6.08	15	Turnout 17 Panel 4
135	4180	4181	24	97	-6.13	15	Turnout 18 Panel 4
136	4190	4191	24	97	-6.19	15	Turnout 19 Panel 4
137	4200	4201	24	101	-6.24	15	Turnout 20 Panel 4
138	4210	4211	24	106	-6.28	15	Turnout 21 Panel 4
139	4220	4221	24	106	-6.33	15	Turnout 22 Panel 4
140	4230	4231	24	106	-6.40	15	Turnout 23 Panel 4
141	4240	4241	24	106	-6.48	15	Turnout 24 Panel 4
142	4250	4251	24	106	-6.51	15	Turnout 25 Panel 4
143	4260	4261	24	106	-6.54	15	Turnout 26 Panel 4
144	4270	4271	24	107	-6.58	15	Turnout 27 Panel 4
145	4280	4281	24	128	-6.63	15	Turnout 28 Panel 4
146	4290	4291	24	147	-6.67	15	Turnout 29 Panel 4
147	4300	4301	24	175	-6.74	15	Turnout 30 Panel 4
148	4011	3012	28	617	-8.22	15	Empl Drift 1 Panel 4
149	4021	3022	28	617	-7.99	15	Empl Drift 2 Panel 4
150	4031	3032	28	617	-7.84	15	Empl Drift 3 Panel 4
151	4041	3042	28	617	-7.74	15	Empl Drift 4 Panel 4
152	4051	3052	28	617	-7.69	15	Empl Drift 5 Panel 4
153	4061	3062	28	617	-7.67	15	Empl Drift 6 Panel 4
154	4071	3072	28	617	-7.66	15	Empl Drift 7 Panel 4
155	4081	3082	28	617	-7.66	15	Empl Drift 8 Panel 4
156	4091	3092	28	634	-7.67	15	Empl Drift 9 Panel 4
157	4101	4102	28	605	-7.70	15	Empl Drift 10 Panel 4
158	4111	4112	28	605	-7.73	15	Empl Drift 11 Panel 4
159	4121	4122	28	605	-7.75	15	Empl Drift 12 Panel 4
160	4131	4132	28	605	-7.79	15	Empl Drift 13 Panel 4
161	4141	4142	28	605	-7.79	15	Empl Drift 14 Panel 4
162	4151	4152	28	605	-7.77	15	Empl Drift 15 Panel 4
163	4161	4162	28	605	-7.75	15	Empl Drift 16 Panel 4
164	4171	4172	28	605	-7.75	15	Empl Drift 17 Panel 4
165	4181	4182	28	605	-7.74	15	Empl Drift 18 Panel 4
166	4191	4192	28	605	-7.74	15	Empl Drift 19 Panel 4

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
167	4201	4202	28	605	-7.74	15	Empl Drift 20 Panel 4
168	4211	4212	28	594	-7.75	15	Empl Drift 21 Panel 4
169	4221	4222	28	584	-7.77	15	Empl Drift 22 Panel 4
170	4231	4232	28	593	-7.87	15	Empl Drift 23 Panel 4
171	4241	4242	28	581	-7.98	15	Empl Drift 24 Panel 4
172	4251	4252	28	569	-8.00	15	Empl Drift 25 Panel 4
173	4261	4262	28	556	-8.05	15	Empl Drift 26 Panel 4
174	4271	4272	28	544	-8.11	15	Empl Drift 27 Panel 4
175	4281	4282	28	526	-8.19	15	Empl Drift 28 Panel 4
176	4291	4292	28	496	-8.27	15	Empl Drift 29 Panel 4
177	4301	4302	28	406	-8.39	15	Empl Drift 30 Panel 4
178	7227	7226	24	30	-8.51	120	lead in drift
179	7312	7311	29	109	-1.81	406	8x8.5 shaft acc
180	7014	7012	29	91	-8.85	243	8x8.5 shaft acc. ECRB
181	7322	7320	25	292	-14.28	343	Exhaust Shaft #3
182	7321	7322	29	20	-13.57	343	8x8.5 shaft acc
183	7310	7312	26	248	-0.81	406	Intake shaft #3
184	7623	7624	17	127	-9.34	185	5x5 shaft access ex #2
185	7624	7625	14	279	-5.11	185	Exhaust Raise #2
186	2010	2011	24	97	-5.32	15	Turnout 1 Panel 2
187	2020	2021	24	97	-5.32	15	Turnout 2 Panel 2
188	2030	2031	24	97	-5.28	15	Turnout 3 Panel 2
189	2040	2041	24	97	-5.27	15	Turnout 4 Panel 2
190	2050	2051	24	97	-5.29	15	Turnout 5 Panel 2
191	2060	2061	24	97	-5.33	15	Turnout 6 Panel 2
192	2070	2071	24	97	-5.37	15	Turnout 7 Panel 2
193	2080	2081	24	97	-5.40	15	Turnout 8 Panel 2
194	2090	2091	24	97	-5.43	15	Turnout 9 Panel 2
195	2100	2101	24	97	-5.45	15	Turnout 10 Panel 2
196	2110	2111	24	97	-5.47	15	Turnout 11 Panel 2
197	2120	2121	24	97	-5.50	15	Turnout 12 Panel 2
198	2130	2131	24	97	-5.52	15	Turnout 13 Panel 2
199	2140	2141	24	97	-5.56	15	Turnout 14 Panel 2
200	2150	2151	24	97	-5.60	15	Turnout 15 Panel 2
201	2160	2161	24	97	-5.65	15	Turnout 16 Panel 2
202	2170	2171	24	97	-5.72	15	Turnout 17 Panel 2
203	2180	2181	24	97	-5.80	15	Turnout 18 Panel 2
204	2190	2191	24	97	-5.90	15	Turnout 19 Panel 2
205	2200	2201	24	97	-6.02	15	Turnout 20 Panel 2
206	2210	2211	24	97	-6.15	15	Turnout 21 Panel 2
207	2220	2221	24	97	-6.31	15	Turnout 22 Panel 2
208	2230	2231	24	97	-6.49	15	Turnout 23 Panel 2

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
209	2240	2241	24	97	-6.68	15	Turnout 24 Panel 2
210	2250	2251	24	97	-6.90	15	Turnout 25 Panel 2
211	2260	2261	24	97	-7.16	15	Turnout 26 Panel 2
212	2270	2271	24	97	-7.47	15	Turnout 27 Panel 2
213	2011	2012	28	753	-8.48	15	Empl Drift 1 Panel 2
214	2021	2022	28	779	-8.59	15	Empl Drift 2 Panel 2
215	2031	2032	28	779	-8.63	15	Empl Drift 3 Panel 2
216	2041	2042	28	775	-8.60	15	Empl Drift 4 Panel 2
217	2051	2052	28	772	-8.58	15	Empl Drift 5 Panel 2
218	2061	2062	28	769	-8.58	15	Empl Drift 6 Panel 2
219	2071	2072	28	766	-8.57	15	Empl Drift 7 Panel 2
220	2081	2082	28	763	-8.57	15	Empl Drift 8 Panel 2
221	2091	2092	28	759	-8.58	15	Empl Drift 9 Panel 2
222	2101	2102	28	756	-8.58	15	Empl Drift 10 Panel 2
223	2111	2112	28	750	-8.60	15	Empl Drift 11 Panel 2
224	2121	2122	28	744	-8.62	15	Empl Drift 12 Panel 2
225	2131	2132	28	737	-8.66	15	Empl Drift 13 Panel 2
226	2141	2142	28	731	-8.72	15	Empl Drift 14 Panel 2
227	2151	2152	28	725	-8.80	15	Empl Drift 15 Panel 2
228	2161	2162	28	718	-8.90	15	Empl Drift 16 Panel 2
229	2171	2172	28	712	-9.04	15	Empl Drift 17 Panel 2
230	2181	2182	28	706	-9.20	15	Empl Drift 18 Panel 2
231	2191	2192	28	699	-9.40	15	Empl Drift 19 Panel 2
232	2201	2202	28	693	-9.64	15	Empl Drift 20 Panel 2
233	2211	2212	28	687	-9.92	15	Empl Drift 21 Panel 2
234	2221	2222	28	680	-10.25	15	Empl Drift 22 Panel 2
235	2231	2232	28	674	-10.62	15	Empl Drift 23 Panel 2
236	2241	2244	28	668	-11.05	15	Empl Drift 24 Panel 2
237	2251	2252	28	655	-11.53	15	Empl Drift 25 Panel 2
238	2261	2262	28	583	-12.08	15	Empl Drift 26 Panel 2
239	2271	2272	28	485	-12.70	15	Empl Drift 27 Panel 2
240	2020	2010	24	83	-2.22	175	Main Drift
241	2030	2020	24	83	-2.11	190	Main Drift
242	7311	2030	24	41	-2.02	205	Main Drift
243	7311	2040	24	42	-2.02	201	Main Drift
244	2040	2050	24	42	-2.09	186	Main Drift
245	2050	2060	24	83	-2.16	170	Main Drift
246	2060	2070	24	83	-2.25	155	Main Drift
247	2070	2080	24	83	-2.32	140	Main Drift
248	2080	2090	24	83	-2.38	125	Main Drift
249	2090	2100	24	83	-2.42	110	Main Drift
250	2100	2110	24	83	-2.46	95	Main Drift

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
251	2110	2120	24	83	-2.48	80	Main Drift
252	2120	2130	24	83	-2.50	65	Main Drift
253	2130	2140	24	83	-2.51	50	Main Drift
254	2140	2150	24	83	-2.51	35	Main Drift
255	2150	2160	24	83	-2.52	19	Main Drift
256	2160	2170	24	83	-2.52	4	Main Drift
257	2180	2170	24	83	-2.52	11	Main Drift
258	2190	2180	24	83	-2.52	26	Main Drift
259	2200	2190	24	83	-2.51	41	Main Drift
260	2210	2200	24	83	-2.50	56	Main Drift
261	2220	2210	24	83	-2.49	71	Main Drift
262	2230	2220	24	83	-2.47	86	Main Drift
263	2240	2230	24	83	-2.44	101	Main Drift
264	2250	2240	24	83	-2.40	116	Main Drift
265	2260	2250	22	83	-2.35	132	Main Drift
266	2270	2260	22	83	-2.32	58	Main Drift
267	2262	2272	22	83	-7.24	319	Main Drift
268	2252	2262	22	83	-11.91	302	Main Drift
269	2244	2252	22	83	-11.39	285	Main Drift
270	2232	2244	22	83	-10.94	268	Main Drift
271	2222	2232	22	83	-10.54	251	Main Drift
272	2212	2222	22	83	-10.19	234	Main Drift
273	2202	2212	22	83	-9.89	217	Main Drift
274	2192	2202	22	83	-9.63	200	Main Drift
275	2182	2192	22	83	-9.41	183	Main Drift
276	2172	2182	22	83	-9.23	166	Main Drift
277	2162	2172	22	83	-9.08	149	Main Drift
278	2152	2162	22	83	-8.97	132	Main Drift
279	2142	2152	22	83	-8.88	115	Main Drift
280	2132	2142	22	83	-8.81	98	Main Drift
281	2122	2132	22	83	-8.76	81	Main Drift
282	2112	2122	22	83	-8.73	64	Main Drift
283	2102	2112	22	83	-8.71	47	Main Drift
284	2092	2102	22	83	-8.70	30	Main Drift
285	2082	2092	22	83	-8.70	13	Main Drift
286	2082	2072	22	83	-8.70	4	Main Drift
287	2072	2062	22	83	-8.70	21	Main Drift
288	2062	2052	22	83	-8.70	38	Main Drift
289	2052	2042	22	83	-8.72	55	Main Drift
290	2042	2032	22	83	-8.74	72	Main Drift
291	2032	7014	22	61	-8.77	89	Main Drift
292	2022	7014	22	21	-8.75	154	Main Drift

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
293	2012	2022	22	83	-8.66	137	Main Drift
294	7226	2012	22	83	-8.56	120	Main Drift
295	4290	4300	22	82	-6.84	19	Main Drift
296	4280	4290	22	82	-5.15	34	Main Drift
297	4270	4280	22	82	-5.14	49	Main Drift
298	4260	4270	22	82	-5.13	64	Main Drift
299	4250	4260	22	82	-5.11	79	Main Drift
300	4240	4250	22	82	-5.09	94	Main Drift
301	4230	4240	22	82	-5.05	109	Main Drift
302	4220	4230	22	82	-5.00	124	Main Drift
303	4210	4220	22	82	-4.94	140	Main Drift
304	4200	4210	22	82	-4.87	155	Main Drift
305	4190	4200	22	82	-4.78	170	Main Drift
306	4180	4190	22	82	-4.67	185	Main Drift
307	6414	4180	22	61	-4.56	200	Main Drift
308	6414	4170	22	21	-4.51	91	Main Drift
309	4170	4160	22	82	-4.52	76	Main Drift
310	4160	4150	22	82	-4.54	61	Main Drift
311	4150	4140	22	82	-4.55	46	Main Drift
312	4140	4130	22	82	-4.56	30	Main Drift
313	4130	4120	22	82	-4.56	15	Main Drift
314	4120	4110	22	82	-4.56	0	Main Drift
315	4100	4110	22	82	-4.56	15	Main Drift
316	4090	4100	22	82	-4.56	30	Main Drift
317	4080	4090	22	82	-4.55	45	Main Drift
318	4070	4080	22	82	-4.54	60	Main Drift
319	4060	4070	22	82	-4.52	75	Main Drift
320	4050	4060	22	82	-4.50	90	Main Drift
321	4040	4050	22	82	-4.47	105	Main Drift
322	4030	4040	22	82	-4.42	121	Main Drift
323	4020	4030	22	82	-4.37	136	Main Drift
324	4010	4020	22	82	-4.29	151	Main Drift
325	3012	6316	22	82	-6.29	230	Main Drift
326	3022	3012	22	82	-8.20	196	Main Drift
327	3032	3022	22	82	-8.01	162	Main Drift
328	3042	3032	22	82	-7.89	128	Main Drift
329	3052	3042	22	82	-7.81	94	Main Drift
330	3062	3052	22	82	-7.78	60	Main Drift
331	3072	3062	22	82	-7.76	26	Main Drift
332	3072	3082	22	82	-7.76	8	Main Drift
333	3082	3092	22	82	-7.77	42	Main Drift
334	3092	7229	22	41	-7.78	76	Main Drift

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
335	7229	3102	22	41	-7.80	32	Main Drift
336	3102	3112	22	82	-7.81	51	Main Drift
337	3112	3122	22	82	-7.83	68	Main Drift
338	3132	7128	22	41	-7.87	6	Main Drift
339	3122	7128	22	41	-7.86	85	Main Drift
340	3132	3142	22	82	-7.87	11	Main Drift
341	3142	7124	22	41	-7.88	28	Main Drift
342	3152	7124	22	41	-7.87	64	Main Drift
343	3162	3152	22	82	-7.85	47	Main Drift
344	3172	3162	22	82	-7.84	30	Main Drift
345	3182	3172	22	82	-7.84	13	Main Drift
346	3182	3192	22	82	-7.84	4	Main Drift
347	3192	3202	22	82	-7.84	21	Main Drift
348	3202	3212	22	82	-7.85	38	Main Drift
349	3222	7228	22	41	-7.87	72	Main Drift
350	7228	4232	22	41	-7.92	137	Main Drift
351	4232	7622	22	41	-8.01	154	Main Drift
352	7622	4242	22	41	-8.07	48	Main Drift
353	4242	4252	22	82	-8.08	65	Main Drift
354	4252	4262	22	82	-8.12	82	Main Drift
355	4262	4272	22	82	-8.16	99	Main Drift
356	4272	4282	22	82	-8.23	116	Main Drift
357	4282	4292	22	41	-8.31	133	Main Drift
358	4292	6113	22	41	-8.40	150	Main Drift
359	6113	4302	22	82	-8.45	43	Main Drift
360	4102	4112	22	82	-7.81	61	Main Drift
361	4112	4122	22	41	-7.84	78	Main Drift
362	4132	7127	22	41	-7.89	5	Main Drift
363	4122	7127	22	41	-7.87	95	Main Drift
364	4132	4142	22	82	-7.89	12	Main Drift
365	4142	7125	22	41	-7.89	29	Main Drift
366	4152	7125	22	41	-7.88	71	Main Drift
367	4162	4152	22	82	-7.86	54	Main Drift
368	4172	4162	22	82	-7.85	37	Main Drift
369	4182	4172	22	82	-7.84	20	Main Drift
370	4192	4182	22	82	-7.84	3	Main Drift
371	4192	4202	22	82	-7.84	14	Main Drift
372	4202	4212	22	82	-7.84	31	Main Drift
373	4212	4222	22	82	-7.85	48	Main Drift
374	4222	7228	22	75	-7.87	65	Main Drift
375	3027	3017	22	82	-9.05	126	Main Drift
376	3037	3027	22	82	-8.96	109	Main Drift

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
377	3047	3037	22	82	-8.90	92	Main Drift
378	3057	3047	22	82	-8.86	75	Main Drift
379	3067	3057	22	82	-8.83	58	Main Drift
380	3077	3067	22	82	-8.82	41	Main Drift
381	3087	3077	22	82	-8.81	24	Main Drift
382	3097	3087	22	82	-8.81	7	Main Drift
383	3097	3107	22	82	-8.81	10	Main Drift
384	3107	3117	22	82	-8.81	27	Main Drift
385	3117	3127	22	82	-8.82	44	Main Drift
386	3127	3137	22	82	-8.84	61	Main Drift
387	3137	3147	22	82	-8.86	78	Main Drift
388	3147	3157	22	82	-8.91	95	Main Drift
389	3157	3167	22	82	-8.97	112	Main Drift
390	3167	3177	22	82	-9.06	129	Main Drift
391	3177	3187	22	82	-9.17	146	Main Drift
392	3197	7623	22	41	-9.34	22	Main Drift
393	3187	7623	22	41	-9.29	163	Main Drift
394	6116	3197	0	0	-5.95	5	Main Drift
395	3010	7223	22	59	-2.32	43	Main Drift
396	3020	3010	22	82	-2.32	58	Main Drift
397	3020	3030	22	82	-2.34	120	Main Drift
398	3030	3040	22	82	-2.38	105	Main Drift
399	3040	3015	22	61	-2.41	90	Main Drift
400	3015	3050	22	21	-2.42	75	Main Drift
401	3050	3025	22	61	-2.43	60	Main Drift
402	3025	3060	22	21	-2.44	45	Main Drift
403	3060	3035	22	27	-2.44	30	Main Drift
404	7214	3070	22	27	-2.46	220	Main Drift
405	3035	7214	22	27	-2.44	15	Main Drift
406	3070	3045	22	61	-2.55	205	Main Drift
407	3045	3080	22	21	-2.62	190	Main Drift
408	3080	3055	22	61	-2.67	175	Main Drift
409	3055	3090	22	21	-2.72	160	Main Drift
410	3090	3065	22	61	-2.76	145	Main Drift
411	3065	3100	22	21	-2.79	130	Main Drift
412	3100	3075	22	61	-2.82	114	Main Drift
413	3075	3110	22	21	-2.84	99	Main Drift
414	3110	3085	22	61	-2.85	84	Main Drift
415	3085	3120	22	21	-2.87	69	Main Drift
416	3120	3095	22	61	-2.87	54	Main Drift
417	3095	3130	22	21	-2.88	39	Main Drift
418	3130	3105	22	61	-2.88	24	Main Drift

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
419	3105	3140	22	21	-2.88	9	Main Drift
420	3115	3140	22	61	-2.88	6	Main Drift
421	3150	3115	22	21	-2.88	21	Main Drift
422	3125	3150	22	61	-2.88	37	Main Drift
423	3160	3125	22	21	-2.87	52	Main Drift
424	3135	3160	22	61	-2.87	67	Main Drift
425	7113	3170	22	27	-2.85	97	Main Drift
426	3170	3135	22	27	-2.86	82	Main Drift
427	7113	3145	22	27	-2.84	22	Main Drift
428	3145	3180	22	21	-2.84	7	Main Drift
429	3155	3180	22	61	-2.84	8	Main Drift
430	3190	3155	22	21	-2.84	23	Main Drift
431	3165	3190	22	61	-2.84	38	Main Drift
432	3200	3165	22	21	-2.84	53	Main Drift
433	3175	3200	22	61	-2.83	68	Main Drift
434	3210	3175	22	21	-2.82	83	Main Drift
435	3185	3210	22	61	-2.80	99	Main Drift
436	3220	3185	22	21	-2.79	114	Main Drift
437	3195	3220	22	61	-2.76	129	Main Drift
438	1010	3195	22	21	-2.73	144	Main Drift
439	1020	1010	22	82	-2.68	159	Main Drift
440	6112	1020	22	30	-2.61	174	Main Drift
441	1030	6112	24	52	-2.59	45	Main Drift
442	6100	1030	24	71	-2.59	60	Main Drift
443	1040	6100	24	11	-2.58	80	Main Drift
444	1050	1040	24	82	-2.56	95	Main Drift
445	1060	1050	24	82	-2.53	110	Main Drift
446	1070	1060	24	82	-2.49	125	Main Drift
447	1080	1070	24	82	-2.43	140	Main Drift
448	6017	1022	15	61	-8.10	47	Main Drift Panel 1 Exhaust
449	1032	6017	15	21	-8.07	27	Main Drift Panel 1 Exhaust
450	1042	1032	15	82	-8.06	10	Main Drift Panel 1 Exhaust
451	1042	1052	15	82	-8.06	7	Main Drift Panel 1 Exhaust
452	1052	1062	15	82	-8.07	24	Main Drift Panel 1 Exhaust
453	1062	1072	15	82	-8.11	41	Main Drift Panel 1 Exhaust
454	1072	1082	15	82	-8.21	58	Main Drift Panel 1 Exhaust
455	6230	6231	22	372	-2.22	80	Main Drift
456	6230	2260	22	460	-2.25	89	Main Drift
457	6220	6230	24	1783	-1.09	169	South Ramp
458	6231	2270	22	219	-2.29	73	Panel 2 Main Drift
459	6231	7321	0	0	-7.89	7	Main Drift
460	2272	7321	22	140	-13.15	336	Panel 2 Main Drift

Source: BSC 2003a, Attachment D and Attachment 2 of this document.



Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
461	7012	7011	25	33	-8.99	243	ECRB Exhaust Shaft
462	6114	7011	24	662	-8.80	150	7x7 ECRB Main Drift
463	6115	6114	24	58	-8.52	42	7x7 ECRB Main Drift
464	7017	6115	24	1000	-5.27	20	7x7 ECRB Main Drift
465	6111	7017	24	244	-2.03	20	7x7 ECRB Main Drift
466	6110	6111	24	1996	-1.01	154	North Portal Ramp
467	1090	1091	24	97	-2.36	5	Panel 1 Lead In
468	1091	1092	0	0	-5.39	5	Panel 1 Main Drift 7x7
469	1093	1092	15	143	-8.37	52	Panel 1 Main Drift 5m dia
470	1082	1093	15	30	-8.30	75	Panel 1 Main Drift 5m dia
471	1022	1012	15	29	-8.13	64	Panel 1 Main Drift 5m dia
472	1013	1012	15	134	-8.15	15	Panel 1 Main Drift 5m dia
473	1090	1080	24	41	-2.38	155	Panel 1 Main Drift 7.62m
474	2010	1090	24	82	-2.31	160	Panel 1 Main Drift 7.62m
475	1092	7227	22	597	-8.46	57	Panel 2 Main Drift 7.62 m
476	7013	7227	22	155	-8.49	63	Panel 2 Main Drift 7.62 m
477	4300	7013	0	0	-6.81	4	Panel 4 Main Drift 7.62 m
478	4302	7013	22	189	-8.46	60	Panel 4 Main Drift 7.62 m
479	1093	6115	7	29	-8.42	23	ECRB-Panel 1 Raise 2 m
480	6113	6114	24	205	-8.48	107	7x7 ECRB-Panel 4 connect
481	6016	6017	15	182	-5.37	20	Observation Drift 5 m dia
482	6015	6016	15	507	-2.64	20	Observation Drift 5 m dia
483	6014	6015	15	59	-2.61	20	Observation Drift 5 m dia
484	6013	6014	15	61	-2.60	20	Observation Drift 5 m dia
485	6011	6013	15	32	-2.60	20	Observation Drift 5 m dia
486	6100	6011	15	129	-2.59	20	Observation Drift 5 m dia
487	7111	7113	22	827	-2.60	119	Int Shft 1 Acc 7.65 m dia
488	7111	6414	22	557	-3.43	291	int shft 1 acc 7.65 m dia
489	6316	7224	22	457	-9.17	234	Main Drifts
490	7224	7225	22	98	-9.72	43	Main Drifts
491	3017	7225	22	716	-9.41	143	Main Drifts
492	6314	6315	22	701	-2.78	171	Main Drifts
493	6315	4010	22	905	-3.73	166	Main Drifts
494	6315	6316	0	0	-5.92	5	int to exh Main Drifts
495	7223	6314	22	293	-2.33	37	Main Drifts
496	6313	6314	22	158	-2.28	133	Main Drifts
497	6312	6313	22	66	-2.17	133	Main Drifts
498	6311	6312	22	2720	-1.11	133	Main Drifts
499	6310	6311	24	18	-0.05	133	7x7 lead in
500	6111	6116	24	732	-2.29	135	Main drift 7.62 m dia
501	6116	6112	24	61	-2.57	129	Main drift 7.62 m dia
502	3212	3222	22	83	-7.86	55	Main Drifts
503	7221	7222	25	10	-10.01	377	Lower Exhaust Shaft #2

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
504	7320	9320	0	0	-7.46	345	Exhaust Shaft #3 Fan
505	7010	9020	0	0	-5.65	394	ECRB Shaft Exhaust Fan
506	7620	9620	0	0	-6.83	186	Exhaust Raise #1 Fan
507	7120	9120	0	0	-5.17	385	Exhaust Shaft #1 Fan
508	7220	9220	0	0	-6.24	385	Exhaust Shaft #2 Fan
509	7625	9622	0	0	0.21	186	Exhaust Raise #2 Fan
510	9321	7320	0	0	-7.46	1.7	Fan Housing Leakage
511	9021	7010	0	0	-5.65	1.5	Fan Housing Leakage
512	9621	7620	0	0	-6.83	1.6	Fan Housing Leakage
513	9121	7120	0	0	-5.17	1.4	Fan Housing Leakage
514	9221	7220	0	0	-6.24	1.5	Fan Housing Leakage
515	9623	7625	0	0	0.21	1.7	Fan Housing Leakage exr 2
516	9997	6220	0	0	0.00	169	Atmospheric Reference
517	9320	9997	0	0	0.00	345	Atmospheric Reference
518	9020	9997	0	0	0.00	394	Atmospheric Reference
519	9620	9997	0	0	0.00	186	Atmospheric Reference
520	9997	7110	0	0	0.00	410	Atmospheric Reference
521	9120	9997	0	0	0.00	385	Atmospheric Reference
522	9997	6310	0	0	0.00	133	Atmospheric Reference
523	9220	9997	0	0	0.00	385	Atmospheric Reference
524	9997	7210	0	0	0.00	399	Atmospheric Reference
525	9997	6110	0	0	0.00	154	Atmospheric Reference
526	9997	7310	0	0	0.00	406	Atmospheric Reference
527	9997	9623	0	0	0.00	1.7	Atmospheric Reference
528	9997	9321	0	0	0.00	1.7	Fan Housing Atmospheric
529	9997	9021	0	0	0.00	1.5	Fan Housing Atmospheric
530	9997	9621	0	0	0.00	1.6	Fan Housing Atmospheric
531	9997	9121	0	0	0.00	1.4	Fan Housing Atmospheric
532	9997	9221	0	0	0.00	1.5	Fan Housing Atmospheric
533	9622	9997	0	0	0.00	186	Fan Housing Atmospheric
534	9997	2272	0	0	-6.39	1.9	inject branch/expansion
535	9997	2262	0	0	-6.09	1.9	inject branch/expansion
536	9997	2252	0	0	-5.82	1.9	inject branch/expansion
537	9997	2244	0	0	-5.58	1.9	inject branch/expansion
538	9997	2232	0	0	-5.36	1.9	inject branch/expansion
539	9997	2222	0	0	-5.18	1.9	inject branch/expansion
540	9997	2212	0	0	-5.01	1.9	inject branch/expansion
541	9997	2202	0	0	-4.87	1.9	inject branch/expansion
542	9997	2192	0	0	-4.76	1.9	inject branch/expansion
543	9997	2182	0	0	-4.66	1.9	inject branch/expansion
544	9997	2172	0	0	-4.58	1.9	inject branch/expansion
545	9997	2162	0	0	-4.51	1.9	inject branch/expansion
546	9997	2152	0	0	-4.46	1.9	inject branch/expansion

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
547	9997	2142	0	0	-4.42	1.9	inject branch/expansion
548	9997	2132	0	0	-4.39	1.9	inject branch/expansion
549	9997	2122	0	0	-4.37	1.9	inject branch/expansion
550	9997	2112	0	0	-4.36	1.9	inject branch/expansion
551	9997	2102	0	0	-4.35	1.9	inject branch/expansion
552	9997	2092	0	0	-4.35	1.9	inject branch/expansion
553	9997	2082	0	0	-4.35	1.9	inject branch/expansion
554	9997	2072	0	0	-4.35	1.9	inject branch/expansion
555	9997	2062	0	0	-4.35	1.9	inject branch/expansion
556	9997	2052	0	0	-4.35	1.9	inject branch/expansion
557	9997	2042	0	0	-4.36	1.9	inject branch/expansion
558	9997	2032	0	0	-4.38	1.9	inject branch/expansion
559	9997	2022	0	0	-4.36	1.9	inject branch/expansion
560	9997	2012	0	0	-4.30	1.9	inject branch/expansion
561	9997	1082	0	0	-4.14	1.9	inject branch/expansion
562	9997	1072	0	0	-4.07	1.9	inject branch/expansion
563	9997	1062	0	0	-4.04	1.9	inject branch/expansion
564	9997	1052	0	0	-4.03	1.9	inject branch/expansion
565	9997	1042	0	0	-4.03	1.9	inject branch/expansion
566	9997	1032	0	0	-4.03	1.9	inject branch/expansion
567	9997	1022	0	0	-4.06	1.9	inject branch/expansion
568	9997	3197	0	0	-4.67	1.9	inject branch/expansion
569	9997	3187	0	0	-4.62	1.9	inject branch/expansion
570	9997	3177	0	0	-4.55	1.9	inject branch/expansion
571	9997	3167	0	0	-4.50	1.9	inject branch/expansion
572	9997	3157	0	0	-4.47	1.9	inject branch/expansion
573	9997	3147	0	0	-4.44	1.9	inject branch/expansion
574	9997	3137	0	0	-4.42	1.9	inject branch/expansion
575	9997	3127	0	0	-4.41	1.9	inject branch/expansion
576	9997	3117	0	0	-4.41	1.9	inject branch/expansion
577	9997	3107	0	0	-4.40	1.9	inject branch/expansion
578	9997	3097	0	0	-4.40	1.9	inject branch/expansion
579	9997	3087	0	0	-4.40	1.9	inject branch/expansion
580	9997	3077	0	0	-4.41	1.9	inject branch/expansion
581	9997	3067	0	0	-4.41	1.9	inject branch/expansion
582	9997	3057	0	0	-4.42	1.9	inject branch/expansion
583	9997	3047	0	0	-4.44	1.9	inject branch/expansion
584	9997	3037	0	0	-4.46	1.9	inject branch/expansion
585	9997	3027	0	0	-4.50	1.9	inject branch/expansion
586	9997	3017	0	0	-4.55	1.9	inject branch/expansion
587	9997	3012	0	0	-4.16	3.8	inject branch/expansion
588	9997	3022	0	0	-4.04	3.8	inject branch/expansion
589	9997	3032	0	0	-3.97	3.8	inject branch/expansion

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

Table 3. Repository Layout Input Parameters (Continued)

Line No.	Inlet Node	Outlet Node	Perimeter (m)	Length (m)	Pres. Drop (mbar)	Flow (m <sup>3</sup> /s)	Description
590	9997	3042	0	0	-3.92	3.8	inject branch/expansion
591	9997	3052	0	0	-3.89	3.8	inject branch/expansion
592	9997	3062	0	0	-3.88	3.8	inject branch/expansion
593	9997	3072	0	0	-3.88	3.8	inject branch/expansion
594	9997	3082	0	0	-3.88	3.8	inject branch/expansion
595	9997	3092	0	0	-3.89	3.8	inject branch/expansion
596	9997	3102	0	0	-3.90	3.8	inject branch/expansion
597	9997	3112	0	0	-3.91	1.9	inject branch/expansion
598	9997	3122	0	0	-3.92	1.9	inject branch/expansion
599	9997	3132	0	0	-3.94	1.9	inject branch/expansion
600	9997	3142	0	0	-3.94	1.9	inject branch/expansion
601	9997	3152	0	0	-3.93	1.9	inject branch/expansion
602	9997	3162	0	0	-3.92	1.9	inject branch/expansion
603	9997	3172	0	0	-3.92	1.9	inject branch/expansion
604	9997	3182	0	0	-3.92	1.9	inject branch/expansion
605	9997	3192	0	0	-3.92	1.9	inject branch/expansion
606	9997	3202	0	0	-3.92	1.9	inject branch/expansion
607	9997	3212	0	0	-3.93	1.9	inject branch/expansion
608	9997	3222	0	0	-3.93	1.9	inject branch/expansion
609	9997	4232	0	0	-3.98	1.9	inject branch/expansion
610	9997	4242	0	0	-4.04	1.9	inject branch/expansion
611	9997	4252	0	0	-4.05	1.9	inject branch/expansion
612	9997	4262	0	0	-4.07	1.9	inject branch/expansion
613	9997	4272	0	0	-4.10	1.9	inject branch/expansion
614	9997	4282	0	0	-4.14	1.9	inject branch/expansion
615	9997	4292	0	0	-4.17	1.9	inject branch/expansion
616	9997	4302	0	0	-4.23	1.9	inject branch/expansion
617	9997	4222	0	0	-3.93	1.9	inject branch/expansion
618	9997	4212	0	0	-3.92	1.9	inject branch/expansion
619	9997	4202	0	0	-3.92	1.9	inject branch/expansion
620	9997	4192	0	0	-3.92	1.9	inject branch/expansion
621	9997	4182	0	0	-3.92	1.9	inject branch/expansion
622	9997	4172	0	0	-3.92	1.9	inject branch/expansion
623	9997	4162	0	0	-3.93	1.9	inject branch/expansion
624	9997	4152	0	0	-3.93	1.9	inject branch/expansion
625	9997	4142	0	0	-3.94	1.9	inject branch/expansion
626	9997	4132	0	0	-3.94	1.9	inject branch/expansion
627	9997	4122	0	0	-3.92	1.9	inject branch/expansion
628	9997	4112	0	0	-3.91	1.9	inject branch/expansion
629	9997	4102	0	0	-3.90	1.9	inject branch/expansion

Source: BSC 2003a, Attachment D and Attachment 2 of this document.

### 6.3.1 Calculation Output

The calculation outputs are presented in Table 4 and Attachment II.

Table 4. Concentration Calculation Outputs

Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL	Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL <sup>a</sup>
1	75	64.3	0.076	36	36	4.9	0.003
2	38	10.3	0.010	37	35	5.1	0.003
3	37	10.1	0.009	38	35	5.5	0.004
4	37	5.7	0.004	39	35	6.1	0.004
5	37	5.1	0.003	40	35	7.3	0.006
6	37	4.7	0.003	41	36	7.5	0.006
7	37	4.3	0.002	42	36	7.6	0.006
8	37	4.1	0.002	43	37	7.2	0.006
9	37	3.8	0.002	44	37	7.6	0.006
10	56	38.7	0.038	45	37	8.1	0.007
11	55	43.4	0.045	46	37	8.9	0.008
12	55	38.9	0.036	47	37	10.9	0.012
13	55	38.3	0.034	48	37	5.8	0.004
14	55	37.6	0.033	49	37	4.8	0.003
15	55	35.0	0.029	50	37	4.3	0.002
16	56	30.2	0.022	51	37	11.4	0.015
17	57	25.3	0.016	52	37	12.3	0.014
18	57	55.9	0.065	53	37	11.4	0.012
19	56	68.7	0.079	54	37	10.9	0.011
20	10	0.1	0.000	55	37	10.5	0.010
21	9	0.1	0.000	56	39	5.8	0.004
22	16	0.3	0.000	57	39	6.3	0.004
23	16	0.7	0.000	58	39	6.8	0.005
24	17	0.7	0.000	59	39	7.8	0.006
25	63	71.5	0.116	60	40	8.0	0.007
26	55	65.1	0.090	61	40	8.2	0.007
27	55	74.1	0.120	62	40	7.8	0.006
28	78	83.9	0.146	63	40	8.2	0.007
29	67	72.5	0.108	64	40	8.9	0.008
30	67	94.4	0.172	65	40	10.3	0.011
31	44	2.2	0.001	66	40	6.5	0.004
32	70	78.4	0.139	67	40	5.3	0.003
33	54	73.0	0.107	68	40	4.7	0.002
34	37	5.2	0.003	69	40	5.0	0.003
35	36	4.6	0.003	70	41	13.0	0.016

NOTE: <sup>a</sup>0.000 means WL is less than 0.0005 WL.

Table 4. Concentration Calculation Outputs (Continued)

Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL	Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL <sup>a</sup>
71	41	11.9	0.013	111	61	41.5	0.043
72	41	11.4	0.012	112	62	39.7	0.039
73	42	11.0	0.011	113	62	37.6	0.034
74	42	10.7	0.010	114	63	37.6	0.034
75	57	41.2	0.038	115	64	36.7	0.032
76	55	39.6	0.036	116	55	69.5	0.100
77	54	39.2	0.036	117	55	60.6	0.078
78	54	39.1	0.037	118	43	14.1	0.019
79	53	39.3	0.037	119	43	14.8	0.020
80	53	39.8	0.038	120	42	14.8	0.020
81	53	40.9	0.041	121	42	15.3	0.021
82	53	41.2	0.042	122	42	15.8	0.022
83	53	41.4	0.042	123	42	16.4	0.024
84	53	40.7	0.040	124	42	17.2	0.025
85	53	41.2	0.041	125	42	18.2	0.028
86	54	41.8	0.043	126	42	18.8	0.029
87	54	42.7	0.045	127	42	20.5	0.033
88	54	44.7	0.050	128	43	28.0	0.075
89	54	39.5	0.037	129	43	13.4	0.014
90	54	38.5	0.035	130	43	9.6	0.007
91	54	37.9	0.034	131	43	7.7	0.005
92	54	45.0	0.053	132	43	6.5	0.004
93	54	46.0	0.054	133	43	5.5	0.003
94	54	45.1	0.051	134	42	4.7	0.002
95	54	44.6	0.049	135	43	4.8	0.002
96	54	44.2	0.048	136	43	5.2	0.003
97	62	53.0	0.057	137	44	5.7	0.003
98	61	55.3	0.062	138	44	6.3	0.004
99	61	56.0	0.064	139	44	6.8	0.004
100	60	55.9	0.064	140	45	7.3	0.005
101	60	55.6	0.064	141	45	7.9	0.005
102	60	55.3	0.064	142	45	8.6	0.006
103	60	53.2	0.059	143	46	9.5	0.007
104	60	50.9	0.055	144	46	10.5	0.008
105	60	48.8	0.052	145	46	12.7	0.012
106	60	47.5	0.051	146	46	15.3	0.016
107	60	41.0	0.037	147	47	21.0	0.027
108	60	37.1	0.030	148	57	50.7	0.063
109	60	34.6	0.026	149	55	50.1	0.063
110	61	34.1	0.026	150	54	49.9	0.064

NOTE: <sup>a</sup>0.000 means WL is less than 0.0005 WL.

Table 4. Concentration Calculation Outputs (Continued)

Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL	Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL <sup>a</sup>
151	54	49.9	0.065	191	37	3.5	0.002
152	53	50.3	0.066	192	38	3.7	0.002
153	53	50.8	0.068	193	38	4.0	0.002
154	53	51.6	0.070	194	38	4.3	0.002
155	53	52.6	0.073	195	38	4.6	0.002
156	53	53.4	0.075	196	38	5.0	0.003
157	53	53.6	0.078	197	39	5.4	0.003
158	53	61.2	0.123	198	39	6.0	0.004
159	54	46.7	0.053	199	39	6.8	0.005
160	54	43.1	0.044	200	39	5.5	0.007
161	54	41.2	0.040	201	40	9.8	0.010
162	54	39.8	0.037	202	40	16.7	0.029
163	54	38.8	0.035	203	41	12.7	0.017
164	54	38.0	0.034	204	41	11.3	0.014
165	54	38.1	0.034	205	42	10.5	0.012
166	54	38.5	0.035	206	43	9.9	0.011
167	54	39.1	0.036	207	44	9.5	0.010
168	54	39.4	0.036	208	45	9.2	0.009
169	54	39.5	0.036	209	46	8.9	0.009
170	54	40.9	0.039	210	48	8.7	0.008
171	55	41.4	0.039	211	50	8.6	0.008
172	55	41.6	0.040	212	52	9.1	0.008
173	56	41.9	0.040	213	59	47.1	0.048
174	56	42.6	0.042	214	59	48.9	0.051
175	57	44.9	0.047	215	60	48.9	0.051
176	57	47.0	0.053	216	59	48.5	0.050
177	58	49.3	0.064	217	59	48.4	0.050
178	59	70.4	0.126	218	59	48.4	0.050
179	14	0.2	0.000	219	59	48.5	0.050
180	61	79.4	0.130	220	59	48.6	0.050
181	97	92.6	0.139	221	59	48.7	0.050
182	93	91.5	0.134	222	59	48.9	0.051
183	7	0.1	0.000	223	59	49.0	0.051
184	64	64.0	0.085	224	59	49.3	0.051
185	36	64.8	0.088	225	60	49.7	0.052
186	37	3.5	0.002	226	60	50.4	0.053
187	37	3.4	0.002	227	61	51.5	0.056
188	37	3.2	0.001	228	61	53.5	0.061
189	37	3.2	0.001	229	62	60.7	0.085
190	37	3.3	0.002	230	63	57.2	0.070

NOTE: <sup>a</sup>0.000 means WL is less than 0.0005 WL.

Table 4. Concentration Calculation Outputs (Continued)

Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL	Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL <sup>a</sup>
231	65	56.3	0.066	271	72	90.6	0.134
232	66	56.2	0.064	272	70	90.1	0.134
233	68	56.5	0.062	273	68	89.6	0.133
234	70	57.1	0.062	274	66	89.2	0.133
235	73	58.0	0.061	275	65	88.7	0.132
236	76	59.3	0.061	276	64	88.1	0.130
237	79	60.2	0.061	277	63	87.1	0.127
238	83	57.0	0.053	278	62	86.7	0.126
239	87	52.0	0.045	279	61	86.4	0.125
240	17	0.6	0.000	280	61	86.3	0.124
241	16	0.4	0.000	281	60	86.2	0.124
242	15	0.3	0.000	282	60	86.1	0.123
243	15	0.3	0.000	283	60	85.9	0.122
244	16	0.3	0.000	284	60	85.6	0.119
245	16	0.5	0.000	285	60	84.3	0.111
246	17	0.7	0.000	286	60	94.8	0.180
247	17	0.9	0.000	287	60	88.1	0.136
248	18	1.2	0.000	288	60	87.5	0.132
249	18	1.5	0.000	289	60	87.3	0.130
250	18	1.8	0.001	290	60	87.3	0.129
251	18	2.2	0.001	291	60	87.3	0.128
252	18	2.7	0.001	292	60	74.1	0.125
253	19	3.4	0.002	293	60	72.7	0.127
254	19	4.3	0.003	294	59	71.0	0.129
255	19	5.8	0.005	295	48	12.2	0.010
256	19	10.9	0.017	296	36	8.9	0.006
257	19	11.3	0.017	297	36	7.3	0.004
258	19	8.8	0.011	298	36	6.1	0.003
259	19	7.7	0.009	299	36	5.2	0.002
260	18	6.9	0.008	300	36	4.5	0.002
261	18	6.3	0.007	301	36	3.8	0.001
262	18	5.9	0.006	302	35	3.3	0.001
263	18	5.5	0.005	303	35	2.8	0.001
264	18	5.2	0.005	304	34	2.4	0.001
265	17	4.9	0.004	305	34	2.0	0.000
266	17	5.4	0.005	306	33	1.6	0.000
267	50	92.8	0.135	307	32	1.4	0.000
268	81	92.5	0.135	308	32	1.3	0.000
269	78	91.8	0.135	309	32	1.8	0.000
270	75	91.2	0.135	310	32	2.7	0.001

NOTE: <sup>a</sup>0.000 means WL is less than 0.0005 WL.



Table 4. Concentration Calculation Outputs (Continued)

Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL	Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL <sup>a</sup>
311	32	3.8	0.001	351	55	68.4	0.077
312	32	5.4	0.003	352	56	69.1	0.081
313	32	8.2	0.006	353	56	68.7	0.083
314	32	126.9	0.940	354	56	68.7	0.085
315	32	19.2	0.031	355	56	68.7	0.087
316	32	16.3	0.024	356	57	68.7	0.088
317	32	14.6	0.021	357	57	68.7	0.089
318	32	13.5	0.019	358	58	68.6	0.089
319	32	12.7	0.017	359	58	70.0	0.096
320	32	12.0	0.016	360	54	74.9	0.115
321	32	11.4	0.015	361	54	77.1	0.127
322	31	10.9	0.014	362	55	69.6	0.094
323	31	10.4	0.013	363	54	76.0	0.122
324	30	10.0	0.013	364	55	69.3	0.092
325	44	70.3	0.092	365	55	68.3	0.089
326	57	70.0	0.092	366	55	65.8	0.084
327	55	69.8	0.092	367	54	65.6	0.084
328	55	69.7	0.092	368	54	65.0	0.081
329	54	69.8	0.093	369	54	64.1	0.076
330	54	69.9	0.093	370	54	75.5	0.141
331	54	69.9	0.091	371	54	64.4	0.076
332	54	73.8	0.115	372	54	65.9	0.084
333	54	71.8	0.102	373	54	66.3	0.028
334	54	71.7	0.100	374	54	66.3	0.046
335	54	72.8	0.106	375	62	93.0	0.141
336	54	68.4	0.096	376	62	92.5	0.141
337	54	68.7	0.097	377	61	91.8	0.139
338	54	69.4	0.092	378	61	90.9	0.137
339	54	68.7	0.095	379	61	89.8	0.135
340	54	69.9	0.095	380	61	88.0	0.131
341	54	70.9	0.098	381	61	85.8	0.127
342	54	55.1	0.063	382	61	83.5	0.126
343	54	50.8	0.057	383	61	81.7	0.115
344	54	41.5	0.043	384	61	80.0	0.115
345	54	8.2	0.008	385	61	76.4	0.107
346	54	16.6	0.023	386	61	73.2	0.101
347	54	63.0	0.083	387	61	70.5	0.095
348	54	67.5	0.094	388	61	68.6	0.092
349	54	69.6	0.097	389	62	68.2	0.092
350	55	68.7	0.077	390	62	67.6	0.091

NOTE: <sup>a</sup>0.000 means WL is less than 0.0005 WL.

Table 4. Concentration Calculation Outputs (Continued)

Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL	Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL <sup>a</sup>
391	63	67.0	0.090	431	21	9.1	0.009
392	64	42.9	0.040	432	21	8.7	0.008
393	64	66.2	0.088	433	21	8.4	0.008
394	42	4.8	0.004	434	21	8.1	0.007
395	17	1.9	0.001	435	21	7.9	0.007
396	17	1.4	0.000	436	20	7.7	0.006
397	17	1.3	0.000	437	20	7.6	0.006
398	18	1.5	0.000	438	20	7.5	0.006
399	18	1.8	0.001	439	20	7.3	0.006
400	18	2.0	0.001	440	19	7.2	0.005
401	18	2.3	0.001	441	19	3.1	0.001
402	18	2.6	0.001	442	19	2.6	0.001
403	18	2.8	0.001	443	19	2.3	0.001
404	18	3.8	0.002	444	19	2.0	0.001
405	18	3.4	0.002	445	19	1.7	0.000
406	19	3.9	0.002	446	18	1.4	0.000
407	19	3.9	0.002	447	18	1.1	0.000
408	20	4.0	0.003	448	56	46.1	0.052
409	20	4.1	0.003	449	56	64.3	0.068
410	20	4.3	0.003	450	56	64.4	0.069
411	20	4.4	0.003	451	56	66.4	0.077
412	21	4.6	0.003	452	56	64.8	0.072
413	21	4.7	0.003	453	56	62.8	0.068
414	21	4.9	0.004	454	57	59.5	0.063
415	21	5.2	0.004	455	17	3.1	0.002
416	21	5.5	0.004	456	17	3.2	0.002
417	21	5.9	0.005	457	9	1.1	0.001
418	21	6.6	0.006	458	17	4.5	0.004
419	21	7.7	0.008	459	55	4.0	0.003
420	21	5.6	0.005	460	90	92.7	0.135
421	21	3.1	0.001	461	62	79.9	0.132
422	21	2.5	0.001	462	61	70.3	0.121
423	21	2.1	0.001	463	59	55.1	0.106
424	21	1.8	0.000	464	37	29.5	0.081
425	21	1.3	0.000	465	15	4.9	0.006
426	21	1.5	0.000	466	8	1.3	0.001
427	21	1.5	0.000	467	17	5.0	0.006
428	21	2.5	0.001	468	38	9.1	0.012
429	21	11.6	0.015	469	58	56.9	0.061
430	21	9.7	0.010	470	57	55.5	0.056

NOTE: <sup>a</sup>0.000 means WL is less than 0.0005 WL.

Table 4. Concentration Calculation Outputs (Continued)

Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL	Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL <sup>a</sup>
471	56	51.9	0.058	511	40	0.0	0.000
472	56	67.9	0.076	512	47	0.0	0.000
473	18	0.9	0.000	513	36	0.0	0.000
474	17	0.7	0.000	514	44	0.0	0.000
475	58	60.6	0.090	515	2	0.0	0.000
476	59	71.3	0.121	516	2	0.0	0.000
477	47	14.5	0.013	517	2	0.0	0.000
478	58	71.0	0.107	518	2	79.0	0.142
479	58	55.9	0.057	519	2	64.8	0.078
480	59	70.2	0.097	520	2	0.0	0.000
481	38	16.7	0.021	521	2	72.2	0.120
482	19	10.2	0.011	522	2	0.0	0.000
483	19	6.0	0.004	523	2	84.6	0.151
484	19	5.1	0.003	524	2	0.0	0.000
485	19	4.4	0.002	525	2	0.0	0.000
486	19	3.2	0.001	526	2	0.0	0.000
487	19	1.7	0.001	527	2	0.0	0.000
488	25	0.7	0.000	528	2	0.0	0.000
489	63	70.6	0.098	529	2	0.0	0.000
490	67	73.5	0.113	530	2	0.0	0.000
491	65	96.0	0.160	531	2	0.0	0.000
492	20	5.7	0.006	532	2	0.0	0.000
493	27	8.3	0.010	533	2	64.6	0.089
494	41	6.7	0.008	534	45	0.0	0.000
495	17	3.7	0.003	535	43	0.0	0.000
496	17	4.5	0.005	536	41	0.0	0.000
497	16	4.2	0.005	537	39	0.0	0.000
498	9	2.1	0.002	538	38	0.0	0.000
499	2	0.0	0.000	539	36	0.0	0.000
500	17	3.7	0.003	540	35	0.0	0.000
501	19	5.0	0.005	541	34	0.0	0.000
502	54	69.2	0.097	542	34	0.0	0.000
503	69	83.9	0.143	543	33	0.0	0.000
504	52	93.2	0.143	544	32	0.0	0.000
505	40	79.0	0.142	545	32	0.0	0.000
506	47	64.8	0.078	546	32	0.0	0.000
507	36	72.2	0.120	547	31	0.0	0.000
508	44	84.6	0.151	548	31	0.0	0.000
509	2	64.6	0.089	549	31	0.0	0.000
510	52	0.0	0.000	550	31	0.0	0.000

NOTE: <sup>a</sup>0.000 means WL is less than 0.0005 WL.

Table 4. Concentration Calculation Outputs (Continued)

Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL	Line No.	Average Flux (pCi/m <sup>2</sup> /s)	Average Radon Conc. pCi/L	Average WL <sup>a</sup>
551	31	0.0	0.000	591	28	0.0	0.000
552	31	0.0	0.000	592	28	0.0	0.000
553	31	0.0	0.000	593	28	0.0	0.000
554	31	0.0	0.000	594	28	0.0	0.000
555	31	0.0	0.000	595	28	0.0	0.000
556	31	0.0	0.000	596	28	0.0	0.000
557	31	0.0	0.000	597	28	0.0	0.000
558	31	0.0	0.000	598	28	0.0	0.000
559	31	0.0	0.000	599	28	0.0	0.000
560	31	0.0	0.000	600	28	0.0	0.000
561	29	0.0	0.000	601	28	0.0	0.000
562	29	0.0	0.000	602	28	0.0	0.000
563	29	0.0	0.000	603	28	0.0	0.000
564	29	0.0	0.000	604	28	0.0	0.000
565	29	0.0	0.000	605	28	0.0	0.000
566	29	0.0	0.000	606	28	0.0	0.000
567	29	0.0	0.000	607	28	0.0	0.000
568	33	0.0	0.000	608	28	0.0	0.000
569	33	0.0	0.000	609	28	0.0	0.000
570	32	0.0	0.000	610	29	0.0	0.000
571	32	0.0	0.000	611	29	0.0	0.000
572	32	0.0	0.000	612	29	0.0	0.000
573	31	0.0	0.000	613	29	0.0	0.000
574	31	0.0	0.000	614	29	0.0	0.000
575	31	0.0	0.000	615	30	0.0	0.000
576	31	0.0	0.000	616	30	0.0	0.000
577	31	0.0	0.000	617	28	0.0	0.000
578	31	0.0	0.000	618	28	0.0	0.000
579	31	0.0	0.000	619	28	0.0	0.000
580	31	0.0	0.000	620	28	0.0	0.000
581	31	0.0	0.000	621	28	0.0	0.000
582	31	0.0	0.000	622	28	0.0	0.000
583	31	0.0	0.000	623	28	0.0	0.000
584	32	0.0	0.000	624	28	0.0	0.000
585	32	0.0	0.000	625	28	0.0	0.000
586	32	0.0	0.000	626	28	0.0	0.000
587	30	0.0	0.000	627	28	0.0	0.000
588	29	0.0	0.000	628	28	0.0	0.000
589	28	0.0	0.000	629	28	0.0	0.000
590	28	0.0	0.000				

NOTE: <sup>a</sup>0.000 means WL is less than 0.0005 WL.

## 6.4 RELEASE CALCULATION

The annual radon release to the atmosphere from the subsurface repository is determined by summing the radon flow rates from the six exhaust shafts.

$$\begin{aligned} \text{Radon release rate} = & [\text{Exhaust Raise \#1}] (6.54\text{E}+01 \text{ pCi/L} \times 185 \text{ m}^3/\text{s}) + \\ & [\text{Exhaust Shaft \#1}] (7.25\text{E}+01 \text{ pCi/L} \times 383 \text{ m}^3/\text{s}) + \\ & [\text{Exhaust Shaft \#2}] (8.49\text{E}+01 \text{ pCi/L} \times 383 \text{ m}^3/\text{s}) + \\ & [\text{ECRB Exhaust Shaft}] (7.93\text{E}+01 \text{ pCi/L} \times 393 \text{ m}^3/\text{s}) + \\ & [\text{Exhaust Shaft \#3}] (9.37\text{E}+01 \text{ pCi/L} \times 343 \text{ m}^3/\text{s}) + \\ & [\text{Exhaust Raise \#2}] (6.52\text{E}+01 \text{ pCi/L} \times 185 \text{ m}^3/\text{s}) \\ & \times 1000 \text{ L} / \text{m}^3 \times 1.0\text{E}-12 \text{ Ci/pCi} \times 365 \text{ d/yr} \times 24 \text{ hr/d} \times 3600 \text{ s/hr} \\ & = 4700 \text{ Ci/Yr.} \end{aligned}$$

## 7. RESULTS

### 7.1 RADON AND WORKING LEVEL CENTRATIONS

The results of concentration calculations are summarized in Table 5. The concentration values listed are distance-weighted average radon concentrations and working levels in various types of drifts. The predicted average radon concentrations in various types of drifts are 5.8 pCi/L in main drifts, 47 pCi/L in emplacement drifts, and 72 pCi/L in exhaust main drifts. The corresponding average working levels are 0.012 WL in main drifts, 0.050 WL in emplacement drifts, 0.10 WL in exhaust main drifts.

### 7.2 COMPLIANCE WITH APPLICABLE LIMITS

This section presents an evaluation of compliance with applicable radiation exposure limits imposed by the regulations of the Occupational Safety and Health Administration (OSHA) under 29 CFR 1910.1096 of the U.S. Department of Labor.

In 29 CFR 1910.1096, the limits for radiation exposure for workers are numerically specified according to Table 1 of Appendix B to 10 CFR Part 20 (U.S. Nuclear Regulatory Commission) as maximum annual average air concentrations by nuclide. The limits are for exposure to the concentrations specified for 40 hours in any workweek of 7 consecutive days. The Rn-222 concentration limits in pCi/L and WL are presented in Table 5 along with the annual average concentrations predicted. In potentially occupied areas in the main drifts, the predicted overall average radon concentration is well below the 30 pCi/L limit. The distance-weighted working-level averages of short-lived radon progeny in all types of drifts including the emplacement and exhaust main drifts are all predicted well below the more applicable 0.33 working level (10 CFR Part 20 expresses limits for Rn-222 and working-level concentrations but allows the optional alternative use of either).

The previous results also indicate that the predicted average radon concentrations could be even lower than the values shown in Table 5 during the development/construction of the repository when the ventilation system is operated as a positive pressure system (BSC 2003f, Section 6). This is because the convective radon flux released from the host rock may be suppressed by the positive pressure as shown by Figure 2 (Equation 1). A proposed radon test in the ESF would provide further information to validate the radon flux rate for the positive and negative pressures.

Table 5. Comparison of Predicted Air Concentrations with 29 CFR 1910.1096 Limits

<b>Distance-Weighted Average Concentrations for Potentially Occupied Areas</b>		
	<b>Rn-222 Concentrations (pCi/L)</b>	<b>Radon Progeny Concentrations (WL)</b>
Main Drifts <sup>a</sup>	5.8	0.012
Emplacement Drifts	47	0.050
Exhaust Main	72	0.10
<b>Applicable Concentration Limits</b>		
29 CFR 1910.1096( c)(1) Limits <sup>b</sup>	30	0.33

NOTES: <sup>a</sup>Potentially occupied areas  
<sup>b</sup>Table 1 of Appendix B to 10 CFR Part 20

## 8. REERENCES

10 CFR 20. Energy: Standards for Protection Against Radiation. Readily Available.

29 CFR 1910. Labor: Occupational Safety and Health Standards. Readily Available.

AP-SI.1Q, Rev. 5, ICN 2. *Software Management*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: DOC.20030902.0003.

AP-3.12Q, Rev. 2, ICN 1. *Design Calculations and Analyses*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: DOC.  
[20030827.0013](#).

BSC (Bechtel SAIC Company) 2003a. *Ventilation Network Model Calculation*. 800-M0C-VU00-00100-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: [ENG.20030714.0001](#).

BSC 2003b. *Underground Layout Configuration*. 800-P0C-MGR0-00100-000-00E. Las Vegas, Nevada: Bechtel SAIC Company. ACC: [ENG.20031002.0007](#).

BSC 2003c. *Q-List*. TDR-MGR-RL-000005 REV 00. Las Vegas, Nevada: Bechtel SAIC Company. ACC: [DOC.20030930.0002](#).

BSC 2003d. *Subsurface Radon Flux Calculation*. 800-HYC-VU00-00100-000-00A. Las Vegas, Nevada: Bechtel SAIC Company.

BSC (Bechtel SAIC Company) 2003e. *Pressure Distribution in the ESF for One and Two Fan Operation*. 800-M0C-VU00-00300-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: [ENG.20030716.0001](#).

BSC 2003f. *Subsurface Construction and Emplacement Ventilation*. 800-P0C-MGR0-00200-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: [ENG.20031013.0001](#).

CRWMS M&O 2000. *Subsurface Radon Calculations*. CAL-SSM-NU-000003 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20001220.0016.

DOE (U.S. Department of Energy) 2003. *Quality Assurance Requirements and Description*. DOE/RW-0333P, Rev. 13. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: [DOC.20030422.0003](#).

Kocher, D.C. 1981. *Radioactive Decay Data Tables, A Handbook of Decay Data for Application to Radiation Dosimetry and Radiological Assessments*. DOE/TIC-11026. Washington, D.C.: U.S. Department of Energy. TIC: [228074](#).

Minwalla, H.J. 2003. *Project Design Criteria Document*. 000-3DR-MGR0-00100-000-001.  
Las Vegas, Nevada: Bechtel SAIC Company. ACC: [ENG.20030402.0001](#).

## 9. ATTACHMENTS

This calculation document includes two attachments as shown in Table 6.

Table 6. List of Attachments

Attachment Number	Description	pages	Date
I	Description of Calculation Worksheets	1	N/A
II	Listing of Electronic File in CD Containing Radon Exposure Calculations	1 and CD 1 of 1	10/27/03



**ATTACHMENT I. DESCRIPTION OF CALCULATION WORKSHEETS**

Table I-1 Input Parameters and Equations Used for Worksheet

Input parameters<sup>a</sup> and equations<sup>b</sup>

Nuclide	Half-life, $T_{1/2}$ (s) <sup>c</sup>	Decay Constant, $\lambda_n$ (1/s)	Ventilation Network Parameters	Branch No.	Branch No.	Branch No.
Rn-222 (n=0)	3.30E+05	2.10E-06	Drift Length, L (m)	Input	Input	Input
Po-218 (n=1)	1.83E+02	3.79E-03	Drift Diameter, D (m)	Input	Input	Input
Pb-214 (n=2)	1.61E+03	4.31E-04	Drift radius, R (m)	$2A/p^d$	$2A/p^d$	$2A/p^d$
Bi-214 (n=3)	1.19E+03	5.80E-04	Cross-section area, A (m <sup>2</sup> )	Input	Input	Input
			Ventilation flow rate, Q (m <sup>3</sup> /s)	Input	Input	Input
			Ventilation flow velocity, v (m/s)	Q/A	Q/A	Q/A
			Pressure drop, $\Delta P$ (mbar)	Input	Input	Input
			Deposition Velocity, $V_d$ (m/s)	Input	Input	Input
			Flux, F (pCi/m <sup>2</sup> /s)	Eq.26	Eq.26	Eq.26
			Inlet Node number 1 (Node 1)	Input	Input	Input
			Outlet Node number 2 (Node 2)	Input	Input	Input

NOTES: <sup>a</sup>Section 6.2.

<sup>b</sup>Equation numbers correspond to equations listed in Section 6.1.

<sup>c</sup>Section 6.2.1.

<sup>d</sup>p = perimeter is an input.

Table I-2 Description of Calculation Worksheet

Equations<sup>a</sup>

Segment	ID1	Node No.	Node 1										
Nuclide	$a_n$ (Eq.23)	$d_n$ (Eq.24)	$C_n(x_1)$ Input	n	$A_n$	$A_{n0}$	$A_{n1}$	$A_{n2}$	$A_{n3}$				
Rn-222	$a_0$	$d_0$	$C_0(x_1)$	n=0	Eq. 9	Eq.11							
Po-218	$a_1$	$d_1$	$C_1(x_1)$	n=1	Eq.10	Eq.12	Eq.13						
Pb-214	$a_2$	$d_2$	$C_2(x_1)$	n=2	Eq.14	Eq.15	Eq.16	Eq.17					
Bi-214	$a_3$	$d_3$	$C_3(x_1)$	n=3	Eq.18	Eq.19	Eq.20	Eq.21	Eq.22				
	Rn-222			Po-218			Pb-214			Bi-214			WL
Distance X(m)	$h=d_0 * X$	EXP(-h)	$C_0(X)$ (pCi/m <sup>3</sup> )	$h=d_1 * X$	EXP(-h)	$C_1(X)$ (pCi/m <sup>3</sup> )	$h=d_2 * X$	EXP(-h)	$C_2(X)$ (pCi/m <sup>3</sup> )	$h=d_3 * X$	EXP(-h)	$C_3(X)$ (pCi/m <sup>3</sup> )	WL(X1) Eq.25
0.1L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.2L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.3L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.4L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.5L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.6L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.7L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.8L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.9L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
Segment	ID2	Node No.	Node 1										
Nuclide	$a_n$ (Eq.23)	$d_n$ (Eq.24)	$C_n(x_1)$ Input	n	$A_n$	$A_{n0}$	$A_{n1}$	$A_{n2}$	$A_{n3}$				
Rn-222	$a_0$	$d_0$	$C_0(x_1)$	n=0	Eq.9	Eq.11							
Po-218	$a_1$	$d_1$	$C_1(x_1)$	n=1	Eq.10	Eq.12	Eq.13						
Pb-214	$a_2$	$d_2$	$C_2(x_1)$	n=2	Eq.14	Eq.15	Eq.16	Eq.17					
Bi-214	$a_3$	$d_3$	$C_3(x_1)$	n=3	Eq.18	Eq.19	Eq.20	Eq.21	Eq.22				
	Rn-222			Po-218			Pb-214			Bi-214			WL
Dist.(X)	$h=d_0 * X$	EXP(-h)	$C_0(X)$ (pCi/m <sup>3</sup> )	$h=d_1 * X$	EXP(-h)	$C_1(X)$ (pCi/m <sup>3</sup> )	$h=d_2 * X$	EXP(-h)	$C_2(X)$ (pCi/m <sup>3</sup> )	$h=d_3 * X$	EXP(-h)	$C_3(X)$ (pCi/m <sup>3</sup> )	WL(X1) Eq.25
0.1L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.2L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.3L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.4L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.5L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.6L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.7L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.8L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.9L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
Segment	ID3	Node No.	Node 1										
Nuclide	$a_n$ (Eq.23)	$d_n$ (Eq.24)	$C_n(x_1)$ Input	n	$A_n$	$A_{n0}$	$A_{n1}$	$A_{n2}$	$A_{n3}$				
Rn-222	$a_0$	$d_0$	$C_0(x_1)$	n=0	Eq.9	Eq.11							
Po-218	$a_1$	$d_1$	$C_1(x_1)$	n=1	Eq.10	Eq.12	Eq.13						
Pb-214	$a_2$	$d_2$	$C_2(x_1)$	n=2	Eq.14	Eq.15	Eq.16	Eq.17					
Bi-214	$a_3$	$d_3$	$C_3(x_1)$	n=3	Eq.18	Eq.19	Eq.20	Eq.21	Eq.22				
	Rn-222			Po-218			Pb-214			Bi-214			WL
Distance X(m)	$h=d_0 * X$	EXP(-h)	$C_0(X)$ (pCi/m <sup>3</sup> )	$h=d_1 * X$	EXP(-h)	$C_1(X)$ (pCi/m <sup>3</sup> )	$h=d_2 * X$	EXP(-h)	$C_2(X)$ (pCi/m <sup>3</sup> )	$h=d_3 * X$	EXP(-h)	$C_3(X)$ (pCi/m <sup>3</sup> )	WL(X1) Eq.25
0.1L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.2L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.3L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.4L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.5L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.6L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.7L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.8L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
0.9L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25
L	$d_0 * X$	EXP(-h)	Eq.5	$d_1 * X$	EXP(-h)	Eq.6	$d_2 * X$	EXP(-h)	Eq.7	$d_3 * X$	EXP(-h)	Eq.8	Eq.25

NOTES: <sup>a</sup>Equation numbers correspond to equations listed in Section 6.1.

**ATTACHMENT II. LISTING OF ELECTRONIC FILE IN CD CONTAINING RADON EXPOSURE CALCULATIONS**

The electronic file (Microsoft Excel workbook) of radon exposure calculations is provided on a compact disk (CD) as Attachment II. The worksheet file names and properties on the compact disk are listed in Table II-1.

Table II-1. Worksheet Names and Properties in the Attachment II Compact Disk

<b>Worksheet Name</b>	<b>Description</b>	<b>File Size (Bytes)</b>	<b>Date</b>	<b>Time</b>
LA	Concentration calculation Main and Calculation for Segments 1 to 120	1,297,408	10/28/2003	1:12:56 PM
LA1	Concentration Calculation for Segments 121 to 240	872,448	10/28/2003	1:13:40 PM
LA2	Concentration Calculation for Segments 241 to 360	877,568	10/28/2003	1:13:40 PM
LA3	Concentration Calculation for Segments 361 to 480	872,960	10/28/2003	1:14:23 PM
LA4	Concentration Calculation for Segments 481 to 629	364,032	10/28/2003	1:14:20 PM
Summary	Concentration Weighted Average Calculations	924,160	10/28/2003	1:14:20 PM
Ventilation Input	Input parameters	527,872	10/28/2003	1:14:20 PM

The above listed files are contained on a single CD-ROM as an attachment to this document.

**BSC**

# Engineering Change Notice

1. QA: NA  
2. Page 1 of 2

*Complete only applicable items.*

800-HYC-VU00-00300-000-00A-ECN1

3. Document Identifier: 800-HYC-VU00-00300-000-00A	4. Rev.: 00A	5. Title: Subsurface Radon Exposure Calculation	6. ECN: 1
7. Reason for Change: Editorial Change:  Page 39: Correct Section 8 Title from "REERENCES" to "REFERENCES", a typo.  This revised page is attached.			
8. Supersedes Change Document: <input type="checkbox"/> Yes    If, Yes, Change Doc.: _____ <input checked="" type="checkbox"/> No			
9. Change Impact:			
Inputs Changed: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Results Impacted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Assumptions Changed: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Design Impacted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
10. Description of Change: (Address any "Yes" answers) The editorial change described in block 7 has been verified as a typo and does not change the calculation input or impact the result.			
11. Originator: (Print/Sign/Date) YuChien Yuan  11/17/05			
Checker: (Print/Sign/Date) Norman Kahler  11/17/05			
Approved: (Print/Sign/Date) Dave Darling  11/17/05			

## 8. REFERENCES

10 CFR 20. Energy: Standards for Protection Against Radiation. Readily Available.

29 CFR 1910. Labor: Occupational Safety and Health Standards. Readily Available.

AP-SI.1Q, Rev. 5, ICN 2. *Software Management*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: DOC.20030902.0003.

AP-3.12Q, Rev. 2, ICN 1. *Design Calculations and Analyses*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: DOC.20030827.0013.

BSC (Bechtel SAIC Company) 2003a. *Ventilation Network Model Calculation*. 800-M0C-VU00-00100-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20030714.0001.

BSC 2003b. *Underground Layout Configuration*. 800-P0C-MGR0-00100-000-00E. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20031002.0007.

BSC 2003c. *Q-List*. TDR-MGR-RL-000005 REV 00. Las Vegas, Nevada: Bechtel SAIC Company. ACC: DOC.20030930.0002.

BSC 2003d. *Subsurface Radon Flux Calculation*. 800-HYC-VU00-00100-000-00A. Las Vegas, Nevada: Bechtel SAIC Company.

BSC (Bechtel SAIC Company) 2003e. *Pressure Distribution in the ESF for One and Two Fan Operation*. 800-M0C-VU00-00300-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20030716.0001.

BSC 2003f. *Subsurface Construction and Emplacement Ventilation*. 800-P0C-MGR0-00200-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20031013.0001.

CRWMS M&O 2000. *Subsurface Radon Calculations*. CAL-SSM-NU-000003 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20001220.0016.

DOE (U.S. Department of Energy) 2003. *Quality Assurance Requirements and Description*. DOE/RW-0333P, Rev. 13. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: DOC.20030422.0003.

Kocher, D.C. 1981. *Radioactive Decay Data Tables, A Handbook of Decay Data for Application to Radiation Dosimetry and Radiological Assessments*. DOE/TIC-11026. Washington, D.C.: U.S. Department of Energy. TIC: 228074.