

Complete only applicable items.

3. System Surface Nuclear Confinement HVAC System	4. Document Identifier 200-M8C-VCT0-00400-000-00C
5. Title RF Heating and Cooling Load Calculation (Tertiary Non-ITS) <span style="float: right;">ENG. 20071218.0014</span>	
6. Group Engineering/Mechanical/HVAC	
7. Document Status Designation <input type="checkbox"/> Preliminary <input checked="" type="checkbox"/> Committed <input type="checkbox"/> Confirmed <input type="checkbox"/> Cancelled/Superseded	

8. Notes/Comments  
 Affected pages: 8 to 12, 14, 18, 19, 22, 24 to 26, 28 to 30, 32, 33, 35 to 39, 41 to 44, 61, 64 to 66, 80 83, 84, 87, 91, 118 to 122, 124 to 128, 132, 135, 138 to 144, 162 to 168, 175 to 177.

Attachments	Total Number of Pages
Attachments 1 through 9 (See Section 5.0 List of Attachments)	40

RECORD OF REVISIONS							
9. No.	10. Reason For Revision	11. Total # of Pgs.	12. Last Pg. #	13. Originator (Print/Sign/Date)	14. Checker (Print/Sign/Date)	15. EGS (Print/Sign/Date)	16. Approved/Accepted (Print/Sign/Date)
00A	Issued for LA	179	179	Ricardo Abraham	Fred Favis	Tracy Johnson	Hadi Jalali
00B	Revised ventilation airflow values of number of rooms to clarify sources of the infiltration and/or cascade air and clarify temperature entries.	179	179	Monico C. Pingul, Jr.	Orlando T. Asuncion	Tracy Johnson	Hadi Jalali
00C	Revised for the latest General Arrangement drawings and update of HVAC, Process, Mech. Handling and Electrical equipment.	177	177	Elpidio S. Castroverde <i>[Signature]</i> 12/18/07	Ricardo Abraham. <i>[Signature]</i> 12/18/07	Tracy Johnson <i>[Signature]</i> 12/18/07	<i>[Signature]</i> Hadi Jalali O.T. Asuncion <i>[Signature]</i> 12/18/07

**DISCLAIMER**

The calculations contained in this document were developed by Bechtel SAIC Company, LLC (BSC) and are intended solely for the use of BSC in its work for the Yucca Mountain Project.

## CONTENTS

	Page
ACRONYMS AND ABBREVIATIONS .....	7
1. PURPOSE .....	8
2. REFERENCES .....	9
2.1 PROCEDURES/DIRECTIVES .....	9
2.2 DESIGN INPUTS .....	9
2.3 DESIGN CONSTRAINTS .....	12
2.4 DESIGN OUTPUTS .....	12
3. ASSUMPTIONS .....	13
3.1 ASSUMPTIONS REQUIRING VERIFICATION .....	13
3.2 ASSUMPTIONS NOT REQUIRING VERIFICATION .....	19
4. METHODOLOGY .....	22
4.1 QUALITY ASSURANCE .....	22
4.2 USE OF SOFTWARE .....	22
4.3 METHODOLOGY .....	22
5. LIST OF ATTACHMENTS .....	24
6. BODY OF CALCULATION .....	25
6.1 ROOM-BY-ROOM COOLING AND HEATING LOADS .....	25
6.2 SUBSYSTEM AIRFLOW RATES .....	34
6.3 COOLING AND HEATING COIL LOADS .....	40
7. RESULTS AND CONCLUSIONS .....	43
APPENDIX A: ROOM LOAD INFORMATION SHEETS AND U-VALUES .....	45
APPENDIX B: ASHRAE TABLE VALUES FOR CLTD AND CORRECTION TABLES FOR LATITUDE AND MONTH .....	103
APPENDIX C: COOLING/HEATING LOAD EQUATIONS .....	107
APPENDIX D: PSYCHROMETRIC CALCULATION EQUATIONS .....	111
APPENDIX E: ROOM EQUIPMENT HEAT GAIN LIST .....	117
APPENDIX F: CALCULATED ROOF AND WALL COOLING LOADS .....	129
APPENDIX G: CALCULATION OF THERMODYNAMIC PROPERTIES OF MOIST AIR .....	135

APPENDIX H: INFILTRATION AIR COOLING LOAD CALCULATION (ROOM-BY-ROOM) .....	136
ATTACHMENT 1: EMAIL REGARDING WASTE PACKAGES AND CANISTERS HEAT GAIN INFORMATION.....	138
ATTACHMENT 2: E-MAIL REGARDING RF ELECTRICAL EQUIPMENT HEAT GAIN INFORMATION.....	140
ATTACHMENT 3: E-MAIL REGARDING ENVIRONMENTAL, SAFETY & HEALTH EQUIPMENT HEAT GAIN INFORMATION.....	145
ATTACHMENT 4: E-MAIL REGARDING INSTRUMENTATION AND CONTROLS EQUIPMENT HEAT GAIN INFORMATION.....	157
ATTACHMENT 5: HVAC AND MECHANICAL PROCESS EQUIPMENT LIST .....	161
ATTACHMENT 6: E-MAIL REGARDING MECHANICAL HANDLING GROUP EQUIPMENT HEAT GAIN INFORMATION.....	166
ATTACHMENT 7: E-MAIL REGARDING THE NUMBER OF OCCUPANTS IN THE RF BUILDING. ....	169
ATTACHMENT 8: SECOND E-MAIL REGARDING MECHANICAL HANDLING GROUP EQUIPMENT HEAT GAIN INFORMATION .....	172
ATTACHMENT 9: E-MAIL REGARDING MECHANICAL HANDLING EQUIPMENT HEAT GAIN DIVERSITY FACTOR.....	175

**TABLES**

	<b>Page</b>
Table 1. Occupancy Numbers.....	17
Table 2. Indoor Design Temperatures .....	26
Table 3. Cooling Load Summary.....	28
Table 4. Heating Load Summary.....	32
Table 5. Space Airflow Rates .....	35
Table 6. Subsystem Airflow Rates.....	39
Table 7. Subsystem Total Cooling Loads.....	41
Table 8. Subsystem Total Heating Loads .....	42
Table 9. Summary of Subsystem Airflow Rates, Cooling Loads, and Heating Loads.....	43
Table 10. Summary Exhaust Airflow Rate.....	44
Table A-1. Roof Type 12: 1'-6" Thick Concrete, with R-30 Insulation .....	99
Table A-2. Roof Type 1: Metal Roofing.....	99
Table A-3. Wall No. 1: 4'-0" Thick Concrete, no insulation .....	100
Table A-4. Wall No. 2: Metal Wall.....	100
Table A-5. Wall No. 3: 2'-0" Thick Concrete, no insulation .....	100
Table A-6. Partition No. 1: 4'- 0" Thick Concrete, no insulation .....	101
Table A-7. Partition No. 2: Gypsum Board, One-Hour Fire Rated .....	101
Table A-8. Partition No. 3: 2'- 0" Thick Concrete, no insulation .....	101
Table A-9. Concrete Floor (2nd Floor): 1'- 6" Thick.....	102
Table A-10. Concrete Floor (2nd Floor): 1'- 6" Thick.....	102
Table A-11. Door: Metal Roll-up.....	102
Table B-1. Unadjusted CLTD Values and CLF Values (°F).....	105
Table B-2. CLTD Correction For Latitude and Month Applied to Walls and Roofs (°F) .	106
Table B-3. Monthly Outdoor Design Temperatures .....	106
Table C-1. Cooling Load Equations .....	107
Table C-2. Heating Load Equations.....	109
Table C-3. Infiltration and Ventilation Cooling and Heating Load Equations.....	110
Table E-1. Equipment Heat Gain List .....	118

Table F-1.	Room-by-Room Calculated Roof Cooling Loads .....	130
Table F-2.	Room-by-Room Calculated Wall Cooling Loads.....	132
Table G-1.	Thermodynamic Properties of Moist Air.....	135
Table H-1.	Infiltration Air Cooling Load.....	136

**ACRONYMS AND ABBREVIATIONS**

ACH	air changes per hour
AHU	air handling unit
ANSI	American National Standards Institute
ASHRAE	American Society for Heating, Refrigeration and Air Conditioning Engineers
BSC	Bechtel SAIC Company, LLC
Btu/h	British thermal unit per hour
CLF	cooling load factor
CLTD	cooling load temperature difference (or differential)
DIRS	Document Input Reference System
DOE	U.S. Department of Energy
HVAC	heating, ventilating, and air conditioning
ITS	important to safety
RF	Receipt Facility
WP	Waste Package

## 1. PURPOSE

The purpose of this calculation is to determine the following quantities for heating, ventilating, and air conditioning (HVAC) subsystems serving the non-ITS tertiary confinement areas of the Receipt Facility (RF):

- Room-by-room cooling and heating loads
- Room airflow rates
- Subsystem airflow rates
- Required outdoor air rates
- Total cooling load per subsystem
- Total heating load per subsystem

The heating and cooling load for the non-confinement (non-ITS) areas of the RF is determined in a separate calculation, 200-M8C-VNI0-00100-000-00B (Reference 2.2.24). The ITS Electrical and Battery Rooms (tertiary confinement areas) cooling and heating load is determined in calculation 200-M8C-VCT0-00700-000-00B (Reference 2.2.27). The ITS confinement breach areas exhaust requirement is determined in calculation 200-M8C-VCT0-00100-000-00A (Reference 2.2.21).

Revision C of this calculation relates the HVAC Subsystems (i.e. AHU-D, EXH-D) to HVAC equipment numbers consistent with References 2.2.29 through Reference 2.2.36. All HVAC equipment numbers are prefixed by "200-VCT0" unless otherwise noted.



## 2. REFERENCES

### 2.1 PROCEDURES/DIRECTIVES

- 2.1.1 EG-PRO-3DP-G04B-00037, Rev. 10, *Calculations and Analyses*. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071018.0001.

### 2.2 DESIGN INPUTS

- 2.2.1 BSC (Bechtel SAIC Company) 2007. *Project Design Criteria Document*. 000-3DR-MGR0-00100-000-007. Las Vegas, Nevada: Bechtel SAIC Company. ACCs: ENG.20071016.0005; ENG.20071108.0001.
- 2.2.2 ANSI/ASHRAE 62.1-2004. 2004. *Ventilation for Acceptable Indoor Air Quality*. Atlanta, Georgia: American Society of Heating, Refrigerating and Air-Conditioning Engineers. TIC: 256875. ISSN: 1041-2336.
- 2.2.3 Rudoy, W. and Cuba, J. F. 1979. *Cooling and Heating Load Calculation Manual*. ASHRAE GRP 158. New York, New York: American Society of Heating, Refrigerating, and Air Conditioning Engineers. TIC: 256896.
- 2.2.4 ASHRAE (American Society of Heating, Refrigerating & Air-Conditioning Engineers) 2005. *2005 ASHRAE® Handbook, Fundamentals*. Inch-Pound Edition. Atlanta, Georgia: American Society of Heating, Refrigerating and Air Conditioning Engineers. TIC: 257499. ISBN: 1-931862-70-2.
- 2.2.5 ASHRAE (American Society of Heating, Refrigerating & Air-Conditioning Engineers) 2001. *2001 ASHRAE Handbook, Fundamentals*. Inch-Pound Edition. Atlanta, Georgia: American Society of Heating, Refrigerating and Air-Conditioning Engineers. TIC: 249910. ISBN: 1-883413-87-7.
- 2.2.6 ANSI/ASHRAE/IESNA Standard 90.1-2004. *2004 Energy Standard for Buildings Except Low-Rise Residential Buildings*. I-P Edition. Atlanta, Georgia: American Society of Heating, Refrigerating and Air-Conditioning Engineers. TIC: 257067. ISSN: 1041-2336.
- 2.2.7 ASHRAE (American Society of Heating, Refrigerating & Air-Conditioning Engineers) 2004. *2004 ASHRAE® Handbook, Heating, Ventilating, and Air-Conditioning Systems and Equipment*. Inch-Pound Edition. Atlanta, Georgia: American Society of Heating, Refrigerating and Air-Conditioning Engineers. TIC: 256641. ISBN: 1-931862-47-8.
- 2.2.8 ASHRAE (American Society of Heating, Refrigerating and Air-Conditioning Engineer) 2007. *2007 ASHRAE® Handbook, Heating, Ventilating, and Air-Conditioning Applications*. Inch-Pound Edition. Atlanta, Georgia: American Society of Heating, Refrigerating and Air-Conditioning Engineers. ISBN: 987-1-933742-14-4.
- 2.2.9 Not Used

- 2.2.10 BSC (Bechtel SAIC Company) 2007. *Basis of Design for the TAD Canister-Based Repository Design Concept*. 000-3DR-MGR0-00300-000-001. Las Vegas, Nevada: Bechtel SAIC Company. ACCs: ENG.20071002.0042; ENG.20071026.0033; ENG.20071108.0002; ENG.20071109.0001; ENG.20071120.0023; ENG.20071126.0049.
- 2.2.11 Not Used
- 2.2.12 BSC (Bechtel SAIC Company) 2007. *RF Ventilation Confinement Zoning Analysis*. 200-M1A-VC00-00100-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20070710.0002.
- 2.2.13 BSC (Bechtel SAIC Company) 2007. *Receipt Facility General Arrangement Legend and General Notes*. 200-P10-RF00-00101-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071212.0010.
- 2.2.14 BSC (Bechtel SAIC Company) 2007. *Receipt Facility General Arrangement Ground Floor Plan*. 200-P10-RF00-00102-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071212.0011.
- 2.2.15 BSC (Bechtel SAIC Company) 2007. *Receipt Facility General Arrangement Second Floor Plan*. 200-P10-RF00-00103-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071212.0012.
- 2.2.16 BSC (Bechtel SAIC Company) 2007. *Receipt Facility General Arrangement Third Floor Plan*. 200-P10-RF00-00104-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071212.0013.
- 2.2.17 BSC (Bechtel SAIC Company) 2007. *Receipt Facility General Arrangement Roof Plan*. 200-P10-RF00-00105-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071212.0014.
- 2.2.18 BSC (Bechtel SAIC Company) 2007. *Receipt Facility General Arrangement Sections A and B*. 200-P10-RF00-00106-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071212.0015.
- 2.2.19 BSC (Bechtel SAIC Company) 2007. *Receipt Facility General Arrangement Sections C and D*. 200-P10-RF00-00107-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071212.0016.
- 2.2.20 BSC (Bechtel SAIC Company) 2007. *Receipt Facility General Arrangement Sections E and F*. 200-P10-RF00-00108-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071212.0017.
- 2.2.21 BSC (Bechtel SAIC Company) 2007. *RF Building Confinement Areas Air Leakage Calculation*. 200-M8C-VCT0-00100-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20070509.0021.

- 2.2.22 ANSI/ASHRAE Standard 55 -2004. 2004. *Thermal Environmental Conditions for Human Occupancy*. Atlanta, Georgia: American Society of Heating, Refrigerating and Air-Conditioning Engineers. TIC: 257066. ISSN: 1041-2336.
- 2.2.23 Not Used
- 2.2.24 BSC (Bechtel SAIC Company) 2007. *RF Heating and Cooling Load Calculation (Non Confinement)*. 200-M8C-VNI0-00100-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071006.0011.
- 2.2.25 White, W.N.; Pahwa, A.; and Cruz, C. 2004. "Heat Loss From Electrical and Control Equipment in Industrial Plants: Part II-Results and Comparisons." *ASHRAE Transactions, [ASHRAE Annual Meeting Technical Program, Nashville, Tennessee, June 27-30, 2004]. NA-04-9-2b*. Atlanta, Georgia: American Society of Heating, Refrigerating and Air-Conditioning Engineers. TIC: 257590. ISSN: 0001-2505.
- 2.2.26 BSC (Bechtel SAIC Company) 2007. *Discipline Design Guide and Standards For Surface Facilities HVAC Systems*. 000-3DG-GEHV-00100-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20070514.0007.
- 2.2.27 BSC (Bechtel SAIC Company) 2007. *RF Combined Cooling/Heating Load, Equipment Sizing and Pressure Drop Calculation (ITS)*. 200-M8C-VCT0-00700-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20070927.0001.
- 2.2.28 Ingersoll Rand 2007. *Nirvana Cycling Refrigerated Dryer: Models NVC 2000A and NVC2000W*. Revision 3, July 20, 2007. Davidson, North Carolina: Ingersoll Rand. TIC: 259808.
- 2.2.29 BSC (Bechtel SAIC Company) 2007. *RF ITS Confinement Areas HEPA Exhaust System-Train A Ventilation & Instrumentation Diagram*. 200-M80-VCT0-00101-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071204.0017.
- 2.2.30 BSC (Bechtel SAIC Company) 2007. *RF ITS Confinement Areas HEPA Exhaust System-Train B Ventilation & Instrumentation Diagram*. 200-M80-VCT0-00102-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071204.0018.
- 2.2.31 BSC (Bechtel SAIC Company) 2007. *RF ITS Confinement Areas HVAC Supply System Ventilation & Instrumentation Diagram*. 200-M80-VCT0-00103-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071002.0025.
- 2.2.32 BSC (Bechtel SAIC Company) 2007. *RF Confinement South Areas HVAC Supply System Ventilation & Instrumentation Diagram*. 200-M80-VCT0-00201-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071010.0005.
- 2.2.33 BSC (Bechtel SAIC Company) 2007. *RF Confinement Non-ITS HEPA Exhaust System Ventilation & Instrumentation Diagram*. 200-M80-VCT0-00205-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071010.0009.

- 2.2.34 BSC (Bechtel SAIC Company) 2007. *RF Confinement Second Floor North Areas HVAC Supply System Ventilation & Instrumentation Diagram*. 200-M80-VCT0-00206-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071010.0010.
- 2.2.35 BSC (Bechtel SAIC Company) 2007. *RF Confinement ITS Battery Room Exhaust System-Train A Ventilation & Instrumentation Diagram*. 200-M80-VCT0-00302-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071201.0004.
- 2.2.36 BSC (Bechtel SAIC Company) 2007. *RF Confinement ITS Battery Room Exhaust System-Train B Ventilation & Instrumentation Diagram*. 200-M80-VCT0-00304-000-00B. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20071201.0005.

### 2.3 DESIGN CONSTRAINTS

None

### 2.4 DESIGN OUTPUTS

- 2.4.1 *RF Equipment Sizing and Selection Calculation (Tertiary Non ITS)*. 200-MC8-VCT0-00200-000.
- 2.4.2 *Receipt Facility Chilled Water System Sizing*. 200-M6C-PSC0-00100-000.
- 2.4.3 *Receipt Facility Hot Water System Sizing*. 200-M6C-PSH0-00100-000.
- 2.4.4 *Receipt Facility Composite Vent Flow Diagram Tertiary Confinement Non-ITS HVAC Supply Sys & ITS Exhaust*. 200-M50-VCT0-00101-000.
- 2.4.5 *Receipt Facility Composite Vent Flow Diagram Tertiary Confinement Non-ITS HVAC Supply & Exhaust System*. 200-M50-VCT0-00201-000.
- 2.4.6 *RF Combined Cooling/Heating Load, Equipment Sizing and Pressure Drop Calculation (ITS)*. 200-M8C-VCT0-00700-000-00A. Las Vegas, Nevada: Bechtel SAIC Company. ACC: ENG.20070702.0017
- 2.4.7 *RF Air Pressure Drop Calculation (Tertiary Non ITS)*. 200-M8C-VCT0-00300-000

### 3. ASSUMPTIONS

#### 3.1 ASSUMPTIONS REQUIRING VERIFICATION

##### 3.1.1 General Arrangement Drawings

It is assumed that the room name designations, dimensions, and constructions are as shown in the Receipt Facility General Arrangement Drawings (References 2.2.13 through 2.2.20).

**Rationale**—The RF General Arrangement Drawings are presently in the preliminary design stage; hence, they are a preliminary source of information for determining the thermal heat loads of the individual rooms in the HVAC system. When the plant design drawings and architectural drawings are issued for construction, the room designations, room dimensions, wall and roof construction, and material information will be verified.

##### 3.1.2 Lighting

The lighting type in rooms with a ceiling height of 14 ft or lower and all first, second and third floor corridors is assumed to be fluorescent, with two lamps per fixture, a lighting density of 2 W/sq. ft, and a ballast factor of 1.2. The lighting for all of the remaining spaces is assumed to be High Bay, Incandescent-type, with a lighting density of 2 W/sq. ft.

**Rationale**—The lighting fixture types have not been specified at this stage in the design. A lighting density of 2 W/sq. ft is a conservative estimate, based on the range of lighting densities allowed by the ANSI/ASHRAE/IESNA Standard 90.1-2004, *2004 Energy Standard for Buildings Except Low-Rise Residential Buildings* (Reference 2.2.6, Tables 9.5.1 and 9.6.1). The assumption of two fluorescent lamps per fixture, according to the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, Table 4.1, p. 4.1), indicates an average ballast factor of 1.2 for use in the lighting portion of the load calculation, for rooms with a ceiling height of 14 ft or lower and all first, second and third floor corridors. The types of fixtures and lighting density will be verified with actual design lighting densities, as the design progresses to completion.

##### 3.1.3 Factor of Safety

It is assumed that the 20% factor of safety, added to each room's cooling load, is adequate to include heat gains in the supply ductwork and to include any uncertainties in equipment heat gain.

**Rationale**—Various heat gain quantities are not firmed-up at this time. Adding a factor of safety for any unverified cooling loads is common engineering practice. The factor of safety will be checked and adjusted as the design progresses to completion.

##### 3.1.4 Equipment Heat Gain List

It is assumed that the equipment heat gain estimates used in Appendix E represent the best available information at this stage of the design.

**Rationale**—The design of the RF is still in a preliminary stage, and accurate configurations and sizes of heat producing equipment are not known. However, a combination of preliminary inputs from interdepartmental disciplines yields conservative estimates for the RF room heat loads. As the design progresses, Appendix E will be updated.

### 3.1.5 Air Temperature Leaving the Cooling Coil

It is assumed that the air temperature leaving the cooling coil is 51°F dry bulb and 46.36°F wet bulb.

**Rationale**—The actual air temperature leaving the cooling coil can only be determined upon selection of a cooling coil. In this calculation a leaving dry bulb temperature of 51°F is assumed, because a normal cooling coil design has a 9°F approach. A typical entering chilled water temperature is 42°F, the 51°F dry bulb leaving air temperature then meets the approach criteria. Per Assumption 3.1.11, the humidity ratio of the indoor air is assumed to be approximately 0.00645 lb moisture/lb of dry air. With this humidity ratio the cooling coil process is expected to be a sensible only process. Consequently, the leaving air humidity ratio will equal 0.00645 lb moisture/lb of dry air and this equates to a wet bulb temperature of 46.36°F.

### 3.1.6 Supply Fan Heat Gain

It is assumed that the maximum temperature rise of the supply air as it passes through the supply fan and motor is 6°F for all subsystems.

**Rationale**—From *2004 ASHRAE HVAC Systems and Equipment* (Reference 2.2.7, Chapter 18, p. 18.6) for low pressure rises, the following equation is used to calculate the temperature rise across a fan:

$$\Delta T = \frac{\Delta P \cdot C_p}{\rho \cdot c_p \cdot J \cdot \eta} \quad (\text{Eq. 1})$$

where

- $\Delta T$  = temperature rise across fan, °F
- $\Delta P$  = pressure rise across fan, in. w.g.
- $C_p$  = conversion factor = 5.193 lbf/ft<sup>2</sup> in. w.g.
- $\rho$  = density of air, lbm/ft<sup>3</sup>
- $c_p$  = specific heat = 0.24 Btu/lbm °F
- $J$  = mechanical equivalent of heat = 778.2 ft lbf/Btu
- $\eta$  = efficiency (combined efficiencies of motor and fan).

A pressure rise across the fan of 9.5 in. w.g. is a reasonable total pressure drop for the RF HVAC systems, especially the units containing HEPA filters. The density of the air at the temperature entering the supply fans, 102°F (highest expected air temperature), is approximately 0.062 lbm/ft<sup>3</sup>. A conservative efficiency for a centrifugal fan is 0.84. A reasonable motor efficiency for motors in the range of 75 hp to 125 hp is 0.90 (Reference 2.2.4, Table 3A p. 30.7). These values give a temperature rise of 5.64°F. Rounding up to  $\Delta T = 6^\circ\text{F}$  gives a conservative estimate for the

temperature rise across the supply fan and motor. This result derives from a subsystem with the worst pressure rise across fan. For other subsystems with lower pressure rise across fan, it will be re-evaluated in the detailed design.

### 3.1.7 Room Ventilation Confinement Zoning

It is assumed that the ventilation confinement zoning classifications, for the layouts given in the *RF Ventilation Confinement Zoning Analysis* (Reference 2.2.12), are suitable for use and are the best available information at this stage of the design.

**Rationale**—The *RF Ventilation Confinement Zoning Analysis* (Reference 2.2.12) is a committed calculation and determines the ventilation confinement zoning for the rooms in the RF. When that calculation is confirmed, the ventilation confinement zoning will be verified.

### 3.1.8 Room Infiltration Rates

It is assumed that the infiltration rates presented in the *RF Building Confinement Areas Air Leakage Calculation* (Reference 2.2.21) are suitable for use and represents the best available information at this stage of the design. Note that Rooms 1006 and 1007A have been changed to Rooms 1212 through 1224 and 1205 as shown on Receipt Facility General Arrangement Drawings (Reference 2.2.13 and 2.2.14).

**Rationale**—This cooling and heating load calculation uses a building layout that has been updated from the layout assumed in the *RF Building Confinement Areas Air Leakage Calculation* (Reference 2.2.21). Consequently, some rooms have minor changes, but these changes have a negligible impact. If the infiltration airflow rates calculated in the next revision of the *RF Building Confinement Areas Air Leakage Calculation* change then the infiltration rates will be verified and updated accordingly. There are non confinement room infiltrations that are accounted for in *RF Heating and Cooling Load Calculation (Non Confinement)* (Reference 2.2.24); however no credit is taken for these rooms that are adjacent to the Tertiary Confinement Non-ITS areas. These rooms are considered non-existent and the Tertiary Confinement Non ITS walls are assumed to face the outside wind conditions which results in higher delta pressure and hence higher infiltration.

### 3.1.9 U-Values for Metal Building

It is assumed that the U-Values for the metal building roofs and walls are as follows:

$$U_{\text{ROOF}} = 0.065 \text{ Btu/h-ft}^2\text{-}^\circ\text{F} \text{ and } U_{\text{WALL}} = 0.113 \text{ Btu/h-ft}^2\text{-}^\circ\text{F}$$

**Rationale**—The design of the building envelope associated with this calculation is in the preliminary stage. These values are the best available information at this time, which are consistent with Table 5.5-5 and Figure B-1 of ASHRAE Standard 90.1-2004, *2004 Energy Standard for Buildings Except Low-Rise Residential Buildings* (Reference 2.2.6). As the design progresses to the detailed design phase, the U-values will be verified and updated appropriately.

### 3.1.10 Cascade Airflow

It is assumed that the cascade airflow “in” and “out” quantities presented in Table 5, Space Airflow Rates, are suitable for use.

**Rationale**–The determination of cascade airflows is an integral part of the design process and is determined based on room layout and room air balance. The cascaded quantities are ideally developed during the conceptual stage of the Ventilation Flow Diagrams but these diagrams are not currently available. The values presented in Table 5 will be updated in future revisions using issued ventilation flow diagrams, as applicable.

### 3.1.11 Humidity Ratio of Indoor Air

It is assumed that the humidity ratio of all air inside the facility for summer design will equal the humidity ratio of the design outdoor air condition 102°F dry bulb/65°F wet bulb which equals approximately 0.00645 lb moisture/lb of dry air.

**Rationale**–This is a reasonable assumption because the expected latent loads in the RF are very small compared to the amount of sensible loads expected. Due to infiltration and ventilation, air entering the building on a continual basis and an expectation that all cooling coil processes will be sensible cooling only, the indoor air should reach, for design purposes, a steady state humidity level equal to the design outdoor conditions.

### 3.1.12 Large Interior and Exterior Metal Doors

It is assumed that the large interior and exterior metal doors (roll-up, etc.) have a U-Value of 1.15 Btu/h-ft<sup>2</sup>-°F and the door dimensions are based on the committed calculation, *RF Building Confinement Areas Air Leakage Calculation* (Reference 2.2.21).

**Rationale**–The door dimensions are not indicated on the RF Layouts and Sections (References 2.2.13 through 2.2.20), consequently the door dimensions used in the *RF Building Confinement Areas Air Leakage Calculation* (Reference 2.2.21), are used in this calculation. Also, the large interior and exterior metal doors have not been specified at this time, therefore the U-Value of 1.15 Btu/h ft<sup>2</sup> °F is taken from the Annunciated Steel Door entry in Table 6 on p. 31.11 of *2005 ASHRAE Fundamentals* (Reference 2.2.4). The number is the most conservative in the Table for Sectional Overhead Doors. The U-Value and dimensions of the large interior and exterior metal doors will be verified in detailed design.

### 3.1.13 Corridor Tunnel Construction

It is assumed that all corridors on the first, second and third level, inside the concrete portion of the structure, are of tunnel construction and have a ceiling height of 14 ft.

**Rationale**–The RF General Arrangement and Sections (References 2.2.13 through 2.2.20) show some of the corridors with a tunnel construction, but not all corridors are visible in the building sections. The current Plant Design computer model shows tunnel construction for the first and second level corridors. Because the Plant Design computer model cannot be referenced, the



construction of the corridors must be assumed. The height of the top of the tunnel ceiling will be verified when the General Arrangement Drawings are issued.

### 3.1.14 Temperature of External Stairwells and Fire Water Riser Valve Rooms

It is assumed that the internal temperatures of all externally located stairwells and all Fire Water Riser Valve Rooms are equal to the outdoor ambient temperature and walls adjacent to the exterior stairwells and fire water riser valve rooms can be treated as walls with sunlit facing exteriors.

**Rationale**—The external stairwells and fire water riser valve rooms are not conditioned spaces at this point in the design of the RF. Their internal temperatures will rise and fall with the outdoor temperature. Consequently, a more conservative load calculation can be achieved if these small areas are assumed to be non-existent. This assumption will be verified during the detailed design phase of the RF.

### 3.1.15 Occupancy Numbers

It is assumed that the number of people in the occupied areas of the RF Tertiary Non-ITS areas is as indicated in Table 1.

Table 1. Occupancy Numbers

Room No.	Room Name	No. of People
1002	Lid Bolting Room	4
1017	Cask Preparation Room	6
1017A	Cask Preparation Annex	2
1212 to 1224	Support Areas	3
Total		15

**Rationale**—The number of people is estimated based on conversations with the Operations group. The preliminary numbers have been confirmed in an e-mail shown in Attachment 7. These occupancy numbers will be verified as the design progresses.

### 3.1.16 Not Used

### 3.1.17 Not Used

### 3.1.18 Equipment Heat Gain in R001, Freight Elevator Machine Room

It is assumed that the equipment heat gain in Room R001, Freight Elevator Machine Room, is equal to 1000 Watts or 3412 Btu/h.

**Rationale**—The equipment in Room R001 has not yet been specified. A heat gain of 1000 W or 3412 Btu/h is assigned to this room as a placeholder for future equipment. During detailed design, the actual equipment heat gain will be verified.

### 3.1.19 Outdoor Ventilation Air

It is assumed that all *ASHRAE Standard 62.1* (Reference 2.2.2) outdoor air requirements are going to be adequately handled with infiltration air and air-handling unit make-up air to offset exhaust air requirements.

**Rationale**—The fundamental design principle for the tertiary confinement area of RF is the use of infiltration and engineered openings to cascade air throughout the building in order to maintain negative pressures between tertiary confinement areas and non-confinement areas. Because the design is in a very early stage, the number of people expected to occupy the building are relatively low (See Assumption 3.1.15), and infiltration and exhaust make-up is the fundamental design principle for maintaining confinement. It is reasonable to assume that the amount of outside air entering the spaces through infiltration and make-up will exceed the amount required by *ASHRAE Standard 62.1* (Reference 2.2.2). During detailed design, the subsystems that serve areas containing people can be analyzed in more depth.

### 3.1.20 Support Areas

It is assumed that Rooms 1212 through 1224 can be modeled as one large space (room) for this load calculation. This is also the case for Rooms 1221 and 1205.

**Rationale**—Grouping the rooms together as one Support Area allows for a simplified approach to calculating the loads and airflows for the overall spaces. The impact on the overall calculation results would only be to the distribution of air and not to the total cooling and heating load required for the space, since all of the individual rooms would be modeled at the same temperature. As the individual rooms are better defined in detailed design, the individual room loads will be calculated.

### 3.1.21 Temperature of Personnel Vestibule Room 1021B

It is assumed that the Personnel Vestibule, Room 1021B, is equal to the outdoor ambient temperature and the walls adjacent to this room can be treated as walls with sunlit facing exteriors.

**Rationale**—The Personnel Vestibule, Room 1021B, is not accounted for in the RF heating and cooling load calculation for the non-confinement areas (Reference 2.2.24), therefore the internal temperature will rise and fall with the outdoor temperature. Thus, the most conservative approach for this calculation is to consider the room as non-existent. This assumption will be verified during the detailed design phase of the RF.

### 3.1.22 HVAC and Mechanical Process Equipment Sizes

The power ratings for the HVAC and mechanical process equipment are assumed as listed in Appendix E, Room Equipment Heat Gain List.

**Rationale**—The equipment list in Attachment 5 contains all of the HVAC and mechanical process equipment necessary to run the RF. The equipment motor horsepower shown in this list were based on the calculated horsepower rating from various Equipment Sizing and Selection

Calculation and shown in V&ID's as referred in Attachment 5. The actual power ratings for the HVAC and mechanical process equipment will be verified during the detailed design phase of the RF.

### **3.1.23 Refrigerated Dryer Package Heat Rejection**

It is assumed that the heat rejection from GP Dryer Package is 120,596 Btu/h based on Vendor's Information for model no. NVC2000A. (Reference 2.2.28).

**Rationale**—The design of the GP Dryer Package located in Room 2012 is in the preliminary stage. The information is representative of similar packages throughout the compressor industry. As the design progresses to the detailed design phase, heat rejection from this equipment will be verified and updated appropriately.

### **3.1.24 Miscellaneous Equipment Heat Gain in Rooms 1002, 1017, 2007 and 2012.**

It is assumed that there are miscellaneous equipment heat gain and future additional heat gain shown in Appendix E that are not known at this time in Rooms 1002, 1017, 2007 and 2012.

**Rationale**—In the revision of this calculation from the previous version, it is not necessary to remove conservative equipment heat gains at this time. Instead, the extra heat gain is categorized as a miscellaneous load. As the design progresses to the detailed design phase, it will be verified and updated.

## **3.2 ASSUMPTIONS NOT REQUIRING VERIFICATION**

### **3.2.1 Hours of Operation**

It is assumed that the RF will operate 7 days a week, 24 hours a day.

**Rationale**—It is expected that 7 days a week, 24 hours a day operation will be necessary to meet throughput requirements. But, whether it is necessary or not, an assumption of continuous operation will provide the most conservative bounding results for this calculation.

### **3.2.2 Outside Air Film Resistance for Calculating U-Values**

The outside air film resistance during summer will be used in this analysis (Reference 2.2.4, Table 1, p. 25.2).

**Rationale**—Calculation of the airflow rate is based on calculated summer heat loads. Higher U-Values translate into higher calculated heat loads, therefore the use of a higher U-Value for the outside air film resistance gives a maximum bounding value.

### **3.2.3 Wall and Roof Color**

A dark colored surface is assumed in determining the cooling load from sunlit walls and flat roofs, in order to provide an upper bounding solar radiation absorption component to the cooling load temperature differences generated.

**Rationale**—The assumption of a dark colored surface for the roof and walls in this calculation allows the use of a CLTD correction factor of 1.0; that maximizes the adjusted CLTD values. Because the color of the walls and roofs are not known at this time, assuming a dark color results in the most conservative upper bounding CLTD values.

### 3.2.4 F-factor for Slab on Grade

The F-factor for calculating heating loads from slab-on-grade floors is  $F = 0.73$ .

**Rationale**—This value is the maximum value allowed by Table 5.5-5 of the *2004 Energy Standard for Buildings Except Low-Rise Residential Buildings* (Reference 2.2.6, p. 27). Using the maximum value allowed for calculating heating loads provides an adequate margin of safety.

### 3.2.5 Lighting Load to Space

For the calculation of cooling loads, it is assumed that 100% of the lighting load is transmitted to the space.

**Rationale**—For conservatism, assuming that 100% of the lighting load is transmitted to the space will provide a maximum, upper bounding, heat gain contribution from the lighting to the space.

### 3.2.6 Cooling Load Factor for Lighting

The lighting Cooling Load Factor (CLF) for every hour of the load calculation is equal to 1.0.

**Rationale**—Per Assumption 3.2.1, the RF is assumed to operate 7 days a week, 24 hours a day. Section 4.1 of the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3) states that a CLF value of 1.0 should be used when lights are on more than 16 hours a day.

### 3.2.7 Cooling Load Factor for People

The person CLF for every hour of the load calculation is equal to 1.0.

**Rationale**—Per Assumption 3.2.1, the RF is assumed to operate 7 days a week, 24 hours a day. It is noted from Table 4.6 of the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3), that the sensible heat cooling load factors for people would approach a value of 1.0 for people in the space 24 hours a day, since a CLF of 0.97 is listed in the table for people in the space for a total of 18 hours.

### 3.2.8 Cooling Load Factor for Equipment

The equipment CLF for every hour of the load calculation is equal to 1.0.

**Rationale**—Per Assumption 3.2.1, the RF is assumed to operate 7 days a week, 24 hours a day. It is noted from Table 4.11 of the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3), that the cooling load factors for equipment (unhooded appliances, motors, etc.), as shown in the table, would approach a value of 1.0 for equipment operating 24 hours a day, since a CLF of 0.98 is listed in the table for equipment operating 18 hours.

### 3.2.9 Air Handling Unit Configurations

It is assumed that all AHUs will be configured with a blow-thru fan configuration.

**Rationale**—The blow-thru configuration is assumed in order to keep the airflow values at a reasonable rate, by lowering the supply air temperature to the room to a value equal to the leaving coil temperature.

## 4. METHODOLOGY

### 4.1 QUALITY ASSURANCE

This calculation was prepared in accordance with procedure EG-PRO-3DP-G04B-00037, *Calculations and Analyses* (Reference 2.1.1). The Tertiary Non-ITS portion of the Surface Nuclear Confinement HVAC System discussed in this calculation is classified as Non-ITS in the *Basis of Design for the TAD Canister-Based Repository Design Concept* (Reference 2.2.10, Section 19.1.2) because during operation the HVAC systems do not mitigate the consequences of a radioactive release. Therefore, the approved version of this calculation is designated QA: N/A.

### 4.2 USE OF SOFTWARE

No software was used in this calculation.

### 4.3 METHODOLOGY

The calculation methodology outlined below is accomplished through the use of hand calculations.

1. Gather room information using the preliminary Receipt Facility General Arrangements (Assumption 3.1.1), and develop a Room Load Information Sheet for each room. Additionally, determine U-values for any roofs, walls, partitions, ceilings, and floors. See Appendix A for Room Load Information Sheets and U-Values for this calculation.
2. Calculate room-by-room cooling loads using the CLTD/CLF method and heating loads using the temperature difference method presented in the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3). Heating loads from slab-on-grade floors are calculated using the simplified slab perimeter method given by Equations 39 and 40 of *2005 ASHRAE Fundamentals* (Reference 2.2.4, Chapter 29, p. 29.13). See Section 6.1.3 for cooling loads and Section 6.1.4 for heating loads.
3. Calculate room-by-room cooling loads from lighting, equipment and people, and include these loads in each room's total cooling loads. See Section 6.1.3.
4. Calculate each subsystem's airflow rate by summing all the peak space airflow rates belonging to each subsystem. This is a conservative approach since the rooms' peak cooling loads do not occur at the same time. See Section 6.2.1.
5. Calculate the minimum required outdoor air rate using ANSI/ASHRAE 62.1-2004, *Ventilation for Acceptable Indoor Air Quality* (Reference 2.2.2, Section 6.2). See Section 6.2.3.
6. Calculate the room-by-room space airflow rates based on the subsystem requirements. See Section 6.2.3 and Table 5.

7. Calculate the cooling and heating ventilation loads from the required outdoor air rates determined above. See Section 6.3.
8. Calculate the cooling (coil) load for each subsystem by determining the cooling coil entering conditions, the mixed air conditions based on the psychometric equations in Appendix D, and using cooling coil leaving conditions from Assumption 3.1.5. Thermodynamic properties of air entering and leaving the coil for each subsystem are shown in Appendix G. The mixed air is the mixture of the return air and the outside air. See Section 6.3.1.
9. Calculate the heating (coil) loads for each subsystem. See Section 6.3.2.
10. Calculate Infiltration/Cascade Air Cooling Load as presented in Appendix H.

## 5. LIST OF ATTACHMENTS

	<b>Number of Pages</b>
Attachment 1: E-mail Regarding Waste Packages and Canisters Heat Gain Information	2
Attachment 2: E-mail Regarding RF Electrical Equipment Heat Gain Information	5
Attachment 3: E-mail Regarding Environmental, Safety & Health Equipment Heat Gain Information	12
Attachment 4: E-mail Regarding Instrumentation and Controls Equipment Heat Gain Information	4
Attachment 5: HVAC and Mechanical Process Equipment List	5
Attachment 6: E-mail Regarding Mechanical Handling Group Equipment Heat Gain Information	3
Attachment 7: E-mail Regarding the Number of Occupants in the RF Building	3
Attachment 8: Second E-mail Regarding Mechanical Handling Group Equipment Heat Gain Information	3
Attachment 9: E-mail Regarding Mechanical Handling Equipment Heat Gain Diversity Factor.	3



## 6. BODY OF CALCULATION

### 6.1 ROOM-BY-ROOM COOLING AND HEATING LOADS

#### 6.1.1 Outdoor Design Conditions

This calculation uses the meteorological conditions at Mercury, Nevada for the cooling and heating load calculations, as directed in section 4.9.2.3.1 of the *Project Design Criteria Document* (Reference 2.2.1, p. 122). The following data is taken from Table 1A and 1B in Chapter 27 of *2001 ASHRAE Fundamentals Handbook* (Reference 2.2.5):

- Site: Mercury, Nevada
- North latitude: 36.62°
- West longitude: 116.02°
- Elevation: 3310 ft
- Heating Dry Bulb Temperature, 99.6% value: 24°F
- Cooling Dry Bulb/Mean Coincident Wet Bulb Temperatures, 0.4% value: 102°F/65°F
- Daily Temperature Range: 25.9°F

The 0.4% annual percentile design value for cooling and the 99.6% design value for heating are used for confinement and sensitive areas as directed by the Project Design Criteria Document (Reference 2.2.1, Section 4.9.2.3.1, p. 122).

#### 6.1.2 Indoor Design Conditions

This calculation uses the summer and winter indoor design temperatures presented in Table 2, as a guide for assigning individual room design temperatures. As for humidity, the normally occupied areas the maximum dew point shall be 62.2°F. There are no established lower humidity limits for thermal comfort per ASHRAE 55-2004 (Reference 2.2.22, Section 5.2.2). Currently, no project requirements exist dictating the need for minimal humidity levels for special processes or equipment needs.

For winter design conditions, there is the possibility for the humidity levels to reach low percentage levels and humidification may be desirable in occupied areas, to reduce skin and eye dryness and in some areas to reduce static electricity generation. But it will not be addressed at this time, since the spaces, processes, and equipment for this facility have not yet been designed in detail.

Table 2. Indoor Design Temperatures

Rooms/Areas	Summer/Winter
Normally Unoccupied Areas (with Occasional Short Term Occupancy): (e.g. Exit / Entrance Vestibules, Electrical & Mechanical Equipment Rooms, LID Bolting Room, and Chases)	90°F (summer)/65°F (winter) (Reference 2.2.26, Section 3.2)
Cask Unloading Room, Loading Room	100°F (summer)/65°F (winter) See Note 1
Cask Preparation Room, Cask Preparation Annex, Canister Transfer Room, Maintenance Room	79°F to 85°F; Use 79°F (summer)/65°F (winter) (Reference 2.2.26, Section 3.2)
Corridors, Lobby	79°F to 85°F; Use 82°F (summer)/65°F (winter) (Reference 2.2.26, Section 3.2)
Battery Room	77°F (summer)/77°F (winter) See Note 2
Support Areas	75°F (summer)/72°F (winter) (Reference 2.2.26, Section 3.2)

## NOTES:

1. These rooms are normally unoccupied and are similar to the Mechanical Equipment Room in Table 1, Chapter 25 of 2007 ASHRAE Applications (Reference 2.2.8), which recommends a maximum room temperature of the "Design Outdoor Temperature + 10°F = (112°F). Electrical equipment (such as a CCTV) within the room cannot sustain a room temperature higher than 104°F; therefore 100°F was used as a design room temperature for conservatism.
2. From Table 1, Chapter 25 of 2007 ASHRAE Applications (Reference 2.2.8).

### 6.1.3 Room-by-Room Cooling Load Calculation

As stated in Section 4.3, the cooling loads are calculated using the CLTD/CLF method presented in the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3). For each room the cooling load is calculated by considering the cooling load contribution from the following load components: roofs, walls, partitions, lighting, people, and equipment. The equations used to calculate the various components of the cooling load are given in Appendix C. The specific values used in these equations are given in the Room Load Information Sheets presented in Appendix A. An explanation regarding the sources of the information contained in the Room Load Information Sheets is given at the beginning of Appendix A. U-values for roofs, walls, and partition types are calculated and presented at the end of Appendix A.

The unadjusted ASHRAE values for CLTDs are presented in Appendix B. The unadjusted roof CLTD values correspond to a Type-12 roof (6-in. h.w. concrete with 1 in. or 2 in. insulation) and a Type 1 roof (steel with 1 in. or 2 in. insulation), per Table 3.8 in the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, p. 3.19). However, from note 4 of Table 3.8 of Reference 2.2.3, an effective CLTD of 29 is used for the Type-12 roof for each solar time, because the RF concrete roof has an R-value of approximately 30 (hr ft<sup>2</sup> F)/Btu greater than the Type-12 roof selected. Also, per note 4 of Table 3.8 of Reference 2.2.3, the CLTD values of a Type 2 roof are used for calculating the cooling load from the metal roof, because of a higher calculated resistance of the roof. The unadjusted CLTD values for the wall Types B and G (Reference 2.2.3,

Table 3.10, p. 3.21) are given in Appendix B. These wall types are determined from Table 3.9 of the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, p. 3.20) by determining the best comparison of the RF walls with the types given in the table. Because the R-value of the RF thick concrete wall is not significantly greater than the Type B wall chosen, a CLTD correction per note 4 of Table 3.10 in Reference 2.2.3 is not required.

The unadjusted CLTD values in Appendix B need to be corrected for latitude-month, color, indoor design temperature, and outdoor design temperature before they can be used in the cooling load equations. See Appendix B for the equations used to correct the unadjusted roof and wall CLTD values. The Latitude and Month corrections for the roofs and walls are given in Table B-2. For the correction of the Roof CLTD and the Wall CLTD, the K-factor is equal to 1.0, based on Assumption 3.2.3. For the correction of the Roof CLTD, the f-factor is taken at 1.0 for conservatism. The monthly outdoor design temperatures used in this calculation are shown in Table B-3. The summer design conditions of 102°F dry bulb/65°F wet bulb were assigned to June, July, August, and September for a more conservative cooling load result. Table F-1 and Table F-2 present the room-by-room roof and wall load calculations, respectively, for the peak month and hour of each room. The roof and wall totals for each room are summarized in Table 3.

The CLF values are also provided in Appendix B, Table B-1. The CLF values for lighting, people, and equipment are all equal to 1.0, based on Assumption 3.2.6, Assumption 3.2.7, and Assumption 3.2.8, respectively.

Partition loads are handled in a simplified and conservative manner in this calculation. Partition loads, due to wall partitions, are considered only when there is a heat gain into the room or space. The negative load value is not considered for the spaces on the side of the partition that experience a heat loss. This method was chosen to make the hand calculations simpler, yet conservative, since not tracking down the heat loss from the multiple partitions and temperature differences that could be experienced by any single room saves time and yields a higher cooling load.

In order to determine the peak cooling load for each room, the maximum value of the sum of the roof, wall, partition, lights, people and equipment heat gains for all months and hourly times is determined. See Example A1.1 in the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3) for an example on how to determine the room peak cooling load. The peak month and hour for each room served by the RF HVAC system is given in Tables F-1 and F-2.

A summary of the cooling load calculation is given in Table 3, for both sensible and latent loads. For conservatism, a 20% factor of safety has been added to the room peak sensible and latent loads to account for duct heat gain and to account for any unknowns at this stage of the design (Assumption 3.1.3).

Subsystem designations are added in Table 3 to identify anticipated zoning of rooms with respective air-handling units.

Table 3. Cooling Load Summary

Room No.	Room Name	Room Peak Mo/hr	SENSIBLE COOLING											LATENT						
			Design Room Temp. °F	Roof Btu/h	Walls Btu/h	Partitions Btu/h	Floors Btu/h	People Btu/h	Lights Btu/h	Equipment Btu/h	Infiltration Btu/h	Room Sensible Btu/h	Factor of Safety	Total Room Peak Sensible Btu/h	People Btu/h	Infiltration Btu/h	Equipment Btu/h	Room Latent Btu/h	Factor of Safety	Total Room Peak Latent Btu/h
Note 1	Note 1	Note 2	Note 1	Note 6	Note 7	Note 8	Note 9	Note 10	Note 11	Note 12	Note 13	Note 14	Note 15	Note 16	Note 10	Note 13	Note 12	Note 17	Note 15	Note 18
AHU-B (AHU-00001, 2 & 3)																				
1002	Lid Bolting Room	6/15	90	1,415	3,309	9,380	0	1,000	13,515	132,327	9,752	170,698	1.2	204,838	800	0	0	800	1.2	960
1003A	Corridor	6/15	82	0	557	5,472	0	0	5,242	307	10,180	21759	1.2	26,111	0	0	0	0	1.2	0
1003B	Corridor	All	82	0	0	7,500	0	0	8,437	205	0	16,142	1.2	19,370	0	0	0	0	1.2	0
1003C	Corridor	6/15	82	0	471	1,584	0	0	5,079	0	6,965	14,099	1.2	16,919	0	0	0	0	1.2	0
1003D	Corridor	All	82	0	0	8,910	0	0	10,894	0	0	19,805	1.2	23,766	0	0	0	0	1.2	0
1004	HVAC Room (ITS HEPA Exhaust Train A)	6/20	90	0	3,374	2,620	0	0	33,038	62,678	321	102,031	1.2	122,437	0	0	0	0	1.2	0
1004A	HVAC Room (ITS HEPA Exhaust for Battery Room Train A)	6/16	90	0	1,920	0	0	0	6,143	8,794	750	17,607	1.2	21,128	0	0	0	0	1.2	0
1212 to 1224	Support Areas [Excluding Room 1221] (Assumption 3.1.20)	6/15	75	0	9,026	27,539	0	750	35,140	23,659	30,621	126,735	1.2	152,082	600	0	0	600	1.2	720
1221 & 1205	Support Areas (Assumption 3.1.20)	6/15	75	3,617	0	0	0	0	5,488	4,027	0	13,132	1.2	15,758	0	0	0	0	1.2	0
2001	Operations/Maintenance Storage Room	6/21	90	1,279	8,659	0	0	0	12,219	341	1,607	24,105	1.2	28,926	0	0	0	0	1.2	0
2002A	Corridor	6/15	82	0	557	7,628	0	0	5,324	102	6,072	19,684	1.2	23,621	0	0	0	0	1.2	0
2002B	Corridor	All	82	0	0	11,974	0	0	12,942	307	0	25,223	1.2	30,268	0	0	0	0	1.2	0
2002C	Corridor	All	82	0	0	1,824	0	0	1,474	102	0	3,401	1.2	4,081	0	0	0	0	1.2	0
2002D	Corridor	6/15	82	0	1,371	5,472	0	0	7,782	0	35,720	50,345	1.2	60,414	0	0	0	0	1.2	0
2003	HVAC Room North (Process Area Supply)	6/16	90	3,458	4,828	0	0	0	33,038	15,916	1,607	58,847	1.2	70,616	0	0	0	0	1.2	0
2004	HVAC Room North (Process Area Supply)	6/16	90	2,265	3,429	0	0	0	21,638	8,532	1,179	37,043	1.2	44,452	0	0	0	0	1.2	0
2005	Instrument and Electrical Shop	6/18	90	3,065	12,297	0	0	0	29,284	341	2,572	47,559	1.2	57,071	0	0	0	0	1.2	0
2007	Canister Transfer Room	6/22	79	8,202	71,571	66,031	0	0	53,038	250,687	2,054	451,583	1.2	541,900	0	0	0	0	1.2	0
2012	Receiver/Dryer Equipment Room	9/21	90	1,904	18,214	0	0	0	29,284	120,425	2,572	172,398	1.2	206,878	0	0	0	0	1.2	0
AHU-C (AHU-00004 & 5)																				
1003E	Corridor	9/16	82	0	1,129	10,664	0	0	14,417	102	0	26,312	1.2	31,574	0	0	0	0	1.2	0
1003F	Corridor	9/15	82	0	504	5,472	0	0	5,242	205	5,894	17,317	1.2	20,780	0	0	0	0	1.2	0
1003G	Corridor	9/15	82	0	388	4,256	0	0	5,079	307	10,537	20,567	1.2	24,680	0	0	0	0	1.2	0
1003H	Utility Chase	All	90	0	0	2,960	0	0	10,894	0	0	13,854	1.2	16,625	0	0	0	0	1.2	0
1012	LLW Staging Room	6/17	90	0	7,161	2,620	0	0	21,707	2,455	4,608	38,551	1.2	46,261	0	0	0	0	1.2	0

Room No.	Room Name	Room Peak Mo/hr	SENSIBLE COOLING												LATENT					
			Design Room Temp. °F	Roof Btu/h	Walls Btu/h	Partitions Btu/h	Floors Btu/h	People Btu/h	Lights Btu/h	Equipment Btu/h	Infiltration Btu/h	Room Sensible Btu/h	Factor of Safety	Total Room Peak Sensible Btu/h	People Btu/h	Infiltration Btu/h	Equipment Btu/h	Room Latent Btu/h	Factor of Safety	Total Room Peak Latent Btu/h
Note 1	Note 1	Note 2	Note 1	Note 6	Note 7	Note 8	Note 9	Note 10	Note 11	Note 12	Note 13	Note 14	Note 15	Note 16	Note 10	Note 13	Note 12	Note 17	Note 15	Note 18
1014	Maintenance Room	All	79	0	0	12,165	0	0	10,376	27,378	0	49,919	1.2	59,903	0	0	0	0	1.2	0
1016	CTM Maintenance Room	All	90	0	0	2,620	0	0	9,215	1,952	0	13,787	1.2	16,544	0	0	0	0	1.2	0
1018	Electrical Room (Normal Power)	6/23	90	0	9,521	0	0	0	25,734	118,271	643	154,169	1.2	185,003	0	0	0	0	1.2	0
1018A	Battery Room (Normal Power)	9/21	77	0	5,820	4,850	0	0	4,505	0	2,456	17,631	1.2	21,157	0	0	0	0	1.2	0
1019	HVAC Room (ITS HEPA Exhaust Train B)	9/22	90	0	5,511	0	0	0	33,038	62,678	321	101,548	1.2	121,858	0	0	0	0	1.2	0
1019A	HVAC Room (ITS HEPA Exhaust for Battery Room Train B)	9/21	90	0	3,485	0	0	0	6,143	9,751	750	20,130	1.2	24,156	0	0	0	0	1.2	0
1028	Freight Elevator	6/16	90	1,150	10,811	0	0	0	2,130	0	0	14,091	1.2	16,909	0	0	0	0	1.2	0
1029	Elevator Lobby	9/15	82	0	5,237	1,920	0	0	3,522	102	31,612	42,394	1.2	50,873	0	0	0	0	1.2	0
2002E	Corridor	All	82	0	0	10,680	0	0	18,184	512	0	29,376	1.2	35,250	0	0	0	0	1.2	0
2002F	Corridor	6/15	82	0	557	7,628	0	0	5,324	102	6,072	19,684	1.2	23,621	0	0	0	0	1.2	0
2002G	Corridor	All	82	0	0	1,824	0	0	1,474	102	0	3,401	1.2	4,081	0	0	0	0	1.2	0
2006	HVAC Room (HEPA Exhaust for Support, Decon and LLW Areas)	6/17	90	2,272	9,459	0	0	0	21,707	53,784	5,465	92,687	1.2	111,224	0	0	0	0	1.2	0
2009	HVAC Room South (Process Area Supply)	6/23	90	2,494	12,804	0	0	0	25,734	6,175	2,036	49,243	1.2	59,092	0	0	0	0	1.2	0
2010	HVAC Room South (Process Area Supply)	9/22	90	2,149	9,150	0	0	0	33,038	12,472	1,607	58,416	1.2	70,099	0	0	0	0	1.2	0
2011	HVAC Room South (Process Area Supply)	9/22	90	1,407	6,498	0	0	0	21,638	6,638	1,179	37,360	1.2	44,832	0	0	0	0	1.2	0
2029	Elevator Lobby	9/15	82	0	8,566	3,104	0	0	3,276	102	20,896	35,945	1.2	43,134	0	0	0	0	1.2	0
3001	Corridor	Tertiary	82	1,225	2,858	874	0	0	2,294	0	3,751	11,001	1.2	13,201	0	0	0	0	1.2	0
3029	Elevator Lobby	Tertiary	82	0	4,465	1,029	0	0	5,406	0	19,825	30,724	1.2	36,869	0	0	0	0	1.2	0
R001	Freight Elevator Machine Room	Tertiary	90	4,158	6,507	0	0	0	7,700	3,412	0	21,777	1.2	26,132	0	0	0	0	1.2	0

Room No.	Room Name	Room Peak Mo/hr	SENSIBLE COOLING											LATENT						
			Design Room Temp. °F	Roof Btu/h	Walls Btu/h	Partitions Btu/h	Floors Btu/h	People Btu/h	Lights Btu/h	Equipment Btu/h	Infiltration Btu/h	Room Sensible Btu/h	Factor of Safety	Total Room Peak Sensible Btu/h	People Btu/h	Infiltration Btu/h	Equipment Btu/h	Room Latent Btu/h	Factor of Safety	Total Room Peak Latent Btu/h
Note 1	Note 1	Note 2	Note 1	Note 6	Note 7	Note 8	Note 9	Note 10	Note 11	Note 12	Note 13	Note 14	Note 15	Note 16	Note 10	Note 13	Note 12	Note 17	Note 15	Note 18
AHU-D (AHU-00006 & 7)																				
1013	Loading Room	All	100	0	0	0	0	0	12,901	132,327	0	145,228	1.2	174,274	0	0	0	0	1.2	0
1015	Cask Unloading Room	All	100	0	0	0	0	0	11,468	87,277	0	98,745	1.2	118,494	0	0	0	0	1.2	0
1017	Cask Preparation Room	6/15	79	7,104	10,753	39,813	0	1,500	45,939	375,760	23,825	504,694	1.2	605,633	1200	0	0	1,200	1.2	1,440
1017A	Cask Preparation Annex	9/19	79	0	4,810	10,640	0	500	10,717	2,083	0	28,749	1.2	34,499	400	0	0	400	1.2	480
Totals				47,164	265,578	276,520	0	3,750	708,245	1,532,697	253,451	3,069,692	1.2	3,683,630	3,000	0	0	3000	1.2	3,600

NOTES:

1. Obtained from the Room Load Information Sheets in Appendix A
2. Determined using the Cooling and Heating Load Calculation Methodology on a room-by-room basis, outlined in Section 6.1.3. "All" means that the load is constant, room has no exterior exposure
3. Not Used
4. Not Used
5. Not Used
6. Roof loads come from Table F-1 in Appendix F
7. Wall loads come from Table F-2 in Appendix F
8. The sum of all of the partition loads from Appendix A information and Equation C-5 in Appendix C
9. There are no heat loads thru the floors
10. People loads (sensible and latent) are calculated using Equations C-7 and C-8 from Appendix C, where input values come from the Room Load Information Sheets in Appendix A
11. Lighting loads are calculated using Equation C-6 from Appendix C, where input values from the Room Load Information Sheets in Appendix A are multiplied by 3.413 to convert from Watts to Btu/h
12. Equipment loads are calculated using Equations C-9, C-10 and C-11 from Appendix C, where input values come from the Room Load Information Sheets in Appendix A
13. Infiltration loads come from Table H-1 in Appendix H
14. Summation of roof, walls, partitions, ceiling, floor, people, lighting equipment, and infiltration/cascade sensible loads
15. Factor of safety is assumed to be 20% (Assumption 3.1.3)
16. Total room sensible load with safety factor
17. Summation of people, equipment and infiltration latent loads
18. Total room latent load with safety factor

#### 6.1.4 Room-by-Room Heating Load Calculation

The room-by-room heating loads are calculated using the equations presented in Appendix C. As stated in Section 4.3 the heating loads are calculated using the method presented in the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3). Heating load due to conduction through the floors is calculated using the perimeter heat loss factor equation. Room information is taken from the Room Load Information Sheets presented in Appendix A.

Partition loads are handled in a simplified and conservative manner in this calculation. Partition loads due to wall partitions and ceiling partitions are considered only when there is a heat loss from the room or space. Heat gain is not considered for the spaces on the side of the partition that may experience it. This method was chosen in this calculation to make the hand calculations simpler yet conservative by not having to track down every heat gain or loss from the multiple partitions and temperature differences that could be experienced by any single room. If all partition and ceiling gains and losses were accounted for, then this total would be equal to zero.

A summary of the components of the heating load and the Total Room Heat Load for each space is presented in Table 4. For conservatism, a 20% factor of safety has been added to the room heat loads to account for any unknowns at this stage of the design.

Table 4. Heating Load Summary

Room No. Note 1	Room Name Note 1	HEATING LOAD, Btu/h							Factor of Safety Note 6	Room Total Heat Load Note 7
		Roof Note 2	Wall Note 2	Partition Note 2	Floor Note 3	Infil- tration Note 4	Room Heat Load Note 5			
AHU-B (AHU-00001, 2 & 3)										
1002	Lid Bolting Room	2,517	24,805	0	1,287	38,952	67,560	1.2	81,072	
1003A	Corridor	0	1,173	0	269	24,398	25,840	1.2	31,008	
1003B	Corridor	0	0	0	0	0	0	1.2	0	
1003C	Corridor	0	992	0	239	16,694	17,925	1.2	21,510	
1003D	Corridor	0	0	0	0	0	0	1.2	0	
1004	HVAC Room (ITS HEPA Exhaust Train A)	0	9,561	0	0	1,284	10,845	1.2	13,014	
1004A	HVAC Room (ITS HEPA Exh for Battery Room Train A)	0	6,314	0	1,497	2,996	10,807	1.2	12,968	
1212 to 1224	Support Areas [Excluding Room 1221]	0	16,368	16,855	1,542	63,642	98,407	1.2	118,089	
1221 and 1205	Support Areas	2,090	0	0	0	0	2,090	1.2	2,508	
2001	Operations/Maintenance Storage Room	2,275	24,534	0	0	6,421	33,230	1.2	39,876	
2002A	Corridor	0	1,173	0	0	14,553	15,726	1.2	18,871	
2002B	Corridor	0	0	0	0	0	0	1.2	0	
2002C	Corridor	0	0	0	0	0	0	1.2	0	
2002D	Corridor	0	1,297	0	0	85,608	86,905	1.2	104,286	
2003	HVAC Room North (Process Area Supply)	6,152	15,875	0	0	6,421	28,447	1.2	34,137	
2004	HVAC Room North (Process Area Supply)	4,029	11,275	0	0	4,708	20,013	1.2	24,015	
2005	Instrument and Electrical Shop	5,453	33,645	0	0	10,273	49,370	1.2	59,244	
2007	Canister Transfer Room	9,876	106,707	0	0	4,280	120,863	1.2	145,035	
2012	Receiver/Dryer Equipment Room	5,453	33,915	0	0	10,273	49,641	1.2	59,569	
<b>Sub-system Total</b>									<b>755,241</b>	
AHU-C (AHU-00004 & 5)										
1003E	Corridor	0	695	0	329	0	1,024	1.2	1,229	
1003F	Corridor	0	1,173	0	269	14,125	15,567	1.2	18,681	
1003G	Corridor	0	902	0	0	25,254	26,156	1.2	31,388	
1003H	Utility Chase	0	0	0	0	0	0	1.2	0	
1012	LLW Staging Room	0	33,837	0	2,604	18,406	54,847	1.2	65,816	
1014	Maintenance Room	0	0	0	0	0	0	1.2	0	
1016	CTM Maintenance Room	0	0	0	0	0	0	1.2	0	
1018	Electrical Room (Normal Power)	0	22,460	0	1,347	2,568	26,375	1.2	31,650	
1018A	Battery Room (Normal Power)	0	8,996	0	2,244	6,087	17,326	1.2	20,792	
1019	HVAC Room (ITS HEPA Exhaust Train B)	0	9,561	0	0	1,284	10,845	1.2	1,3014	
1019A	HVAC Room (ITS HEPA Exhaust for Battery Room Train B)	0	6,314	0	1,497	2,996	10,807	1.2	12,968	



Room No. Note 1	Room Name Note 1	HEATING LOAD, Btu/h							Factor of Safety Note 6	Room Total Heat Load Note 7
		Roof Note 2	Wall Note 2	Partition Note 2	Floor Note 3	Infil- tration Note 4	Room Heat Load Note 5			
1026	Stair #4	0	0	0	0	0	0	1.2	0	
1028	Freight Elevator	693	10,841	0	0	0	11,534	1.2	13,841	
1029	Elevator Lobby	0	3,428	0	688	75,763	79,880	1.2	95,856	
2002E	Corridor	0	0	0	0	0	0	1.2	0	
2002F	Corridor	0	1,173	0	0	14,553	15,726	1.2	18,871	
2002G	Corridor	0	0	0	0	0	0	1.2	0	
2006	HVAC Room (HEPA Exh for Support, Decon & LLW Area)	4,042	48,401	0	0	21,830	74,272	1.2	89,127	
2009	HVAC Room South (Process Area Supply)	4,436	29,676	0	0	8,133	42,244	1.2	50,693	
2010	HVAC Room South (Process Area Supply)	6,152	15,875	0	0	6,421	28,447	1.2	34,137	
2011	HVAC Room South (Process Area Supply)	4,029	11,275	0	0	4,708	20,013	1.2	24,015	
2026	Stair #4	0	0	0	0	0	0	1.2	0	
2029	Elevator Lobby	0	6,255	0	0	50,081	56,335	1.2	67,602	
3001	Corridor	746	2,270	0	0	8,989	12,005	1.2	14,406	
3026	Stair #4	0	0	0	0	0	0	1.2	0	
3029	Elevator Lobby	0	4,262	0	0	47,512	51,775	1.2	62,130	
R001	Firefight Elevator Machine Room	2,505	8,061	0	0	0	10,567	1.2	12,680	
R026	Firefight Elevator Machine Stair	0	0	0	0	0	0	1.2	0	
<b>Sub-system Total</b>									<b>678,896</b>	
AHU-D (AHU-00006 & 7)										
1013	Loading Room	0	0	0	0	0	0	1.2	0	
1015	Cask Unloading Room	0	0	0	0	0	0	1.2	0	
1017	Cask Preparation Room	8,554	21,197	0	0	49,653	79,403	1.2	95,284	
1017A	Cask Preparation Annex	0	6,043	0	629	0	6,672	1.2	8,006	
<b>Sub-system Total</b>									<b>103,290</b>	
<b>Totals (Note 8)</b>		<b>60,448</b>	<b>513,089</b>	<b>16,855</b>	<b>13,812</b>	<b>599,213</b>	<b>1,203,414</b>		<b>1,547,388</b>	

## NOTES:

1. From information and data contained in Room Load Information Sheets in Appendix A. See the Room Load Information Sheets for any additional remarks about loads per room.
2. From Equation C-12 in Appendix C and specific values from Room Load Information Sheets in Appendix A.
3. From Equation C-13 and C-14 in Appendix C and data from Room Load Information Sheets in Appendix A.
4. From Equation C-15 in Appendix C and data from Room Load Information Sheets in Appendix A.
5. Sum of Roof, Wall, Partition, Floor, and Infiltration loads.
6. Factor of safety to account for unknowns.
7. Total of Room Heat Load multiplied by factor of safety.
8. Totals are given for informational purposes in order to get an indication of the overall loads in RF. They are not necessarily meant to indicate the heating load for any single HVAC subsystem.

## 6.2 SUBSYSTEM AIRFLOW RATES

### 6.2.1 Space Airflow Rates

To calculate the airflow rates required by each room the Total Sensible Heat Equation (Equation D-14, Appendix D) is rearranged to solve for CFM.

$$CFM = \frac{Q_s}{60 \cdot d \cdot (0.24 + 0.444W) \cdot (T_L - T_E)} \quad (\text{Eq. 2})$$

where

- $CFM$  = airflow rate, cu. ft./min
- $Q_s$  = sensible heat gain, Btu/h
- $d$  = density of incoming air, lb/cu. ft. @  $T_E$
- $W$  = humidity ratio, lb water vapor/lb dry air
- $T_L$  = dry bulb temperature of leaving air, °F
- $T_E$  = dry bulb temperature of entering air, °F
- 60 = minutes per hour
- 0.24 = specific heat of dry air, Btu/lb °F
- 0.444 = specific heat of water vapor, Btu/lb °F.

For each room, the sensible heat gain,  $Q_s$ , is taken from the Total Room Peak Sensible value presented in Table 3. The density of air at 3,310 feet elevation can be calculated using the psychometric equations presented in Appendix D. For all rooms served directly by air-handling units, the entering air to the room is equal to the leaving coil temperature because the air-handling units are assumed to be configured with a blow-thru fan arrangement (Assumption 3.2.9). The room entering air temperature,  $T_E$ , is assumed at 51°F dry bulb and a corresponding wet bulb temperature shown in Appendix G based on the leaving cooling coil conditions (Assumption 3.1.5). The density of the entering air is equal to 0.068 lb/cu. ft. The humidity ratio of the incoming air is determined at the same conditions in lb water vapor/lb dry air shown in Appendix G. The quantity  $0.444W$  equals 0.0029 and is treated as negligible. The leaving air temperature for each room is taken as the room design temperature for each particular room as indicated in the Room Load Information Sheets in Appendix A.

The rooms being cooled with cascaded air from adjacent rooms is dependent upon the temperature of the adjacent room from where the air comes. The values used in calculating the airflow rates and the results of the calculation are given in Table 5. Adjusted room sensible loads based on the rounded airflow rates are presented in Table 5. They represent the sensible cooling load capability of the airflow values selected for use in each room.

Subsystem designations are added in Table 5 to identify anticipated zoning of rooms with respective air-handling units. This allows a determination of total airflow requirements for subsystems as presented in Section 6.2.2.

Table 5. Space Airflow Rates

Input Data				Cascade Airflow In						Supply Air Flow			Cascade Airflow Out			Infiltration	Return Air	Exhaust Air	Exhaust Sub-system Note 10
Room No. Note 1	Room Name Note 1	Design Room Temp T <sub>L</sub> °F Note 5	Room Total Peak Sensible Btu/h Note 2	Airflow cfm Note 11	Density of Entering Air, ρ lb/ft <sup>3</sup> Note 3	Constant 60 x ρ x 0.24 Note 4	T <sub>E</sub> °F Note 6	Sensible Load Btu/h Note 13	From Note 12	Required Airflow cfm Note 7	Use Airflow cfm Note 8	Adjusted Room Sensible Load Btu/h Note 9	Airflow cfm Note 11	T <sub>L</sub> °F Note 5	To Note 14	Outside Air Infiltration @102°F cfm Note 1	Airflow cfm Note 15	Airflow cfm Note 16	
AHU-B (AHU-00001, 2 & 3) Note 10																			
1002	Lid Bolting Room	90	204,838	540			102	Note 26	Note 19	5,364	5,370	205,074	910	90	Rm 1013	370	0	5,370	EXH-D
1003A	Corridor	82	26,111	0	-	-	-	0	-	860	870	26,409	0	-	-	570	Note 18	Note 18	
1003B	Corridor	82	19,370	0	-	-	-	0	-	638	640	19,427	770	82	Rm 1005	0	Note 18	Note 18	
1003C	Corridor	82	16,919	0	-	-	-	0	-	557	560	16,999	200	82	Rm 1017 & 1017A	390	Note 18	Note 18	
1003D	Corridor	82	23,766	0	-	-	-	0	-	783	790	23,981	200	82	Rm 1014	0	Note 18	Note 18	
Corridor Totals				0				0			2,860	86,816	1,170			960	2,650	0	
1004	HVAC Room (ITS HEPA Exhaust Train A)	90	122,437	800	0.064	0.922	82	-5,898	Rm 2002A, B, C & D	3,052	3,060	116,858	0	-	-	30	0	3,890	EXH-D
1004A	HVAC Room (ITS HEPA Exhaust for Battery Room Train A)	90	21,128	200	0.064	0.922	82	-1,475	Rm 2002A, B, C & D	515	520	19,859	0	-	-	70	0	790	To ITS Train A Battery Room Exhaust
1212 to 1224	C2 Support Areas, Excluding 1221 (Assumption 3.1.20)	75	152,082	1,270			102	Note 26	Rms 1203 & 1021A/B	6471	6480	152,285	0	-	-		6350	1,400	EXH-D
1221 & 1205	C2 Support Areas	75	15,758	0	-	-	-	0	-	671	680	15,981	0	-	-	0	580	100	EXH-D
2001	Operations/Maint. Storage Room	90	28,926	0	-	-	-	0	-	757	760	29,023	0	-	-	150	910	0	
2002A	Corridor	82	23,621	0	-	-	-	0	-	778	780	23,677	0	-	-	340	Note 18	Note 18	
2002B	Corridor	82	30,268	0	-	-	-	0	-	997	1,000	30,355	0	-	-	0	Note 18	Note 18	
2002C	Corridor	82	4,081	0	-	-	-	0	-	134	140	4,250	0	-	-	0	Note 18	Note 18	
2002D	Corridor	82	60,414	390	0.063	0.907	90	2,830	Rm 2005	2,083	2,090	63,442	1,000	82	Rm 1004 & 1004A	2,000	Note 18	Note 18	
Corridor Totals				390				2,830			4,010	121,704	1,000			2,340	5,740	0	
2003	HVAC Room North (Process Area Supply)	90	70,616	0	-	-	-	0	-	1,850	1,860	71,031	0	-	-	150	1,860	150	EXH-D
2004	HVAC Room North (Process Area Supply)	90	44,452	0	-	-	-	0	-	1,164	1,170	44,681	0	-	-	110	1,170	110	EXH-D
2005	Instrument and Electrical Shop	90	57,071	0	-	-	-	0	-	1,494	1,500	57,283	390	90	Rm 2002 A, B, C & D	240	1350	0	

Input Data				Cascade Airflow In						Supply Air Flow			Cascade Airflow Out			Infiltration	Return Air	Exhaust Air	Exhaust Sub-system Note 10
Room No. Note 1	Room Name Note 1	Design Room Temp T <sub>L</sub> °F Note 5	Room Total Peak Sensible Btu/h Note 2	Airflow cfm Note 11	Density of Entering Air, ρ lb/ft <sup>3</sup> Note 3	Constant 60 x ρ x 0.24 Note 4	T <sub>E</sub> °F Note 6	Sensible Load Btu/h Note 13	From Note 12	Required Airflow cfm Note 7	Use Airflow cfm Note 8	Adjusted Room Sensible Load Btu/h Note 9	Airflow cfm Note 11	T <sub>L</sub> °F Note 5	To Note 14	Outside Air Infiltration @102°F cfm Note 1	Airflow cfm Note 15	Airflow cfm Note 16	
2007	Canister Transfer Room	79	541,900	400	0.064	0.922	82	1,106	Rm 1028A, 1029, 2029, 3029 & 3001	19,805	19,810	543,142	1,300	79	Rm 1013	100	17,710		
													1,300	79	Rm 1015				
	Canister Transfer Room Total			400				1,106		19,805	19,810	543,142	2,600	79		100	17,710	0	
2012	Receiver /Dryer Equipment Room	90	206,878	0	-	-	-	-	-	5,417	5,420	206,983	0	-	-	240	0	5,660	EXH-D
Sub-system Totals				3,600				-3,437		Total	53,500	1,670,090	6070			4,760	38,320		
AHU-C (AHU-00004 & 5) NOTE 10																			
1012	LLW Staging Room	90	46,261	450 Note 22	0.063	0.907	90	0	Rm 1014	1,211	1,220	46,590				180	0	1,850	EXH-D
1014	Maintenance Room	79	59,903	200	0.064	0.922	82	553	Rm 1003A thru D	2,205	2,210	60,593	200	90	Rm 1012	0	0	2,210	EXH-D
1016	CTM Maintenance Room	90	16,544	0	-	-	-	-	-	433	440	16,803	440	90	Rm 1017	0	0	0	
1018	Electrical Room (Normal Power)	90	185,003	0	-	-	-	-	-	4,844	4,850	185,215	60	90	Rm 1018A	60	4,850		
1018A	Battery Room (Normal Power)	77	21,157	60	0.063	0.907	90	708	Rm 1018	859	860	21,895				110		1,030	To ITS Train B Battery Room Exhaust
1003E	Corridor	82	31,574	-	-	-	-	-	-	1,040	1,050	31,873	770	82	Rm 1020	0	Note 18	Note 18	
1003F	Corridor	82	20,780	-	-	-	-	-	-	685	690	20,945				330	Note 18	Note 18	
1003G	Corridor	82	24,680	-	-	-	-	-	-	813	820	24,891				590	Note 18	Note 18	
1003H	Utility Chase	90	16,625	-	-	-	-	-	-	435	440	16,803				0	Note 18	Note 18	
2002E	Corridor	82	35,250	-	-	-	-	-	-	1,160	1,160	35,250				0	Note 18	Note 18	
2002F	Corridor	82	23,621	50 Note 21			102	Note 26	Rm 2008	778	780	23,677				290	Note 18	Note 18	
2002G	Corridor	82	4,081	-	-	-	-	-	-	134	140	4,250				0	Note 18	Note 18	
Sub-total of Rms 2003E, F, & G		82		3,860	0.064	0.922	82	0	Rm 1029, 2029 & 3029				1,000 Note 25	82			Note 18	Note 18	
Corridor Total				3,910				0			5,000	155,223	1,770			1,210	8,430	0	
2006	HVAC Room (HEPA Exhaust for Support, Decon and LLW areas)	90	111,224	0	-	-	-	-	-	2,912	2,920	111,511	0	-	-	510	0	3,430	EXH-D

Input Data				Cascade Airflow In						Supply Air Flow			Cascade Airflow Out			Infiltration	Return Air	Exhaust Air	Exhaust Sub-system Note 10
Room No. Note 1	Room Name Note 1	Design Room Temp T <sub>L</sub> °F Note 5	Room Total Peak Sensible Btu/h Note 2	Airflow cfm Note 11	Density of Entering Air, ρ lb/ft <sup>3</sup> Note 3	Constant 60 x ρ x 0.24 Note 4	T <sub>E</sub> °F Note 6	Sensible Load Btu/h Note 13	From Note 12	Required Airflow cfm Note 7	Use Airflow cfm Note 8	Adjusted Room Sensible Load Btu/h Note 9	Airflow cfm Note 11	T <sub>L</sub> °F Note 5	To Note 14	Outside Air Infiltration @102°F cfm Note 1	Airflow cfm Note 15	Airflow cfm Note 16	
2009	HVAC Room South (Process Area Supply)	90	59,092	0	-	-	-	-	-	1,547	1,550	59,193	0	-	-	190	1,590	150	EXH-D
2010	HVAC Room South (Process Area Supply)	90	70,099	0	-	-	-	-	-	1,836	1,840	70,267	0	-	-	150	1,840	150	EXH-D
2011	HVAC Room South (Process Area Supply)	90	44,832	0	-	-	-	-	-	1,174	1,180	45,063	0	-	-	110	1,140	150	EXH-D
1028	Freight Elevator	90	16,909	0	-	-	-	-	-	443	450	17,185	0	-	-	0	450	0	
1029	Elevator Lobby	82	50,873	0	-	-	-	-	-	1,676	1,680	50,997	1,770	-	Rms 1003E, F & G	1,770	1,680	0	
2029	Elevator Lobby	82	43,134	0	-	-	-	-	-	1,421	1,430	25,516	1,170	-	Rms 2003E, F & G	1,170	1,430	0	
3029	Elevator Lobby	82	36,869	0	-	-	-	-	-	1,215	1,220	37,033	920	82	Rm 2003E, F & G	1,110	1,410	0	
3001	Corridor	82	13,201	0	-	-	-	-	-	435	440	13,356	400	82	Rm 2007	210	250	0	
1019	HVAC Room (ITS HEPA Exhaust Train B)	90	121,858	800	0.063	0.907	82	-5,804	Rm 1003E, F, G & 2002E, F & G	3,038	3,100 Note 24	118,385	0	-	-	30	0	3930	EXH-D
1019A	HVAC Room (ITS HEPA Exhaust for Battery Room Train B)	90	24,156	200	0.063	0.907	82	-1,451	Rm 1003E, F, G & 2002E, F & G	594	610 Note 24	23,295	0	-	-	70	0	880	To ITS Train B Battery Room Exhaust
R0001	Freight Elevator Machine Room	90	26,132	0	-	-	-	-	-	684	690	26,350	0	-	-	0	0	690	EXH-D
Sub-system Totals				5,620				-8,022		Total	31,770	1,094,970	7,330			7,180	23,070	29,240	TOTAL EXH-D
AHU-D (AHU-00006 & 7) Note 10																			
1013	Loading Room	100	174,274	1,300	0.065	0.936	79	-25,553	Rm 2007	3,100	3,100	148,740							
		100		910	0.063	0.907	90	-8,256	Rm 1002	-172	-180	-8,637							
	Loading Room Total			2,210				-33,809			2,920	140,103	0			0	0	5,130	EXH-E
1015	Cask Unloading Room	100	118,494	1,300	0.065	0.936	79	-25,553	Rm 2007	1,937	1,940	93,083	0	-	-	0	0	3,240	EXH-E
1017	Cask Preparation Room	79	605,633	800			102	Note 26	Rm 1021 Note 23	22,089	22,090	605,654	0	-	-	360	0	23,190	EXH-E

Input Data			Cascade Airflow In							Supply Air Flow			Cascade Airflow Out			Infiltration	Return Air	Exhaust Air	Exhaust Sub-system Note 10
Room No. Note 1	Room Name Note 1	Design Room Temp T <sub>L</sub> °F Note 5	Room Total Peak Sensible Btu/h Note 2	Airflow cfm Note 11	Density of Entering Air, ρ lb/ft <sup>3</sup> Note 3	Constant 60 x ρ x 0.24 Note 4	T <sub>E</sub> °F Note 6	Sensible Load Btu/h Note 13	From Note 12	Required Airflow cfm Note 7	Use Airflow cfm Note 8	Adjusted Room Sensible Load Btu/h Note 9	Airflow cfm Note 11	T <sub>L</sub> °F Note 5	To Note 14	Outside Air Infiltration @102°F cfm Note 1	Airflow cfm Note 15	Airflow cfm Note 16	
1017A	Cask Preparation Annex	79	34,499	200	0.064	0.922	82	553	Rm 1003A, B, C & D	1,278	1,280	35,095	0	-	-	0	0	1,540	
				440	0.063	0.907	90	4,390	Rm 1016	160	160	4,386	0	-	-	0	0	600	
Cask Preparation Annex Total				640				4,943			1,440	39,481	0	-	-	0	0	2,140	EXH-E
Sub-system Totals				4,950				-54,419			28,390	878,321	0			360	0	33,700	TOTAL EXH-E

NOTES:

1. From the Room Load Information Sheets in Appendix A.
2. From Table 3, Cooling Load Summary.
3. Density of the entering cascade air. Refer to Appendix D for the appropriate equations to calculate air density.
4. Constant based on the density of cascade air entering the room. Refer to Equation 2 in Section 6.2.1.
5. Temperature of Return Air leaving the room (dry bulb). This is the same as the design room temperature (dry bulb), which comes from the Room Load Information Sheets in Appendix A.
6. Temperature of Cascade Air entering the room. For conservatism of cooling load calculation, air cascaded from C1 areas used as outdoor air temperature instead of actual room temperature.
7. From Equation 2, using the "Room Total Peak Sensible" column, an entering air temperature 51°F, a density of air at 51°F, and accounting for the cascade load.
8. Airflow rates rounded up to the nearest 10 cfm.
9. Adjusted room sensible load comes from using the rounded airflow rates in Equation 2.
10. The supply (AHU) or exhaust (EXH) Sub-system serving the listed room.
11. Cascade air to balance room airflow and for proper airflow direction, see Assumption 3.1.10.
12. Room the cascaded air is coming from.
13. From Equation 2.
14. Room the cascaded air is going to.
15. Amount of air returned to the AHU.
16. Amount of air exhausted to the atmosphere.
17. These values are calculated using the mixed air equations in Appendix D.
18. Connected corridors can be considered as one space for exhaust and return airflow rates.
19. 540 cfm is cascaded from C1 Room 1001.
20. Value consists of 870 cfm cascaded from C1 Room 1021A/B and 400 cfm cascaded from C1 Room 1203.
21. 50 cfm is cascaded from C1 Room 2008.
22. Value includes 250 cfm cascaded from C1 Room 1011. (250 cfm is part of 430 cfm total infiltration to Room 1012).
23. 800 cfm is cascaded from C1 Room 1021. (800 cfm is part of 1160 cfm total infiltration to Room 1017).
24. For conservatism, the airflow rate value is retained from previous revision.
25. 800 cfm to Room 1019 and 200 cfm from Room 1019A.
26. The cascaded airflow loads is already accounted for in the room total peak sensible load.

### 6.2.2 Subsystem Airflow Rate

The total airflow rate for each Air Handling Unit in this calculation is determined by summing the peak room airflow rates in Table 5 for all the rooms that will be served by a system. The total airflow rates calculated in Table 5 for each expected subsystem as shown below in Table 6.

Table 6. Subsystem Airflow Rates

Subsystem No.	Area Served	Total Airflow Rate (cfm) Note 1
AHU-B (AHU-00001, 2 & 3)	1st and 2nd Floor North Areas	53,500
AHU-C (AHU-00004 & 5)	1st and 2nd Floor South Areas	31,770
AHU-D (AHU-00006 & 7)	Loading and Unloading rooms, Cask Preparation room and Annex	28,390

NOTE:

1. From summation of all rooms assigned to a subsystem number in Table 5.

### 6.2.3 Required Outdoor Air Ventilation Rate

The required outdoor air ventilation rate is calculated after analyzing the system exhaust rates, and the minimum required outdoor air rates. It is assumed in Assumption 3.1.19 that the *ASHRAE Standard 62.1-2004* (Reference 2.2.2) required outdoor air rate are satisfied with the amount of infiltration and exhaust make-up coming into the rooms and zones of the building. The exhaust rates for the rooms requiring exhaust are presented in Table 5.

The total infiltration air in this calculation (excluding the non-confinement areas) is 14,910 CFM, shown in Appendix H.

The ventilation air for Subsystem AHU-B serving the Northside ground and second level of the RF facility including C2 support areas is 15,180 cfm (supply airflow minus return airflow) as presented in Table 5.

The ventilation air for Subsystem AHU-C serving the Southside ground and second level of the RF facility is 8,700 cfm (supply airflow minus return airflow) as presented in Table 5.

The ventilation air for Subsystem AHU-D is 28,390 cfm. This subsystem is 100% makeup air supply to Rooms 1013, 1015, 1017, and 1017A which are exhausted 100% directly to atmosphere.

Exhaust for Battery Room 1018A is based on Chapter 25 of *2007 ASHRAE Applications* (Reference 2.2.8) where it states that "the recommended H<sub>2</sub> concentration in the battery room is 2% or less of room volume. When no battery design information is available, a general ventilation requirement exhaust rate of 2 to 4 air changes per hour (ACH) may be adequate for preventing the hydrogen concentration in the battery room from reaching the explosive limits". However, from p. 26.8 of *ASHRAE HVAC Applications – 2003* the minimum number of air changes per hour is five.

For conservatism of this calculation 5 ACH will be used to calculate for the ventilation air requirement for the battery room to prevent the hydrogen concentration in battery room from reaching explosive limit. The battery room ventilation required for hydrogen concentration dilution will be:

$$Q_{\text{VENT}} = \frac{\text{Volume} \times \text{ACH}}{60}$$

where

$Q_{\text{VENT}}$  = required ventilation airflow rate, CFM

Volume = 7,700 ft<sup>3</sup> (volume of the battery room, obtained from area and height shown on Appendix A)

ACH = 5 air changes per hour required to prevent the hydrogen concentration in the battery room from reaching the explosive limits.

60 = conversion for 60 minutes per hour

$$Q_{\text{VENT}} = \frac{7,700 \times 5}{60}$$

$$Q_{\text{VENT}} = 642 \text{ CFM}$$

The ventilation airflow to the battery room is exhausted to outdoors, this is consistent with sound and practical engineering practice that: (1) exhausting the ventilation air will avoid accumulation of combustible H<sub>2</sub> gas in the space and (2) maintaining the room at negative pressure will prevent the escape/migration of combustible gas into the adjacent rooms.

As indicated in Table 5, the required airflow rate due to calculated heat load and maintain the non-ITS Battery Room (1018A) at indoor design temperature of 77°F is = 860 CFM. The total exhaust airflow rate from the non-ITS Battery Room is 860 CFM + 110 CFM (outside air infiltration to Room 1018A, see Appendix H) + 60 CFM (cascading air into the room from adjoining electrical equipment room) = 1,030 CFM. This value is greater than the required exhaust of 642 CFM.

## 6.3 COOLING AND HEATING COIL LOADS

### 6.3.1 Cooling Coil Load

The total cooling load is the load required by the chilled water coil. In this calculation, it is determined by calculating the load required to cool the return/mixed air or 100% outside air down to the leaving coil conditions. The conditions of the return air are required to determine the cooling load. This is accomplished by tracking the conditions of the air as it leaves the cooling coil and makes its way back to the air handling unit. The dry bulb temperature of the air leaving the cooling coil is assumed to be 51°F (Assumption 3.1.5) and the wet bulb temperature is as



shown in Appendix G for each corresponding air handling unit. The properties of the air leaving the coil are also presented in Appendix G.

Thermodynamic properties of moist air for each system were determined using psychrometric equations presented in Appendix D. The process of cooling the air from entering the coil to leaving coil conditions (supply air) is constant sensible cooling load process, where dew point temperature and humidity ratio are constant as shown in Appendix G.

As the supply air passes through the supply fan, it gains 6°F of sensible heat per Assumption 3.1.6. The properties of the air leaving the supply fan are presented in Appendix G.

### 6.3.1.1 Sub-Systems AHU-B and AHU-C

These air handling units are recirculating systems with a quantity of outside air mixed with return air. The cooling coil load is determined by using Equation D-16 in Appendix D. Air supply flow rates as determined on Table 5, density of air entering the coil, enthalpy of air entering the coil, and enthalpy of air leaving the coil are as shown in Appendix G. Summary of Sub-system cooling coil loads and airflow rates are shown in Table 7 below.

### 6.3.1.2 Sub-system AHU-D

These air handling units are 100% outside air. In this calculation, Cooling coil capacity is determined by calculating the load required to cool the 100% outdoor air down to the leaving coil conditions to maintain the room indoor design conditions. The cooling coil load is determined by using equation 16 in Appendix D. Air flow rates as determined in Table 5, density of air entering the coil, enthalpy of air entering the coil, and enthalpy of air leaving the coil are as shown on Appendix G. Summary of Sub-system cooling coil loads and airflow rates are shown in Table 7 below.

Table 7. Subsystem Total Cooling Loads

System No.	Total Airflow Rate cfm Note 1	Air Density Note 2	60 min/hr Note 3	$h_1$ Note 4	$h_2$ Note 5	Total Cooling Load Note 6
AHU-B (AHU-00001, 2 & 3)	53,500	0.063	60	29.33	19.23	2,042,523
AHU-C (AHU-00004 & 5)	31,770	0.063	60	30.15	19.23	1,311,389
AHU-D (AHU-00006 & 7)	28,390	0.061	60	33.08	19.23	1,439,117

NOTES:

1. From Table 6
2. Density of air entering the coil in pounds per cubic feet from Appendix G.
3. Minutes per hour conversion
4. Enthalpy of air entering the coil in Btu/lb from Appendix G.
5. Enthalpy of air leaving the coil in Btu/lb from Appendix G.
6. Total cooling load for each subsystem

### 6.3.2. Heating Coil Load

The Sub-system heating load (total of room by room) plus the outside ventilation air is the load required by the hot water coil. Ventilation load is determined by using equation C-15 and outside ventilation air cfm shown in Appendix G and based on winter outdoor and indoor air design conditions of 24°F and 65°F respectively. The density of outside air at 24°F dry bulb and 3,310 feet elevation is approximately 0.0725 lbs/cu.ft. The summary of the subsystem total heating load is shown in Table 8.

Table 8. Subsystem Total Heating Loads

System No.	Outside air cfm Note 1	Air Density Note 2	T1 Note 3	T2 Note 4	Ventilation Load Btu/h Note 5	Room Heating Load Btu/h Note 6	Total Heating Load Btu/h Note 7
AHU-B (AHU-00001, 2 & 3)	15,180	0.0725	66.13	24	667,673	755,241	1,422,914
AHU-C (AHU-00004 & 5)	8,700	0.0725	65	24	372,394	678,896	1,051,290
AHU-D (AHU-00006 & 7)	28,390	0.0725	65	24	1,215,206	103,290	1,318,496

NOTES:

1. From Appendix G.
2. Density of air entering the coil in pounds per cubic feet
3. Winter rooms inside mixed air design condition per Appendix D, Equation D-13.
4. Winter outside air design condition.
5. Ventilation Load per Appendix C, Equation C-15
6. Total Room Heating Load for each subsystem from Table 4.
7. Total Heating Load is the sum of Room Load Heating Load and Ventilation Load.

## 7. RESULTS AND CONCLUSIONS

The room by room cooling and heating loads were calculated in Sections 6.1.3 and 6.1.4. The results are shown in Tables 4 and 5, respectively, and not repeated here.

The room-by-room and subsystem airflow rates were calculated in Table 5 and in Section 6.2.2. The subsystem airflow rates are summarized in Table 6.

The required outdoor air rates were calculated in Section 6.2.3. The infiltration air rates are shown in Appendix H and the ventilation air rates for each subsystem are shown in Appendix G.

The total cooling and heating loads for each subsystem were calculated in Section 6.3. The results are summarized in Table 9, below.

Table 9. Summary of Subsystem Airflow Rates, Cooling Loads, and Heating Loads

Subsystem	Supply Airflow Rate cfm Note 1	Outdoor Air Rate cfm Note 5	Total Sensible Cooling Load Btu/h Note 2	Total Latent Cooling Load Btu/h Note 2	Grand Total Cooling Load Btu/h Note 3	Total Heating Load Btu/h Note 4
AHU-B (AHU-00001, 2 & 3)	53,500	15,180	2,042,523	1,680	2,044,203	1,422,914
AHU-C (AHU-00004 & 5)	31,770	8,700	1,311,389	0	1,311,389	1,051,290
AHU-D (AHU-00006 & 7)	28,390	28,390	1,439,117	1,920	1,437,489	1,318,496
<b>Grand Totals:</b>					<b>4,793,081</b>	<b>3,792,700</b>
<b>1 ton = 12,000 Btu/h</b>					<b>= 400 tons</b>	

NOTES:

1. From Table 6
2. From Table 3
3. From Table 7
4. From Table 8
5. From Table G-1

The room by room exhaust flow rates were calculated and are shown in Table 5, respectively, and not repeated here. Table 10 contains the summary of airflow rates by exhaust subsystem.

Table 10. Summary Exhaust Airflow Rate

Exhaust Sub-system	Area Served	Exhaust Airflow (cfm)
EXH-D (EXH-00001, 2 & 13)	See Table 5 for areas served	29,240
EXH-E (EXH-00005 & 6)	Loading Room 1013, Cask Unloading Room 1015, Cask Preparation Room 1017, and Cask Preparation Annex 1017A	33,700
ITS Train A Battery Room EXH (EXH-00009 & 10)	HVAC Room 1004A (ITS HEPA Exhaust for Battery Room Train A)	1,670 Note 1
ITS Train B Battery Room EXH (EXH-00011 & 12)	HVAC Room 1019A (ITS HEPA Exhaust for Battery Room Train B), and Battery Room 1018A (Normal Power)	2,760 Note 2

## NOTES:

Exhaust airflow will be combined with the ITS Train A Battery Room exhaust (Reference 2.4.6)

Exhaust airflow will be combined with the ITS Train B Battery Room exhaust (Reference 2.4.6)

All results are calculated using the best information available at the present stage of the design. The results of this calculation are reasonable for inputs. As the design progresses, all internal and external heat gains/losses will be re-evaluated.

## APPENDIX A: ROOM LOAD INFORMATION SHEETS AND U-VALUES

The following room load information sheets were assembled using a variety of references:

Room Number and Name: From the General Arrangement Drawings (Assumption 3.1.1).

Room Area: Floor area take-off is from the General Arrangement Drawings (Assumption 3.1.1), where distance is measured from center of wall to center of wall and the total area is rounded to the nearest 10 square feet.

Room Height: Room height is from the General Arrangement Drawings (Assumption 3.1.1), where room height is measured from top of floor to the top of floor above or top of roof/partition.

Room Design Temperature (Summer/Winter): Assigned using the information presented in Section 6.1.2.

Room Design Relative Humidity (Summer/Winter): No requirement, not controlled.

Ventilation Confinement Classification: Assumption 3.1.7.

Roof U-Value: See the end of this appendix for U-Value calculations.

Roof Area: Taken to be equal to room area. Note, that for corridors with a 14 ft ceiling height, and an interstitial space or chase with a roof above the ceiling, the roof area above the interstitial space or chase is added to the roof area for the adjacent room, in order to account for that external load.

Roof Color: Roof color is not known at the time of this calculation. Conservatively, a dark roof color is assumed in this calculation (Assumption 3.2.3).

Wall Height: From the General Arrangement Drawings (Assumption 3.1.1). All wall heights are measured from top of floor to the top of floor above or top of roof/partition.

Wall Width: From the General Arrangement Drawings (Assumption 3.1.1), where distance is measured from center of wall to center of wall.

Wall Orientation: Relative to the true north arrow on the General Arrangement Drawings (Assumption 3.1.1).

Wall U-Value: See the end of this appendix for U-Value calculations.

Wall Area: Product of Wall Height and Wall Width or as noted. Also, for conservatism, the areas of any vents, grilles, pipes, and all doors are included in the wall area. Note, that for corridors with a 14 ft ceiling height, external exposure, and an interstitial space or chase above the ceiling, the wall area for the interstitial space or chase is added to the wall area for the adjacent room, in order to account for that external load.

**Wall Group:** Wall group type is determined by comparing the wall types from the General Arrangement Drawings (Assumption 3.1.1) with the wall types presented in the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, Table 3.9, p. 3.20).

**Wall Color:** Wall color is not known at the time of this calculation. Conservatively, a dark wall color is assumed in this calculation (Assumption 3.2.3).

**Floor F-Value:** Taken conservatively as  $F = 0.73$  (Assumption 3.2.4).

**Floor Perimeter:** Taken from the General Arrangement Drawings (Assumption 3.1.1), where distance is measured from center of wall to center of wall.

**Partition U-Value:** See the end of this appendix for U-Value calculations. When a room has multiple partitions, the two highest U-Values are used to calculate the room partition load. Exceptions are as noted on the individual Room Load Information Sheet.

**Partition Area:** Partition lengths and heights are taken from the General Arrangement Drawings (Assumption 3.1.1). All partition heights are measured from top of floor to top of partition, for conservatism. Exceptions are as noted on any individual Room Load Information Sheet.

**Partition Temperature Difference:** Taken as the temperature difference between the design room temperatures of the spaces on each side of the partition.

**Ceiling U-Value:** See the end of this appendix for U-Value calculations. When a room has multiple ceiling partitions, the two highest U-Values are used to calculate the room ceiling partition load.

**Ceiling Area:** Ceiling area is taken from the General Arrangement Drawings (Assumption 3.1.1).

**Ceiling Partition Temperature Difference:** Taken as the temperature difference between the design room temperatures of the spaces on each side of the ceiling partition.

**Large Interior and Exterior Door U-Value, Area, and Temperature Difference:** The U-Value for all of these doors is  $1.15 \text{ Btu/h-ft}^2\text{-}^\circ\text{F}$  and the areas are taken from RF Air Leakage Calculation (Assumption 3.1.12). Temperature difference is taken as the temperature difference between the design room or exterior temperatures of the spaces on each side of the door.

**Light Type:** The types of light fixtures are not known at this time. A two lamp fluorescent fixture is assumed and a ballast factor of 1.2 is used in rooms and corridors with a 14 ft ceiling height or lower. The lighting for all of the remaining spaces is assumed to be High Bay, Incandescent-type. (Assumption 3.1.2.)

**Light Total Wattage:** The light total wattage is not known at this time. A lighting density of  $2 \text{ W/sq. ft}$  is assumed in all rooms (Assumption 3.1.2), with 100% of all lighting load going to the space (Assumption 3.2.5). The Room Area value is used to determine the Lights Total Wattage for a room, even in instances where the area of the ceiling may be greater due to the presence of tunnel-type corridors and battery rooms with ceilings that do not go up to structure.

Light Ballast Factor: From Assumption 3.1.2 for Fluorescent lighting.

People Activity Type: Activity type is assigned by comparison of the type of space with the representative rates at which heat and moisture are given off by human beings in different states of activity, as presented in *ASHRAE Fundamentals* (Reference 2.2.4, Table 1, p. 30.4).

Number of People: Indicated on the Room Load Information Sheets of this appendix (Assumption 3.1.15).

People Q Sensible: Sensible heat gain is from *ASHRAE Fundamentals* (Reference 2.2.4, Table 1, p. 30.4).

People Q Latent: Latent heat gain is from *ASHRAE Fundamentals* (Reference 2.2.4, Table 1, p. 30.4).

Equipment: Equipment heat gain, sensible and latent, comes from Appendix E (Assumption 3.1.4).

Infiltration: Infiltration rates are based on the RF Air Leakage Calculation (Assumption 3.1.8).

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1002 Lid Bolting Room							Remarks	
Room Area (sf)	1980	Rm. Height (ft)	64					
Indoor Design Conditions	Summer DB, °F	90	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary				
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	1980			Roof Type 12, 1'-6" concrete
Wall	64	43	NW	0.22	2750	B		Wall 1, 4' concrete
Wall								
Door								
Floor					F=0.73			Perimeter = 43 Feet
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT °F	Remarks		
Partition (summer)			0.2	1470	10	Partition 1, 4' Concrete		
Partition (winter)						No heat loss through partitions		
Large Interior Door (summer)			1.15	560	10			
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	3960	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
Standing, Light work, Walking	4	250	200	See Assumption 3.1.15				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
132,327	0	From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
910	See Assumption 3.1.8. Infiltration airflow rate includes 540 cfm cascaded from C1 Room 1001.							
<b>Notes/Remarks</b>								



ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1003A Corridor							Remarks	
Room Area (sf)	640	Rm. Height (ft)	14					
Indoor Design Conditions	Summer DB, °F	82	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary				
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	14	9	NE	0.22	130	B		Wall 1, 4' concrete
Wall								
Wall								
Wall								
Floor					F=0.73			Perimeter = 9 Feet
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT °F	Remarks		
NE Partition (summer)			0.2	990	8	Partition 1, 4' Concrete		
Partition (winter)						No heat loss through partitions		
SE Partition and Ceiling (summer)			0.3	1620	8	Partition 2, Gypsum Board		
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1536	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
307		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
570	See Assumption 3.1.8							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET									
Room Number and Name: 1003B Corridor									Remarks
Room Area (sf)	1030	Rm. Height (ft)	14						
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity			Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification			Tertiary		
<b>External Conduction</b>									
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft² F	Area ft²	Wall Group	Color	Remarks	
Roof									
Wall									
Wall									
Wall									
Door									
Floor									
<b>Internal Conduction</b>									
Item				U Btu/h-ft² F	Area ft²	ΔT °F	Remarks		
NE Partition and Ceiling (summer)				0.3	2270	8	Partition 2, Gypsum Board		
Partition (winter)							No heat loss through partitions		
SW Partition (summer)				0.2	570	18	Partition 1, 4' Concrete		
<b>Lights</b>									
Type	W/sq. ft.		Ballast Factor	Total Watts	Remarks				
Fluorescent	2		1.2	2472	See Assumption 3.1.2				
<b>People</b>									
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>									
Q Sensible Btu/h		Q Latent Btu/h	Remarks						
205			From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>									
Airflow cfm		Remarks							
<b>Notes/Remarks</b>									

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1003C Corridor						Remarks		
Room Area (sf)	620	Rm. Height (ft)	14					
Indoor Design Conditions	Summer DB, °F	82	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary				
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft² F	Area ft²	Wall Group	Color	Remarks
Roof								
Wall	14	8	NE	0.22	110	B		Wall 1, 4' concrete
Wall								
Wall								
Door								
Floor					F=0.73			Perimeter = 8 Feet
<b>Internal Conduction</b>								
Item			U Btu/h-ft² F	Area ft²	ΔT °F	Remarks		
Partition (summer)			0.2	990	8	Partition 1, 4' Concrete		
Partition (winter)						No heat loss through partitions		
Ceiling (summer/winter)						No heat gain/loss through partition		
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1488	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
<b>Infiltration</b>								
Airflow cfm	Remarks							
390	See Assumption 3.1.8							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1003D Corridor						Remarks		
Room Area (sf)	1330	Rm. Height (ft)	14					
Indoor Design Conditions	Summer DB, °F	82	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary				
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft² F	Area ft²	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Door								
Floor								
<b>Internal Conduction</b>								
Item		U Btu/h-ft² F	Area ft²	ΔT °F	Remarks			
NW and SE Partition 1 (summer)		0.2	1150	18	Partition 1, 4' Concrete			
NW and SE Partition 2 (summer)		0.2	920	8	Partition 1, 4' Concrete			
Partition (winter)					No heat loss through partitions			
Ceiling (summer)		0.31	1330	8	Concrete Floor (2nd Floor), 1'- 6" Thick			
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	3192	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
<b>Infiltration</b>								
Airflow cfm	Remarks							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1003E Corridor							Remarks	
Room Area (sf)	1760	Rm. Height (ft)	14					
Indoor Design Conditions	Summer DB, °F		82	Relative Humidity		Not Controlled		
	Winter DB, °F		65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	14	11	SW	0.113	150	G		Wall 2, Metal Wall
Wall								
Wall								
Door								
Floor					F=0.73			Perimeter = 11 Feet
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT °F	Remarks	
NE and NW Partitions (summer)				0.2	1580	8	Partition 1, 4' Concrete	
SW Partitions and Ceiling (summer)				0.3	3390	8	Partition 2, Gypsum Board	
Partition (winter)							No heat loss through partitions	
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	4224	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
102		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1003F Corridor							Remarks	
Room Area (sf)	640	Rm. Height (ft)	14					
Indoor Design Conditions	Summer DB, °F		82	Relative Humidity		Not Controlled		
	Winter DB, °F		65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft² F	Area ft²	Wall Group	Color	Remarks
Roof								
Wall	14	9	SW	0.22	130	B		Wall 1, 4' concrete
Wall								
Wall								
Door								
Floor					F=0.73			Perimeter = 9 Feet
<b>Internal Conduction</b>								
Item				U Btu/h-ft² F	Area ft²	ΔT °F	Remarks	
SE Partition and Ceiling (summer)				0.3	1620	8	Partition 2, Gypsum Board	
NW Partition (summer)				0.2	990	8	Partition 1, 4' Concrete	
Partition (winter)							No heat loss through partitions	
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1536	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
205			From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
330		See Assumption 3.1.8						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1003G Corridor							Remarks	
Room Area (sf)	620	Rm. Height (ft)	14					
Indoor Design Conditions	Summer DB, °F	82	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary				
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	14	7	SW	0.22	100	B		Wall 1, 4' concrete
Wall								
Wall								
Door								
Floor								
<b>Internal Conduction</b>								
Item	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT °F	Remarks				
SE Partition and Ceiling (summer)	0.3	1100	8	Partition 2, Gypsum Board				
NW Partitions (summer)	0.2	1010	8	Partition 1, 4' Concrete				
Partition (winter)				No heat loss through partitions				
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1488	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
307		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
590	See Assumption 3.1.8							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1003H Utility Chase						Remarks		
Room Area (sf)	1330	Rm. Height (ft)	18					
Indoor Design Conditions	Summer DB, °F	90	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary				
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Door								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT °F	Remarks		
NW and SE Partitions (summer)			0.2	1480	10	Partition 1, 4' Concrete		
Partition (winter)						No heat loss through partitions		
Ceiling (summer/winter)						No heat gain/loss through partition		
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	3192	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
<b>Infiltration</b>								
Airflow cfm	Remarks							
<b>Notes/Remarks</b>								



ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1004 HVAC Room (ITS HEPA Exhaust Train A)							Remarks	
Room Area (sf)	4840	Rm. Height (ft)	32					
Indoor Design Conditions	Summer DB, °F	90	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary				
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft² F	Area ft²	Wall Group	Color	Remarks
Roof								
Wall	18	59	NE	0.22	1060 <sup>1</sup>	B		Wall 1, 4' concrete
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item	U Btu/h-ft² F	Area ft²	ΔT °F	Remarks				
Partition (summer)	0.2	1310	10	Partition 1, 4' Concrete				
Partition (winter)				No heat loss through partitions				
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1.0	9680	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
62,678		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
30	See Assumption 3.1.8							
<b>Notes/Remarks</b>								
1. Minus the area of the 1003A Corridor entrance (130 sq. ft.) and the amount of wall that is Room 1004A's exterior (700 sq. ft.)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1004A HVAC Room (ITS HEPA Exhaust for Battery Room Train A)								
							Remarks	
Room Area (sf)	750	Rm. Height (ft)	14					
Indoor Design Conditions	Summer DB, °F		90	Relative Humidity		Not Controlled		
	Winter DB, °F		65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	14	50	NE	0.22	700	B		Wall 1, 4' Concrete
Wall								
Wall								
Wall								
Floor					F=0.73			Perimeter = 50 Feet
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Remarks		
Partition (summer)						No heat gain through partition.		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1800	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
8,794		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
70	See Assumption 3.1.8							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1012 LLW Staging Room							Remarks	
Room Area (sf)	3180	Rm. Height (ft)	32					
Indoor Design Conditions	Summer DB, °F	90	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary				
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	32	43	NE	0.22	1380	B		Wall 1, 4' Concrete
Wall	32	44 <sup>1</sup>	NW	0.37	1410	B		Wall 3, 2' Concrete
Wall								
Wall								
Floor					F=0.73			Perimeter = 87 feet
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)			0.2	1310	10	Partition 1, 4' Concrete		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	6360	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
2,455		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
430	See Assumption 3.1.8. Infiltration airflow rate includes 250 cfm cascaded from C1 Room 1011.							
<b>Notes/Remarks</b>								
1. Minus the width of Room 1011's exterior (30 ft)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1013 Loading Room						Remarks		
Room Area (sf)	1890	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	100	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification	Tertiary			
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)						No heat gain through partitions		
Partition (winter)						No heat loss through partitions		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	3780	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
132,327		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET							
Room Number and Name: 1014 Maintenance Room						Remarks	
Room Area (sf)	1520	Rm. Height (ft)	32				
Indoor Design Conditions		Summer DB, °F	79	Relative Humidity	Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary	
<b>External Conduction</b>							
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group Color	Remarks
Roof							
Wall							
Wall							
Wall							
Wall							
Floor							
<b>Internal Conduction</b>							
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)		0.2	1470	21	Partition 1, 4' Concrete		
Partition (summer)		0.2	2400	11	Partition 1, 4' Concrete		
Partition (summer)		0.2	1185	3	Partition 1, 4' Concrete		
Partition (winter)					No heat loss through partitions		
Ceiling							
<b>Lights</b>							
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks			
High Bay	2	1	3040	See Assumption 3.1.2			
<b>People</b>							
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks		
<b>Equipment Heat Gain</b>							
Q Sensible Btu/h	Q Latent Btu/h	Remarks					
27,378		From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>							
Airflow cfm	Remarks						
<b>Notes/Remarks</b>							

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1015 Cask Unloading Room							Remarks	
Room Area (sf)	1680	Rm. Height (ft)	32					
Indoor Design Conditions	Summer DB, °F	100	Relative Humidity	Not Controlled				
	Winter DB, °F	65	Ventilation Confinement Classification			Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks				
Partition (summer)				No heat gain through partitions				
Partition (winter)				No heat loss through partitions				
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	3360	See assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
87,277		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1016 CTM Maintenance Room							Remarks	
Room Area (sf)	1350	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification	Tertiary			
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Partition (summer)		0.2	1310	10	Partition 1, 4' Concrete			
Partition (winter)					No heat loss through partitions			
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	2700	See assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
1,952			From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1017 Cask Preparation Room							Remarks	
Room Area (sf)	6730	Rm. Height (ft)	72					
Indoor Design Conditions		Summer DB, °F	79	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	6730			Roof Type 12, 1'-6" concrete
Wall	12 <sup>1</sup>	74	SE	0.22	890	B		Wall 1, 4' Concrete
Wall	8 <sup>2</sup>	91	NE	0.22	730	B		Wall 1, 4' Concrete
Wall	8 <sup>2</sup>	91	SW	0.22	730	B		Wall 1, 4' Concrete
Wall								
Floor								
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Partition (summer)		0.2	3790	3	Partition 1, 4' Concrete			
Partition (summer)		0.2	7840	11	Partition 1, 4' Concrete			
Partition (summer)		0.2	1310	21	Partition 1, 4' Concrete			
Large Interior Door (summer)		1.15	100	11				
Large Interior Door (summer)		1.15	560	21				
Partition (winter)					No heat loss through partitions			
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	13460	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
Standing, Light work, Walking		6	250	200	See Assumption 3.1.15			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
375,760			From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
1160		See Assumption 3.1.8. Infiltration airflow rate includes 800 cfm cascaded from C1 Room 1021.						
<b>Notes/Remarks</b>								
1. Minus the height of the adjacent support rooms and HVAC room (60 ft).								
2. Minus the height of the adjacent ground and second floors (64 ft).								



ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1017A Cask Preparation Annex							Remarks	
Room Area (sf)	1570	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	79	Relative Humidity		Not controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	32	21 <sup>1</sup>	SE	0.22	670	B		Wall 1, 4' Concrete
Wall								
Wall								
Wall								
Floor					F=0.73			Perimeter = 21 feet
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Large Interior Door (summer)		1.15	510	11	See Note 2			
Partition (winter)					No heat loss through partition.			
Ceiling (summer)		0.31	470	3	Concrete Floor (2nd Floor), 1'- 6" Thick			
Ceiling (summer)		0.31	1100	11	Concrete Floor (2nd Floor), 1'- 6" Thick			
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	3140	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
Standing, Light work, Walking		2	250	200	See Assumption 3.1.15			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
2,083		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
<b>Notes/Remarks</b>								
1. Minus the width of the adjacent support areas (9 feet)								
2. Since there are more than two partitions only the door is considered for the SW wall.								
3. Adjacent corridor (1003G) is not considered, since the area is small and the temperature difference is low.								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1018 Electrical Room (Normal Power)							Remarks	
Room Area (sf)	3770	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity		Not controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	32	57	NW	0.22	1660 <sup>2</sup>	B		Wall 1, 4' Concrete
Wall	18	46	SW	0.22	830	B		Wall 1, 4' Concrete
Wall								
Wall								
Floor					F=0.73			Perimeter= 45 Feet <sup>1</sup>
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks	
Partition (summer)							No heat gain through partition.	
Partition (winter)							No heat loss through partition.	
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	7540	See Assumption 3.1.2				
<b>People</b>								
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
118,271		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
60	See Assumption 3.1.8							
<b>Notes/Remarks</b>								
1. Perimeter does not include the exterior area that is adjacent to Room 1018A								
2. Minus the exterior area of the adjacent Room 1018A								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1018A Battery Room (Normal Power)								
								Remarks
Room Area (sf)	550	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	77	Relative Humidity		Not Controlled		
		Winter DB, °F	77	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	14	46	SW	0.22	640	B		Wall 1, 4' Concrete
Wall	14	12	NW	0.22	170	B		Wall 1, 4' Concrete
Wall								
Wall								
Floor					F=0.73			Perimeter= 58 Feet
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Partition and ceiling (summer)		0.3	1200	13	Partition 2, Gypsum Board			
SE Partition (summer)		0.2	170	5	Partition 1, 4' Concrete			
Partition (winter)								
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1320	See assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
<b>Infiltration</b>								
Airflow cfm		Remarks						
110		See Assumption 3.1.8						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1019 HVAC Room (ITS HEPA Exhaust Train B)								Remarks
Room Area (sf)	4840	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	18	59	SW	0.22	1060 <sup>1</sup>	B		Wall 1, 4' Concrete
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks	
Partition (summer)							No heat gain through partition.	
Partition (winter)							No heat loss through partition.	
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	9680	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
62,678			From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
30		See Assumption 3.1.8						
<b>Notes/Remarks</b>								
1. Minus the area of the 1003F Corridor entrance (130 sq. ft.) and the amount of wall that is Room 1019A's exterior (700 sq. ft.)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1019A HVAC Room (ITS HEPA Exhaust for Battery Room Train B)								
							Remarks	
Room Area (sf)	750	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	14	50	SW	0.22	700	B		Wall 1, 4' Concrete
Wall								
Wall								
Wall								
Floor					F=0.73			Perimeter = 50 Feet
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Partition (summer)					No heat gain through partition.			
Partition (winter)					No heat loss through partition.			
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1800	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
9,751			From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
70		See Assumption 3.1.8						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1026 Stair #4 <sup>1</sup>							Remarks	
Room Area (sf)	400	Rm. Height (ft)	16					
Indoor Design Conditions		Summer DB, °F	102	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)								
Partition (winter)								
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								
1. This is a non-conditioned space (Assumption 3.1.14)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1028 Freight Elevator							Remarks	
Room Area (sf)	260	Rm. Height (ft)	90					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification	Tertiary			
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.065	260			Roof Type 1, Metal Roofing
Wall	72	15	NW	0.113	1080	G		Wall No. 2, Metal Wall
Wall	72	11	SW	0.113	790	G		Wall No. 2, Metal Wall
Wall	26	18	NE	0.113	470	G		Wall No. 2, Metal Wall
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)						No heat gain through partition.		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	624	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1029 Elevator Lobby							Remarks	
Room Area (sf)	430	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity		Not controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	32	23 <sup>1</sup>	SW	0.113	740	G		Wall 2, Metal Wall
Wall								
Wall								
Door								
Floor					F=0.73			Perimeter = 23 Feet
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
NE Partition (summer)		0.2	480	8	Partition 1, 4' Concrete			
NW Partition (summer)		0.3	480	8	Partition 2, Gypsum Board			
Partition (winter)					No heat loss through partition.			
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1.2	1032	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
102			From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
1770		See Assumption 3.1.8						
<b>Notes/Remarks</b>								
1. Assumption 3.1.15								



ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1212 to 1224 Support Areas [Excluding Room 1221] (Assumption 3.1.20)								
							Remarks	
Room Area (sf)	4290	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	75	Relative Humidity		Not Controlled		
		Winter DB, °F	72	Ventilation Confinement Classification		Tertiary		
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	32	52	NE	0.22	1550 <sup>1</sup>	B		Wall 1, 4' Concrete
Wall								
Wall								
Floor					F=0.73			Perimeter = 44 feet
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Corridor Partition and Ceiling (summer)			0.3	1800	7	Partition 2, Gypsum Board		
NW Partition (summer)			0.2	1270	15	Partition 1, 4' Concrete		
Ceiling (summer)			0.31	4290	15	Concrete Floor, 1'-6" Thick		
Corridor Partition and Ceiling (winter)			0.3	1800	7	Partition 2, Gypsum Board		
NW and SW Partition (winter)			0.2	2690	7	Partition 1, 4' Concrete		
Ceiling (winter)			0.31	4290	7	Concrete Floor, 1'-6" Thick		
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	10296	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
Standing, Light work, Walking		3	250	200	See Assumption 3.1.15			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
23,659		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
1270 <sup>3</sup>	See Assumption 3.1.8. Infiltration consists of 870 cfm from Rooms 1021A/B and 400 cfm from Room 1203.							
<b>Notes/Remarks</b>								
1. Minus the exterior area of the 1003C corridor (112 sq. ft.)								
2. Room 1017 is ignored for summer, since the one degree temperature differential is assumed negligible.								
3. Reference 2.2.21, Section 7.2 indicates Rooms 1007A and 1006 which are now Rooms 1212 thru 1224 and 1205.								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 1221 and 1205 Support Areas (Assumption 3.1.20)								Remarks
Room Area (sf)	670	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	75	Relative Humidity		Not Controlled		
		Winter DB, °F	72	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.065	670			Roof Type 1, Metal Roofing
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks	
Partition (summer)							No heat gain through partition.	
Partition (winter)							No heat loss through partition.	
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1.2	1608	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
4027			From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2001 Operations/Maintenance Storage Room							Remarks	
Room Area (sf)	1790	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	1790			Roof 1, 1'-6" concrete
Wall	32	46	NE	0.22	1470	B		Wall 1, 4' concrete
Wall	32	39	NW	0.22	1250	B		Wall 1, 4' concrete
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)						No heat gain through partition.		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	3580	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
341		From Equipment Heat Gain List, See Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
150	See Assumption 3.1.8							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2002A Corridor							Remarks	
Room Area (sf)	650	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	14	9'	NE	0.22	130	B		Wall 1, 4' concrete
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
SE Partition and Ceiling (summer)			0.3	1660	8	Partition 2, Gypsum Board.		
NW Partitions (summer)			0.2	1010	8	Partition 1, 4' Concrete		
Partition (winter)						No heat loss through partition.		
Floor (summer)			0.39	650	8	Concrete Floor (2nd Floor): 1'- 6" Thick		
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1560	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
102			From Equipment Heat Gain List, See Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
340		See Assumption 3.1.8						
<b>Notes/Remarks</b>								
1. Assumption 3.1.15								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2002B Corridor							Remarks	
Room Area (sf)	1580	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
NE Partition and Ceiling (summer)			0.3	3550	8	Partition 2, Gypsum Board		
NW Partition (summer)			0.2	150	8	Partition 1, 4' Concrete		
Partition (winter)						No heat loss through partition.		
Floor			0.39	1030	8	Concrete Floor (2nd Floor): 1'- 6" Thick		
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	3792	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
307		From Equipment Heat Gain List, Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2002C Corridor							Remarks	
Room Area (sf)	180	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft² F	Area ft²	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item		U Btu/h-ft² F	Area ft²	ΔT F	Remarks			
Ceiling and Partitions (summer)		0.3	580	8	Partition 2, Gypsum Board			
NW Partition (summer)		0.2	270	8	Partition 1, 4' Concrete			
Partition (winter)					No heat loss through partition.			
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	432	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
102			From Equipment Heat Gain List, Assumption 3.1.4.					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2002D Corridor							Remarks	
Room Area (sf)	950	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity	Not controlled			
		Winter DB, °F	65	Ventilation Confinement Classification	Tertiary			
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	14	10	NE	0.113	140	G		Wall No. 2, Metal Wall
Wall	14	10	SW	0.113	140	G		Wall No. 2, Metal Wall
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
SE Partition and Ceiling (summer)			0.3	2280	8	Partition 2, Gypsum Board		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	2280	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
<b>Infiltration</b>								
Airflow cfm		Remarks						
2000		See Assumption 3.1.8						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2002E Corridor						Remarks		
Room Area (sf)	2220	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
SW Partition and Ceiling (summer)		0.3	4450	8	Partition 2, Gypsum Board			
Partition (winter)					No heat loss through partition.			
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	5328	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
512			From Equipment Heat Gain List, Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								



ROOM LOAD INFORMATION SHEET									
Room Number and Name: 2002F Corridor									
									Remarks
Room Area (sf)	650	Rm. Height (ft)	14						
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity		Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification			Tertiary		
<b>External Conduction</b>									
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks	
Roof									
Wall	14	9	NE	0.22	130	B		Wall 1, 4' concrete	
Wall									
Wall									
Wall									
Floor									
<b>Internal Conduction</b>									
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
SE Partition and Ceiling (summer)				0.3	1660	8	Partition 2, Gypsum Board.		
NW Partitions (summer)				0.2	1010	8	Partition 1, 4' Concrete		
Partition (winter)							No heat loss through partition.		
Floor (summer)				0.39	650	8	Concrete Floor (2nd Floor): 1'- 6" Thick		
<b>Lights</b>									
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks					
Fluorescent	2	1.2	1560	See assumption 3.1.2					
<b>People</b>									
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks				
<b>Equipment Heat Gain</b>									
Q Sensible Btu/h		Q Latent Btu/h	Remarks						
102			From Equipment Heat Gain List, Assumption 3.1.4						
<b>Infiltration</b>									
Airflow cfm		Remarks							
340		See Assumption 3.1.8. Infiltration airflow rate includes 50 cfm cascaded from C1 Room 2008.							
<b>Notes/Remarks</b>									

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2002G Corridor							Remarks	
Room Area (sf)	180	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Ceiling and Partitions (summer)		0.3	580	8	Partition 2, Gypsum Board			
NW Partition (summer)		0.2	270	8	Partition 1, 4' Concrete			
Partition (winter)					No heat loss through partition.			
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	432	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
102			From Equipment Heat Gain List, Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2003 HVAC Room North (Process Area Supply)								Remarks
Room Area (sf)	4840	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	4840			Roof 1, 1'-6' concrete
Wall	32	59	NE	0.22	1760 <sup>1</sup>	B		Wall 1, 4' Concrete
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)						No heat gain through partition.		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	9680	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
15,916			From Equipment Heat Gain List, Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
150		See Assumption 3.1.8						
<b>Notes/Remarks</b>								
1. Minus the exterior area of the adjacent corridor 2002A (130 sq. ft.)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2004 HVAC Room North (Process Area Supply)								Remarks
Room Area (sf)	3170	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
External Conduction								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	3170			Roof 1, 1'-6' Concrete
Wall	32	39	NE	0.22	1250	B		Wall 1, 4' Concrete
Wall								
Wall								
Wall								
Floor								
Internal Conduction								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks	
Partition (summer)							No heat gain through partition.	
Partition (winter)							No heat loss through partition.	
Ceiling								
Lights								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	6340	See Assumptions 3.1.2				
People								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
Equipment Heat Gain								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
8,532			From Equipment Heat Gain List, Assumption 3.1.4					
Infiltration								
Airflow cfm		Remarks						
110		See Assumption 3.1.8						
Notes/Remarks								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2005 Instrument and Electrical Shop								Remarks
Room Area (sf)	4290	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	4290			Roof 1, 1'-6" concrete
Wall	32	52	NE	0.22	1660	B		Wall 1, 4' concrete
Wall	28	74	SE	0.22	2070	B		Wall 1, 4' concrete
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks	
Partition (summer)							No heat gain through partition.	
Partition (winter)							No heat loss through partition.	
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	8580	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
341		From Equipment Heat Gain List, Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
240	See Assumption 3.1.8							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2006 HVAC Room (HEPA Exhaust for Support, Decon and LLW Areas)							Remarks	
Room Area (sf)	3180	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	3180			Roof 1, 1'-6" concrete
Wall	32	43	NE	0.22	1380	B		Wall 1, 4' concrete
Wall	32	74	NW	0.37	2370	B		Wall 3, 2' concrete
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Partition (summer)					No heat gain through partition.			
Partition (winter)					No heat loss through partition.			
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	6360	See assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
53,784			From Equipment Heat Gain List, Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
510		See Assumption 3.1.8						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2007 Canister Transfer Room								
								Remarks
Room Area (sf)	7770	Rm. Height (ft)	68					
Indoor Design Conditions		Summer DB, °F	79	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification			Tertiary	
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	7770			Roof 1, 1'-6" Concrete
Wall	36	105	NE	0.22	3780	B		Wall 1, 4' concrete
Wall	36	105	SW	0.22	3320 <sup>1</sup>	B		Wall 1, 4' concrete
Wall	36	74	NW	0.22	2660	B		Wall 1, 4' concrete
Wall	28	74	SE	0.22	2070	B		Wall 1, 4' concrete
Floor								
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks	
Partitions Next to Corridors (summer)				0.2	2300	3	Partition 1, 4' Concrete	
Large Second Floor Partitions (summer)				0.2	6790	11	Partition 1, 4' Concrete	
Floor (summer)				0.39	4200	21	Concrete Floor (2nd Floor): 1'- 6" Thick	
Floor (summer)				0.39	3570	11	Concrete Floor (2nd Floor): 1'- 6" Thick	
Partition (winter)							No heat loss through partition.	
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	15540	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
250,687			From Equipment Heat Gain List, Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
100		See Assumption 3.1.8						
<b>Notes/Remarks</b>								
1. Minus the exterior area of Room 3001 (460 ft.)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2009 HVAC Room South (Process Area Supply)								
							Remarks	
Room Area (sf)	3770	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	3490 <sup>1</sup>			Roof 1, 1'-6" concrete
Wall	32	46	SW	0.22	1470	B		Wall 1, 4' Concrete
Wall	32	57	NW	0.22	1820	B		Wall 1, 4' Concrete
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item		U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Partition (summer)					No heat gain through partition.			
Partition (winter)					No heat loss through partition.			
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	7540	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
6,175			From Equipment Heat Gain List, Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
190		See Assumption 3.1.8						
<b>Notes/Remarks</b>								
1. Minus the area of Room 3001 (280 sq. ft.)								



ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2010 HVAC Room South (Process Area Supply)							Remarks	
Room Area (sf)	4840	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	4840			Roof 1, 1'-6" Concrete
Wall	32	59	SW	0.22	1760'	B		Wall 1, 4' Concrete
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)						No heat gain through partition.		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	9680	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
12,472		From Equipment Heat Gain List, Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
150	See Assumption 3.1.8							
<b>Notes/Remarks</b>								
1. Minus the exterior area of Corridor 2002F (130 sq. ft.)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2011 HVAC Room South (Process Area Supply)							Remarks	
Room Area (ft)	3170	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	3170			Roof 1, 1'-6" concrete
Wall	32	39	SW	0.22	1250	B		Wall, 4' concrete
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)						No heat gain through partition.		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	6340	See assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
6638			From Equipment Heat Gain List, Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
110		See Assumption 3.1.8						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2012 Receiver/Dryer Equipment Room							Remarks	
Room Area (ft)	4290	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.031	4290			Roof 1, 1'-6" Concrete
Wall	28	52	SW	0.22	1460	B		Wall 1, 4" Concrete
Wall	32	72	SE	0.22	2300	B		Wall 1, 4" Concrete
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)						No heat gain through partition.		
Partition (winter)						No heat loss through partition.		
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
High Bay	2	1	8580	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
120,425			From Equipment Heat Gain List, Assumption 3.1.4					
<b>Infiltration</b>								
Airflow cfm		Remarks						
240		See Assumption 3.1.8						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2026 Stair#4 <sup>1</sup>							Remarks	
Room Area (sf)	400	Rm. Height (ft)	16					
Indoor Design Conditions		Summer DB, °F	102	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)								
Partition (winter)								
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								
1. This is a non-conditioned space (Assumption 3.1.14)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 2029 Elevator Lobby							Remarks	
Room Area (ft)	400	Rm. Height (ft)	32					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	32	33	SW	0.113	1060	G		Wall 2. Metal Wall
Wall	32	9	NW	0.113	290	G		Wall 2. Metal Wall
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
NE and SE Partitions (summer)			0.2	1220	8	Partition 1, 4' Concrete		
NW Partition (summer)			0.3	480	8	Partition 2, Gypsum Board		
Partition (winter)						No heat loss through partition.		
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	960	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
102		From Equipment Heat Gain List, Assumption 3.1.4						
<b>Infiltration</b>								
Airflow cfm	Remarks							
1170	See Assumption 3.1.8							
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET							
Room Number and Name: 3001 Corridor						Remarks	
Room Area (sf)	280	Rm. Height (ft)	14				
Indoor Design Conditions	Summer DB, °F	82	Relative Humidity	Not Controlled			
	Winter DB, °F	65	Ventilation Confinement Classification	Tertiary			
<b>External Conduction</b>							
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group Color	Remarks
Roof				0.065	280		Roof 2, Metal Roofing
Wall	14	21	SW	0.113	290	G	Wall 2, Metal Wall
Wall	14	14	SE	0.113	200	G	Wall 2, Metal Wall
Wall							
Wall							
Floor							
<b>Internal Conduction</b>							
Item	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks			
Floor (summer)	0.39	280	8	Concrete Floor (2nd Floor): 1'- 6" Thick			
Partition (winter)				No heat loss through partition.			
Ceiling							
<b>Lights</b>							
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks			
Fluorescent	2	1.2	672	See Assumption 3.1.2			
<b>People</b>							
Activity Type	No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>							
Q Sensible Btu/h	Q Latent Btu/h	Remarks					
<b>Infiltration</b>							
Airflow cfm	Remarks						
210	See Assumption 3.1.8						
<b>Notes/Remarks</b>							

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 3026 Stair #4 <sup>1</sup>							Remarks	
Room Area (sf)	400	Rm. Height (ft)	16					
Indoor Design Conditions		Summer DB, °F	102	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
Partition (summer)								
Partition (winter)								
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								
1. This is a non-conditioned space (Assumption 3.1.14)								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: 3029 Elevator Lobby							Remarks	
Room Area (sf)	660	Rm. Height (ft)	12					
Indoor Design Conditions		Summer DB, °F	82	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification			Tertiary	
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall	12	33	SW	0.113	400	G		Wall 2. Metal Wall
Wall	12	9	NW	0.113	110	G		Wall 2. Metal Wall
Wall	12	10	SE	0.113	120	G		Wall 2. Metal Wall
Wall	12	24	NE	0.113	290	G		Wall 2. Metal Wall
Floor								
<b>Internal Conduction</b>								
Item			U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks		
NW Partition (summer)			0.3	180	8	Partition 2, Gypsum Board		
Partition (winter)						No heat loss through partition.		
Ceiling (summer)			0.113	660	8	Wall 2. Metal Wall		
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	1584	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
<b>Infiltration</b>								
Airflow cfm		Remarks						
1110		See Assumption 3.1.8						
<b>Notes/Remarks</b>								



ROOM LOAD INFORMATION SHEET								
Room Number and Name: R001 Firefight Elevator Machine Room							Remarks	
Room Area (sf)	940	Rm. Height (ft)	14					
Indoor Design Conditions		Summer DB, °F	90	Relative Humidity		Not Controlled		
		Winter DB, °F	65	Ventilation Confinement Classification		Tertiary		
<b>External Conduction</b>								
Item	Height ft	Width ft	Orien-tation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof				0.065	940			Roof 2, Metal Roofing
Wall	14	43	NE	0.113	600	G		Wall 2, Metal Wall
Wall	14	24	SE	0.113	340	G		Wall 2, Metal Wall
Wall	14	33	SW	0.113	460	G		Wall 2, Metal Wall
Wall	14	24	NW	0.113	340	G		Wall 2, Metal Wall
Floor								
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks	
Partition (summer)							No heat gain through partition.	
Partition (winter)							No heat loss through partition.	
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
Fluorescent	2	1.2	2256	See Assumption 3.1.2				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h	Q Latent Btu/h	Remarks						
3412		See Assumption 3.1.18						
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								

ROOM LOAD INFORMATION SHEET								
Room Number and Name: R026 Firefight Elevator Machine Stair <sup>1</sup>								Remarks
Room Area (sf)	400	Rm. Height (ft)	26					
Indoor Design Conditions		Summer DB, °F	102	Relative Humidity	Not Controlled			
		Winter DB, °F	65	Ventilation Confinement Classification			Tertiary	
<b>External Conduction</b>								
Item	Height ft	Width ft	Ori-entation	U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	Wall Group	Color	Remarks
Roof								
Wall								
Wall								
Wall								
Floor								
<b>Internal Conduction</b>								
Item				U Btu/h-ft <sup>2</sup> F	Area ft <sup>2</sup>	ΔT F	Remarks	
Partition (summer)								
Partition (winter)								
Ceiling								
<b>Lights</b>								
Type	W/sq. ft.	Ballast Factor	Total Watts	Remarks				
<b>People</b>								
Activity Type		No. of People	Q Sensible Btu/h Ea.	Q Latent Btu/h Ea.	Remarks			
<b>Equipment Heat Gain</b>								
Q Sensible Btu/h		Q Latent Btu/h	Remarks					
<b>Infiltration</b>								
Airflow cfm		Remarks						
<b>Notes/Remarks</b>								
1. This is a non-conditioned space (Assumption 3.1.14)								

## Calculation of U-Values

### Roof Assembly U-Value

The elements of construction come from the General Arrangement Drawings (Assumption 3.1.1). Values of resistance come from *ASHRAE Fundamentals* (Reference 2.2.4, Chapter 25). Where a range of resistance is given, the average resistance value is used in this calculation. The concrete density of 150 pounds per cubic foot comes from Section 4.2.11.6.6 of the *Project Design Criteria Document* (Reference 2.2.1). Roof deck thickness comes from Assumption 3.1.1.

Table A-1. Roof Type 12: 1'-6" Thick Concrete, with R-30 Insulation

Element	Reference	Resistance, R ft <sup>2</sup> -°F-h/Btu
Moving Air, Any Position. At 7.5 mph wind – Summer (Assumption 3.2.2)	ASHRAE Fundamentals 2005, Table 1, p25.2	0.25
R-30 Insulation		30.00
Concrete 18" thick at density of 150 lb/ft <sup>3</sup>	ASHRAE Fundamentals 2005, Table 4, p25.8	1.35
Still Air, Horizontal-Downward Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.92
Total Resistance, R <sub>T</sub> =		32.52
<b>U-Factor = 1/R<sub>T</sub>, Btu/h-ft<sup>2</sup>-°F</b>		<b>0.031</b>

Table A-2. Roof Type 1: Metal Roofing

Element	Reference	Resistance, R ft <sup>2</sup> -°F-h/Btu
See Assumption 3.1.9		
<b>U-Factor = Btu/h-ft<sup>2</sup>-°F</b>		<b>0.065</b>

### Wall Assembly U-Value

The elements of construction come from the General Arrangement Drawings (Assumption 3.1.1). Values of resistance come from *ASHRAE Fundamentals* (Reference 2.2.4, Chapter 25) and *ASHRAE Std. 90.1-2004* (Reference 2.2.6, Table A9.2B). The concrete density of 150 pounds per cubic foot comes from Section 4.2.11.6.6 of the *Project Design Criteria Document* (Reference 2.2.1).

Table A-3. Wall No. 1: 4'-0" Thick Concrete, no insulation

Element	Reference	Resistance, R ft <sup>2</sup> -°F-h/Btu
Moving Air, Any Position. At 7.5 mph wind Summer (Assumption 3.2.2)	ASHRAE Fundamentals 2005, Table 1, p25.2	0.25
Concrete 48" thick at density of 150 lb/ft <sup>3</sup> (Reference 2.2.1, Section 4.2.11.6.6)	ASHRAE Fundamentals 2005, Table 4, p25.8	3.60
Still Air, Horizontal Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.68
Total Resistance, R <sub>T</sub> =		4.53
<b>U-Value = 1/R<sub>T</sub>, Btu/h-ft<sup>2</sup>-°F</b>		<b>0.22</b>

Table A-4. Wall No. 2: Metal Wall

Element	Reference	Resistance, R ft <sup>2</sup> -°F-h/Btu
See Assumption 3.1.9		
<b>U-Value = Btu/h-ft<sup>2</sup>-°F</b>		<b>0.113</b>

Table A-5. Wall No. 3: 2'-0" Thick Concrete, no insulation

Element	Reference	Resistance, R ft <sup>2</sup> -°F-h/Btu
Moving Air, Any Position. At 7.5 mph wind Summer (Assumption 3.2.2)	ASHRAE Fundamentals 2005, Table 1, p25.2	0.25
Concrete 48" thick at density of 150 lb/ft <sup>3</sup> (Reference 2.2.1, Section 4.2.11.6.6)	ASHRAE Fundamentals 2005, Table 4, p25.8	1.80
Still Air, Horizontal Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.68
Total Resistance, R <sub>T</sub> =		2.73
<b>U-Value = 1/R<sub>T</sub>, Btu/h-ft<sup>2</sup>-°F</b>		<b>0.37</b>

### Partition U-Values

The elements of construction come from the General Arrangement Drawings (Assumption 3.1.1). Values of resistance come from *ASHRAE Fundamentals* (Reference 2.2.4, Chapter 25) and *ASHRAE Std. 90.1-2004* (Reference 2.2.6, Table A9.2B). The concrete density of 150 pounds per cubic foot comes from Section 4.2.11.6.6 of the *Project Design Criteria Document* (Reference 2.2.1).

Table A-6. Partition No. 1: 4'- 0" Thick Concrete, no insulation

Element	Reference	Resistance, R ft <sup>2</sup> -°F-h/Btu
Still Air, Horizontal Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.68
Concrete 48" thick at density of 150 lb/ft <sup>3</sup>	ASHRAE Fundamentals 2005, Table 4, p25.8	3.60
Still Air, Horizontal Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.68
Total Resistance, R <sub>T</sub> =		4.96
<b>U-Value = 1/R<sub>T</sub>, Btu/h-ft<sup>2</sup>-°F</b>		<b>0.20</b>

Table A-7. Partition No. 2: Gypsum Board, One-Hour Fire Rated

Element	Reference	Resistance, R ft <sup>2</sup> -°F-h/Btu
Still Air, Horizontal Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.68
5/8" gypsum board	ASHRAE Fundamentals 2005, Table 4, p25.5	0.56
4" metal stud, 24" O.C. with air space. No insulation.	ASHRAE 90.1 - 2004, Table A9.2B, Effective resistance. (Reference 2.1.13)	0.91
5/8" gypsum board	ASHRAE Fundamentals 2005, Table 4, p25.5	0.56
Still Air, Horizontal Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.68
Total Resistance, R <sub>T</sub> =		3.39
<b>U-Value = 1/R<sub>T</sub>, Btu/h-ft<sup>2</sup>-°F</b>		<b>0.30</b>

Table A-8. Partition No. 3: 2'- 0" Thick Concrete, no insulation

Element	Reference	Resistance, R ft <sup>2</sup> -°F-h/Btu
Still Air, Horizontal Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.68
Concrete 24" thick at density of 150 lb/ft <sup>3</sup>	ASHRAE Fundamentals 2005, Table 4, p25.8	1.80
Still Air, Horizontal Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.68
Total Resistance, R <sub>T</sub> =		3.16
<b>U-Value = 1/R<sub>T</sub>, Btu/h-ft<sup>2</sup>-°F</b>		<b>0.32</b>

Table A-9. Concrete Floor (2nd Floor): 1'- 6" Thick

Element	Reference	Resistance, R ft <sup>2</sup> ·°F·h/Btu
Still Air, Downward Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.92
Concrete 18" thick at density of 150 lb/ft <sup>3</sup>	ASHRAE Fundamentals 2005, Table 4, p25.8	1.35
Still Air, Downward Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.92
Total Resistance, R <sub>T</sub> =		3.19
U-Value = 1/R <sub>T</sub> , Btu/h-ft <sup>2</sup> ·°F		0.31

Table A-10. Concrete Floor (2nd Floor): 1'- 6" Thick

Element	Reference	Resistance, R ft <sup>2</sup> ·°F·h/Btu
Still Air, Upward Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.61
Concrete 18" thick at density of 150 lb/ft <sup>3</sup>	ASHRAE Fundamentals 2005, Table 4, p25.8	1.35
Still Air, Upward Flow	ASHRAE Fundamentals 2005, Table 1, p25.2	0.61
Total Resistance, R <sub>T</sub> =		2.57
U-Value = 1/R <sub>T</sub> , Btu/h-ft <sup>2</sup> ·°F		0.39

### Interior and Exterior Roll-up Door U-Value

Table A-11. Door: Metal Roll-up

Element	Reference	Resistance, R ft <sup>2</sup> ·°F·h/Btu
See Assumption 3.1.12		
U-Value = Btu/h-ft <sup>2</sup> ·°F		1.15

### Floor F-Factor

For calculating the heat loss during winter, for slab-on-grade construction, the floor F-Factor is 0.73, according to *Energy Standard for Buildings Except Low-Rise Residential Buildings* (Reference 2.2.6, Table 5.5-5 and Appendix B) based on climate zone and building envelope requirements.

## APPENDIX B: ASHRAE TABLE VALUES FOR CLTD AND CORRECTION TABLES FOR LATITUDE AND MONTH

Table B-1 presents the unadjusted Cooling Load Temperature Difference (CLTD) and Cooling Load Factor (CLF) values used in this calculation. The unadjusted roof CLTD values come from Table 3.8 of the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, p. 3.19). The unadjusted wall CLTD values come from Table 3.10, p. 3.21, of the same reference. The CLF for Lights, People, and Equipment are based on the similar tables in Chapter 4 of the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, pp. 4.4, 4.6, and 4.9). All Cooling Load Factors are equal to 1.0, based on Assumption 3.2.6, Assumption 3.2.7, and Assumption 3.2.8. See Section 6.1.3 of this calculation for determination of roof and wall types and additional information on correcting the unadjusted values for latitude-month, color, indoor design temperature, and outdoor design temperature.

Table B-2 presents the CLTD correction for latitude and month related to the design latitude for this building, as given in Section 6.1.1. The CLTD correction values were interpolated from the 32 degree and 40 degree North latitude values given in Table 3.12 of the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, p. 3.23). Table B-3 presents the winter outdoor design temperature of 24°F dry bulb and 20°F wet bulb and the summer outdoor design temperature of 102°F dry bulb and 65°F wet bulb. For the summer the four months: June, July, August, and September, are assigned for conservatism. All  $K$  factors for roof and wall color are taken at a value of 1.0, per Assumption 3.2.3. The  $f$  factor for the roof CLTD correction is taken at a value of 1.0, for conservatism.

For flat roofs, the following formula (Reference 2.2.3, Table 3.8, Note 2, p. 3.19) is used to correct the roof CLTD values:

$$CLTD_{roof,corr} = [(CLTD + LM) \times K + (78^\circ\text{F} - T_r) + (T_o - 85^\circ\text{F})] \times f \quad (\text{Eq. B-1})$$

where

$CLTD$  = from Table B-1

$LM$  = Latitude-month correction from Table B-2, for a horizontal surface

$K$  = Color adjustment factor, equal to 1.0 (Assumption 3.2.3)

$T_r$  = Indoor design room temperature, °F

$T_o$  = Average outside temperature on design day, °F.  $T_o = 102^\circ\text{F} - (25.9/2) = 89.05^\circ\text{F}$  for a 102°F outdoor design temperature

$f$  = factor for attic fan and/or ducts above ceiling taken at a value equal to 1.0 for no attic fan or ducts and a value equal to 0.75 for positive ventilation

For sunlit walls, the following formula (Reference 2.2.3, Table 3.10, Note 2, p. 3.21) is used to correct the wall CLTD values:

$$CLTD_{wall,corr} = (CLTD + LM) \times K + (78^\circ\text{F} - T_r) + (T_o - 85^\circ\text{F}) \quad (\text{Eq. B-2})$$

where

$CLTD$  = from Table B-1

$LM$  = Latitude-month correction from Table B-2

$K$  = Color adjustment factor, equal to 1.0 (Assumption 3.2.3)

$T_r$  = Indoor design room temperature, °F

$T_o$  = Average outside temperature on design day, °F.  $T_o = 102^\circ\text{F} - (25.9/2) = 89.05^\circ\text{F}$   
for a 102°F outdoor design temperature



Table B-1. Unadjusted CLTD Values and CLF Values (°F)

ASHRAE TABLE VALUES FOR CLTD																								
Hour	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
Roof 1 (Type 12) (Note 1 & 7)	31	28	25	22	20	17	15	14	14	16	18	22	26	31	36	40	43	45	45	44	42	40	37	34
Roof 2 (Type 1) (Note 1 & 8)	6	3	0	-1	-3	-3	-2	4	14	27	39	52	62	70	74	74	70	62	51	38	28	20	14	9
Group B Wall -N (Note 2)	15	14	14	13	12	11	11	10	9	9	9	8	9	9	9	10	11	12	13	14	14	15	15	15
-NE (Note 2)	19	18	17	16	15	14	13	12	12	13	14	15	16	17	18	19	19	20	20	21	21	21	20	20
-E (Note 2)	23	22	21	20	18	17	16	15	15	15	17	19	21	22	24	25	26	26	27	27	26	26	25	24
-SE (Note 2)	23	22	21	20	18	17	16	15	14	14	15	16	18	20	21	23	24	25	26	26	26	26	25	24
-S (Note 2)	21	20	19	18	17	15	14	13	12	11	11	11	11	12	14	15	17	19	20	21	22	22	22	21
-SW (Note 2)	27	26	25	24	22	21	19	18	16	15	14	14	13	13	14	15	17	20	22	25	27	28	28	28
-W (Note 2)	29	28	27	26	24	23	21	19	18	17	16	15	14	14	14	15	17	19	22	25	27	29	29	30
-NW (Note 2)	23	22	21	20	19	18	17	15	14	13	12	12	12	11	12	12	13	15	17	19	21	22	23	23
Group G Wall -N (Note 2)	3	2	1	0	-1	2	7	8	9	12	15	18	21	23	24	24	25	26	22	15	11	9	7	5
-NE (Note 2)	3	2	1	0	-1	9	27	36	39	35	30	26	26	27	27	26	25	22	18	14	11	9	7	5
-E (Note 2)	4	2	1	0	-1	11	31	47	54	55	50	40	33	31	30	29	27	24	19	15	12	10	8	6
-SE (Note 2)	4	2	1	0	-1	5	18	32	42	49	51	48	42	36	32	30	27	24	19	15	12	10	8	6
-S (Note 2)	4	2	1	0	-1	0	1	5	12	22	31	39	45	46	43	37	31	25	20	15	12	10	8	5
-SW (Note 2)	5	4	3	1	0	0	2	5	8	12	16	26	38	50	59	63	61	52	37	24	17	13	10	8
-W (Note 2)	6	5	3	2	1	1	2	5	8	11	15	19	27	41	56	67	72	67	48	29	20	15	11	8
-NW (Note 2)	5	3	2	1	0	0	2	5	8	11	15	18	21	27	37	47	55	55	41	25	17	13	10	7
Glass (Note 3)	1	0	-1	-2	-2	-2	-2	0	2	4	7	9	12	13	14	14	13	12	10	8	6	4	3	2
ASHRAE TABLE VALUES FOR CLF																								
Lights (Note 4)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
People (Note 5)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Equipment hooded (N/A)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Equip. non-hooded (Note 6)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

Notes:

1. From Table 3.8 in Reference 2.2.3.
2. From Table 3.10 in Reference 2.2.3.
3. From Table 3.23 in Reference 2.2.3.
4. From Assumption 3.2.6.
5. From Assumption 3.2.7.
6. From Assumption 3.2.8.
7. The unadjusted values listed here are for a Type 12 roof. But because the RF insulated concrete roof has a much higher resistance (See U-Value Calculation in Appendix A) compared to the Type12 roof listed in Table 3.8 of the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, page 3.19) Note 4 of Table 3.8 is used to determine that an effective CLTD of 29°F should be used in the Cooling Load Calculation.
8. The roof type selected in this calculation for the sheet metal roof is Type 1. The unadjusted CLTD values in this table are from a Type 2 roof because the requirement from Note 4 of Table 3.8 in the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3, page 3.19) was used. Since, the RF metal roof has a higher value by over R-7 and less than R-14 (See U-Value Calculation in Appendix A) the CLTD data was analyzed and the Type 2 CLTD data was chosen as the best set of values to use in this calculation.

Table B-2. CLTD Correction For Latitude and Month Applied to Walls and Roofs (°F)

North Latitude	Month	N	NNE NNW	NE NW	ENE WNW	E W	ESE WSW	SE SW	SSE SSW	S	HOR
36.62	Dec	-5.58	-7.58	-10.00	-12.16	-9.16	-6.16	0.85	7.85	10.85	-19.31
	Jan/Nov	-5.00	-7.00	-9.58	-11.58	-8.58	-5.16	1.42	8.42	11.42	-17.31
	Feb/Oct	-4.58	-6.58	-7.58	-8.58	-5.16	-2.58	3.42	8.00	11.58	-12.31
	Mar/Sep	-3.58	-4.58	-4.58	-5.16	-2.58	-1.00	3.58	6.16	8.73	-6.73
	Apr/Aug	-2.00	-2.58	-1.58	-2.00	0.00	-0.42	1.16	2.16	2.73	-2.16
	May/Jul	0.42	0.42	0.42	0.00	0.00	-0.42	-0.42	-1.27	-0.69	1.00
	Jun	1.00	1.42	1.42	0.42	0.58	-0.85	-0.85	-2.27	-2.27	2.00

NOTE:

All values from interpolation of Table 3.12 in Reference 2.2.3.

Table B-3. Monthly Outdoor Design Temperatures

Month	Outside Design Temperature	
	db F	wb F
JAN	24	20
JUN	102	65
JUL	102	65
AUG	102	65
SEP	102	65
DEC	24	20

NOTE:

The summer outdoor design temperature of 102°F dry bulb and 65°F wet bulb are assigned for the four months: June, July, August, and September, for conservatism.

### APPENDIX C: COOLING/HEATING LOAD EQUATIONS

Table C-1 contains the equations used by the CLTD/CLF cooling load calculation method discussed in the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3). The table references given after the definition of the equation variable in Table C-1 are specific to the *Cooling and Heating Calculation Manual*. In many instances, newer sources and other sources have been used. See the main body of the calculation for those sources.

Table C-1. Cooling Load Equations

Load Source	Cooling Load Equation	Equation No.	Reference, Tables, Description [From ASHRAE GRP 158, <i>Cooling and Heating Load Manual</i> (Reference 2.2.3)]
Roof	$q = U \times A \times \text{CLTD}$	Equation C-1	<p>U = Design Heat transmission Coefficients, Btu/(hr ft<sup>2</sup> °F) - Tables 3.1 - 3.5; A3.1 and A3.2,  A = Areas Calculated from Building Plans, ft<sup>2</sup>  CLTD = Cooling Load Temperature Difference at Base Condition for Roofs, °F - Table 3.8 and Notes  Note 2 - Correction for color of Exterior surface  Note 2 - Correction for Outside Dry Bulb Temperature and Daily Range - Table 3.13  Note 2 - Correction for Inside Dry Bulb Temperature - Table 3.13  Note 2 - Application of Latitude and Month - Table 3.12  Note 4 - For a more conservative roof load result, corrections for additional insulation are not used.</p>
Walls	$q = U \times A \times \text{CLTD}$	Equation C-2	<p>U = Design Heat transmission Coefficients, Btu/(hr ft<sup>2</sup> °F) - Tables 3.1 - 3.4; A3.1 and A3.2  A = Areas Calculated from Building Plans, ft<sup>2</sup>  CLTD = Cooling Load Temperature Difference at Base Condition for Wall Group, °F - Table 3.9, 3.10 + Notes  Note 2 - Correction for color of Exterior surface  Note 2 - Correction for Outside Dry Bulb Temperature and Daily Range - Table 3.13  Note 2 - Correction for Inside Dry Bulb Temperature - Table 3.13  Note 2 - Application of Latitude and Month - Table 3.12</p>
Glass Conduction	$q = U \times A \times \text{CLTD}$	Equation C-3	<p>U = Overall Heat Transmission Coefficient for type of Glass and Interior Shading, if used, Btu/(hr ft<sup>2</sup> °F) - Tables 3.14 - 3.16 &amp; A3.4  A = Glass Areas Calculated from Building Plans, ft<sup>2</sup>  CLTD = Cooling Load Temp. Difference for Conduction Load through Glass, °F - Table 3.23  Correction for Outside Dry Bulb Temperature and Daily Range - Table 3.13  Correction for Inside Dry Bulb Temp. Table 3.13</p>

Load Source	Cooling Load Equation	Equation No.	Reference, Tables, Description [From ASHRAE GRP 158, Cooling and Heating Load Manual (Reference 2.2.3)]
Glass Solar.	$q = A \times SC \times SHGF \times CLF$	Equation C-4	<p>A = Glass Area Calculated from Building Plans, ft<sup>2</sup></p> <p>SC = Shading coefficients for combined type of Glass and type of shading - Table 3.17 - 3.22</p> <p>SHGF = Solar Heat Gain Factor for specific orientation of surface, Btu/(hr ft<sup>2</sup>)</p> <p>Latitude and Month - Table 3.25 for no external shading</p> <p>Externally shaded - Location less than 24 deg Latitude - Table 3.26</p> <p>Location at or more than 24 deg Latitude - Table 3.25-N orient.</p> <p>CLF = Cooling Load Factor</p> <p>With no interior shading - Table 3.27</p> <p>With interior shading - Table 3.28</p> <p>For glass areas shaded externally, use north orientation with either Table 3.27 or 3.28.</p>
Partitions, Ceilings, Floors	$q = U \times A \times TD$	Equation C-5	<p>U = Design Heat transmission Coefficients, Btu/(hr ft<sup>2</sup> °F) - Tables 3.1 - 3.5 &amp; A3.1</p> <p>A = Areas Calculated from Building Plans, ft<sup>2</sup></p> <p>TD = Design Temperature Difference between rooms, °F</p>
Internal Lights	$q = \text{Input} \times CLF$	Equation C-6	<p>Input = Input rating from electrical Plans or Lighting Fixture data, Btu/h - Table 4.1</p> <p>Coefficient "a" and "b" for type of fixture - Tables 4.2 &amp; 4.3</p> <p>CLF = Cooling Load Factor based on total hours of operation and time - Table 4.4</p> <p>Note 1: Correction for Schedule of Operation of Lights and Cooling System, CLF=1 when cooling system is operated only when lights are on or when lights are on 24 hrs/day.</p>
People Sensible	$q = \text{No.} \times \text{Sens. HG} \times CLF$	Equation C-7	<p>No. = Number of People in space, from survey or Table 5.3</p> <p>Sens. HG = Sensible Heat Gains from Occupants, Btu/h - Table 4.5</p> <p>CLF = Cooling Load Factor - based on duration of occupancy and time of entry - Table 4.6</p>
People Latent	$q = \text{No.} \times \text{Latent HG}$	Equation C-8	<p>No. = Number of People in space, from survey or Table 5.3</p> <p>Latent HG = Latent Heat Gain from Occupants, Btu/h - Table 4.5</p>
Equipment/ Appliances Sensible	$q = \text{Heat Gain} \times CLF$	Equation C-9	<p>Heat Gain = Recommended rate of heat gain - sensible heat, Btu/h - Tables 4.8 &amp; 4.9</p> <p>CLF = Cooling Load Factor</p> <p>For use with hood - Table 4.10</p> <p>For use without hood - Table 4.11</p>

Load Source	Cooling Load Equation	Equation No.	Reference, Tables, Description [From ASHRAE GRP 158, Cooling and Heating Load Manual (Reference 2.2.3)]
Equipment/ Appliances Latent	$q = \text{Heat Gain}$	Equation C-10	Heat Gain = Recommended rate of heat gain, Btu/h Latent heat without hood - Tables 4.8 & 4.9 Set Equal to zero when hood is used over appliances.
Power	$q = \text{Heat Gain} \times \text{CLF}$	Equation C-11	Heat Gain = Manufacturer's Data or Tables 4.12 & 4.13, Btu/h CLF = Cooling Load Factor - Table 4.11 or CLF = 1.0 if cooling system is not operated continuously

Table C-2 contains the equations used by the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3) to calculate the heating load for roofs, walls, glass, and floors over exterior spaces. The table references given after the definition of the equation variable in Table C-2 are specific to the *Cooling and Heating Calculation Manual*. In many instances, newer sources and other sources have been used. See the main body of the calculation for those sources. The equation for calculating the heating load from slab-on-grade floors is from *2005 ASHRAE Fundamentals* (Reference 2.2.4, Chapter 29, p. 29.13).

Table C-2. Heating Load Equations

Heating Load	Heating Load Equation	Equation No.	Reference, Tables, Description
Roofs, Walls, Partitions, Glass	$q = U \times A \times \text{TD}$	Equation C-12	[From ASHRAE GRP 158, Cooling and Heating Load Manual (Reference 2.2.3)] U = Design Heat transmission Coefficients, Btu/(hr ft <sup>2</sup> °F) - Tables 3.1 - 3.5; A3.1 and A3.2, A = Areas Calculated from Building Plans, ft <sup>2</sup> TD = Temperature Difference between inside design db and design outside db - Table 2.1
Floors over exterior space	$q = U \times A \times \text{TD}$	Equation C-13	[From ASHRAE GRP 158, Cooling and Heating Load Manual (Reference 2.2.3)] U = Design Heat transmission Coefficients, Btu/(hr ft <sup>2</sup> °F) - Tables 3.1 - 3.5; A3.1 and A3.2, A = Areas Calculated from Building Plans, ft <sup>2</sup> TD = Temperature Difference between inside design db and design outside db - Table 2.1
Slab-on-grade floors	$q = F_p \times P \times \text{TD}$	Equation C-14	From ASHRAE Fundamentals (Reference 2.2.4, Chapter 29, Equations 39 and 40) $F_p$ = Heat loss coefficient per foot of perimeter, Btu/(hr ft <sup>2</sup> °F) P = Perimeter (exposed edge) of slab, ft. TD = Temperature Difference between inside design db and ambient temperature, °F

Table C-3 contains the equations used by the *Cooling and Heating Load Calculation Manual* (Reference 2.2.3) to calculate the sensible and latent heating and cooling loads for infiltration and ventilation. The table references given after the definition of the equation variable in Table C-3 are specific to the *Cooling and Heating Calculation Manual*. In many instances, newer sources and other sources have been used. See the main body of the calculation for those sources.

Table C-3. Infiltration and Ventilation Cooling and Heating Load Equations

Heating Load	Equation	Equation No.	Reference, Tables, Description
Sensible	$q = \text{density} \times 0.24 \times 60 \times \text{Airflow cfm} \times \text{TD}$	Equation C-15	[From <i>ASHRAE GRP 158, Cooling and Heating Load Manual</i> (Reference 2.2.3)] Airflow cfm = Ventilation/Infiltration Air, Standard Airflow cfm, Chapter 5
Latent	$q = 4840 \times \text{Airflow cfm} \times (W_1 - W_2)$		TD = Temperature Difference between inside design db and Outside temperatures, °F
Total	$q = 4.5 \times \text{Airflow cfm} \times (H_1 - H_2)$		Inside – Outside Humidity Ratio, lb. water/lb dry air, Table 2.1 & Table 2.3 Inside – Outside Air Enthalpy, Btu/lb. dry air, Table 2.1 & Table 2.3

## APPENDIX D: PSYCHROMETRIC CALCULATION EQUATIONS

The following methods and equations are used to numerically calculate the various thermodynamic properties of moist air. These equations are derived from Chapter 6 of the *2005 ASHRAE Handbook, Fundamentals* (Reference 2.2.4). These equations are used throughout the calculation whenever individual air properties, mixed air properties, sensible heat gain, latent heat gain, and total heat gain need to be calculated.

### 1. Barometric Pressure, $P$ - [Equation 3, p. 6.1]

$$P = K \cdot [1 - 6.8754 \times 10^{-6} Z]^{5.2559} \quad (\text{Eq. D-1})$$

where

$P$  = barometric pressure (in. w.g.; in. Hg; or psia)

$Z$  = elevation above sea level (ft)

$K$  = a constant (407.1894 in. w.g./atm, 29.921 in. Hg/atm., or 14.696 psia/atm.)

### 2. Water Vapor Saturation Pressure, $P_{ws}$ (for Temperature < 32°F) [Equation 5, p. 6.2]

$$\ln P_{ws} = C1/R + C2 + C3 \cdot R + C4 \cdot R^2 + C5 \cdot R^3 + C6 \cdot R^4 + C7 \cdot \ln R \quad (\text{Eq. D-2})$$

or

$$P_{ws} = e^{\ln P_{ws}}$$

where

$P_{ws}$  = saturation pressure, psia (at the dry bulb or wet bulb temperature)

$R$  = absolute Temp, °R = (T + 459.67)

$T$  = dry or wet bulb temperature, °F

$C1$  = -1.0214165E+04

$C2$  = -4.8932428E+00

$C3$  = -5.3765794E-03

$C4$  = 1.9202377E-07

$C5$  = 3.5575832E-10

$C6$  = -9.0344688E-14

$C7$  = 4.1635019E+00

### 3. Water Vapor Saturation Pressure, $P_{ws}$ (for Temperature = or > 32°F) [Equation 6, p. 6.2]

$$\ln P_{ws} = C8/R + C9 + C10 \cdot R + C11 \cdot R^2 + C12 \cdot R^3 + C13 \cdot \ln R \quad (\text{Eq. D-3})$$

or

$$P_{ws} = e^{\ln P_{ws}}$$

where

$P_{ws}$  = saturation pressure, psia (at the dry bulb or wet bulb temperature)

$R$  = absolute Temp, °R = (T + 459.67)

$T$  = dry or wet bulb temperature, °F

$C8$  = -1.0440397E+04

$C9$  = -1.1294650E+01

$C10$  = -2.7022355E-02

$C11$  = 1.2890360E-05

$C12$  = -2.4780681E-09

$C13$  = 6.5459673E+00

### 4. Humidity Ratio or Moisture Content, $W$ [Equation 35, p. 6.13]

$$W = \frac{(1093 - 0.556T_{wb}) \cdot W_s - 0.24 \cdot (T_{db} - T_{wb})}{1093 + 0.444T_{db} - T_{wb}} \quad (\text{Eq. D-4})$$

where

$W$  = humidity Ratio or Moisture content, lb water/lb dry air

$W_s$  = 0.62198 [( $P_{ws}/(P - P_{ws})$ )]

$P_{ws}$  = saturation pressure (for  $T_{db}$ ), psia (from Equation D-2 or Equation D-3 above)

$P$  = barometric pressure, psia (from Equation B-1 above)

$T_{db}$  = dry bulb temperature, °F

$T_{wb}$  = wet bulb temperature, °F

### 5. Water Vapor Partial Pressure, $P_w$ [Equation 38, p. 6.13]

$$P_w = (P \cdot W) / (0.62198 + W) \quad (\text{Eq. D-5})$$

where

$P_w$  = water vapor partial pressure, psia

$P$  = barometric pressure, psia (from Equation D-1 above)

$W$  = humidity ratio, lb water/lb dry air (from Equation D-4 above)



**6. Relative Humidity [Equation 24, p. 6.12]**

$$RH = (P_w / P_{ws}) \cdot 100 \quad (\text{Eq. D-6})$$

where

$RH$  = relative humidity, percent

$P_w$  = water vapor partial pressure, psia (from Equation D-5 above)

$P_{ws}$  = saturation pressure (for  $T_{db}$ ), psia (from Equation D-2 or Equation D-3 above)

**7. Specific Volume [Equation 28, p. 6.12]**

$$v = [0.3704 \cdot (T_{db} + 459.67) \cdot (1 + 1.6078 \cdot W)] / P \quad (\text{Eq. D-7})$$

where

$v$  = specific volume, cu. ft./lb dry air

$T_{db}$  = dry bulb temperature, °F

$W$  = humidity ratio, lb water/lb dry air (from Equation D-4 above)

$P$  = total pressure, psia (from Equation B-1 above)

**8. Density of moist air mixture,  $d$  [Equation 11, p. 6.2]**

$$d = (1/v) \cdot (1 + W) \quad (\text{Eq. D-8})$$

where

$d$  = density, lb/cu. ft.

$v$  = specific volume, cu. ft./lb dry air (from Equation D-7 above)

$W$  = humidity ratio, lb water/lb dry air (from Equation D-4 above)

**9. Enthalpy,  $h$  [Equation 32, p. 6.13]**

$$h = (0.24 \cdot T_{db}) + [W \cdot (1061 + (0.444 \cdot T_{db}))] \quad (\text{Eq. D-9})$$

where

$h$  = enthalpy, Btu/lb dry air

$T_{db}$  = dry bulb temperature, °F

$W$  = humidity ratio, lb water/lb dry air (from Equation D-4 above)

**10. Dew Point,  $T_d$  (for Temperature < 32°F) [Equation 40, p. 6.13]**

$$T_d = 90.12 + [26.142 \cdot \ln(P_w)] + [0.8927 \cdot (\ln(P_w))^2] \quad (\text{Eq. D-10})$$

where

$T_d$  = dew point temperature, °F

$\ln$  = natural logarithm

$P_w$  = water vapor partial pressure, psia (from Equation D-5 above)

**11. Dew Point,  $T_d$  (for Temperature = or > 32°F) [Equation 39, p. 6.13]**

$$T_d = 100.45 + [33.193 \cdot \ln(P_w)] + [2.319 \cdot (\ln(P_w))^2] + [0.17074 \cdot (\ln(P_w))^3] + [1.2063 \cdot (P_w)^{0.1984}] \quad (\text{Eq. D-11})$$

where

$T_d$  = dew point temperature, °F

$\ln$  = natural logarithm

$P_w$  = water vapor partial pressure, psia (from Equation D-5 above)

**12. Mass of dry air, Mass**

$$M = CFM / v \quad (\text{Eq. D-12})$$

where

$M$  = mass of air, lb/min

$Airflow\ cfm$  = airflow rate, cu. ft./min

$v$  = specific volume, cu. ft./lb dry air (from Equation D-7 above)

**13. Mixed Air Psychometric (Adiabatic Mixing) [Equation 46, p. 6.17]**

$$M_{Prop} = [(Prop1 \cdot Mass1) + (Prop2 \cdot Mass2)] / [Mass1 + Mass2] \quad (\text{Eq. D-13})$$

where

$M_{prop}$  = property of mixed air, enthalpy (h) or humidity ratio (W)

$Prop1$  = property of air stream #1, enthalpy (h) or humidity ratio (W)

$Mass1$  = mass of dry air stream #1, lb/min (from Equation D-12 above)

$Prop2$  = property of air stream #2, enthalpy (h) or humidity ratio (W)

$Mass2$  = mass of air stream #2, lb/min (from Equation D-12 above)

NOTE: It should be noted that only the enthalpy and the humidity ratio follows the above equation. Knowing two properties ( $h$  and  $W$ ), the rest of the other psychrometric properties are determined using the equations found in Items 1 to 12. Also, wet bulb temperature calculation using the humidity ratio equation above will require trial and error because the saturated water pressure ( $P_{ws}$ ) based on wet bulb temperature is required in the humidity ratio calculation. For initial value of the wet bulb temperature, the value determined from the mixed air equation above may be used, and then adjusted accordingly until the values converge.

#### 14. Total Sensible Heat and Air flow Equation [Equation 43, p. 6.16]

From Equation D-16,

$$Q = (CFM \cdot d) \cdot 60 \cdot (h_L - h_E);$$

Substituting the value of enthalpy,  $h$  from Equation D-9 equation (with  $W_E = W_L$ ):

$$Q_s = CFM \cdot 60 \cdot d_E \cdot (0.24 + 0.444W) \cdot (T_L - T_E) \quad (\text{Eq. D-14})$$

where

$Q_s$	= sensible heat gain, Btu/h
$Airflow\ cfm$	= airflow rate, cu. ft./min
$d_E$	= density of incoming air, lb/cu. ft. @ $T_E$
$W$	= humidity ratio, lb water vapor/lb dry air
$T_L$	= dry bulb temperature of leaving air, °F
$T_E$	= dry bulb temperature of entering air, °F
60	= minutes per hour
0.24	= specific heat of dry air, Btu/lb °F
0.444	= specific heat of water vapor, Btu/lb °F

The value of  $0.444W$  being very small is disregarded.

#### 15. Latent Heat and Air flow Equation [Equation 43, p. 6.16]

From Equation B-16,

$$Q = (CFM \cdot d) \cdot 60 \cdot (h_L - h_E);$$

Substituting the value of enthalpy,  $h$  from Equation D-9 equation (with  $T_E = T_L$ ):

$$Q_L = CFM \cdot 60 \cdot d_E \cdot (1061 + 0.444T_E) \cdot (W_L - W_E) \quad (\text{Eq. D-15})$$

where

- $Q_L$  = latent heat gain, Btu/h  
 $d_E$  = density of incoming air, lb/cu. ft. @  $T_E$   
 $T_E$  = dry bulb temperature of entering air, °F  
 $W_L$  = humidity ratio of leaving air, lb water vapor/lb dry air  
 $W_E$  = humidity ratio of entering air, lb water vapor/lb dry air  
60 = minutes per hour  
1061 = energy content of water vapor at 50% RH and 75°F, Btu/lb °F  
0.444 = specific heat of water vapor, Btu/lb °F

#### 16. Grand Total Heat and Air flow Equation [Equation 45, p. 6.16]

$$Q_T = CFM \cdot d_E \cdot 60 \cdot (h_L - h_E) - [(W_L - W_E) \cdot h_{WL}] \quad (\text{Eq. D-16})$$

where

- $Q_T$  = Grand Total heat gain, Btu/h  
*Airflow cfm* = airflow rate in cu. ft/min  
 $d_E$  = density of incoming air, lb/cu. ft.  
60 = minutes per hour  
 $h_L$  = enthalpy of leaving air, Btu/lb dry air (from Equation D-9 above)  
 $h_E$  = enthalpy of entering air, Btu/lb dry air (from Equation D-9 above)  
 $W_L$  = humidity ratio of leaving air, lb water vapor/lb dry air  
 $W_E$  = humidity ratio of entering air, lb water vapor/lb dry air  
 $h_{WL}$  = enthalpy of condensed water leaving, Btu/lb water.

NOTE: The value of  $[(W_L - W_S) \cdot h_{WL}]$  is negligible and is ignored.

## **APPENDIX E: ROOM EQUIPMENT HEAT GAIN LIST**

The Room Equipment Heat Gain List was originally assembled by asking each group/discipline to provide a list of equipment; they specified equipment room-by-room with their corresponding heat load and approximate number of hours or usage within a 24-hour period. After some follow-up conversations with each group/discipline, a Room Equipment Heat Gain List was assembled. Confirmation responses and original e-mails from each group/discipline are contained in Attachments 1 through 6 and Attachment 8.

Table E-1. Equipment Heat Gain List

(See Assumption 3.1.4)

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
1002	LID BOLTING ROOM	SITE TRANSPORTER	1	0.25	0.85	75.0	HP	A	212,000			X	11,263		Mechanical Handling	See Attachment 8 & Note 15
1002	LID BOLTING ROOM	CASK PREPARATION PLATFORM	1	1.00	0.85	5.0	HP	A	15,500		X		0		Mechanical Handling	See Attachment 8
1002	LID BOLTING ROOM	LOADING ROOM SHIELD DOOR	1	0.10	1.00	(2) 7.5	HP	A	22,700 each		X		1,135		Mechanical Handling	See Attachment 6 & Note 15
1002	LID BOLTING ROOM	TAD	1	1.00	1.00	25.0	KW	N/A	85,325			X	85,325		Thermal Analysis	See Attachment 1
1002	LID BOLTING ROOM	LID BOLTING RM. CRANE (VFD) RATED 10 TON	1	0.35	1.00	25	HP	A	72,300		X		6,326		Mechanical Handling	See Attachment 6 & Note 15
1002	LID BOLTING ROOM	LID BOLTING RM. CRANE ASD	1	0.35	1.00	25	HP	A	2388		X		209			See Note 15
1002	LID BOLTING ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
1002	LID BOLTING ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1174		ES&H	See Attachment 3
1002	LID BOLTING ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
1002	LID BOLTING ROOM	MISC. EQUIPMENT	1	1.00	1.00				26,117	x			26,117		Mechanical Handling	See Note 16
1002	LID BOLTING ROOM												132,327			
1003A	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	3	1.00	1.00	30	Watts	N/A	102	X			307		ES&H	See Attachment 3
1003A	CORRIDOR												307			
1003B	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	2	1.00	1.00	30	Watts	N/A	102	X			205		ES&H	See Attachment 3
1003B	CORRIDOR												205			
1003E	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
1003E	CORRIDOR												102			
1003F	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	2	1.00	1.00	30	Watts	N/A	102	X			205		ES&H	See Attachment 3
1003F	CORRIDOR												205			
1003G	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	3	1.00	1.00	30	Watts	N/A	102	X			307		ES&H	See Attachment 3
1003G	CORRIDOR												307			
1004	HVAC ROOM (ITS HEPA	EXH-G EXHAUST FAN	1	1.00	1.00	200	HP	C	50,300	X			50,300		HVAC	See Attachment 5 and

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
	EXHAUST TRAIN A)															Assumption 3.1.22
1004	HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	EXH-G EXHAUST FAN ASD	1	1.00	1.00	200	HP	C	10,426	X			10,426		HVAC	See Attachment 5 and Note 14
1004	HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
1004	HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1,174		ES&H	See Attachment 3
1004	HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
1004	HVAC ROOM (ITS HEPA EXHAUST TRAIN A)												62,678			
1004A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN A)	200-VCTO-EXH-00009 EXHAUST FAN	1	1.00	1.00	5	HP	C	2,790	X			2,790		HVAC	See Attachment 5, Assumption 3.1.22 & Note 17
1004A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN A)	200-VCTO-EXH-00009 EXHAUST FAN ASD	1	1.00	1.00	5	HP	C	1,471	X			1,471		HVAC	See Attachment 5, Note 14 & Note 17
1004A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN A)	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
1004A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN A)	CONTINUOUS AIR MONITOR	8	1.00	1.00	150	Watts	N/A	512	X			4,096		ES&H	See Attachment 3
1004A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN A)												8,794			
1012	LLW STAGING ROOM	AREA RADIATION MONITOR	10	1.00	1.00	16	Watts	N/A	55	X			546		ES&H	See Attachment 3
1012	LLW STAGING ROOM	CONTINUOUS AIR MONITOR	10	1.00	1.00	43	Watts	N/A	147	X			1,466		ES&H	See Attachment 3
1012	LLW STAGING ROOM	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
1012	LLW STAGING ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
1012	LLW STAGING ROOM	LLW LIQUID SUMP PUMP	1	1.00	1.00	2	HP	C	1350		X		0		Mechanical Process	See Attachment 5
1012	LLW STAGING ROOM	LLW SAMPLING PUMP	1	1.00	1.00	0.5	HP	C	850		X		0		Mechanical Process	See Attachment 5
1012	LLW STAGING ROOM												2,455			
1013	LOADING ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
1013	LOADING ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1174		ES&H	See Attachment 3
1013	LOADING ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
1013	LOADING ROOM	TAD	1	1.00	1.00	25.0	KW	N/A	85,325			X	85,325		Thermal	See Attachment 1

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
															Analysis	
1013	LOADING ROOM	SITE TRANSPORTER	1	0.25	0.85	75.0	HP	A	212,000			X	45,050		Mechanical Handling	See Attachment 8
1013	LOADING ROOM													132,327		
1014	MAINTENANCE ROOM	CHW PUMP	1	1.00	1.00	50	HP	C	15,700	X			15,700		Mechanical Process	See Attachment 5 and Assumption 3.1.22
1014	MAINTENANCE ROOM	CHW PUMP ASD	1	1.00	1.00	50	HP	C	3,538	X			3,538		Mechanical Process	See Attachment 5 and Note 14
1014	MAINTENANCE ROOM	TBD HW PUMP	1	1.00	1.00	15	HP	C	6,210	X			6,210		Mechanical Process	See Attachment 5 and Assumption 3.1.22
1014	MAINTENANCE ROOM	TBD HW PUMP ASD	1	1.00	1.00	15	HP	C	1,930	X			1,930		Mechanical Process	See Attachment 5 and Note 14
1014	MAINTENANCE ROOM													27,378		
1015	CASK UNLOADING ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
1015	CASK UNLOADING ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1174		ES&H	See Attachment 3
1015	CASK UNLOADING ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
1015	CASK UNLOADING ROOM	TAD	1	1.00	1.00	25.0	KW	N/A	85,325			X	85,325		Thermal Analysis	See Attachment 1
1015	CASK UNLOADING ROOM	CASK TRANSFER TROLLEY	1	1.00	1.00	5.0	HP	A	15,500			X	0		Mechanical Handling	See Attachment 6: air operated motor
1015	Cask Unloading Room													87,277		
1016	CTM MAINTENANCE ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
1016	CTM MAINTENANCE ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1174		ES&H	See Attachment 3
1016	CTM MAINTENANCE ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
1016	CTM MAINTENANCE ROOM													1,952		
1017	CASK PREPARATION ROOM	AREA RADIATION MONITOR	12	1.00	1.00	16	Watts	N/A	55	X			655		ES&H	See Attachment 3
1017	CASK PREPARATION ROOM	CONTINUOUS AIR MONITOR	12	1.00	1.00	43	Watts	N/A	147	X			1761		ES&H	See Attachment 3
1017	CASK PREPARATION ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
1017	CASK PREPARATION ROOM	CASK PREPARATION PLATFORM	1	0.45	1.00	(2) 10	HP	A	29,900 each		X		6,728		Mechanical Handling	See Attachment 6 & Note 15
1017	CASK PREPARATION ROOM	CASK HANDLING CRANE (VFD) RATED: 200 TON	1	0.45	1.00	90	HP	A	254,600			X	28,642		Mechanical Handling	See Attachment 6 & Note 15.-Equip Load interpolated between 75 & 100 hp of Table 4.12 (Ref. 2.2.4)



Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
1017	CASK PREPARATION ROOM	CASK HANDLING CRANE ASD	1	0.45	1.00	90	HP	A	5374		X		604		Mechanical Handling	See Note 15
1017	CASK PREPARATION ROOM	TRANSPORTATION CASK WITH TAD ON RAIL CAR	1	1.00	1.00	25.0	KW	N/A	85,325			X	85,325		Waste Package	See Attachment 1
1017	CASK PREPARATION ROOM	CASK UNLOADING ROOM SHIELD DOOR	1	0.10	1.00	(2) 7.5	HP	A	22,700 each		X		1,135		Mechanical Handling	See Attachment 6 & Note 15
1017	CASK PREPARATION ROOM	MISC. EQUIPMENT	1	1.00	1.00				250,569	X			250,569		Mechanical Handling	See Note 16
1017	CASK PREPARATION ROOM													375,760		
1017A	CASK PREPARATION ANNEX	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
1017A	CASK PREPARATION ANNEX	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1174		ES&H	See Attachment 3
1017A	CASK PREPARATION ANNEX	CASK PREP. ROOM EQUIP CONFINEMENT DOOR SOUTH	1	0.10	1.00	(2) 3	HP	A	9,430 each		X		472		Mechanical Handling	See Attachment 6 & Note 15
1017A	CASK PREPARATION ANNEX													2,083		
1018	ELECTRICAL ROOM (NORMAL POWER)	480 V LOAD CENTER	1	1.00	1.00	11.16	KW	N/A	38,089	X			38,089		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	480 V MCC 1A	1	1.00	1.00	0.631	KW	N/A	2,154	X			2,154		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	480 V MCC 1B	1	1.00	1.00	0.631	KW	N/A	2,154	X			2,154		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	480 V MCC 1C	1	1.00	1.00	0.631	KW	N/A	2,154	X			2,154		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	480 V MCC 1D	1	1.00	1.00	0.631	KW	N/A	2,154	X			2,154		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	480 V MCC 1E	1	1.00	1.00	0.631	KW	N/A	2,154	X			2,154		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	480 V MCC 1F	1	1.00	1.00	0.631	KW	N/A	2,154	X			2,154		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	LIGHTING PANEL	1	1.00	1.00	0.5	KW	N/A	1,707	X			1,707		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	LIGHTING PANEL	1	1.00	1.00	0.5	KW	N/A	1,707	X			1,707		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	75 KVA XFMR	1	1.00	1.00	2.695	KW	N/A	9,198	X			9,198		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	DISTRIBUTION PANEL	1	1.00	1.00	0.5	KW	N/A	1,707	X			1,707		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	75 KVA XFMR	1	1.00	1.00	2.695	KW	N/A	9,198	X			9,198		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	DISTRIBUTION PANEL	1	1.00	1.00	0.5	KW	N/A	1,707	X			1,707		Electrical	See Attachment 2

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
1018	ELECTRICAL ROOM (NORMAL POWER)	DCMIS PANEL	1	1.00	1.00	0.4	KW	N/A	1,365	X			1,365		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	DCMIS PANEL	1	1.00	1.00	0.4	KW	N/A	1,365	X			1,365		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	PLC PANELS	1	1.00	1.00	0.34	KW	N/A	1,160	X			1,160		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	PLC PANELS	1	1.00	1.00	0.34	KW	N/A	1,160	X			1,160		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	UPS 05A	1	1.00	1.00	6.556	KW	N/A	22,376	X			22,376		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	MAINTENANCE BYPASS XFMR (40 KVA)	1	1.00	1.00	0.5	KW	N/A	1,707	X			1,707		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)	CABLE TRAY 36", 350'	1	1.00	1.00	3.78	KW	N/A	12,901	X			12,901		Electrical	See Attachment 2
1018	ELECTRICAL ROOM (NORMAL POWER)													118,271		
1019	HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	EXH-H EXHAUST FAN	1	1.00	1.00	200	HP	C	50,300	X			50,300		HVAC	See Attachment 5 and Assumption 3.1.22
1019	HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	EXH-H EXHAUST FAN ASD	1	1.00	1.00	200	HP	C	10,426	X			10,426		HVAC	See Attachment 5 and Note 14
1019	HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
1019	HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1,174		ES&H	See Attachment 3
1019	HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
1019	HVAC ROOM (ITS HEPA EXHAUST TRAIN B)													62,678		
1019A	HVAC ROOM (ITS HEPA EXHAUST FOR BATTERY ROOM TRAIN B)	200-VCTO-EXH-00011 EXHAUST FAN	1	1.00	1.00	15	HP	C	6,210	X			6,210		HVAC	See Attachment 5 and Assumption 3.1.22
1019A	HVAC ROOM (ITS HEPA EXHAUST FOR BATTERY ROOM TRAIN B)	200-VCTO-EXH-00011 EXHAUST FAN ASD	1	1.00	1.00	15	HP	C	1,930	X			1,930		HVAC	See Attachment 5 and Note 14
1019A	HVAC ROOM (ITS HEPA	AREA RADIATION	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
	EXHAUST FOR BATTERY ROOM (TRAIN B)	MONITOR														
1019A	HVAC ROOM (ITS HEPA EXHAUST FOR BATTERY ROOM (TRAIN B))	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1,174		ES&H	See Attachment 3
1019A	HVAC ROOM (ITS HEPA EXHAUST FOR BATTERY ROOM (TRAIN B))												9,751			
1029	ELEVATOR LOBBY	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
1029	ELEVATOR LOBBY												102			
1212	RP GEAR SUPPLY ROOM	PC	4	1.00	1.00	30	Watts	N/A	102	X			410		ES&H	See Attachment 3
1215	RP EQUIPMENT ROOM	PC	4	1.00	1.00	30	Watts	N/A	102	X			410		ES&H	See Attachment 3
1216	RESPIRATOR ROOM	PC	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
1216	RESPIRATOR ROOM	RESPIRATOR DRYING EQUIPMENT	1	1.00	1.00	2,760	Watts	N/A	9,420		X		0		ES&H	See Attachment 3
1216	RESPIRATOR ROOM	RESPIRATOR WASHING EQUIPMENT	1	1.00	1.00	2,760	Watts	N/A	9,420		X		0		ES&H	See Attachment 3
1217	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	5	1.00	1.00	30	Watts	N/A	102	X			512		ES&H	See Attachment 3
1218	RP LAB/COUNT ROOM	ALPHA SPECTOMETER	1	1.00	1.00	3	Watts	N/A	10	X			10		ES&H	See Attachment 3
1218	RP LAB/COUNT ROOM	FRISKER STATION	2	1.00	1.00	0	Watts	N/A	0	X			0		ES&H	See Attachment 3
1218	RP LAB/COUNT ROOM	GAMMA SPECTOMETER	2	1.00	1.00	1,200	Watts	N/A	4,096	X			8,191		ES&H	See Attachment 3
1218	RP LAB/COUNT ROOM	LIQUID SCINTILLATION COUNTER	1	1.00	1.00	1,230	Watts	N/A	4,198	X			4,198		ES&H	See Attachment 3
1218	RP LAB/COUNT ROOM	PROPORTIONAL COUNTER	1	1.00	1.00	575	Watts	N/A	1,962	X			1,962		ES&H	See Attachment 3
1218	RP LAB/COUNT ROOM	SWIPE COUNTER	2	1.00	1.00	575	Watts	N/A	1,962	X			3,925		ES&H	See Attachment 3
1219	RP LAB/SAMPLE PREPARATION ROOM	FRISKER STATION	1	1.00	1.00	0	Watts	N/A	0	X			0		ES&H	See Attachment 3
1219	RP LAB/SAMPLE PREPARATION ROOM	SAMPLE PREPARATION HOOD	1	1.00	1.00	0	Watts	N/A	0	X			0		ES&H	See Attachment 3
1220	DECON ROOM	FRISKER STATION	2	1.00	1.00	0	Watts	N/A	0	X			0		ES&H	See Attachment 3
1223	GAS SAMPLING ROOM	200-M60-MREO-00101-000	1	1.00	1.00	1	HP	A	3,390	X			3,390		Mechanical Process	See Attachment 5 and Assumption 3.1.22
1223	GAS SAMPLING ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4; Room 1006 is now Room 1223
1223	GAS SAMPLING ROOM	FRISKER STATION	2	1.00	1.00	0	Watts	N/A	0	X			0		ES&H	See Attachment 3

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
1224	RP INSTRUMENT ROOM	ELECTRONIC DOSIMETER CALIBRATOR	1	1.00	1.00	1	Watts	N/A	3	X			3		ES&H	See Attachment 3
1224	RP INSTRUMENT ROOM	PC	2	1.00	1.00	30	Watts	N/A	102	X			205		ES&H	See Attachment 3
Support Area 1212 thru 1224														23,659		
1221	RA EXIT/ PCM ROOM	COMPUTER TERMINAL WALL DISPLAY	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
1221	RA EXIT/ PCM ROOM	FRISKER	1	1.00	1.00	0	Watts	N/A	0	X			0		ES&H	See Attachment 3
1221	RA EXIT/ PCM ROOM	RADIATION AREA ACCESS CONTROL STATION	4	1.00	1.00	30	Watts	N/A	102	X			410		ES&H	See Attachment 3
1221	RA EXIT/ PCM ROOM	SMALL EQUIPMENT MONITOR	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
1221	RA EXIT/ PCM ROOM	PERSONNEL PORTAL MONITOR	4	1.00	1.00	250	Watts	N/A	853	X			3,413		ES&H	See Attachment 3
1221	RA EXIT/ PCM ROOM													4,027		
2001	OPERATIONS/MAINTENANCE STORAGE ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
2001	OPERATIONS/MAINTENANCE STORAGE ROOM													341		
2002A	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
2002A	CORRIDOR													102		
2002B	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	3	1.00	1.00	30	Watts	N/A	102	X			307		ES&H	See Attachment 3
2002B	CORRIDOR													307		
2002C	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
2002C	CORRIDOR													102		
2002E	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	5	1.00	1.00	30	Watts	N/A	102	X			512		ES&H	See Attachment 3
2002E	CORRIDOR													512		
2002F	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
2002F	CORRIDOR													102		
2002G	CORRIDOR	RADIATION AREA	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
		ACCESS CONTROL STATION														
2002G	CORRIDOR													102		
2003	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
2003	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1,174		ES&H	See Attachment 3
2003	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
2003	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	AHU-C AIR HANDLING UNIT ASD	1	1.00	1.00	125	HP	C	6,982	X			6,982		HVAC	See Attachment 5 and Note 14
2003	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	AHU-D AIR HANDLING UNIT ASD	1	1.00	1.00	125	HP	C	6,982	X			6,982		HVAC	See Attachment 5 and Note 14
2003	HVAC ROOM NORTH (PROCESS AREA SUPPLY)													15,916		
2004	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	AREA RADIATION MONITOR	6	1.00	1.00	16	Watts	N/A	55	X			328		ES&H	See Attachment 3
2004	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	CONTINUOUS AIR MONITOR	6	1.00	1.00	43	Watts	N/A	147	X			881		ES&H	See Attachment 3
2004	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
2004	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	AHU-E AIR HANDLING UNIT ASD	1	1.00	1.00	125	HP	C	6,982	X			6,982		HVAC	See Attachment 5 and Note 14
2004	HVAC ROOM NORTH (PROCESS AREA SUPPLY)													8,532		
2005	INSTRUMENT AND ELECTRICAL SHOP	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
2005	INSTRUMENT AND ELECTRICAL SHOP													341		
2006	HVAC ROOM (HEPA EXHAUST FOR SUPPORT, DECON AND LLW AREAS)	AREA RADIATION MONITOR	10	1.00	1.00	16	Watts	N/A	55	X			546		ES&H	See Attachment 3
2006	HVAC ROOM (HEPA EXHAUST FOR SUPPORT, DECON AND LLW AREAS)	CONTINUOUS AIR MONITOR	10	1.00	1.00	43	Watts	N/A	147	X			1,468		ES&H	See Attachment 3
2006	HVAC ROOM (HEPA EXHAUST FOR SUPPORT, DECON AND LLW AREAS)	EXH-D & E EXHAUST FAN	2	1.00	1.00	75	HP	C	21,200	X			42,400		HVAC	See Attachment 5 and Assumption 3.1.22
2006	HVAC ROOM (HEPA EXHAUST FOR SUPPORT, DECON AND LLW AREAS)	EXH-D & E EXHAUST FAN ASD	2	1.00	1.00	75	HP	C	4,685	X			9370		HVAC	See Attachment 5 and Note 14
2006	HVAC ROOM (HEPA EXHAUST FOR SUPPORT, DECON AND LLW AREAS)													53,784		
2007	CANISTER TRANSFER ROOM	CTM MAINTENANCE	1	0.10	0.85	35	HP	A	99,850		X		2,122		Mechanical	See Attachment 6 &

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
		CRANE (VFD) RATED 15 TON													Handling	Note 15 -Equipment Load interpolated between 30 & 40 hp of Table 4.12 (Ref. 2.2.4)
2007	CANISTER TRANSFER ROOM	CTM MAINTENANCE CRANE ASD	1	0.10	0.85	35	HP	A	2,849				61		Mechanical Handling	See Note 15
2007	CANISTER TRANSFER ROOM	CANISTER TRANSFER MACHINE (VFD): RATED: 450 TON	1	0.20	1.00	60	HP	A	172,000			X	8,600		Mechanical Handling	See Attachment 6
2007	CANISTER TRANSFER ROOM	CANISTER TRANSFER MACHINE ASD	1	0.20	1.00	60	HP	A	3,996				200		Mechanical Handling	See Note 15
2007	CANISTER TRANSFER ROOM	CAST PORT SLIDE GATE	1	0.10	1.00	(2) 0.5	HP	A	2,120 each		X		106		Mechanical Handling	See Attachment 6 & Note 15
2007	CANISTER TRANSFER ROOM	A/O/STC PORT SLIDE GATE	1	0.10	1.00	(2) 0.5	HP	A	2,120 each		X		106		Mechanical Handling	See Attachment 6 & Note 15
2007	CANISTER TRANSFER ROOM	TAD	1	1.00	1.00	25.0	KW	N/A	85,325			X	85,325		Thermal Analysis	See Attachment 1
2007	CANISTER TRANSFER ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
2007	CANISTER TRANSFER ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1,174		ES&H	See Attachment 3
2007	CANISTER TRANSFER ROOM	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
2007	CANISTER TRANSFER ROOM	MISC. EQUIPMENT	1	1.00	1.00				152,215	X			152,215		Mechanical Handling	See Note 16
2007	Canister Transfer Room												250,687			
2009	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
2009	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	AHU-F AIR HANDLING UNIT ASD	1	1.00	1.00	100	HP	C	5,834	X			5,834		HVAC	See Attachment 5 and Note 14
2009	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)												6,175			
2010	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3
2010	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1,174		ES&H	See Attachment 3
2010	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
2010	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	AHU-G AIR HANDLING UNIT ASD	1	1.00	1.00	100	HP	C	5,834	X			5,834		HVAC	See Attachment 5 and
2010	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	AHU-H AIR HANDLING UNIT ASD	1	1.00	1.00	75	HP	C	4,686	X			4,686		HVAC	See Attachment 5 and
2010	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)												12,472			
2011	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	AREA RADIATION MONITOR	8	1.00	1.00	16	Watts	N/A	55	X			437		ES&H	See Attachment 3

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
2011	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	Watts	N/A	147	X			1,174		ES&H	See Attachment 3
2011	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	RIO	1	1.00	1.00	100	Watts	N/A	341	X			341		I & C	See Attachment 4
2011	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	AHU-I AIR HANDLING UNIT ASD	1	1.00	1.00	75	HP	C	4,686	X			4,686		HVAC	See Attachment 5, and Assumption 3.1.22
2011	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)												6,638			
2012	RECIVER/DRYER EQUIPMENT ROOM	480V LOAD CENTER	1	1.00	1.00	7.1	KW	N/A	24,232	X			24,232		ELECTRIC AL	See Attachment 2
2012	RECIVER/DRYER EQUIPMENT ROOM	480V MCC	1	1.00	1.00	0.631	KW	N/A	2,154	X			2,154		ELECTRIC AL	See Attachment 2
2012	RECIVER/DRYER EQUIPMENT ROOM	480V MCC	1	1.00	1.00	0.631	KW	N/A	2,154	X			2,154		ELECTRIC AL	See Attachment 2
2012	RECIVER/DRYER EQUIPMENT ROOM	75 KVA XFMR	1	1.00	1.00	2.695	KW	N/A	9,198	X			9,198		ELECTRIC AL	See Attachment 2
2012	RECIVER/DRYER EQUIPMENT ROOM	LIGHTING PANEL	1	1.00	1.00	0.5	KW	N/A	1,707	X			1,707		ELECTRIC AL	See Attachment 2
2012	RECIVER/DRYER EQUIPMENT ROOM	DISTRIBUTION PANEL	1	1.00	1.00	0.5	KW	N/A	1,707	X			1,707		ELECTRIC AL	See Attachment 2
2012	RECIVER/DRYER EQUIPMENT ROOM	CABLE TRAY 36", 350'	1	1.00	1.00	3.78	KW	N/A	12,901	X			12,901		ELECTRIC AL	See Attachment 2
2012	RECIVER/DRYER EQUIPMENT ROOM	REFRIG. AIR DRYER AIR-COOLED CONDENSER HEAT REJECTION	1	0.50	1.00	120,596	BTU/H	N/A	60,298			X	60,298		Mechanical Process	Reference 2.2.28 Assumption 3.1.23
2012	RECIVER/DRYER EQUIPMENT ROOM	IA DRYER PACKAGED	1	0.50	1.00	3	KW	N/A	5120			X	5,120		Mechanical Process	See Attachment 5
2012	RECIVER/DRYER EQUIPMENT ROOM	MISC. EQUIPMENT	1	1.00	1.00				954				954			
2012	RECIVER/DRYER EQUIPMENT ROOM												120,425			
2029	ELEVATOR LOBBY	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	Watts	N/A	102	X			102		ES&H	See Attachment 3
2029	ELEVATOR LOBBY												102			

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load, Each Note 5	Units Note 6	Motor Location Note 7	Equip Load Btu/h Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Equip Load by Process Btu/hr Note 12	Equip Load USED, per Rm Btu/h Note 13	Originating Group/ Discipline	Remarks
----------	-----------	-----------------------	----------------	----------------------	-----------------------	---------------------------	-----------------	--------------------------	----------------------------	--------------------------------	-----------------------------------	--	---	--	----------------------------------	---------

- NOTES:
1. Description of equipment that gives up heat in a room.
  2. Quantity of equipment in a room.
  3. USE FACTOR means the approximate usage of equipment based on a 24 hour period.
  4. LOAD FACTOR applies to equipment driven by electric motor such as Cranes, Trolleys and Site Transporter. The electric motor horsepower selection is based on the maximum capacity that the equipment can handle. In reality, these pieces of equipment are not lifting or pulling the maximum load all the time during a 24 hour period, therefore 85% load factor is a very conservative assumption.
  5. Heat load that each equipment gives up into a room. Refer to next column for units (WATTS, KW or HP)
  6. The conversion factor used to convert WATTS to Btu/hr is 3.413 and KW to Btu/hr is 3413. For HP, refer to Note 7.
  7. Refer to Table 4.12 of ASHRAE Cooling and Heating Load Calculation Manual (Reference 2.2.4) for location of motor and driven equipment with respect to conditioned space or airstream (A - motor in, driven equipment in, B - motor out, driven equipment in, C - motor in, driven equipment out) and equivalent Btu/hr rating for listed motor hp.
  8. Equipment heat load in Btu/hr
  9. "Continuous Operation" means equipment is operating all the time 24 hour a day, heat load is constant.
  10. "Intermittent Operation" means equipment is operating ON and OFF during a 24 hour period. The time of operation is not simultaneous with other equipment in a room which is also operating intermittently.
  11. "Simultaneous Operation" means the equipment is also operating ON and OFF, but it operates at same time with other equipment which is also operating intermittently.
  12. Heat load by an individual equipment based on the type of operation (continuous, intermittent or simultaneous).
  13. The total equipment heat load per room (Obtained by adding all the equipment heat load in a room under the column "Equipment Load by Process"
  14. Reference 2.2.25, Equation 34, p. 868
  15. A 25% Diversity Factor is applied to the overall mechanical handling equipment (e.g. crane motors) heat gain per Attachment 9. (Example: Equip Load by Process = Use Factor x Load Factor x Equip Load X 0.25)
  16. Miscellaneous Equipment are future additional load that are not known at this time. (See Assumption 3.1.24)
  17. The brake horsepower for this exhaust fan increases from 5 to 5.65, however 5 brake horsepower was used in this calculation for this room only. The total heat load difference between 5 and 5.65 bhp is 252 Btu/h (approx. 7cfm) which is negligible.



**APPENDIX F: CALCULATED ROOF AND WALL COOLING LOADS**

Tables F-1 and F-2 present the room-by-room roof and wall cooling load calculations, respectively, for the peak month and hour of each room.

Table F-1. Room-by-Room Calculated Roof Cooling Loads

Room No. Note 1	Room Name Note 1	Room Peak Mo/hr Note 2	Design Room Temp. °F Note 1	Roof Area ft <sup>2</sup> Note 1	Roof Type Note 1	U-value of Roof Btu/h ft <sup>2</sup> °F Note 1	Unadjusted Roof CLTD °F Note 4	CLTD Correction for Latitude And Month °F Note 5	K Color Correction Factor Note 6	CLTD Indoor Temperature Adjustment °F Note 7	CLTD Outdoor Temperature Adjustment °F Note 8	f-factor Note 9	Adjusted Roof CLTD °F Note 10	Calculated Roof Load Btu/h Note 11
1002	Lid Bolting Room	6/15	90	1,980	Type 12	0.031	29	2	1	-12	4.05	1	23.05	1,415
1003A	Corridor	6/15	82	0										0
1003B	Corridor	All	82	0										0
1003C	Corridor	6/15	82	0										0
1003D	Corridor	All	82	0										0
1003E	Corridor	9/16	82	0										0
1003F	Corridor	9/15	82	0										0
1003G	Corridor	9/15	82	0										0
1003H	Utility Chase	All	90	0										0
1004	HVAC Room (ITS HEPA Exhaust Train A)	6/20	90	0										0
1004A	HVAC Room (ITS HEPA Exhaust for Battery Room Train A)	6/16	90	0										0
1012	LLW Staging Room	6/17	90	0										0
1013	Loading Room	All	100	0										0
1014	Maintenance Room	All	79	0										0
1015	Cask Unloading Room	All	100	0										0
1016	CTM Maintenance Room	All	90	0										0
1017	Cask Preparation Room	6/15	79	6,730	Type 12	0.031	29	2	1	-1	4.05	1	34.05	7,104
1017A	Cask Preparation Annex	9/19	79	0										0
1018	Electrical Room (Normal Power)	6/23	90	0										0
1018A	Battery Room (Normal Power)	9/21	77	0										0
1019	HVAC Room (ITS HEPA Exhaust Train B)	9/22	90	0										0
1019A	HVAC Room (ITS HEPA Exhaust for Battery Room Train B)	9/21	90	0										0
1028	Freight Elevator	6/16	90	260	Type 1	0.065	74	2	1	-12	4.05	1	68.05	1,150
1029	Elevator Lobby	9/15	82	0										0
1212 to 1224	Support Areas [Excluding Room 1221] (Assumption 3.1.20)	6/15	78	0										0
1221 & 1205	Support Areas (Assumption 3.1.20)	6/15	78	670	Type 1	0.065	74	2	1	0	4.05	1	80.05	3,486
2001	Operations/Maintenance Storage Room	6/21	90	1,790	Type 12	0.031	29	2	1	-12	4.05	1	23.05	1,279
2002A	Corridor	6/15	82	0										0
2002B	Corridor	All	82	0										0
2002C	Corridor	All	82	0										0
2002D	Corridor	6/15	82	0										0
2002E	Corridor	All	82	0										0
2002F	Corridor	6/15	82	0										0

Room No. Note 1	Room Name Note 1	Room Peak Mo/hr Note 2	Design Room Temp. °F Note 1	Roof Area ft <sup>2</sup> Note 1	Roof Type Note 1	U-value of Roof Btu/h ft <sup>2</sup> °F Note 1	Unadjusted Roof CLTD °F Note 4	CLTD Correction for Latitude And Month °F Note 5	K Color Correction Factor Note 6	CLTD Indoor Temperature Adjustment °F Note 7	CLTD Outdoor Temperature Adjustment °F Note 8	f-factor Note 9	Adjusted Roof CLTD °F Note 10	Calculated Roof Load Btu/h Note 11
2002G	Corridor	All	82	0										0
2003	HVAC Room North (Process Area Supply)	6/16	90	4,840	Type 12	0.031	29	2	1	-12	4.05	1	23.05	3,458
2004	HVAC Room North (Process Area Supply)	6/16	90	3,170	Type 12	0.031	29	2	1	-12	4.05	1	23.05	2,265
2005	Instrument and Electrical Shop	6/18	90	4,290	Type 12	0.031	29	2	1	-12	4.05	1	23.05	3,065
2006	HVAC Room (HEPA Exhaust for Support, Decon and LLW Areas)	6/17	90	3,180	Type 12	0.031	29	2	1	-12	4.05	1	23.05	2,272
2007	Canister Transfer Room	6/22	79	7,770	Type 12	0.031	29	2	1	-1	4.05	1	34.05	8,202
2009	HVAC Room South (Process Area Supply)	6/23	90	3,490	Type 12	0.031	29	2	1	-12	4.05	1	23.05	2,494
2010	HVAC Room South (Process Area Supply)	9/22	90	4,840	Type 12	0.031	29	-6.73	1	-12	4.05	1	14.32	2,149
2011	HVAC Room South (Process Area Supply)	9/22	90	3,170	Type 12	0.031	29	-6.73	1	-12	4.05	1	14.32	1,407
2012	Receiver/Dryer Equipment Room	9/21	90	4,290	Type 12	0.031	29	-6.73	1	-12	4.05	1	14.32	1,904
2029	Elevator Lobby	9/15	82	0										0
3001	Corridor	9/15	82	280	Type 1	0.065	74	-6.73	1	-4	4.05	1	67.32	1,225
3029	Elevator Lobby	6/15	82	0										0
R001	Firefight Elevator Machine Room	6/16	90	940	Type 1	0.065	74	2	1	-12	4.05	1	68.05	4,158
													Grand Total	47,033

## NOTES:

- From information and data contained in the Room Load Information Sheets in Appendix A. See the Room Load Information Sheets for additional remarks about the loads per room.
- Determined using the Cooling and Heating Load Calculation Methodology on a room-by-room basis, outlined in Section 6.1.3. "All" means that the load is constant, room has no exterior exposure.
- Not Used.
- From Appendix B, Table B-1.
- From Appendix B, Table B-2.
- See Assumption 3.2.3.
- Appendix B, From Equation B-1. The value equals 78 oF minus the design room temperature.
- Appendix B, From Equation B-1. The value equals the average outside temperature on design day minus 85 oF, where the average outside temperature is 89.05 oF for 102 oF.
- From Appendix B text and part of Equation B-1.
- Using Equation B-1 with information from the previous columns.
- Product of "Roof Area", "U-Value of Roof," and "Adjusted Roof CLTD." (Equation C-1)

Table F-2. Room-by-Room Calculated Wall Cooling Loads

Room No. Note 1	Room Name Note 1	Room Peak Mo/hr Note 2	Design Room Temp. °F Note 1	Wall Orientation Note 1	U-value of Wall Btu/h ft <sup>2</sup> °F Note 1	Wall Area ft <sup>2</sup> Note 1	Wall Group Note 1	Unadjusted Wall CLTD °F Note 4	CLTD Correction for Latitude And Month °F Note 5	K Color Correction factor Note 6	CLTD Indoor Temperature Adjustment °F Note 7	CLTD Outdoor Temperature Adjustment °F Note 8	Adjusted Wall CLTD °F Note 9	Calculated Wall Load Btu/h Note 10	Total Wall Load Btu/h Note 11
1002	Lid Bolting Room	6/15	90	NW	0.22	2750	B	12	1.42	1	-12	4.05	5.47	3,309	3,309
1003A	Corridor	6/15	82	NE	0.22	130	B	18	1.42	1	-4	4.05	19.47	557	557
1003B	Corridor	All	82												0
1003C	Corridor	6/15	82	NE	0.22	110	B	18	1.42	1	-4	4.05	19.47	471	471
1003D	Corridor	All	82												0
1003E	Corridor	9/16	82	SW	0.113	150	G	63	3.58	1	-4	4.05	66.63	1,129	1,129
1003F	Corridor	9/15	82	SW	0.22	130	B	14	3.58	1	-4	4.05	17.63	504	504
1003G	Corridor	9/15	82	SW	0.22	100	B	14	3.58	1	-4	4.05	17.63	388	388
1003H	Utility Chase	All	90												0
1004	HVAC Room (ITS HEPA Exhaust Train A)	6/20	90	NE	0.22	1060	B	21	1.42	1	-12	4.05	14.47	3,374	3,374
1004A	HVAC Room (ITS HEPA Exhaust for Battery Room Train A)	6/16	90	NE	0.22	700	B	19	1.42	1	-12	4.05	12.47	1,920	1,920
1012	LLW Staging Room	6/17	90	NE	0.22	1380	B	19	1.42	1	-12	4.05	12.47	3,786	
		6/17	90	NW	0.37	1410	B	13	1.42	1	-12	4.05	6.47	3,375	
														Total	7,161
1013	Loading Room	All	100												0
1014	Maintenance Room	All	79												0
1015	Cask Unloading Room	All	100												0
1016	CTM Maintenance Room	All	90												0
1017	Cask Preparation Room	6/15	79	SE	0.22	890	B	21	-0.85	1	-1	4.05	23.2	4,543	
		6/15	79	NE	0.22	730	B	18	1.42	1	-1	4.05	22.47	3,609	
		6/15	79	SW	0.22	730	B	14	-0.85	1	-1	4.05	16.2	2,602	
														Total	10,753
1017A	Cask Preparation Annex	9/19	79	SE	0.22	670	B	26	3.58	1	-1	4.05	32.63	4,810	4,810
1018	Electrical Room (Normal Power)	6/23	90	SW	0.22	830	B	28	-0.85	1	-12	4.05	19.2	3,506	
		6/23	90	NW	0.22	1660	B	23	1.42	1	-12	4.05	16.47	6,015	
														Total	9,521
1018A	Battery Room (Normal Power)	9/21	77	SW	0.22	640	B	27	3.58	1	1	4.05	35.63	5,017	
		9/21	77	NW	0.22	170	B	21	-4.58	1	1	4.05	21.47	803	
														Total	5,820
1019	HVAC Room (ITS HEPA Exhaust Train B)	9/22	90	SW	0.22	1060	B	28	3.58	1	-12	4.05	23.63	5,511	5,511
1019A	HVAC Room (ITS HEPA Exhaust for Battery Room Train B)	9/21	90	SW	0.22	700	B	27	3.58	1	-12	4.05	22.63	3,485	3,485
1028	Freight Elevator	6/16	90	NW	0.113	1080	G	47	1.42	1	-12	4.05	40.47	4,939	
		6/16	90	SW	0.113	790	G	63	-0.85	1	-12	4.05	54.2	4,838	

Room No. Note 1	Room Name Note 1	Room Peak Mo/hr Note 2	Design Room Temp. °F Note 1	Wall Orientation Note 1	U-value of Wall Btu/h ft <sup>2</sup> °F Note 1	Wall Area ft <sup>2</sup> Note 1	Wall Group Note 1	Unadjusted Wall CLTD °F Note 4	CLTD Correction for Latitude And Month °F Note 5	K Color Correction factor Note 6	CLTD Indoor Temperature Adjustment °F Note 7	CLTD Outdoor Temperature Adjustment °F Note 8	Adjusted Wall CLTD °F Note 9	Calculated Wall Load Btu/h Note 10	Total Wall Load Btu/h Note 11
		6/16	90	NE	0.113	470	G	26	1.42	1	-12	4.05	19.47	1,034	
														Total	10,811
1029	Elevator Lobby	9/15	82	SW	0.113	740	G	59	3.58	1	-4	4.05	62.63	5,237	5,237
1212 to 1224	Support Areas [Excluding Room 1221] (Assumption 3.1.20)	6/15	78	NE	0.22	1550	B	18	1.42	1	0	4.05	23.47	8,003	8,003
1221 & 1205	Support Areas (Assumption 3.1.20)	6/15	78												0
2001	Operations/Maintenance Storage Room	6/21	90	NE	0.22	1470	B	21	1.42	1	-12	4.05	14.47	4,680	
		6/21	90	NW	0.22	1250	B	21	1.42	1	-12	4.05	14.47	3,979	
														Total	8,659
2002A	Corridor	6/15	82	NE	0.22	130	B	18	1.42	1	-4	4.05	19.47	557	557
2002B	Corridor	All	82												0
2002C	Corridor	All	82												0
2002D	Corridor	6/15	82	NE	0.113	140	G	27	1.42	1	-4	4.05	28.47	450	
		6/15	82	SW	0.113	140	G	59	-0.85	1	-4	4.05	58.2	921	
														Total	1,371
2002E	Corridor	All	82												0
2002F	Corridor	6/15	82	NE	0.22	130	B	18	1.42	1	-4	4.05	19.47	557	557
2002G	Corridor	All	82												0
2003	HVAC Room North (Process Area Supply)	6/16	90	NE	0.22	1760	B	19	1.42	1	-12	4.05	12.47	4,828	4,828
2004	HVAC Room North (Process Area Supply)	6/16	90	NE	0.22	1250	B	19	1.42	1	-12	4.05	12.47	3,429	3,429
2005	Instrument and Electrical Shop	6/18	90	NE	0.22	1660	B	20	1.42	1	-12	4.05	13.47	4,919	
		6/18	90	SE	0.22	2070	B	25	-0.85	1	-12	4.05	16.2	7,377	
														Total	12,297
2006	HVAC Room (HEPA Exhaust for Support, Decon and LLW Areas)	6/17	90	NE	0.22	1380	B	19	1.42	1	-12	4.05	12.47	3,786	
		6/17	90	NW	0.37	2370	B	13	1.42	1	-12	4.05	6.47	5,674	
														Total	9,459
2007	Canister Transfer Room	6/22	79	NE	0.22	3780	B	21	1.42	1	-1	4.05	25.47	21,181	
		6/22	79	SW	0.22	3320	B	28	-0.85	1	-1	4.05	30.2	22,058	
		6/22	79	NW	0.22	2660	B	22	1.42	1	-1	4.05	26.47	15,490	
		6/22	79	SE	0.22	2070	B	26	-0.85	1	-1	4.05	28.2	12,842	
														Total	71,571
2009	HVAC Room South (Process Area Supply)	6/23	90	SW	0.22	1470	B	28	-0.85	1	-12	4.05	19.2	6,209	
		6/23	90	NW	0.22	1820	B	23	1.42	1	-12	4.05	16.47	6,595	
														Total	12,804

Room No. Note 1	Room Name Note 1	Room Peak Mo/hr Note 2	Design Room Temp. °F Note 1	Wall Orientation Note 1	U-value of Wall Btu/h ft <sup>2</sup> °F Note 1	Wall Area ft <sup>2</sup> Note 1	Wall Group Note 1	Unadjusted Wall CLTD °F Note 4	CLTD Correction for Latitude And Month °F Note 5	K Color Correction factor Note 6	CLTD Indoor Temperature Adjustment °F Note 7	CLTD Outdoor Temperature Adjustment °F Note 8	Adjusted Wall CLTD °F Note 9	Calculated Wall Load Btu/h Note 10	Total Wall Load Btu/h Note 11
2010	HVAC Room South (Process Area Supply)	9/22	90	SW	0.22	1760	B	28	3.58	1	-12	4.05	23.63	9,150	9,150
2011	HVAC Room South (Process Area Supply)	9/22	90	SW	0.22	1250	B	28	3.58	1	-12	4.05	23.63	6,498	6,498
2012	Receiver/Dryer Equipment Room	9/21	90	SW	0.22	1460	B	27	3.58	1	-12	4.05	22.63	7,269	
		9/21	90	SE	0.22	2300	B	26	3.58	1	-12	4.05	21.63	10,945	
														Total	18,214
2029	Elevator Lobby	9/15	82	SW	0.113	1060	G	59	3.58	1	-4	4.05	62.63	7,502	
		9/15	82	NW	0.113	290	G	37	-4.58	1	-4	4.05	32.47	1,064	
														Total	8,566
3001	Corridor	9/15	82	SW	0.113	290	G	59	3.58	1	-4	4.05	62.63	2,052	
		9/15	82	SE	0.113	200	G	32	3.58	1	-4	4.05	35.63	805	
														Total	2,858
3029	Elevator Lobby	6/15	82	SW	0.113	400	G	59	-0.85	1	-4	4.05	58.2	2,631	
		6/15	82	NW	0.113	110	G	37	1.42	1	-4	4.05	38.47	478	
		6/15	82	SE	0.113	120	G	32	-0.85	1	-4	4.05	31.2	423	
		6/15	82	NE	0.113	290	G	27	1.42	1	-4	4.05	28.47	933	
														Total	4,465
R001	Firefight Elevator Machine Room	6/16	90	NE	0.113	600	G	26	1.42	1	-12	4.05	19.47	1,320	
		6/16	90	SE	0.113	340	G	30	-0.85	1	-12	4.05	21.2	815	
		6/16	90	SW	0.113	460	G	63	-0.85	1	-12	4.05	54.2	2,817	
		6/16	90	NW	0.113	340	G	47	1.42	1	-12	4.05	40.47	1,555	
														Total	6,507
														Grand Total	264,554

NOTES:

1. From information and data contained in the Room Load Information Sheets in Appendix A. See the Room Load Information Sheets for additional remarks about the loads per room.
2. Determined using the Cooling and Heating Load Calculation Methodology on a room-by-room basis, outlined in Section 6.1.3. "All" means that the load is constant, room has no exterior exposure.
3. Not Used.
4. From Appendix B, Table B-1.
5. From Appendix B, Table B-2.
6. See Assumption 3.2.3.
7. Appendix B, From Equation B-2. The value equals 78°F minus the design room temperature.
8. Appendix B, From Equation B-2. The value equals the average outside temperature on design day minus 85°F, where the average outside temperature is 89.05°F for 102°F.
9. Using Equation B-2 with information from the previous columns.
10. Product of "Wall Area," "U-Value of Wall," and "Adjusted Wall CLTD." (Equation C-2)
11. Sum of Calculated Wall Loads per room.

**APPENDIX G: CALCULATION OF THERMODYNAMIC PROPERTIES OF MOIST AIR**

Table G-1. Thermodynamic Properties of Moist Air

<b>SYSTEM AHU-B (AHU-00001, 2 &amp; 3) (Recirculating with Outside Air)</b>									
Description	Air Flow Cfm Note 1	Elevation ft. Note 2	Air Dry Bulb Temp. °F Note 5	Air Wet Bulb Temp. °F Note 3	Air Dew Point Temp. °F Note 3	Humidity Ratio W lb water/lb dry air Note 4	Specific Volume v cu. ft./lb dry air Note 3	Enthalpy h Btu/lb dry air Note 3	Density d lb/cu. ft. Note 3
Supply Air Leaving Coil	53,500	3,310	51 Note 5	46.36	42.5	0.00645	14.7	19.23	0.068
Air Leaving Supply Fan / Entering the Coil	53,500	3,310	92.56 Note 6	62.05	42.5	0.00645	15.87	29.33	0.063
Return Air	38,320	3,310	80.45 Note 7	57.97	42.5	0.00645	15.52	26.39	0.064
Mixed Air Ent. Fan	53,500	3,310	86.56 Note 8	60.07	42.5	0.00645	15.70	27.87	0.064
Outside Air	15,180	3,310	102 Note 2	65	42.5	0.00645	16.15	31.63	0.062
<b>SYSTEM AHU-C (AHU-00004 &amp; 5) (Recirculating with Outside Air)</b>									
Supply Air Leaving Coil	31,770	3,310	51 Note 5	46.36	42.5	0.00645	14.7	19.23	0.068
Air Leaving Supply Fan / Entering the Coil	31,770	3,310	95.96 Note 6	63.13	42.5	0.00645	15.97	30.15	0.063
Return Air	23,070	3,310	85.42 Note 7	59.69	42.5	0.00645	15.67	27.60	0.064
Mixed Air Ent. Fan	31,770	3,310	89.96 Note 8	61.20	42.5	0.00645	15.80	28.70	0.063
Outside Air	8,700	3,310	102 Note 2	65	42.5	0.00645	16.15	31.63	0.062
<b>SYSTEM AHU-D (AHU-00006 &amp; 7) (100% Outside Air)</b>									
Supply Air Leaving Coil	28,390	3,310	51 Note 5	46.36	42.5	0.00645	14.7	19.23	0.068
Air Leaving Supply Fan / Entering the Coil	28,390	3,310	108 Note 6	66.78	42.5	0.00645	16.32	33.08	0.061
Outside Air Ent. Fan	28,390	3,310	102 Note 2	65	42.5	0.00645	16.15	31.63	0.062

## NOTES:

1. Taken from Table 5. Outside air is taken as the difference between the supply airflow and the return airflow.
2. Site elevation, see Section 6.1.1.
3. The thermodynamic properties of moist air are determined using psychrometric equations in Appendix D.
4. Assumption 3.1.11.
5. Assumption 3.1.5.
6. Air temperature entering fan plus 6°F (Assumption 3.1.6).
7. Mixed return air temperature from multiple rooms (individual airflow and temperature taken from Table 5), using equation D-13.
8. Mixed return/outside air temperature, using equation D-13.

## APPENDIX H: INFILTRATION AIR COOLING LOAD CALCULATION (ROOM-BY-ROOM)

Table H-1. Infiltration Air Cooling Load

INPUT DATA							SENSIBLE
Room No.	Room Name	Design Temperature			Infiltration CFM	Constant 60 x 0.24 x 0.062 = 0.893	Infiltration Load Btu/h
		Outdoor °F	Adjacent Room °F	Room °F			
Note 1		Note 2	Note 4	Note 1	Note 1	Note 5	Note 3
1002	Lid Bolting Room	102	-	90	910	0.893	9,752
1003A	Corridor	102	-	82	570	0.893	10,180
1003B	Corridor	102	-	82	0	0.893	0
1003C	Corridor	102	-	82	390	0.893	6,965
1003D	Corridor	102	-	82	0	0.893	0
1003E	Corridor	102	-	82	0	0.893	0
1003F	Corridor	102	-	82	330	0.893	5,894
1003G	Corridor	102	-	82	590	0.893	10,537
1003H	Utility Chase	102	-	90	0	0.893	0
1004	HVAC Room (ITS HEPA Exhaust Train A)	102	-	90	30	0.893	321
1004A	HVAC Room (ITS HEPA Exhaust for Battery Room Train A)	102	-	90	70	0.893	750
1012	LLW Staging Room	102	-	90	430	0.893	4,608
1013	Loading Room	102	-	100	0	0.893	0
1014	Maintenance Room	102	-	79	0	0.893	0
1015	Cask Unloading Room	102	-	100	0	0.893	0
1016	CTM Maintenance Room	102	-	90	0	0.893	0
1017	Cask Preparation Room	102	-	79	1,160	0.893	23,825
1017A	Cask Preparation Annex	102	-	79	0	0.893	0
1018	Electrical Room (Normal Power)	102	-	90	60	0.893	643
1018A	Non ITS Battery Room	102	-	77	110	0.893	2,456
1019	HVAC Room (ITS HEPA Exhaust Train B)	102	-	90	30	0.893	321
1019A	HVAC Room (ITS HEPA Exhaust for Battery Room Train B)	102	-	90	70	0.893	750
1028	Freight Elevator	102	-	90	0	0.893	0
1029	Elevator Lobby	102	-	82	1,770	0.893	31,612
1212 to 1224	C2 Support (Excluding 1221, Assumption 3.1.20)	102	-	75	1,270	0.893	30,621
1221 & 1205	C2 Support	102	-	75	0	0.893	0
2001	Operations/Maintenance Storage Room	102	-	90	150	0.893	1,607
2002A	Corridor	102	-	82	340	0.893	6,072
2002B	Corridor	102	-	82	0	0.893	0
2002C	Corridor	102	-	82	0	0.893	0
2002D	Corridor	102	-	82	2,000	0.893	35,720



INPUT DATA							SENSIBLE
Room No.	Room Name	Design Temperature			Infiltration CFM	Constant 60 x 0.24 x 0.062 = 0.893	Infiltration Load Btu/h
		Outdoor °F	Adjacent Room °F	Room °F			
Note 1		Note 2	Note 4	Note 1	Note 1	Note 5	Note 3
2002E	Corridor	102	-	82	0	0.893	0
2002F	SW Corridor	102	-	82	340	0.893	6,072
2002G	Corridor	102	-	82	0	0.893	0
2003	HVAC Room North (Process Area Supply)	102	-	90	150	0.893	1,607
2004	HVAC Room North (Process Area Supply)	102	-	90	110	0.893	1,179
2005	Instrument and Electrical Shop	102	-	90	240	0.893	2,572
2006	HVAC Room (HEPA Exhaust for Support, Decon and LLW Areas)	102	-	90	510	0.893	5,465
2007	Canister Transfer Rm	102	-	79	100	0.893	2,054
2009	HVAC Room South (Process Area Supply)	102	-	90	190	0.893	2,036
2010	HVAC Room South (Process Area Supply)	102	-	90	150	0.893	1,607
2011	HVAC Room South (Process Area Supply)	102	-	90	110	0.893	1,179
2012	Receiver /Dryer Equipment Room	102	-	90	240	0.893	2,572
2029	Elevator Lobby	102	-	82	1,170	0.893	20,896
3001	Corridor	102	-	82	210	0.893	3,751
3029	Elevator Lobby	102	-	82	1,110	0.893	19,825
R001	Freight Elevator Machine Room	102	-	90	0	0.893	0
Totals			-		14,910		253,451


## NOTES:


1. Obtained from the Room Load Information Sheets in Appendix A
2. Outdoor dry bulb design temperature, Section 6.1.1
3. Infiltration loads are calculated using Equation C-15 from Appendix C, where input data comes from the Room Load Information Sheets in Appendix A.
4. This information is not used in the calculation of the infiltration loads
5. Constant based on Density of Air at 3310 ft. altitude (0.062 lbs./cu. ft.), Refer to Appendix D for the appropriate equations to calculate air density

**ATTACHMENT 1: EMAIL REGARDING WASTE PACKAGES AND CANISTERS  
HEAT GAIN INFORMATION**

(2 pages)

This e-mail is from Delwin Mecham of BSC Thermal Analysis, dated 12/18/07, to Greg Gould of the BSC Mechanical HVAC Group. It confirms the use of Waste Cask heat load in the RF as an assumption requiring verification.

 Delwin Mecham  
12/18/2007 07:19 AM

To: Greg Gould/YM/RWDOE@CRWMS  
cc:  
Subject: Re: Fw: HVAC Heat Load input 

LSN: Not Relevant - Not Privileged  
User Filed as: Exc/AdminMgmt-14-4/QA:N/A

Based on the following, I suggest the surface design HVAC to the following heat loads:

TAD	25 kW each
DOE canisters	1.5 kW each
Naval canisters	11.8 kW each
Waste Packages	18 kW to 25 kW each

Total heat load per room will depend on number of items per room.

---

TAD 25 kW based on the range in the TAD draft specification, also Thermal Management Study Section 3.4. (DIRS 172739). There really is no limit, it is whatever the vendors design, but 30 kW should be bounding, 22 kW is more likely.

WP 18.0 kW based on pending TMRB decision (TMRB 2007-084), but better use 25 kW to meet potential changes in drift thermal requirements.

DOE canister 1500 watts REF: [DIRS 176668] "Request for Updated U.S. Department of Energy (DOE) Canister Thermal Output Limits in Support of Repository Design (EM-FMDP-06-006)." Memorandum from M.R. Arenaz (DOE) to W.J. Arthur, III (DOE/ORD), February 6, 2006, 0210065322, with enclosures. ACC: MOL.20060315.0141.


Naval canister 11.8 kW REF: Section 11 of [DIRS 165219] Naval Nuclear Propulsion Program Technical Baseline Compliance Document, Revision 1, October 2002. Letter from J.M. McKenzie (DOE) to J. Williams (DOE/OCRWM)

**ATTACHMENT 2: E-MAIL REGARDING RF ELECTRICAL EQUIPMENT HEAT  
GAIN INFORMATION**

(5 pages)

This e-mail is from Arsenio Mendiola of the BSC Electrical Group to Tracy Johnson of the BSC Mechanical HVAC Group, and then forwarded to Greg Gould of the BSC Mechanical HVAC Group. It confirms the electrical heat load in the RF Electrical Room (Normal Power).

There are seven files attached to the e-mail. Three pertain to different facilities and the one that pertains to the RF ITS Electrical Room is not applicable to this calculation. Only the file that contains information on the RF Electrical Room 1018 (Normal Power) and Room 2012 are shown and deemed pertinent to this calculation.

 Greg Gould  
11/14/2007 11:38 AM


To: Monico Pingul/YM/RWDOE@CRWMS, Elpidio Castroverde/YM/RWDOE@CRWMS, Gin Cababa/YM/RWDOE@CRWMS, Fred Favis/YM/RWDOE@CRWMS, Orlando Santiago/YM/RWDOE@CRWMS, Jerry Herszman/YM/RWDOE@CRWMS, Hang Yang/YM/RWDOE@CRWMS, Oscar Rosales/YM/RWDOE@CRWMS, Ricardo Abraham/YM/RWDOE@CRWMS, Orlando Asuncion/YM/RWDOE@CRWMS, Francis Banea/YM/RWDOE@CRWMS

cc:  
Subject: Fw: Heat Loss update

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA:NA

FYI.

----- Forwarded by Greg Gould/YM/RWDOE on 11/14/2007 11:37 AM -----

 Arsenio Mendiola  
11/14/2007 11:33 AM


To: Tracy Johnson/YM/RWDOE@CRWMS  
cc: Debra Nevergold/YM/RWDOE@CRWMS, David Tooker/YM/RWDOE@CRWMS, Roshellia Goines/YM/RWDOE@CRWMS, Hadi Jalali/YM/RWDOE@CRWMS, Greg Gould/YM/RWDOE@CRWMS, Robert Slovic/YM/RWDOE@CRWMS, Muhammad N Islam/YM/RWDOE@CRWMS  
Subject: Heat Loss update

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA:NA

Attached below are the estimated heat losses for nuclear facilities.

Regards,  
Arsenio





----- Forwarded by Arsenio Mendiola/YM/RWDOE on 11/14/2007 10:58 AM -----

 Muhammad N Islam  
11/14/2007 10:08 AM

To: Arsenio Mendiola/YM/RWDOE@CRWMS  
cc: Amando de la Cruz/YM/RWDOE@CRWMS  
Subject: Heat Loads Updated

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA:NA

Incorporated your comments.

     
CRCF Heat Loads.xls Heat loss for RF (normal).xls Heat loss for RF ITS Train B.xls Heat loss for RF ITS TrainA.xls



Heat loss for RF ROOM 2012.xls IHF Heat Loads.xls WHF Heat Loads 1.xls

## Attachment 2 – Print of Attached File, Normal RF.xls

RF HANDLING FACILITY (RF)		
ELECTRICAL ROOM 1018(Normal) HEAT LOSS ESTIMATE (PRELIMINARY)		
ELECTRICAL EQUIPMENT	HEAT LOSS IN kW	EQUIPMENT NUMBER
480 V Load Center	11.160	200-EEN0-LC-00001
480 V MCC	0.631	200-EEN0-MCC-00001
480 V MCC	0.631	200-EEN0-MCC-00002
480 V MCC	0.631	200-EEN0-MCC-00003
480 V MCC	0.631	200-EEN0-MCC-00004
480 V MCC	0.631	200-EEN0-MCC-00005
480 V MCC	0.631	200-EEN0-MCC-00006
Lighting Panel	0.500	200-EULO-PL-00001
Lighting Panel	0.500	200-EULO-PL-00002
75 kVA XFMR	2.695	200-EEN0-XFMR-00004
Distribution Panel	0.500	200-EEN0-PL-00004
75 kVA XFMR	2.695	200-EEN0-XFMR-00003
Distribution Panel	0.500	200-EEN0-PL-00003
DCMIS Panel	0.400	
DCMIS Panel	0.400	
PLC Panels	0.340	
PLC Panels	0.340	
UPS 05A	6.556	200-EEPO-UX-00001
Maintenance Bypass XFMR (40 kVA)	0.500	200-EEPO-XFMR-00001
Cable Tray 36", 350'	3.780	
<b>Total In kW</b>	<b>34.652</b>	

## Attachment 2 – Print of Attached File, Normal RF.xls


RF HANDLING FACILITY (RF)		
ELECTRICAL ROOM 2012 (Normal) HEAT LOSS ESTIMATE (PRELIMINARY)		
ELECTRICAL EQUIPMENT	HEAT LOSS IN kW	EQUIPMENT NUMBER
480 V Load Center	7.1	200-EEN0-LC-00002
480 V MCC	0.631	200-EEN0-MCC-00007
480 V MCC	0.631	200-EEN0-MCC-00008
Lighting Panel	0.5	200-EUL0-PL-00007
75 kVA XFMR	2.695	200-EEN0-XFMR-00005
Distribution Panel	0.5	200-EEN0-PL-00005
Cable Tray 36", 350'	3.78	
<b>Total In kW</b>	<b>15.837</b>	



**ATTACHMENT 3: E-MAIL REGARDING ENVIRONMENTAL, SAFETY & HEALTH  
EQUIPMENT HEAT GAIN INFORMATION**

(12 pages)

This e-mail is from Thomas Bastian of the BSC Environmental, Safety And Health Group, dated 6/20/07, to Ricardo Abraham of the BSC Mechanical HVAC Group. It confirms the heat loads of various pieces of equipment located throughout the RF.

 Ricardo Abraham  
07/09/2007 07:58 AM

To: Clayton De Losier/YM/RWDOE@CRWMS  
cc:  
Subject: Fw: HVAC Heat Gain Information for RF Facility

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

FYI

----- Forwarded by Ricardo Abraham/YM/RWDOE on 07/09/2007 08:02 AM -----

  
Thomas Bastian 06/20/2007 02:43 PM

To: Ricardo Abraham/YM/RWDOE@CRWMS  
cc: Gregory Eadie/YM/RWDOE@CRWMS, Stacy Junio/YM/RWDOE@CRWMS  
Subject: Re: HVAC Heat Gain Information for RF Facility <sup>19</sup>

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

Ricardo,

I have attached the file containing an estimate of the heat producing radiation protection equipment in the RF.

I will be out of the office until 6/25. I can answer any questions when I return.

Tom



RP Equipment Load List RF (06-25-07).xls

▼ Ricardo Abraham

 Ricardo Abraham:  
06/15/2007 03:18 PM

To: Thomas Bastian/YM/RWDOE@CRWMS  
cc: Oscar Rosales/YM/RWDOE@CRWMS, Tracy Johnson/YM/RWDOE@CRWMS  
Subject: HVAC Heat Gain Information for RF Facility

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

Tom,

I'm doing the HVAC cooling load calculation for the RF facility (C2) areas. Please provide the ES&H equipment list, location, and load that will be release to the rooms for all the equipment that you are using for the RF facility

Attached is our standard form that you might want to use for listing the equipment.

Thanks,

Ricardo



EquipHtGainListForm.xls

Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Use Factor Note 3	Load Factor Note 4	Heat Load Note 5	Units Note 6	Motor Location Type Note 7	Equip Load Btu/hr Note 8	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittant) Note 11	Equipment Load by Process Btu/h Note 12	Process Note 13	Equip Load USED, per RM Btu/h Note 14	Originating Group/ Discipline	Remarks
1001	SITE TRANSPORTER VESTIBULE	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1002	LID BOLTING ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1002	SITE TRANSPORTER VESTIBULE	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1002	LID BOLTING ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1004	HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1004	HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1011	LLW VESIBULE	AREA RADIATION MONITOR	4	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1011	LLW VESIBULE	CONTINUOUS AIR MONITOR	4	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1012	LLW STAGING ROOM	AREA RADIATION MONITOR	10	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR

## Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)

1012	LLW STAGING ROOM	CONTINUOUS AIR MONITOR	10	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1012	LLW STAGING ROOM ENTRANCE	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1013	LOADING ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1013	LOADING ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1015	CASK UNLOADING ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1015	CASK UNLOADING ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1016	CTM MAINTENANCE ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1016	CTM MAINTENANCE ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1017	CASK PREPARATION ROOM	AREA RADIATION MONITOR	12	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1017	CASK PREPARATION ROOM	CONTINUOUS AIR MONITOR	12	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1019	HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR

## Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)

1019	HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA ICAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1021	TRANSPORTATION CASK VESIBULE ANNEX	AREA RADIATION MONITOR	4	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1021	TRANSPORTATION CASK VESIBULE ANNEX	CONTINUOUS AIR MONITOR	4	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA ICAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1029	ELEVATOR LOBBY	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1203	RA CONTROL POINT	BAR CODE SCANNER	1	1.00	1.00	0			0	X						ES&H	ASSUME NO HEAT LOAD
1203	RA CONTROL POINT	PC	2	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1203	RA CONTROL POINT	RADIATION AREA ACCESS CONTROL STATION	4	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1207	OPERATIONS ROOM	DISPLAY BOARD	10	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME 1 PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8 (BASED ON NO. OF WORKSTATION ON PLAN)
1209	RP STAFF WORK ROOM	DISPLAY BOARD	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME 1 PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8 (BASED ON NO. OF WORKSTATION ON PLAN)

Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)

1209	RP STAFF WORK ROOM	PC	4	1.00	1.00	30	WATTS	102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1212	RP GEAR SUPPLY ROOM	PC	4	1.00	1.00	30	WATTS	102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1215	RP EQUIPMENT ROOM	PC	4	1.00	1.00	30	WATTS	102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1216	RESPIRATOR ROOM	PC	1	1.00	1.00	30	WATTS	102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1216	RESPIRATOR ROOM	RESPIRATOR DRYING EQUIPMENT	1	1.00	1.00	2760	WATTS	9,420		X					ES&H	BASED ON AMERICAN AIRWORKS GS1500 RESPIRATOR DRYER
1216	RESPIRATOR ROOM	RESPIRATOR WASHING EQUIPMENT	1	1.00	1.00	2760	WATTS	9,420		X					ES&H	BASED ON AMERICAN AIRWORKS GS4800 RESPIRATOR WASHER
1217	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	5	1.00	1.00	30	WATTS	102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30.
1218	RP LAB/COUNT ROOM	ALPHA SPECTOMETER	1	1.00	1.00	3	WATTS	10	X						ES&H	ASSUME POWER REQUIREMENTS OF 3 WATTS FOR CANBERRA MODEL 7401 ALPHA SPECTOMETER
1218	RP LAB/COUNT ROOM	FRISKER STATION	2	1.00	1.00	0		0	X						ES&H	ASSUME NO HEAT LOAD

## Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)

1218	RP LAB/COUNT ROOM	GAMMA SPECTOMETER	2	1.00	1.00	1200	WATTS		4,095	X						ES&H	ASSUME POWER REQUIREMENTS OF 1200 WATTS FOR CANBERRA, GAM-AN1 GAMMA SPECTOMETER
1218	RP LAB/COUNT ROOM	LIQUID SCINTILATION COUNTER	1	1.00	1.00	1230	WATTS		4,198	X						ES&H	ASSUME POWER REQUIREMENTS OF 1230 WATTS FOR BECKMAN COULTER, MODEL 6500 SCINTILATION COUNTING SYSTEM
1218	RP LAB/COUNT ROOM	PROPORTIONAL COUNTER	1	1.00	1.00	575	WATTS		1,962	X						ES&H	ASSUME POWER REQUIREMENTS OF 575 WATTS FOR TENNELEC LB4100, MULTI-DETECTOR COUNTING SYSTEM
1218	RP LAB/COUNT ROOM	SWIPE COUNTER	2	1.00	1.00	575	WATTS		1,962	X						ES&H	ASSUME POWER REQUIREMENTS OF 575 WATTS FOR TENNELEC LB4100, MULTI-DETECTOR COUNTING SYSTEM
1219	RP LAB/SAMPLE PREPARATION ROOM	FRISKER STATION	1	1.00	1.00	0			0	X						ES&H	ASSUME NO HEAT LOAD
1219	RP LAB/SAMPLE PREPARATION ROOM	SAMPLE PREPARATION HOOD	1	1.00	1.00	0			0	X						ES&H	ASSUME EXHAUST FAN MOTOR IS EXTERNAL TO BUILDING
1220	DECON ROOM	FRISKER STATION	2	1.00	1.00	0			0	X						ES&H	ASSUME NO HEAT LOAD
1221	RA EXIT/ PCM ROOM	COMPUTER TERMINAL WALL DISPLAY	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME 1 PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1221	RA EXIT/ PCM ROOM	FRISKER	1	1.00	1.00	0			0	X						ES&H	ASSUME NO HEAT LOAD
1221	RA EXIT/ PCM ROOM	RADIATION AREA ACCESS CONTROL STATION	4			30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8

Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)

1221	RA EXIT/ PCM ROOM	SMALL EQUIPMENT MONITOR	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME 1 PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1221	RA EXIT/ PCM ROOM	PERSONNEL PORTAL MONITOR	4	1.00	1.00	250	WATTS		853	X						ES&H	BASED ON THERMO EBERLINE PCM-2 WHOLE BODY CONTAMINATION MONITOR
1223	GAS SAMPLING ROOM	FRISKER STATION	2	1.00	1.00	0			0	X						ES&H	ASSUME NO HEAT LOAD
1224	HP INSTRUMENT ROOM	ELECTRONIC DOSIMETER CALIBRATOR	1	1.00	1.00	1	WATTS		3	X						ES&H	ASSUME 0.9 WATTS POWER CONSUMPTION FOR GDS MODEL LDM220
1224	HP INSTRUMENT ROOM	PC	2	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
2003	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
2003	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA ICAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
2004	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	AREA RADIATION MONITOR	6	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
2004	HVAC ROOM NORTH (PROCESS AREA SUPPLY)	CONTINUOUS AIR MONITOR	6	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA ICAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
2006	HVAC ROOM (HEPA EXHAUST FOR SUPPORT, DECON AND LLW AREAS)	AREA RADIATION MONITOR	10	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
2006	HVAC ROOM (HEPA EXHAUST FOR SUPPORT, DECON AND LLW AREAS)	CONTINUOUS AIR MONITOR	10	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA ICAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM



Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)

2007	CANISTER TRANSFER ROOM	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
2007	CANISTER TRANSFER ROOM	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
2010	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
2010	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
2011	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
2011	HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
2023	STAIR #2	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
2027	STAIR #5	RADIATION AREA ACCESS CONTROL STATION	5	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
2029	ELEVATOR LOBBY	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1003A	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	3	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8

## Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)

1003B	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	2	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1003E	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1003F	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	2	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1003G	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	3	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
1004A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN A)	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1004A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN A)	CONTINUOUS AIR MONITOR	8	1.00	1.00	150	WATTS		512	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND 3/4 HP VACUUM PUMP MOTOR
1017A	CASK PREPARATION ROOM ANNEX	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR
1017A	CASK PREPARATION ROOM ANNEX	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA iCAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
1018A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN B)	AREA RADIATION MONITOR	8	1.00	1.00	16	WATTS		55	X						ES&H	BASED ON CANBERRA ADM606M MULTI-PURPOSE RADIATION MONITOR

Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)

1019A	HVAC ROOM (ITS HEPA EXHAUST BATTERY ROOM FOR TRAIN B)	CONTINUOUS AIR MONITOR	8	1.00	1.00	43	WATTS		147	X						ES&H	BASED ON CANBERRA ICAM ALPHA/BETA AIR MONITOR AND USE OF FACILITY VACUUM SYSTEM
2002A	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
2002B	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	3	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
2002C	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
2002E	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	5	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
2002F	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8
2002G	CORRIDOR	RADIATION AREA ACCESS CONTROL STATION	1	1.00	1.00	30	WATTS		102	X						ES&H	ASSUME AS PC IN ENERGY SAVE MODE AT 30 WATTS EACH, MONITOR AT 0 WATTS PER ASHRAE (2005) CH. 30, TABLE 8

## Attachment 3 – Print of Attached File, RF Equipment Load List RF (06-25-07).xls (Continued)


## Notes:

1. Description of equipment giving heat to the room.
2. Quantity of equipment in the room.
3. "Use Factor" means the approximate usage of equipment based on a 24 hour period.
4. "Load Factor" applies to equipment driven by electric motor such as Cranes, Trolleys and Site Transporter. The electric motor horsepower selection is based on the maximum capacity that the equipment can handle. In reality, these pieces of equipment are not lifting or pulling the maximum load all the time during a 24 hour period, therefore 85% load factor is a very conservative assumption.
5. Heat load that each equipment gives up into a room. Refer to next column for units (Watts, kW or HP)
6. The conversion factor used to convert Watts to Btu/h is 3.413 and kW to Btu/h is 3413. For HP conversion, refer to Note 7.
7. Refer to Table 4.12 of ASHRAE Cooling and Heating Load Calculation Manual (Reference 2.2.4) for location of motor and driven equipment with respect to conditioned space or airstream (A - motor in, driven equipment in; B - motor out, driven equipment in; C - motor in, driven equipment out) and equivalent Btu/h rating for listed motor HP.
8. Equipment heat load in Btu/hr.
9. "Continuous Operation" means equipment is operating all the time 24 hour a day, heat load is constant.
10. "Intermittent Operation" means equipment is operating ON and OFF during a 24 hour period. The time of operation is not simultaneous with other equipment in a room which is also operating intermittently.
11. "Simultaneous Operation" means the equipment is also operating ON and OFF, but it operates at the same time with other equipment which is also operating intermittently.
12. Heat load by an individual piece of equipment based on the type of operation (continuous, intermittent or simultaneous).
13. Most of the equipment listed in this table operates intermittently. There are certain types of work when an appropriate piece of equipment is used to handle that particular job. The process that utilizes the most equipment working simultaneously represents the highest heat load. That figure is used as the room equipment heat load. When numbers are shown (1,2,3 etc.) they represent the number of scenarios where equipment works simultaneously with the other equipment. The type of work that utilizes the most equipment represents the highest heat load and it is the figure used as the room equipment heat load.
14. The total equipment heat load per room obtained by adding all the equipment heat load in a room under the column "Equipment Load by Process".

**ATTACHMENT 4: E-MAIL REGARDING INSTRUMENTATION AND CONTROLS  
EQUIPMENT HEAT GAIN INFORMATION**

(4 pages)

This attachment contains an e-mail from Lino Salgado of the BSC Instrumentation and Controls Group, dated 6/20/2007, to Ricardo Abraham of the BSC Mechanical HVAC Group. It confirms the locations and heat gains of various instrumentation and controls equipment located throughout the RF.


 Ricardo Abraham  
07/09/2007 07:56 AM

To: Clayton De Losier/YM/RWDOE@CRWMS  
cc:  
Subject: Fw: HVAC Heat Gain Information for RF Facility

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

FYI

----- Forwarded by Ricardo Abraham/YM/RWDOE on 07/09/2007 07:59 AM -----

 Lino Salgado  
06/20/2007 10:17 AM

To: Ricardo Abraham/YM/RWDOE@CRWMS  
cc: Steve Schumde/YM/RWDOE@CRWMS, Oscar Rosales/YM/RWDOE@CRWMS, Tracy Johnson/YM/RWDOE@CRWMS  
Subject: Re: HVAC Heat Gain Information for RF Facility ^

LSN: Not Relevant  
User Filed as: Not a Record

Heat gain information for Rf Facility per your request:



RF Heat Load List(C&I).xls

Lino  
1-8635

Attachment 4 – Print of File, RF Heat Load List (C&I).xls

RF Heat Load List

Room No.	Conf. Zoning C or NC	Area	Room Name	Heat Source	Qty.	Heat Load/Equipment (Watts)	Motor Location Type	Total Equip Load (Btu/hr)	Continuous Operation	Intermittent Operation	Simultaneous Operation	Indoor Design Temp	Reference Document	Originating Group/ Discipline	Contact Person	Remarks		
1001			Site Transport Vestibule	Remote I/O (RIO)	1	100		341					Delta V product data sheet (typical for all RIOs)	I&C	Lino Salgado			
1002			Lid Bolting Room	RIO	1	100		341										
1004			HVAC Room (ITS HEPA Exhaust Train A)	RIO	1	100		341										
				DCMIS I/O Cabinet	1	1000		3413										
1005			Electrical Room (ITS Train A)	PLC	1	350		1195					Triconex Corporation Topical Reports 7286-545 "Qualification Summary Report"					Assumed 2 power supplies per PLC
1006			Gas Sampling Room	RIO	1	100		341										
1008			Operations Room	DCMIS Workstations	2	920		6280										1 control console consists of 1 computer and 4 screens. Power supply for computer is 200 w (Dell Model DHP) and 180 w (Dell model 1905 FP) for 1 screen. Total power supply is 920 watts.
				CCTV Power supplies	2	960		6553					Source: SuperON Technology Co website (http://www.globalsources.com/gso/ /CCTV-control/p/sm/1000532009.htm)					
				DCMIS Network Cabinet	1	500		1707										Assumed 500 watts each.
1009			Communication Room	Comm Cabinets	5	750		12799										Assumed 750 watts each
				RIO	1	100		341										
1011			LLW Vestibule	RIO	1	100		341										
1012			LLW Staging Room	RIO	1	100		341										
1013			Loading Room	RIO	1	100		341										
1015			Cask Unloading Room	RIO	1	100		341										
1016			CTM Maintenance Room	RIO	1	100		341										
1017			Cask Preparation Room	RIO	1	100		341										
1018			Electrical Room (normal Power)	DCMIS I/O Cabinet	1	1000		3413										
				PLC	2	350		2389										
1019			HVAC Room (ITS HEPA Exhaust Train B)	RIO	1	100		341										
1020			Electrical Room (ITS Train B)	DCMIS I/O Cabinet	1	1000		3413										
				PLC	1	350		1195										
1021A			Transportation Cask Vestibule	RIO	1	100		341										
2001			Operations/Maintenance Storage Room	RIO	1	100		341									Room 2001 is not identified in Reference 2	
2003			HVAC Room North (Process Area Supply)	RIO	1	100		341										
2004			HVAC Room North (Process Area Supply)	RIO	1	100		341										
2005			Instrument & Electrical Storage	RIO	1	100		341									Room 2005 is not identified in Reference 2	
2007			Canister Transfer Room	RIO	1	100		341										
2009			HVAC Room South	RIO	1	100		341									Labeled as "HVAC Room South (Process Area Supply)" in Reference 2.	
2010			HVAC Room South (Process Area Supply)	RIO	1	100		341										

Attachment 4 – Print of File, RF Heat Load List (C&I).xls (Continued)

RF Heat Load List

Room No.	Conf. Zoning C or NC	Area	Room Name	Heat Source	Qty.	Heat Load/Equipment (Watts)	Motor Location Type	Total Equip Load (Btu/hr)	Continuous Operation	Intermittent Operation	Simultaneous Operation	Indoor Design Temp	Reference Document	Originating Group/ Discipline	Contact Person	Remarks
2011			HVAC Room South (Process Area Supply)	RIO	1	100		341								Room 2011 is not identified in Reference 2.
NOTE: VALUES IN THIS TABLE ARE PRELIMINARY AND WILL BE VERIFIED AS THE DESIGN PROGRESSES.																
REFERENCES:																
1) 200-P0K-RF00-10101-000, REV 00A - RECEIPT FACILITY PRELIMINARY LAYOUT GROUND FLOOR PLAN																
2) 200-P0K-RF00-10102-000, REV 00A - RECEIPT FACILITY PRELIMINARY LAYOUT SECOND FLOOR PLAN																
3) 200-30R-RF00-00200-000 I&C 6-18-07.DOC (INTEGRATED SYSTEM OPERATION REPORT: RECEIPT FACILITY) (FILE LOCATION: O:\D&E\CONTROL SYSTEMS\SORS\RECEIPT FACILITY)																



**ATTACHMENT 5: HVAC AND MECHANICAL PROCESS EQUIPMENT LIST**

(5 pages)

This list contains HVAC and Mechanical Process equipment and their motor drive using drawings with their document number listed in the Remarks/Additional Info column as reference.

## Attachment 5 – Enclosure 5

RF HVAC EQUIPMENT														
COMPONENT ID	COMPONENT DESCRIPTION	LOCATION	COMPONENT RATING			SAFETY CLASS (Note 1)		LOAD TYPE (Note 2)	PACKAGED EQPT.		LOAD STATUS (Note 3)	OTHER REQUIREMENTS (Note 4)	OPERATIONAL REQUIREMENTS (Note 5)	REMARKS/ADDITIONAL INFO.
			HP/KVA/KW	VOLTAGE	PHASE	ITS	NON-ITS		YES	NO				
200-VCT0-AHU-00001	AIR HANDLING UNIT	2003 HVAC ROOM NORTH (PROCESS AREA SUPPLY)	125 HP	Note 6	Note 6		X	C		X	Calc	ASD		V&ID: 200-M80-VCT0-00206-000
200-VCT0-AHU-00002	AIR HANDLING UNIT	2003 HVAC ROOM NORTH (PROCESS AREA SUPPLY)	125 HP	Note 6	Note 6		X	C		X	Calc	ASD		V&ID: 200-M80-VCT0-00206-000
200-VCT0-AHU-00003	AIR HANDLING UNIT	2004 HVAC ROOM NORTH (PROCESS AREA SUPPLY)	125 HP	Note 6	Note 6		X	S		X	Calc	ASD		V&ID: 200-M80-VCT0-00206-000
200-VCT0-AHU-00004	AIR HANDLING UNIT	2009 HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	100 HP	Note 6	Note 6		X	C		X	Calc	ASD		V&ID: 200-M80-VCT0-00201-000
200-VCT0-AHU-00005	AIR HANDLING UNIT	2010 HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	100 HP	Note 6	Note 6		X	S		X	Calc	ASD		V&ID: 200-M80-VCT0-00201-000
200-VCT0-AHU-00006	AIR HANDLING UNIT	2010 HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	75 HP	Note 6	Note 6		X	C		X	Calc	ASD		V&ID: 200-M80-VCT0-00103-000
200-VCT0-AHU-00007	AIR HANDLING UNIT	2011 HVAC ROOM SOUTH (PROCESS AREA SUPPLY)	75 HP	Note 6	Note 6		X	S		X	Calc	ASD		V&ID: 200-M80-VCT0-00103-000
200-VCT0-EXH-00001	EXHAUST FAN	2006 HVAC ROOM (HEPA EXHAUST FOR SUPORT, DECON AND LLW AREAS)	75 HP	Note 6	Note 6		X	C		X	Calc	ASD		V&ID: 200-M80-VCT0-00205-000
200-VCT0-EXH-00002	EXHAUST FAN	2006 HVAC ROOM (HEPA EXHAUST FOR SUPORT, DECON AND LLW AREAS)	75 HP	Note 6	Note 6		X	C		X	Calc	ASD		V&ID: 200-M80-VCT0-00205-000
200-VCT0-EXH-00005	EXHAUST FAN (TRAIN A)	1004 HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	200 HP	Note 6	Note 6	X		C		X	Calc	ASD		V&ID: 200-M80-VCT0-00101-000
200-VCT0-EXH-00006	EXHAUST FAN (TRAIN B)	1019 HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	200 HP	Note 6	Note 6	X		S		X	Calc	ASD		V&ID: 200-M80-VCT0-00102-000
200-VCT0-EXH-00009	EXHAUST FAN (TRAIN A)	1004A HVAC ROOM (ITS HEPA EXHAUST FOR BATTERY ROOM TRAIN A)	7.5 HP	Note 6	Note 6	X		C		X	Calc	ASD		V&ID: 200-M80-VCT0-00302-000
200-VCT0-EXH-00010	EXHAUST FAN (TRAIN A)	1004A HVAC ROOM (ITS HEPA EXHAUST FOR BATTERY ROOM TRAIN A)	7.5 HP	Note 6	Note 6	X		S		X	Calc	ASD		V&ID: 200-M80-VCT0-00302-000
200-VCT0-EXH-000011	EXHAUST FAN (TRAIN B)	1019A HVAC ROOM (ITS HEPA EXHAUST FOR BATTERY ROOM TRAIN B)	15 HP	Note 6	Note 6	X		C		X	Calc	ASD		V&ID: 200-M80-VCT0-00304-000
200-VCT0-EXH-00012	EXHAUST FAN (TRAIN B)	1019A HVAC ROOM (ITS HEPA EXHAUST FOR BATTERY ROOM TRAIN B)	15 HP	Note 6	Note 6	X		S		X	Calc	ASD		V&ID: 200-M80-VCT0-00304-000
200-VCT0-EXH-00013	EXHAUST FAN	2006 HVAC ROOM (HEPA EXHAUST FOR SUPORT, DECON AND LLW AREAS)	75 HP	Note 6	Note 6		X	S		X	Calc	ASD		V&ID: 200-M80-VCT0-00205-000

RF HVAC EQUIPMENT														
COMPONENT ID	COMPONENT DESCRIPTION	LOCATION	COMPONENT RATING			SAFETY CLASS (Note 1)		LOAD TYPE (Note 2)	PACKAGED EQPT.		LOAD STATUS (Note 3)	OTHER REQUIREMENTS (Note 4)	OPERATIONAL REQUIREMENTS (Note 5)	REMARKS/ADDITIONAL INFO.
			HP/KVA/KW	VOLTAGE	PHASE	ITS	NON-ITS		YES	NO				
200-VCT0-FLT-00001	HEPA FILTER PLENUM	2006 HVAC ROOM (HEPA EXHAUST FOR SUPORT, DECON AND LLW AREAS)	N/A	N/A	N/A		X	C		X	Calc	N/A		V&ID: 200-M80-VCT0-00205-000
200-VCT0-FLT-00002	HEPA FILTER PLENUM	2006 HVAC ROOM (HEPA EXHAUST FOR SUPORT, DECON AND LLW AREAS)	N/A	N/A	N/A		X	C		X	Calc	N/A		V&ID: 200-M80-VCT0-00205-000
200-VCT0-FLT-00005	EXHAUST HEPA FILTER PLENUM (TRAIN A)	1004 HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	N/A	N/A	N/A	X		C		X	Calc	N/A		V&ID: 200-M80-VCT0-00101-000
200-VCT0-FLT-00006	EXHAUST HEPA FILTER PLENUM (TRAIN A)	1004 HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	N/A	N/A	N/A	X		C		X	Calc	N/A		V&ID: 200-M80-VCT0-00101-000
200-VCT0-FLT-00007	EXHAUST HEPA FILTER PLENUM (TRAIN A)	1004 HVAC ROOM (ITS HEPA EXHAUST TRAIN A)	N/A	N/A	N/A	X		C		X	Calc	N/A		V&ID: 200-M80-VCT0-00101-000
200-VCT0-FLT-00008	EXHAUST HEPA FILTER PLENUM (TRAIN B)	1019 HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	N/A	N/A	N/A	X		S		X	Calc	N/A		V&ID: 200-M80-VCT0-00102-000
200-VCT0-FLT-00009	EXHAUST HEPA FILTER PLENUM (TRAIN B)	1019 HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	N/A	N/A	N/A	X		S		X	Calc	N/A		V&ID: 200-M80-VCT0-00102-000
200-VCT0-FLT-00010	EXHAUST HEPA FILTER PLENUM (TRAIN B)	1019 HVAC ROOM (ITS HEPA EXHAUST TRAIN B)	N/A	N/A	N/A	X		S		X	Calc	N/A		V&ID: 200-M80-VCT0-00102-000
200-VCT0-FLT-00013	HEPA FILTER PLENUM	2006 HVAC ROOM (HEPA EXHAUST FOR SUPORT, DECON AND LLW AREAS)	N/A	N/A	N/A		X	S		X	Calc	N/A		V&ID: 200-M80-VCT0-00205-000

Note 1: Safety class applies to electrical requirements only.

Note 2: Load Type: C = Continuous, I = Intermittent, S = Standby

Note 3: Load Status: Prel = Preliminary, Calc = Calculated, or Conf = Confirmed

Note 4: Other Requirements: ASD (Adjustable Speed Drive), 2-Speed Drive, 1-Speed Drive, etc.

Note 5: Operational Requirements: All HVAC equipment must be running for this building to be operational for production.

Note 6: Electrical discipline will specify the component voltage and phase based on provided HP

Attachment 5 – Enclosure 5 (Continued)

RF MECHANICAL SYSTEMS/PROCESS EQUIPMENT (Last updated on 11/12/07)														
COMPONENT ID	COMPONENT DESCRIPTION	LOCATION	COMPONENT RATING			SAFETY CLASS (Note 1)		LOAD TYPE (Note 2)	PACKAGED EQPT.		LOAD STATUS (Note 3)	OTHER REQUIREMENTS (Note 4)	OPERATIONAL REQUIREMENTS (Note 5)	REMARKS/ADDITIONAL INFO.
			HP/kVA/kW	VOLTAGE	PHASE	ITS	NON-ITS		YES	NO				
200-PSG0-VSL-00001	GPA RECEIVER	ROOM 2012, 2ND FLOOR	N/A	N/A	N/A		X	N/A		X	PREL			
200-PSA0-VSL-00001	IA RECEIVER	ROOM 2012, 2ND FLOOR	N/A	N/A	N/A		X	N/A		X	PREL			
200-PSG0-SKD-00001	GP DRYER PACKAGE	ROOM 2012, 2ND FLOOR	13.5 kW	Note 6	Note 6		X	I	X		PREL	Yes	Calculation in Check and P&ID in drafting. NOTE 9	
200-PSA0-SKD-00001	IA DRYER PACKAGE	ROOM 2012, 2ND FLOOR	3 kW	Note 6	Note 6		X	I	X		PREL	Yes	Calculation in Check and P&ID in drafting. NOTE 9	
200-PSG0-CMP0-00001-A	AIR COMPRESSOR	OUTSIDE	200 HP	Note 6	Note 6		X	I	X		PREL	Yes	Calculation in Check and P&ID in drafting. NOTE 9	
200-PSG0-CMP0-00001-B	AIR COMPRESSOR	OUTSIDE	200 HP	Note 6	Note 6		X	I	X		PREL	Yes	Calculation in Check and P&ID in drafting. NOTE 9	
200-PSG0-CMP0-00001-C	AIR COMPRESSOR	OUTSIDE	200 HP	Note 6	Note 6		X	S	X		PREL	Yes	Calculation in Check and P&ID in drafting. STANDBY	
200-PSE0-VSL-00001	ME SERVICE GAS STORAGE VESSEL (He)	OUTSIDE THE NORTH SUPPORT AREA	N/A	N/A	N/A		X	N/A	X		PREL			
200-PSC0-P-00001-A	ME CHILLED WATER PUMP	MAINTENANCE ROOM # 1014	This equipment is in inspection and can be found on the issued P&ID: 200-M60-PSC0-00101-000 to 200-M60-PSC0-00103-000.											
200-PSC0-P-00001-B	ME CHILLED WATER PUMP	MAINTENANCE ROOM # 1014												
200-PSH0-P-00001-A	HOT WATER PUMP	MAINTENANCE ROOM # 1014	This equipment is in inspection and can be found on the issued P&ID: 200-M60-PSH0-00101-000 to 200-M60-PSH0-00103-000.											
200-PSH0-P-00001-B	HOT WATER PUMP	MAINTENANCE ROOM # 1014												
200-MRE0-DET-00001	MP CASK CAV GAS SAMPLING UNIT (VENDOR PACKAGE)	GROUND FLOOR, ROOM 1006	1kW (Note 7)	Note 6	Note 6		X	I	X		PREL	N/A	Yes	
200-MRE0-VACP-00001	MP CASK CAV GAS SAMPLING VAC PUMP	GROUND FLOOR, ROOM 1006	This equipment is in inspection and can be found on the issued P&ID: 200-M60-MRE0-00101-000-00A.											See Note 7.
200-MWL0-P-00002	MP LIQUID LLW SUMP PUMP	SUMP PIT, ROOM P001	This equipment is in inspection and can be found on the issued P&ID: 200-M60-MWL0-00107-000-00A.											
200-MWL0-P-00001	MP LIQUID LLW SAMPLING PUMP	SUMP PIT, ROOM P001	This equipment is in inspection and can be found on the issued P&ID: 200-M60-MWL0-00107-000-00A.											
200-MWL0-TK-00001	MP LIQUID LLW SAMPLING TANK	SUMP PIT, ROOM P001	N/A	N/A	N/A		X			X	PREL			
200-MWL0-SUMP-00001	MP LIQUID LLW SUMP	SUMP PIT, ROOM P001	N/A	N/A	N/A		X			X	PREL			
200-MWL0-TK-00002	MP LIQUID LLW COLLECTION TANK	SUMP PIT, ROOM P001	N/A	N/A	N/A		X			X	PREL			
200-MWL0-SUMP-00002	MP LIQUID LLW SUMP	SUMP PIT, ROOM P001	N/A	N/A	N/A		X			X	PREL			

Note 1: Safety class applies to electrical requirements only.  
 Note 2: Load Type: C = Continuous, I = Intermittent, S = Standby.  
 Note 3: Load Status: PREL = Preliminary, Calc = Calculated, or Conf = Confirmed.  
 Note 4: Other Requirements: VFD (Variable Frequency Drive), 2-Speed Drive, 1-Speed Drive, etc.  
 Note 5: Operational Requirements: All equipment must be running for this building to be operational for production.  
 Note 6: Electrical discipline will specify the component voltage and phase based on provided HP.


Note 7: Based on engineering estimate. Calculation for the gas sampling will be revised to reflect the power requirements and bases. Typical unit is single phase, 120 VAC.

Note 9: Estimated hours of operation of compressors and dryers are 6 hours per use and a total of 12 hours per day. This requires further confirmation.

**ATTACHMENT 6: E-MAIL REGARDING MECHANICAL HANDLING GROUP  
EQUIPMENT HEAT GAIN INFORMATION**

(3 pages)

This e-mail is from Bryan Elliot of the BSC Mechanical Handling Group, dated 11/14/07, to Greg Gould of the BSC Mechanical HVAC Group, and then forwarded to Elpidio S. Castroverde of the BSC Mechanical HVAC Group. It confirms the heat load and use factor of various pieces of equipment used throughout the RF.

 Greg Gould  
11/15/2007 07:58 AM

To: Monico Pingul/YMRWDOE@CRWMS, Elpidio Castroverde/YMRWDOE@CRWMS, Gin Cababa/YMRWDOE@CRWMS, Fred Favis/YMRWDOE@CRWMS, Oscar Rosales/YMRWDOE@CRWMS, Ricardo Abraham/YMRWDOE@CRWMS, Orlando Santiago/YMRWDOE@CRWMS, Jerry Herszman/YMRWDOE@CRWMS, Hang Yang/YMRWDOE@CRWMS, Orlando Asuncion/YMRWDOE@CRWMS  
cc: Tracy Johnson/YMRWDOE  
Subject: Fw: Mechanical Handling Equipment Loads


LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA:N/A

Gentlemen,

Bryan has taken a final look at the mechanical equipment loads and use factors. He has also addressed the incidental loads (See below). Please use the attached spreadsheet for your calculation. Please look at the information and elevate any problems you find.

Greg

----- Forwarded by Greg Gould/YMRWDOE on 11/15/2007 07:55 AM -----

 Bryan Elliott  
11/14/2007 05:04 PM

To: Greg Gould/YMRWDOE@CRWMS  
cc: Daryl Lopez/YMRWDOE@CRWMS, Maurice LaFountain/YMRWDOE@CRWMS  
Subject: Mechanical Handling Equipment Loads

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA:N/A

Greg,

Attached is an Excel file providing the loads for the mechanical handling equipment.

The loads are based on the motor sizes shown on issued mechanical equipment envelope drawings. This table also provides the updated usage factors, based on the throughput studies.

After some investigation, incidental loads (power for controls) are insignificant, and are thus not included within the table.

Please let me know if you need anything further.

Bryan Elliott



MH Equipment Load List.xls


Equipment Number	Room Number	Room Name	Description	Use Factor	Load Factor	Equipment Motors	Continuous operation	Intermittent operation	Simultaneous operation	Reference Drawing	Remark 1
200-HM00-CRN-00001	1017	Cask Preparation Room	CASK HANDLING CRANE	0.45	1.00	H 90HP, A 45HP, T 7.5HP & B 30HP	X			200-MJ0-HM00-00101-000	Only one motor operates at a time
200-HMCO-CRN-00001	1002	Lid Bolting Room	LID BOLTING ROOM CRANE	0.35	1.00	H 25HP, T 1.5HP & B 3HP	X			200-MJ0-HMCO-00101-000	Only one motor operates at a time
200-HMCO-PLAT-00001	1017	Cask Preparation Room	MOBILE ACCESS PLATFORM	0.45	1.00	(4) 1HP, (4) 5HP, (2) 10HP	X	X		000-MJ0-HMCO-00301-000	Use (2) 10 HP motors for load. Equipment can operate at the same time as the Cask Handling Crane
200-HTC0-CRN-00001	2007	Canister Transfer Room	CTM MAINTENANCE CRANE	0.10	0.85	H 35HP, T 2HP & B 7.5HP	X			200-MJ0-HTC0-00101-000	Only one motor operates at a time
200-HTC0-FHM-00001	2007	Canister Transfer Room	CANISTER TRANSFER MACHINE	0.20	1.00	45HP, 3HP, (2) 7.5HP, 60HP, 5 HP	X			000-MJ0-HTC0-00201-000	Only one motor operates at a time
200-HTC0-HTCH-00001	2007	Canister Transfer Room	CASK PORT SLIDE GATE	0.10	1.00	(2) .5 HP	X			000-MJ0-H000-00301-000	Both motors operate at the same time
200-HTC0-HTCH-00002	2007	Canister Transfer Room	AO PORT SLIDE GATE	0.10	1.00	(2) .5 HP	X			000-MJ0-H000-00301-000	Both motors operate at the same time
200-RF00-DR-00001	1017	Cask Preparation Room	CASK UNLOADING ROOM SHIELD DOOR (TYPE 5)	0.10	1.00	7.5 HP, 7.5 HP	X			000-MJ0-H000-01101-000	Both motors operate at the same time
200-RF00-DR-00002	1002	Lid Bolting Room	LOADING ROOM SHIELD DOOR (TYPE 2)	0.10	1.00	7.5 HP, 7.5 HP	X			000-MJ0-H000-00801-000	Both motors operate at the same time
200-RF00-DR-00003	1017A	Cask Preparation Annex	CASK PREPARATION ROOM EQUIPMENT CONFINEMENT DOOR SOUTH	0.10	1.00	(2) 3HP	X			200-MJ0-HMH0-00301-000	Both motors operate at the same time



**ATTACHMENT 7: E-MAIL REGARDING THE NUMBER OF OCCUPANTS IN THE  
RF BUILDING.**

(3 pages)

This attachment contains e-mails from Clarence Smith to Ricardo Abraham and Clayton De Losier, dated 06/12/2007 and 07/09/2007, confirming the number and distribution of occupants in the RF building.



Ricardo Abraham  
07/03/2007 04:19 PM

To: Clayton De Losier/YM/RWDOE@CRWMS  
cc:  
Subject: Fw: Number of Personnel in the RF Facility

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

----- Forwarded by Ricardo Abraham/YM/RWDOE on 07/03/2007 04:19 PM -----



Clarence Smith  
06/12/2007 07:23 AM


To: Ricardo Abraham/YM/RWDOE@CRWMS  
cc: Clarence Smith/YM/RWDOE@CRWMS  
Subject: Re: Number of Personnel in the RF Facility "

LSN: Not Relevant - **Privileged**  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

Ricardo the staffing for the RF will be approximately 20 people per shift for a 24/7 operation this will include Rad protection, QC, Operation, maintenance and supervisors.  
If you have any questions please give me a call

Thanks  
Clarence

▼ Ricardo Abraham



Ricardo Abraham  
06/11/2007 04:32 PM

To: Clarence Smith/YM/RWDOE@CRWMS  
cc: Tracy Johnson/YM/RWDOE@CRWMS, Oscar Rosales/YM/RWDOE@CRWMS  
Subject: Number of Personnel in the RF Facility

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

Clarence,  
I'm doing the HVAC cooling load calculation for the RF facility. I need the number of personnel that will be working in this Facility to be included in my cooling and heating load calculation. Please provide the number of Personnel on each area in the the RF facility.

Thanks,  
Ricardo



Clarence Smith  
07/09/2007 11:32 AM

To: Clayton De Losier/YM/RWDOE@CRWMS  
cc: Clarence Smith/YM/RWDOE@CRWMS  
Subject: Re: RF Personnel <sup>13</sup>

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

I concur the data listed below is per our conversation as to the location of personnel within the RF facility.

Thanks  
Clarence

▼ Clayton De Losier



Clayton De Losier  
07/09/2007 09:57 AM

To: Clarence Smith/YM/RWDOE@CRWMS  
cc:  
Subject: RF Personnel

LSN: Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA/N/A

Dear Clarence Smith,

I need to have documentation of our earlier conversation for my document; therefore, can you please reply to this e-mail and state that the following personnel distribution for the RF is correct, per our earlier discussion.

Room No.	Room Name	No. of People
1001	Site Transporter Vestibule	1
1002	Lid Bolt Room	4
1017 and 1017A	Cask Preparation Room and Annex	8
1207	Operations Room	2
1209	Staff Work Room	2
1223	Gas Sampling Room	1
1224	Instrument Room	2

Thank You,

Clayton De Losier

**ATTACHMENT 8: SECOND E-MAIL REGARDING MECHANICAL HANDLING  
GROUP EQUIPMENT HEAT GAIN INFORMATION**

(3 pages)

This e-mail is from Scott Drummond of the BSC Mechanical Handling Group, dated 7/13/07, to Clayton De Losier of the BSC Mechanical HVAC Group. It confirms the heat loads of pieces of equipment that were left off in the first e-mail.


**Scott Drummond****07/13/2007 07:59 AM**

To: Clayton De Losier/YM/RWDOE@CRWMS  
 cc: Lisa Green/YM/RWDOE@CRWMS  
 Subject: Fw: RF Mechanical Handling Equipment

LSN: Not Relevant - Not Privileged  
 User Filed as: Excl/AdminMgmt-14-4/QA/N/A

Clayton  
 Per our conversation:  
 The information on the attache sheets is correct: the site transporter that enters the CRCF is the same that enters RF.  
 The platform motor size is correct. you could reference the MEE for both.  
 Scott

----- Forwarded by Scott Drummond/YM/RWDOE on 07/13/2007 08:00 AM -----

 Lisa Green  
 07/13/2007 07:06 AM

To: Scott Drummond/YM/RWDOE@CRWMS  
 cc: Clayton De Losier/YM/RWDOE@CRWMS  
 Subject: Fw: RF Mechanical Handling Equipment

LSN: Not Relevant - Not Privileged  
 User Filed as: Excl/AdminMgmt-14-4/QA/N/A


Scott,

Please verify and get back to Clayton.

Thanks :O)

Lisa

----- Forwarded by Lisa Green/YM/RWDOE on 07/13/2007 07:08 AM -----

 Clayton De Losier  
 07/12/2007 03:46 PM

To: Lisa Green/YM/RWDOE@CRWMS  
 cc:  
 Subject: RF Mechanical Handling Equipment

LSN: Not Relevant - Not Privileged  
 User Filed as: Excl/AdminMgmt-14-4/QA/N/A

Dear Lisa Green,

I am working on a calculation and I need to verify some information. Can you please review the attached file and let me know if this information is correct.

Thank You,

Clayton De Losier

 RF Equipment.xls


## Attachment 8 – Print of File, RF Equipment.xls

Room No.	Room Name	Heat Source Note 1	Qty. Note 2	Heat Load, Each Note 5	Units Note 6	Continuous Operation Note 9	Intermittent Operation Note 10	Simultaneous Operation (Intermittent) Note 11	Originating Group/ Discipline
1002	LID Bolting Room	SITE TRANSPORTER	1	75.0	HP			X	Mechanical Handling
1002	LID Bolting Room	CASK PREPARATION PLATFORM	1	5.0	HP		X		Mechanical Handling
1013	Loading Room	SITE TRANSPORTER	1	75.0	HP			X	Mechanical Handling

**ATTACHMENT 9: E-MAIL REGARDING MECHANICAL HANDLING EQUIPMENT  
HEAT GAIN DIVERSITY FACTOR**

(3 pages)

This e-mail is from Steve Ployhar of BSC Mechanical Handling Group, dated 11/17/07, to Greg Gould of BSC Mechanical HVAC Group and forwarded to Elpidio S. Castroverde of BSC Mechanical HVAC Group stating that a factor of 4 reduction in heat load from operation of Mechanical Handling equipment motors, from what is assumed based on the throughput use factors, is justified and still conservative.

 **Greg Gould**  
11/17/2007 08:38 AM

To: Fred Favis/YM/RWDOE@CRWMS, Monico Pingu/YM/RWDOE@CRWMS, Elpidio Castroverde/YM/RWDOE@CRWMS, Ricardo Abraham/YM/RWDOE@CRWMS, Orlando Santiago/YM/RWDOE@CRWMS  
cc: Gin Cababa/YM/RWDOE@CRWMS, Oscar Rosales/YM/RWDOE@CRWMS, Jerry Herszmar/YM/RWDOE@CRWMS, Orlando Asuncion/YM/RWDOE@CRWMS, Tracy Johnson/YM/RWDOE, Hadi Jalali/YM/RWDOE@CRWMS, Debra Nevergold/YM/RWDOE@CRWMS, David Tooker/YM/RWDOE@CRWMS  
Subject: Fw: MH Equipment Heat Loads

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA:N/A

Please use where applicable in your calculations. Coordinate with Fred Favis as to a consistent approach.

Greg

----- Forwarded by Greg Gould/YM/RWDOE on 11/17/2007 08:32 AM -----

 **Steve Ployhar**  
11/17/2007 08:19 AM  
.....

To: Greg Gould/YM/RWDOE@CRWMS  
cc: Bryan Elliott/YM/RWDOE@CRWMS, Tracy Johnson/YM/RWDOE@CRWMS  
Subject: MH Equipment Heat Loads

LSN: Not Relevant - Not Privileged  
User Filed as: Excl/AdminMgmt-14-4/QA:N/A

Greg,

I believe that a factor of 4 reduction in heat load from operation of MH equipment motors, from what is assumed based on throughput use factors, is justified and still conservative. See attachment.

Steve



MH Equipment Heat Loads for HVAC Load Calcs\_17Nov07.doc



### Mechanical Handling Equipment Heat Loads for Use in HVAC Load Calculations

HVAC engineers are assuming that mechanical handling equipment motors operate continuously based on the use factors defined in the YMP throughput analyses. This assumption is conservative. While the equipment may be "occupied," meaning it is dedicated to a task for those periods, it is not in continuous operation (producing heat) during all of that time. Two examples from WHF evaluated below.

#### Canister Transfer Machine

Use Factor (WHF) = 0.20

Time CTM in use each 24 hours: 288 minutes

On a busy day, the WHF CTM might handle the import of a DPC (from an AO to an STC) and the export of a loaded TAD (from an STC to an AO). This involves two canister lifts and 8 lid lifts (conservatively assume remove and replace at each end of the transfer). The total vertical travel of the CTM hoist for all these lifts (up and down) is on the order of 200 feet. At 5 feet per minute hoist speed, the hoist will be operating (producing heat) for 40 minutes.

Other, smaller CTM motors will be in use for horizontal travel from port to port and back and forth to the lid staging location. A total of 500 feet of travel is estimated. At 20 feet per minute this is another 25 minutes of motor operation.

Based on this conservative evaluation, the large CTM motors are producing heat only about 23% of the time that the CTM is occupied based on the use factor.

#### Site Transporter Vestibule Shield Door

Use Factor (WHF) = 0.10

Time Shield Door in use each 24 hours: 144 minutes

On a busy day it could be assumed that this shield door might be opened 4 times to allow a site transporter to enter or depart. This door has a travel of 20' - 6". Total travel distance is thus 164 feet. Assuming a slow travel speed of 5 fpm (actual speed not known) result in a motor operating time of 32.8 minutes.

Based on this conservative evaluation, the large shield door drive motor is producing heat only about 23% of the time that the shield door is occupied based on the use factor.

#### Conclusion:

These two examples produced a similar result by chance, but I believe these results are typical for cranes and other mechanical handling equipment. Where HVAC load calculations assume continuous motor heat generation based on the throughput study use factors, I believe these heat loads could be reduced by a factor of four and still be conservative.






Steve Ployhar/ November 17, 2007

**BSC**

# Calculation/Analysis Change Notice

1. QA: N/A  
2. Page 1 of 1

Complete only applicable items.

3. Document Identifier: 200-M8C-VCT0-00400-000		4. Rev.: 00C	5. CACN: 001
6. Title: RF Heating and Cooling Load Calculation (Tertiary Non ITS)			
7. Reason for Change: In Table 5 Space Airflow Rates, there is an administrative error in Room 2012 (period instead of comma) and a typing error in "Corridor Total" under "Use Airflow cfm" and "Adjusted Room Sensible Load Btu/h". Actual values will be added above Note 18 on Rooms 1003E, 1003F, 1003G, 2002E, 2002F, 2002G, 2003E, 2003F, & 2003G under "Return Air" and "Exhaust Air". <i>This is documented in CR 11593 BR 12/27/07</i> This change does not impact the results of this calculation.			
8. Supersedes Change Notice:		<input type="checkbox"/> Yes    If, Yes, CACN No.: _____ <input checked="" type="checkbox"/> No	
9. Change Impact:			
Inputs Changed:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Results Impacted:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Assumptions Changed:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Design Impacted:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
10. Description of Change:			
<p>(1) On Page 36, Table 5 Space Airflow Rates, Room 2012 under "Use Airflow cfm" change "5.420" to "5,420".</p> <p>(2) On Page 36, Table 5 Space Airflow Rates, Corridor Total under "Use Airflow cfm" change "5,000" to "5,080".</p> <p>(3) On Page 36, Table 5 Space Airflow Rates, Corridor Total under "Adjusted Room Sensible Load" change "155,223" to "157,689".</p> <p>(4) On Page 37, Table 5 Space Airflow Rates, Sub system Totals under "Adjusted Room Sensible Load Btu/h" change "1,094,970" to "1,086,936".</p> <p>(5) On Page 36, Table 5 Space Airflow Rates, Rooms 1003E, 1003F, 1003G, 1003H, 2002E, 2002F, 2002G, 2003E, 2003F, and 2003G under "Exhaust Air" add "0" (zero) above Note 18 in each cell.</p> <p>(6) On Page 36, Table 5 Space Airflow Rates, Rooms 1003E, 1003F, 1003G, 1003H, 2002E, 2002F, 2002G, 2003E, 2003F, and 2003G under "Exhaust Air" add actual values above "Note 18" in each cell as follows: Rooms 1003E=280, 1003F=1020, 1003G=1410, 1003H=440, 2002E=1160, 2002F=1120, 2002G=140, and 2003E through 2003G=2860.</p>			
<b>11. REVIEWS AND APPROVAL</b>			
<b>Printed Name</b>	<b>Signature</b>	<b>Date</b>	
11a. Originator: Elpidio S. Castroverde		12/20/07	
11b. Checker: Greg W. Gould		12/20/07	
11c. EGS: Tracy L. Johnson		12/20/07	
11d. DEM: Hadi Jalali / <i>for</i> O.T. Asuncion		12/20/07	
11e. Design Authority: Barbara Rusinko		12/27/07	

3. Document Identifier: 200-M8C-VCT0-00400-000	4. Rev.: 00C	5. CACN: CACN002
---	-----------------	---------------------

6. Title:  
RF Heating and Cooling Load Calculation (Tertiary Non ITS)

7. Reason for Change:  
In Table 5 Space Airflow Rates, there is an administrative error in Room 2012 (period instead of comma) and a typing error in "Corridor Total" under "Use Airflow cfm" and "Adjusted Room Sensible Load Btu/h". Actual values will be added above Note 18 on Rooms 1003E, 1003F, 1003G, 2002E, 2002F, 2002G, 2003E, 2003F, & 2003G under "Return Air" and "Exhaust Air". This is documented in CR11593.  
  
This change does not impact the results of this calculation.

8. Supersedes Change Notice:  Yes if, Yes, CACN No.: CACN001  No






9. Change Impact:

Inputs Changed:  Yes  No Results Impacted:  Yes  No

Assumptions Changed:  Yes  No Design Impacted:  Yes  No

10. Description of Change:  
(1) On Page 36, Table 5 Space Airflow Rates, Room 2012 under "Use Airflow cfm" change "5.420" to "5,420".  
(2) On Page 36, Table 5 Space Airflow Rates, Corridor Total under "Use Airflow cfm" change "5,000" to "5,080".  
(3) On Page 36, Table 5 Space Airflow Rates, Corridor Total under "Adjusted Room Sensible Load" change "155,223" to "157,689".  
(4) On Page 37, Table 5 Space Airflow Rates, Sub system Totals under "Adjusted Room Sensible Load Btu/h" change "1,094,970" to "1,086,936".  
(5) On Page 36, Table 5 Space Airflow Rates, Rooms 1003E, 1003F, 1003G, 1003H, 2002E, 2002F, 2002G, 2003E, 2003F, and 2003G under "Return Air" add actual values above "Note 18" in each cell as follows:  
Rooms 1003E=280, 1003F=1020, 1003G=1410, 1003H=440, 2002E=1160, 2002F=1120, 2002G=140, and 2003E through 2003G=2860.  
(6) On Page 36, Table 5 Space Airflow Rates, Rooms 1003E, 1003F, 1003G, 1003H, 2002E, 2002F, 2002G, 2003E, 2003F, and 2003G under "Exhaust Air" add "0" (zero) above "Note 18" in each cell.

11. REVIEWS AND APPROVAL

Printed Name	Signature	Date
11a. Originator: Elpidio S. Castroverde		1/9/08
11b. Checker: Greg W. Gould		1/9/08
11c. EGS: Tracy L. Johnson		1/9/08
11d. DEM: Hadi Jalali		01/09/08
11e. Design Authority: Barbara Rusinko		1/15/08