



BERNALILLO COUNTY GUIDELINES FOR
RESIDENTIAL PLUMBING AND GAS INSPECTIONS.

ADDRESS MUST BE POSTED ON JOB SITE VISIBLE FROM THE STREET FOR ALL INSPECTIONS CALLED

YARD LINES

1. WATER, SEWER, GAS AND ELECTRIC LINES MAY BE INSTALLED IN SAME TRENCH. SEPERATION OF 12" HORIZONTALLY BETWEEN WATER AND SEWER AND GAS SEPERATION OF 12" HORIZONTALLY AND 12" VERTICALLY BETWEEN GAS AND ELECTRIC

GAS YARD LINES

1. ALL METAL PIPE MUST BE FACTORY COATED AND ALL JOINTS GLUED AND WRAPPED. 18" MIN. BURY DEPTH.
2. ALL PLASTIC PIPE MUST BE 18" BURY DEPTH. TRACER WIRE MUST BE INSTALLED. WIRE SHALL BE ATTACHED TO METAL RISERS. DO NOT ATTACH OR TOUCH WIRE TO PLASTIC PIPE.
3. PIPE SHALL BE LEFT UNCOVERED FOR INSPECTION.
4. UNDERGROUND GAS PIPING SHALL BE ELECTICALLY ISOLATED FROM THE PIPING THAT ENTERS INTO BUILDING WITH DIELECTIC UNION.

WATER YARD LINES

1. BURY DEPTH IS 28" MIN. IN ALL AREAS OF THE COUNTY EXCEPT EAST MOUNTAINS. BURY DEPTH IN EAST MOUNTAINS IS 3 - 4 FEET MIN
2. PLASTIC FEMALE ADAPTERS SHALL NOT BE ALLOWED.
3. THREE WATER CLOSETS OR MORE REQUIRE A MIN OF 1" WATER SERVICE.
4. BUILDINGS WITH CHECK VAVLES INSTALLED ON WATER METER YOKES OR IN FRONT OF METERS SHALL INSTALL A THERMAL EXPANSION CONTROL DEVICE.

GRAVITY SEWER YARD LINES

1. BURY DEPTH IS 12" MIN.
2. TWO WAY CLEANOUTS MUST BE INSTALLED ON EVERY LINE. CLEANOUTS ARE REQUIRED EVERY 100 FEET.
3. CHECK IF TOP OF PIPE IS BELOW THE UPSTREAM MANHOLE, IF SO, THEN A BACKWATER SHAL BE INSTALLED. ACCESS BOX IS REQUIRED.

AIR VAC SEWER YARD LINES.

1. MUST BE A MIN. OF 4" ABS/PVC SCHEDULE 40 PIPE OR EQUIVILANT
2. VENT WYE MUST BE AT LEAST 20 FEET AWAY FROM SUMP
3. A BACKWATER VALVE MUST BE INSTALLED BETWEEN THE VENT AND THE HOUSE.
4. THE BACKWATER VALVE MUST BE ACCESSIBLE BY MEANS OF EITHER A BOX OR A 6" OR LARGER SLEEVE.
5. THE CANDY CANE VENT MUST HAVE A CLEARANCE OF 18" FROM THE GROUND TO THE AIR INLET.

BERNAILLO COUNTY GUIDELINES FOR
RESIDENTIAL PLUMBING AND GAS INSPECTIONS.

SANITARY ROUGH IN

1. 3 WATER CLOSETS REQUIRE A MINIMUM OF 1" WATER SUPPLY LINE
2. SANITARY TEES WILL NOT BE LAID ON SIDE, THEY MUST BE AT 45 DEGREE MIN FOR VENTING.
3. PIPES MUST BE FILLED WITH WATER 48" ABOVE FLOOR GRADE OR AIR TEST 5 LBS MAX. PRESSURE
4. ALL PIPES MUST BE WRAPPED AND PROTECTED IF IN CONTACT WITH CONCRETE.
5. CLEAN DIRT MUST BE USED FOR BACKFILL
6. ALL FLOOR DRAINS REQUIRE TRAP PRIMERS.
7. PIPING AND DRAINS CAN NOT BE RUN HORIZONTALLY IN FOOTING TRENCHES. MUST BE RUN 45 DEGREES THERE FROM.
8. VENTS MUST BE DOWNSTREAM OF TRAPS UNDER SLAB
9. COPPER MUST BE "L" "M" OR "K" MIN UNDERSLAB. COPPER MUST BE "L" OR "K" AND JOINTS IN COPPER UNDERGROUND MUST BE BRAZED.
10. TRAP ARM MUST BE PROPER LENGTHS
11. TRAPS SHALL BE PLUMB.
12. NO FLAT VENTING. MAKE SURE PIPES SO NOT BACK GRADE.
13. BATHTUB TRAP AND TRAP ARM 1 1/2"
14. BACKWATER VALVE MUST BE INSTALLED IF PIPING IS ABOVE MANHOLE.

PLUMBING TOP OUT

1. WATER CLOSETS MUST HAVE MIN. 15" CLEARANCE ON EITHER SIDE AND MIN. 24" IN FRONT.
2. RISER ON AUTO WASHER STANDPIPE MUST BE BETWEEN 18" TO 30" FROM BOX TO TRAP. TRAP MUST BE AT 6" MIN. AND 18" MAX FROM FLOOR.
3. FHA STRAPS MUST BE INSTALLED ON ALL STUDS HAVING HOLES/NOTCHES 1" OF EXPOSED FRAMING.
4. ALL WATER PIPES IN OUTSIDE WALLS MUST BE INSULATED. OR ON HEATING SIDE OF HOUSE INSULATION.
5. PIPES PENETRATING FIRE RATED FLOOR/CEILING MUST BE METAL OR PROTECTED.
6. WATER HEATER AND FURNACES SHALL NOT BE INSTALLED IN BEDROOM, BATHROOM OR ROOMS LEADING TO BEDROOM OR BATHROOM.
7. WATER HEATER RELIEF LINE WILL NOT BE TRAPPED. RELIEF LINE WILL BE 3/4" RUN TO OUTSIDE WITH A 90* TURN DOWN OR RUN TO AN APPROVED DRAIN WITH 1" MIN. AIR GAP TO DRAIN. ALL RELIEF LINES SHALL RUN SEPARATE.
8. PROPERLY SIZED GAS PIPING.
9. HORIZONTAL VENTING MUST BE 6" MIN ABOVE FLOOD LEVEL.
10. ISLAND SINKS MUST HAVE CLEANOUT ON FOOT VENTS. MUST USE DRAIN FITTINGS , NO SAN TEES INSTALLED ON THEIR BACK, MUST USE COMBO. FOOT VENT CLEANOUTS MUST BE READILY ACCESSIBLE.
11. GAS PIPE SLEEVING UNDER SLAB MUST BE VENTED. FLEX PIPING SHALL HAVE PROPER CAP AND TERMINATION.
12. GAS FIRE PLACE MUST HAVE SHUT OFF WITHIN 4' OF APPLIANCE UNLESS UNIT IS REMOVABLE WITHOUT DISTURBING GAS COCK AND FLEX.
13. SHOWER COMPARTMENTS ARE 30" MIN.
14. WATER LINES MUST BE PRESSURE TESTED WITH AT LEAST 50 LBS OF AIR OR WORKING WATER PRESSURE.
15. WATER SOFTNERS SHALL NOT HAVE REDUCTION OF INLET.
16. VENT OPENING SHALL NOT BE BELOW TRAP WEIR.
17. TRAP AND ARM MUST BE SAME SIZE AND RUN IN PRACTICAL ALIGMENT.
18. BACK TO BACK FIXTURES REQUIRE DOUBLE FIXTURE FITTING. DOUBLE TEE OR COMBO. CAN BE USED IF A SEPARATE CLEANOUT IS INSTALLED.
19. DISSIMILIAR METAL MUST BE PROTECTED OR SEPERATED.

BERNAILLO COUNTY GUIDELINES FOR
RESIDENTIAL PLUMBING AND GAS INSPECTIONS.

PLUMBING TOP OUT CONTINUED

20. ALL PIPING MUST BE PROPERLY SUPPORTED AND STRAPPED.
21. ALL SINKS MUST HAVE CLEANOUT.
22. NO FLAT VENTING. NO BACKGRADING ON SANITARY PIPES.
23. VENTS MUST TERMINATE MIN. 6" ABOVE ROOF AND 12" AWAY FROM VERTICAL SURFACE.
24. RELIEF LINES FOR WATER HEATER, BOILER, CONBRACO THERMAL EXPANSION VALVE
MUST BE RUN INDEPENDENTLY OF EACH OTHER
25. SECOND STORY SANITARY SYSTEMS SHALL BE FILLED WITH WATER TESTED ABOVE THE TUB
OVERFLOW OR LAV. TRAP ARM.
26. SECOND STORY SANITARY REQUIRES SEPARATE HS WHEN A BACKWATER VALVE IS INSTALLED
27. 3" HOUSE SEWER REQUIRES A MIN. OF (3-2" VENTS) (2-2" AND 1- 1 ½" VENTS) OR
(1-2" AND 3 - 1 ½")
28. 4" HOUSE SEWER REQUIRES A MIN OF (1-3" AND 2-2" VENTS) (1-3" AND 4 -1 ½" VENTS) (1 -3", 1- 2"
AND 2 -1 ½" VENTS) (4 -2" VENTS) (3-2" AND 2 - 1 ½" VENTS) (2-2" AND 4 - 1 ½" VENTS) (1-2"
AND 6 1 ½" VENTS) (8 - 1 ½" VENTS)
29. GAS APPLIANCES IN GARAGES AND IN ADJACENT SPACES THAT OPEN TO THE GARAGE AND
ARE NOT PART OF THE DWELLING SPACE SHALL BE INSTALLED WITH BURNERS NO LESS THAN
18" ABOVE THE FLOOR, EXCLUDING DRYERS.
30. APPROVED OFFSET CLOSET FLANGES MAY BE INSTALLED
31. GAS REGULATORS WITH LIMITERS SHALL BE HORIZONTAL AND UPRIGHT, NO VERTICAL
INSTALLS.

GAS TO ISLAND RANGES

1. FOLLOW DRAWINGS FROM C.I.D FOR SLEEVING REQUIREMENTS

TEMP GAS

1. TEMP GAS OCTOBER 31ST - APRIL 30TH
2. ONE GAS APPLIANCE MUST BE INSTALLED FOR TEMP GAS

SHOWER PAN LINERS

1. ALL HORIZONTAL SURFACES (FLOOR AND SEAT) MUST BE COVERED WITH VINYL OR
APPROVED MATERIAL.
2. LINING MUST BE NO LESS THAN 3" ABOVE DAM AND ON ALL SIDES.
3. FINISHED DAM SHALL BE MIN 2" AND MAX. 9"
4. CORNERS SHALL BE PREFORMED ON DAM, INSIDE CORNERS MAY BE PREFORMED OR FOLDED.
5. NO HOLES IN VINYL. NAILS MUST BE HIGHER THAN 1" FROM DAM
6. PREFORMED CORNERS MUST BE USED AT DOOR WAY.

PLUMBING FINAL

1. SINKS, LAVATORIES AND WATER CLOSETS MUST BE CHAULKED OR GROUTED AROUND COUNTER AND
FLOORS.
2. LAUNDRY TUB AND WALL HUNG LAVS. MUST BE CHAULKED BETWEEN WALL AND FIXTURE.
3. WHIRLPOOL TUB MUST HAVE MIN 12 X 12 ACCESS PANEL FOR PUMP.
4. DISHWASHER MUST HAVE AIR GAP INSTALLED ON TOP OF COUNTER.
5. DISHWASHER DISCHARGE MUST BE AHEAD OF GARBAGE DISPOSAL.
6. IF CHECK VALVE IS INSTALLED ON WATER METER, THERMAL EXPANSION MUST BE INSTALLED.
7. WATER HEATERS MUST BE PROTECTED FROM PHYSICAL DAMAGE IN GARAGE.
8. WATER HEATER AND FURNACE MUST BE INSTALLED 18" ABOVE GARAGE FLOOR.

BERNALLO COUNTY GUIDELINES FOR
RESIDENTIAL PLUMBING AND GAS INSPECTIONS

PLUMBING FINAL CONTINUED

9. WATER HEATER AND FURNACE VENTS MUST HAVE 3 SCREWS ON JOINT AND 1" MIN. CLEARANCE FROM DOUBLE WALL TO COMBUSTIBLES.
10. ALL DOMESTIC LINES DRAINING INTO SANITARY DRAIN MUST HAVE MIN. 1" CLEARANCE.
11. HOSE BIBBS MSUT HAVE VACCUM BREAKERS.
12. PERMITS MUST HAVE CORRECT FIXTURE COUNT.
13. IF YARD HYDRANT IS INSTALLED, A REDUCED PRESSURE BACKFLOW OR A PRESSURE VACCUM BREAKER MUST BE INSTALLED AHEAD OF HYDRANT. CANNOT HAVE SCREW ON VACCUM BREAKER ON END OF OUTLET

MERC GAS FINAL

1. LOW PRESSURE UP TO AND INCLUDING 3 LBS MERC TEST- AN AIR TEST OF MIN 10 LBS WITH A 15 LB GAUGE MARKED OFF IN 1/10TH LB INCREMENTS OR MERC GAUGE MIN 8" OF MERC.
2. OVER 3 LBS SHALL REQUIRE A 24-HOUR RECORDER AT 30 LBS
3. REPAIR PIPING ONLY ON EXISTING HIGH PRESSURE. CAN DO 60 LBS FOR 30 MINUTES.
4. ALL GAS PIPING MUST HAVE DIELECTRIC UNION INSTALLED BETWEEN GROUND AND BUILDING.
5. FOR GAS CONVERSIONS AND EXISTING HOMES NEEDING MERC TEST- ALL GAS APPLIANCES SHALL BE BROUGHT UP TO CURRENT CODES.

EXCEPTIONS: GAS APPLIANCE

APPLANCES INSTALLED IN BEDROOMS DO NOT HAVE TO BE MOVED, CLOSET SHALL BE WEATHER-STRIPPED WITH OUTSIDE COMBUSTION AIR AND BOILERS DO NOT HAVE TO HAVE DOUBLE CHECK OR WATTS 9 D IF QUIPPED WITH A CHECK VALVE

6. ALL GAS COCKS SHALL BE INSTALLED. FUTURE USE WILL BE CAPPED OR NIPPLE AND PLUG
7. ALL JOINTS ON VENT PIPING MUST HAVE MIN 3 SHEET METAL SCREWS
8. SINGLE WALL PIPE MUST HAVE 6" CLEARANCE TO COMBUSTIBLES
9. DOUBLE WALL PIPE MUST HAVE 1" CLEARANCE TO COMBUSTIBLES
10. NEW BOILERS MUST HAVE WATTS 9 D OR EQUIVALENT BACKFLOW.
11. T & P VALVES MUST BEEN IN WORKING CONDITION AND LINE RUN TO OUTSIDE
12. MUST HAVE PROPER COMBUSTION AIR PROVIDED
13. COPPER AND BRASS PIPE SHALL NOT BE USED FOR GAS PIPING.
14. MUST HAVE SEDIMENT TRAPS AT APPLIANCE CONNECTIONS.
15. ALL GAS FIREPLACES REQUIRE OUTSIDE SHUT OFF VALVE WITH IN 4' OF APPLIANCE

SWIMMING POOLS AND SPAS

1. ALL MD AND CIR UNDERGROUND INSPECTIONS REQUIRE MINIMUM OF 36" AIR OR WATER
2. SPAS AND HOT TUBS BUILT ON SITE SHALL HAVE 2 MAIN DRAINS A MINIMUM OF 36" APART. SWIMMING POOLS CAN USE THE SKIMMER AS ONE OF THE TWO MAIN DRAINS OR ANTI VORTEX DRAIN.
3. WATER FILL SPOUTS SHALL BE ABOVE THE FLOOD LEVEL RIM OR BE PROTECTED BY A BACKFLOW PREVENTER.
4. ALL POOL BOILERS SHALL HAVE A PRESSURE/TEMPERATURE RELIEF VALVE AND SHALL BE PIPED WITH COPPER, BLACK OR GALV STEEL TO POINT TO GROUND LEVEL
5. WHEN MAKING GAS PIPING CONNECTIONS TO GAS METERS, A SEPARATE TEE SHALL BE INSTALLED ON THE DISCHARGE SIDE OF THE METER. THIS TEE IS REQUIRED FOR THE GAS COMPANY TO USE AS A BYPASS FOR INSPECTIONS.
6. IF DISCHARGE IS CONNECTED TO CITY SEWER, A 3" P TRAP SHALL SERVE AS SAND TRAP WITH INDIRECT 1 1/2" FROM BACKWASH OR FOR DRAINING THE POOL.