

2007 Biosolids Quality Summary

Biosolids Management Program



Department of Natural Resources and Parks Wastewater Treatment Division

Creating Resources from Wastewater

2007 BIOSOLIDS QUALITY SUMMARY

May 2008

Prepared by

King County Department of Natural Resources and Parks Wastewater Treatment Division Resource Recovery Section 201 S. Jackson Street, KSC-NR-0512 Seattle, Washington 98104-3855

This information is available in accessible formats upon request at (206) 684-1247 (voice) or 711 (for TTY/TDD users only).

EXECUTIVE SUMMARY

Biosolids are the nutrient-rich organic byproducts of the wastewater treatment process. Biosolids contain water, sand, organic matter, microorganisms, trace metals, and other chemicals. Because of their moisture content, humus-like characteristics, essential nutrients for plants, and very low levels of pollutants, biosolids are beneficial and safe to use as a soil conditioner, fertilizer for forest trees and agricultural crops, and as an ingredient of composts for landscaping.

This report summarizes the 2007 monitoring of biosolids from the West Point Treatment Plant (WPTP) and the South Treatment Plant (STP) at Renton. Both plants provide secondary wastewater treatment with anaerobic digestion of all solids followed by a dewatering process. The King County Wastewater Treatment Division (WTD) began recycling biosolids on land in 1973. The program has grown to beneficially recycle more than 110,000 wet tons (or approximately 27,000 dry tons) annually in forestry, agriculture, soil reclamation and compost.

To ensure the safety of biosolids recycling, the physical, chemical, and microbial characteristics of biosolids are routinely monitored. This monitoring is performed monthly in order to characterize the biosolids, examine changes over time, and determine appropriate application rates for biosolids at reuse sites.

RESULTS OF 2007 MONITORING AND DATA ANALYSIS

Biosolids are regulated under both state and federal regulations (WAC 173-308 and 40 CFR Part 503). King County's biosolids meet quality standards for metals, pathogen reduction (Class B) and vector attraction reduction, which means they are safe for all land application projects.

Metals

Trend analyses of data collected from WPTP and STP since 1990 indicate that concentrations of most metals have declined. The concentrations of all regulated metals in biosolids from both treatment plants throughout 2007 fell below the most stringent state and federal regulatory levels labeled Very High Quality in Figures Ex-1 and Ex-2.

Comparisons of 2007 metals concentrations to 2006 concentrations yielded a statistical decrease in silver in WPTP biosolids. Two metals (cadmium and molybdenum) in STP biosolids were statistically lower in 2007 when compared to 2006 levels.

Conventional Constituents

In WPTP biosolids, pH statistically decreased in 2007. Potassium was statistically lower in STP biosolids in 2007 than in 2006.

The fertilizer value of nitrogen in biosolids is measured as total nitrogen (the sum of organic nitrogen, ammonia, and nitrate-nitrite nitrogen). However, nitrate-nitrite nitrogen constitutes less than 0.01 percent in anaerobically digested biosolids and is disregarded in computations of fertilizer value. The average total nitrogen content of WPTP and STP biosolids in 2007 was about 5.9 and 7.1 percent, respectively, which was similar to 2006 levels.

Microbial Constituents


Analysis of all 2007 microbiological data for WPTP biosolids showed no significant difference from 2006 data. In STP biosolids, fecal coliform annual average showed a significant decrease in 2007 as compared to 2006.

Organic Constituents

While not required by federal or state biosolids regulations, King County's biosolids are analyzed for 135 trace organic compounds listed on the EPA Priority Pollutant List (40 CFR 423, Appendix A) and the Hazardous Substances List (40 CFR 116.4 A & B) as part of the National Pollutant Discharge Elimination System (NPDES) permit monitoring. Less than 15 percent of these compounds were detected in biosolids during 2007. Twenty and thirteen priority pollutants were detected at very low concentrations in WPTP and STP biosolids, respectively. These compounds included polynuclear aromatic hydrocarbons (PAHs), phthalates, polychlorinated biphenyls (PCBs), and solvents.

CONCLUSIONS

The 2007 data from WPTP and STP show that King County's biosolids quality is excellent when compared with all relevant criteria. Concentrations of regulated metals in biosolids were consistently below the most stringent state and federal standards for land application. Biosolids from both treatment plants may be used safely to improve soils and provide nutrients for agricultural crops and trees.





* indicates statistically significant increase or decrease by Mann-Whitney U test between 2007 and 2006 values.

Note: The WPTP was a primary treatment plant until 1996 when it was converted to full secondary treatment.

2007 Biosolids Quality Summary




Figure Ex-2. Trends in Annual Average Concentrations of Metals in STP Biosolids

* indicates statistically significant increase or decrease by Mann-Whitney U test between 2007 and 2006 values.

TABLE OF CONTENTS

EXE	CUTIVE SUMMARY	iii
1.0	INTRODUCTION	
	1.1 Wastewater Treatment Plant Processes	
	1.2 Pathogen Reduction and Stabilization	
	1.3 EMS Continual Improvement	
2.0	SAMPLING METHODOLOGY AND DATA ANALYSIS	1
2.0	2.1 Sampling Methodology and Sample Analysis	
	2.2 Data Analysis2.3 Hypothesis Testing	
3.0	RESULTS AND CONCLUSIONS.	
	3.1 Conventional Constituents	б
	3.1.1 Nitrogen	6
	<i>3.1.2 pH</i>	6
	3.1.3 Phosphorus and Potassium.	7
	3.1.4 Sulfur	7
	3.1.5 Solids	7
	3.2 Metals	
	3.2.1 Metals Trend Analyses	
	3.3 Trace Organic Compounds	9
	3.4 Microbiology	
	3.5 Conclusions	
4.0	MICROBIAL CONSTITUENTS OF BIOSOLIDS	
	4.1 Fecal Coliform Bacteria	
	4.2 Salmonellae Bacteria	
	4.3 Total Enteric Viruses	
	4.4 Parasites	
5.0	PLANT-ESSENTIAL MICRONUTRIENTS AND	
5.0	MACRONUTRIENTS FOUND IN BIOSOLIDS	14
	5.1 Macronutrients	
	5.2 Micronutrients	
6.0	GLOSSARY	
7.0	REFERENCES	

CONTENTS (continued)

APPENDIX

- A SUMMARY TABLES OF ALL PARAMETERS
- B RAW DATA TABLES OF PARAMETERS
- C WEST POINT (WPTP) TRACE METALS TREND PLOTS
- D SOUTH PLANT (STP) TRACE METALS TREND PLOTS

Note: Appendix C and D not included in on-line PDF file – available upon request.

1.0 INTRODUCTION

Biosolids are a combination of water, sand, organic and inorganic particles, nutrients, microorganisms, trace metals, and chemicals. Biosolids are recycled as a fertilizer and soil amendment because they contain all essential micronutrients and significant amounts of macronutrients such as nitrogen, phosphorus, potassium, and sulfur, which plants need for growth and development. Their high organic matter content also aids in improving soil structure, moisture holding capacity and tilth.

The King County Biosolids Management Program (BMP) began recycling biosolids in 1973. Staff from the BMP, wastewater treatment plants, Hazardous Waste and Industrial Waste programs, Environmental Laboratory, and others collaborate to ensure that King County's biosolids continue to be as high in quality as is economically and practically achievable, safe, and used beneficially in a variety of projects. An integral part of this effort is the biosolids monitoring program which has included systematic sampling and analysis of biosolids since the early 1980s. The constituents routinely monitored include chemicals of health and environmental concern, industrial byproducts, microbes, and essential elements for plant and animal growth and development.

In 1993, the EPA implemented a federal rule, 40 CFR Part 503, in compliance with the Federal Clean Water Act, which set standards for the use of biosolids to protect public health and the environment. In 1998 the Washington State Department of Ecology (Ecology) implemented a new state biosolids rule (WAC 173-308) as part of the process to seek delegation for biosolids management from EPA. State and federal rules include operational standards, monitoring requirements, quality criteria and site management requirements.

Among the quality criteria set by state and federal standards are limits for concentrations of metals in biosolids. All biosolids applied to land must meet the ceiling limits for nine metals (Table 1, 40 CFR 503.13 and WAC 173-308-160). These limits are labeled in this report as "high quality biosolids." A more stringent "pollutant concentration limit" (Table 3 in 40 CFR 503.13 and WAC 173-308-160) is designated as "very high quality" in this report.

This report summarizes the 2007 monitoring of biosolids from the West Point Treatment Plant (WPTP) in Seattle and the South Treatment Plant (STP) in Renton. In 2007 biosolids were analyzed for the following constituents:

Conventionals including total solids, total volatile solids, pH, ammonia, organic nitrogen, total phosphorus, total potassium and total sulfur.

Microbes, including fecal coliforms, *Salmonellae*, parasites and total viruses. (See Section 4 for a discussion of the microbial constituents.)

Metals and other elements including arsenic, cadmium, copper, lead, mercury, molybdenum, nickel, selenium, zinc, barium, beryllium, boron, calcium, chromium, iron, magnesium, manganese, potassium, and silver (the first nine listed are regulated by Ecology and EPA).

Trace organics including volatiles, bases, neutrals, acids, pesticides, polynuclear aromatic hydrocarbons (PAHs) and polychlorinated biphenyls (PCBs) from EPA's priority pollutant list (40 CFR 423, Appendix A) and Hazardous Substances List (40 CFR 116.4 A & B).

1.1 Wastewater Treatment Plant Processes

Both WPTP and STP utilize primary and secondary wastewater treatment in their process stream. Preliminary and primary treatment consists of screening, grit removal and gravitational settling. The primary effluent continues on to secondary treatment where microbial action and aeration remove more of the dissolved and suspended organic matter. Together, primary and secondary treatment removes 85 percent or more of the dissolved and suspended organic matter. The solids collected from both processes are directed to thickeners followed by mesophilic, anaerobic digestion where complex organic molecules are converted to methane, carbon dioxide, ammonia, water and other by-products. During digestion the volatile solids are reduced, which lowers the mass weight of total solids by almost half and homogenizes the biosolids. Bound to the organic matter are metals, additional microbes, and organic compounds. The organic matter is the source of conventional constituents including nitrogen, phosphorus, and sulfur. It is these compounds which make biosolids a valuable soil additive and source of nutrients for improved plant growth.

Although the two plants employ similar treatment processes they have differences which exist in the source of wastewater and composition of the conveyance system. South Plant influent is primarily from sanitary sewers from newer developments east of Lake Washington, whose dwellings have been equipped with copper piping. On the other hand, West Point receives wastewater from sanitary and storm sewers (a combined system), which results in large volumes of water surging into the plant during large rain events. These increased flows carry with it additional sediment along with contaminants from roads and other impervious surfaces. Furthermore, most of the sanitary flow to West Point originates from older Seattle neighborhoods which are plumbed with galvanized pipes (containing lead and iron). These differences help explain some of the biosolids quality variations seen between the two plants.

1.2 Pathogen Reduction and Stabilization

Under federal and state standards, King County's biosolids from WPTP and STP are considered Class B biosolids, safe for all land application projects. EPA classifies biosolids as Class A or Class B based on the level of pathogen reduction. Additionally, biosolids must be stabilized for vector attraction reduction. To meet Class A standards, biosolids are treated to eliminate pathogens. Class B biosolids have been treated to reduce pathogens, but complete die-off occurs after land application. According to the EPA (1992), the "goal of the Class B requirements is to ensure that pathogens have been reduced to levels that are unlikely to pose a threat to public health and the environment under the specific use conditions." Several process alternatives are provided by the EPA to confirm that the required pathogen reduction and vector attraction reduction have been achieved.

Pathogen reduction of King County biosolids is accomplished by anaerobic digestion of wastewater solids. This is alternative 2 of 40 CFR 503 [503.32(b)(3)]. The solids are digested at mesophilic temperatures (95° to 98° F) for at least 15 days. WPTP and STP anaerobic digestion processes meet EPA criteria for a "Process to Significantly Reduce Pathogens" (PSRP), and qualify biosolids as Class B. At WPTP and STP, anaerobic digestion produces biosolids with microbial populations that are at least 90 percent lower than the populations in the raw solids entering the digesters. Any remaining pathogenic organisms die-off quickly after land application.

Vectors include "any living organisms capable of transmitting a pathogen from one organism to another..." (EPA 1992). According to the EPA, vectors for pathogens in biosolids would most likely include insects, rodents, and birds. One way to achieve vector attraction reduction is to reduce the amount of total volatile solids at least 38 percent during processing thus reducing odors that might attract vectors. The biosolids thus contain biodegradable material that decomposes so slowly that vectors are not attracted (EPA 1992). The volatile solids reduction is measured routinely at each treatment plant and is more than 50% at both WPTP and STP.

1.3 Continual Improvement

In July 2004, King County's Wastewater Treatment Division was certified into the National Biosolids Partnership's (NBP) Environmental Management System (EMS) for biosolids. King County is the third agency in the nation to achieve this certification following a rigorous, independent, third-party verification audit of its biosolids program. The EMS audit verified that King County, along with all of their biosolids partners, meets the requirements for certification and admittance to the NBP EMS program and is committed to excellence in biosolids management practices, goes beyond regulatory compliance obligations, and provides meaningful opportunities for public participation.

2.0 SAMPLING METHODOLOGY AND DATA ANALYSIS

WPTP and STP biosolids were monitored monthly for metals, conventional constituents and microbes. This frequency is twice the rate currently required by federal and state regulations. Organic compounds are monitored annually as required under our National Pollutant Discharge Elimination System (NPDES) permit.

2.1 Sampling Methodology and Sample Analysis

Biosolids samples are analyzed by the King County Environmental Laboratory and the WPTP and STP laboratories. Some analyses are performed by contract laboratories. Testing equipment and protocols at all laboratories comply with those recommended by EPA.

Samples of biosolids are collected monthly from WPTP and STP. The monthly sample from STP consists of grab samples taken every three hours and composited over a 24-hour period. The monthly sample from WPTP consists of grab samples collected every two hours during a 24-hour period; the subsamples are then combined and analyzed. Although collected in a single day, these combined samples reflect digester solids loading over an average of about 25 days at WPTP and 25 to 30 days at STP.

2.2 Data Analysis

Raw data for all constituents are presented in Appendix B. Relevant data are compared to state and federal regulatory limits (WAC 173-308-160 and 40 CFR Part 503.13, Tables 1 and 3) for high quality biosolids, State of Washington Dangerous Waste Criteria, and previously reported biosolids quality data from WPTP and STP. All data are stored and accessed on the King County Environmental Data Station (EDS) database.

2.3 Hypothesis Testing

Annual data are compared using statistical methods to evaluate year to year changes in biosolids quality. The selection of appropriate statistical tests for comparison strongly depended on the number of observations and their underlying distribution.

When a constituent was present in a sample in sufficient quantity to be detected with certainty by the laboratory analytical procedure, the detected concentration is reported. This is referred to as a "hit." When constituents were not present in a sample in sufficient concentration to be quantified (i.e., less than the method detection limit), the detection limit for the constituent is reported, which means the lowest concentration that can be detected. These data points are referred to as "undetecteds." Data sets that contain both hits and undetecteds are called "censored." There are several generally accepted ways to compute descriptive statistics for such data sets. The advice of Gilbert (1987) and of Helsel (1990) were followed in the treatment of censored data sets.

The underlying distribution refers to the shape of the frequency plot of all data for a particular constituent. The frequency distribution referred to as "normal" has a bell shape that is symmetrical about a central point, and is defined by a specific equation. Environmental data may follow this distribution, but often they follow others including skewed or bimodal frequency distributions.

With few exceptions, metals and conventional constituents such as nitrogen and potassium are always detected in biosolids. Some constituents show a reasonably normal distribution, but others do not. In order to compare data sets a single statistical procedure was chosen that was valid regardless of the distribution and the number of "hits." The most appropriate testing procedure that will yield valid results regardless of the distribution is the Mann-Whitney U test, also known as the Wilcoxon Rank Sum test. It permits the use of all data, including detection limits from censored data sets. It tests the hypothesis that the data sets represent two random samples from the same population regardless of the underlying distribution. If the test indicated a statistically significant difference (95% confidence or p<0.05) between data sets, it was concluded that they did not represent random samples from the same population.

Summary statistics including means and standard deviations are calculated for conventionals and metals. Since trace organic compounds are tested for twice per year, it is not possible to do statistical computations. Additionally, most trace organic compounds that are tested for are not detected. In lieu of statistics, the current year's values are compared to historical values for detected organic compounds.

Outlier analysis (using SPSS software application) is performed annually on metals data to identify outliers, or values that lie so far away from the rest of the data that they are likely not accurate measurements. If outliers cannot be explained by corresponding influent metal concentrations, known discharges or modeling, it is considered not representative of reality. Such values are reported, but excluded from the calculations of averages and statistics.

For microbiological data the annual geometric mean is used since the monthly values typically show variable results believed to be due to the irregular distribution of bacteria in a subsample. The geometric mean (GM) was calculated by using the following equation:

 $GM = [e^{(\Sigma \ln x_i / n)}]$

 $\begin{array}{ll} \mbox{Where:} & n = n \mbox{umber of times a compound was detected} \\ & x_i = the \ ith \ value \ that \ was \ detected \end{array}$

Although called a mean, the geometric mean is an estimator of the median for populations with a log normal distribution, which is the distribution that most environmental data follows. For heavily skewed data sets, the median is a robust indicator of central tendency because its position is unaffected by very large or very small values. The median is that value above which 50 percent of the data are situated and below which 50 percent of the data are situated.

3.0 RESULTS AND CONCLUSIONS

Results of monitoring are given in tables in appendices of this report and include summary statistics, raw data, and charts. All data included in tables have been rounded in accordance with the accuracy of the particular analytical procedure used. Unless otherwise noted, all concentrations are reported on a dry weight basis. Concentrations of metals, conventionals, and organic compounds are reported in terms of parts per million (ppm or mg/kg) dry, and microbial concentrations are reported as number of organisms per gram dry and per 100 grams wet weight (Appendix B). This is the only exception to the reporting of results on a dry weight basis.

3.1 Conventional Constituents

Analytical results for WPTP and STP conventionals are shown in Tables A-1 and A-2 in Appendix A. The majority of these parameters are comparable to the 2006 WPTP and STP levels. Monthly values for all conventionals from each treatment plant are presented in Tables B-1 and B-2 in Appendix B.

3.1.1 Nitrogen

Total nitrogen (as measured by the Total Kjeldahl Nitrogen method) in biosolids has three components: readily available ammonia, which accounts for 15 to 20 percent of the total, bound organic nitrogen which accounts for most of the remainder, and nitratenitrite nitrogen which accounts for less than one one-hundredth of one percent (<0.01 percent) of the total. The ammonia and nitrate-nitrite fractions are associated with the water portion of the biosolids. Thus, the concentration of these constituents on a dry basis will likely drop with an increase in cake solids.

The average concentrations of organic and ammonia nitrogen are used to determine biosolids application rates. All the ammonia is immediately available for plant uptake, but may be lost by volatilization if biosolids are not incorporated into the soil. Of the bound organic nitrogen, 10 to 40 percent is mineralized and available for plant use during the first year after biosolids application. These are estimates that vary with the type of biosolids processing, site management practices such as incorporation into the soil, and weather or field conditions.

Average total nitrogen concentrations remained similar to the previous year. For WPTP biosolids, the 2007 average total nitrogen concentration was about 59,400 mg/kg dry, or about 5.9 percent. The 2007 average total nitrogen concentration for STP biosolids measured 70,800 mg/kg dry, or about 7.1 percent. These numbers were not significantly different from 2006 values.

3.1.2 pH

WPTP and STP biosolids showed 2007 average pH values of 8.80 and 8.55 units, respectively. WPTP's 2007 pH is statistically lower than in 2006.

3.1.3 Phosphorus and Potassium

The average total phosphorus concentration of WPTP biosolids (18,200 mg/kg dry) and the total potassium concentrations (1,700 mg/kg dry) were statistically unchanged when compared with the previous year. At STP phosphorus (22,500 mg/kg dry) was statistically unchanged when compared with 2006 but potassium (2,200 mg/kg dry) was significantly decreased from 2006 levels.

3.1.4 Sulfur

Sulfur, a plant-essential macronutrient, is present in biosolids as a constituent of organic compounds, in inorganic compounds that may include the sulfide, thiosulfate, and the sulfate (SO_4^{-2}) ions, and as elemental sulfur. One potential source of sulfate in biosolids is hydrocarbons that get washed into the collection system during rain events.

Organic sulfur compounds act as slow-release sources of sulfur as land-applied biosolids decompose. Sulfur is absorbed by plants primarily as the sulfate ion, although several sulfur containing amino acids may also be directly absorbed and metabolized. The 2007 average total sulfur content was 11,170 mg/kg dry and 11,100 mg/kg dry in WPTP and STP biosolids, respectively. These averages are both statistically similar to the previous year's averages.

3.1.5 Solids

The total solids (TS) content of biosolids is influenced by many factors, some of which include the proportion of primary solids mixed with waste activated sludge in the digester; the effectiveness of the digestion process at converting solids to gas; the intended end-use of the biosolids and the dewatering process employed. Digestion, the process that follows thickening of primary and secondary sludges, breaks down organic compounds into gases, water, and a more stable organic matrix, and reduces the total solids. The final step in the production of biosolids is dewatering. Centrifuges dewater the biosolids with the addition of polymers.

The 2007 average percent TS (based on monthly samples) of WPTP biosolids was 26.7 percent and the 2007 average (based on monthly samples) for STP biosolids was 22.4 percent. Both TS averages were statistically similar to the previous year. Daily samples are also analyzed to monitor treatment plant processes. TS values are used to convert wet weight lab results to a dry weight basis for uniform comparison to regulatory standards and to calculate biosolids application rates.

Volatile solids (VS) are that portion of the total solids that can be burned-off (volatilized) at 550°C. These solids represent the easily decomposed, potentially putrescible organic material that could attract vectors. If this is reduced or minimized during digestion by at least 38 percent then vector attraction will likewise be reduced which is one of the criteria of producing good quality, Class B biosolids. The average VS concentration at WPTP in 2007 was 62%, and at STP the average VS concentration was 69%.

3.2 Metals

Monthly samples were analyzed for the presence and concentrations of 17 metals. Tables A-3 and A-4 in Appendix A present statistical summaries of the key metals concentrations from WPTP and STP biosolids during 2007. Tables B-3 and B-4 in Appendix B provide monthly values for all metals analyzed from WPTP and STP, respectively.

All metals concentrations in biosolids from WPTP and STP met federal criteria for land application. Silver was statistically lower in 2007 than in 2006 in WPTP biosolids (see Table A-3). Two metals in STP biosolids (cadmium and molybdenum) were statistically lower in 2007 than their levels in 2006 (see Table A-4). See Section 3.2.1 for further discussion.

Statistical outlier analysis identified three measures at WPTP as outliers (see section 2.3). In January and February arsenic was higher than normal and selenium was high in February, though all measures were well below the most stringent regulatory limits. Quality control at the labs was reviewed and all values appear normal and within control limits. There are no known regulated industrial sources of these metals, however, they are found in trace amounts in products used by consumers. Another possible source for these metals at WPTP could be from stormwater runoff coming from the combined sewer system serving downtown Seattle. Since these high values are plausible they are not considered to be outliers and therefore were included in the statistical analyses.

Only one outlier measurement for nickel was found at STP in December. This metal measured higher than usual in the influent sample which suggests that the level found in biosolids is representative. A large storm event occurred in early December which probably scoured out the sewage pipes bringing excess sediment and pollutants into the treatment plant. Since this high value can be explained it is not considered an outlier and therefore was included in the statistical analyses.

3.2.1 Metals Trend Analyses

The 2007 data for each metal from WPTP and STP are presented in Appendix B, Tables B-3 and B-4. For most metals there is very little monthly variation during 2007. Most WPTP metals data are available since 1981, while STP metals data are available since 1988. Plots of annual average concentrations of key metals from 1990 to 2007 are presented in the Executive Summary and Appendices C and D.

Since 2000, mercury levels in King County biosolids have dropped by 52%. This is primarily the result of a 2003 King County policy requiring dentists to install amalgam separators in their offices. Concentrations of silver in biosolids continue to decline. Silver at STP has decreased 54% and at WPTP, it has decreased 66% since 2002. The reason for this decline is not clear, however the Washington Department of Ecology has put an emphasis on silver recovery from photography operations over the past few years. This, in combination with the increase in digital photography at the expense of film photography, and the increased usage of amalgam separators by dentists, is a likely reason for the decrease in silver.

There is a slight decline in cadmium at STP but it seems to have some annual variability. Last year it was slightly higher. Cadmium is required in manufacturing some aircraft parts. Since several of these plants have closed in our area there is the expectation that we would see less cadmium in our biosolids.

Molybdenum (Mo) has been steadily declining at WPTP over the last four years and more noticeably dropping at South Plant the last two years. The Industrial Waste Program has been researching sources of Mo into our treatment plants over the last couple of years. One major source is cooling tower water where Mo is used as a corrosion inhibitor. Staff have begun to educate industries via newsletters and workshops about the problems that Mo can cause to the treatment process and biosolids quality. More outreach will be done later this year to help reduce the amount of Mo being discharged to the sewer.

The reduced concentrations of many metals in biosolids over the years are attributed to the ongoing corrosion control project implemented by the City of Seattle, King County's Hazardous Waste Management and Industrial Waste Program, and the removal of lead from gasoline. Additionally the City of Renton started adding caustic to their water supply to reduce corrosion in 1999. This not only reduced corrosion from homes and businesses but also from the STP which used a considerable amount of city water as process water.

3.3 Trace Organic Compounds

The WPTP and STP biosolids were analyzed for 135 trace organic compounds (listed in Table A-7 in Appendix A). Prior to 1997, trace organic compounds were analyzed monthly. Very few compounds were ever detected and usually the same ones were seen from month to month with only minimal variation. Since 1997, testing has been conducted annually to meet NPDES permit requirements. EPA did not establish biosolids standards or monitoring requirements for organics due to low concentrations and minimal risk to public health and the environment. In general, research on the bioavailability of toxic organic compounds to plants indicates that the risk to humans consuming food crops grown on soils amended with biosolids is negligible. No adverse human acute or chronic toxicity effects have been reported resulting from ingestion of food plants grown in soils amended by biosolids (NRC, 1996).

In 2007, two composite samples from each plant were analyzed for the baseneutral extractables, pesticides, herbicides, PCBs, acid extractable fractions, and volatile organic compounds. The detectable organic compounds from WPTP and STP are summarized in Tables A-5 and A-6 in Appendix A, respectively. For comparison purposes the range of minimum and maximum 1996 values are included for each compound. Of the 135 organic compounds sought in 2007, only 20 were detected in WPTP biosolids and 13 were detected in STP biosolids. This represents about the same number of compounds for STP and a few more for WPTP as in 2006 samples.

The following types of organic compounds were detected in very low concentrations during 2007: Polynuclear Aromatic Hydrocarbons (PAHs): components of fuel, asphalt, creosote, and products of combustion which are commonly found in the environment. Transfer of PAHs from soil has been shown to be minimal for root crops, and essentially zero for above-ground crops (NRC, 1996).

Phthalates, which are plasticizers used in many products including in food wrap, are prevalent in the environment. Phthalates do not persist in soils and are rapidly removed by volatilization and microbial decomposition (NRC, 1996).

Solvents, such as chlorobenzene, phenol, and 4-methylphenol, which are widely used as disinfectants.

PAHs and PCBs are two classes of trace organics that are of particular interest in determining dangerous or hazardous qualities of a solid waste residual, according to Ecology dangerous waste regulations (WAC 173-303-9903). The concentrations of the 7 PAH compounds detected in WPTP biosolids totaled <21.61 mg/kg dry in 2007. Three PAH compound were detected in STP biosolids with a total concentration of <3.07 mg/kg dry. The yearly totals continue to be well below Ecology's criterion of 10,000 mg/kg dry for total PAH compounds (WAC 173-303-100).

Three PCBs, Aroclor 1248, 1254 and 1260 were detected in WPTP biosolids in minute concentrations, while only one, Aroclor 1248 was detected in STP biosolids. The concentrations of all PCBs were well below the federal prescribed use guidelines of 10 mg/kg dry (40 CFR Part 761).

3.4 Microbiology

Results of microbiological analyses are summarized in Tables A-1 and A-2 in Appendix A. The levels of fecal coliform and *Salmonella* showed no statistical difference in 2007 when compared to 2006 levels in WPTP biosolids. Fecal coliform in STP biosolids showed a statistical decrease in 2007. Viruses were detected once at STP during 2007 (See Appendix B, Tables B-1 and B-2 for monthly values, except viruses which are analyzed quarterly).

In 2007 we discontinued the analysis for enterococcus bacteria. In the past the Department of Ecology (DOE) was thinking of using enterococcus as an indicator of fecal contamination in freshwater. After their last Triennial Review for Water Quality Standards they decided to use fecal coliform as the indicator organism.

Additionally biosolids are tested quarterly for the presence of several parasites having public health significance. These include Ascaris, Coccidia, Giardia, Mite-ova, Nematodes, Taenia, Toxocara and Viable Helminth ova. None of these parasites were detected in WPTP or STP biosolids during 2007.

Fecal coliform and *Salmonellae* bacteria analyses are all performed by using the Most Probable Number (MPN) approach. This technique results in population counts that are reported as an MPN index. The index is an estimate based on probability formulas

and a certain number of replicate tests from the same biosolids sample. Each replicate may give quite different results because of the irregular distribution of bacteria in the subsamples. The results of the test are compared to MPN tables, and the MPN index is assigned.

The MPN index is derived from a probability formula and statistics. Associated with each MPN index is a range called the 95% confidence interval. For example, an MPN index of 26 organisms/100 gram has a range of 9 to 78 organisms. This means that 95 percent of the replicates analyzed from a particular sample whose index is 26 will have bacterial counts that fall between 9 and 78 organisms/100 g, with a most probable number of 26 organisms/100 g. The important point to remember is that the MPN index is not a definite number, but rather the most probable number within a range of values.

3.5 Conclusions

Biosolids data from WPTP and STP for 2007 continue to show that King County's biosolids are of high quality when compared to all relevant criteria including prescribed use guidelines and the 2006 WPTP and STP biosolids quality data. Concentrations of most metals have leveled off or continue to decline in biosolids at both plants, and all metals for which there are regulatory criteria are detected in concentrations well below maximum allowable concentrations and below the more stringent 40 CFR Part 503.13 Table 3 limits.

WPTP and STP biosolids are very similar in terms of meeting the federal and state criteria. King County biosolids meet all Class B pathogen reduction standards under the federal regulation 40 CFR Part 503. As such, they are deemed safe for a variety of projects and applications including fertilization of food chain crops, forestlands, and general soil improvement. It is King County's continuing goal to achieve further improvements in biosolids quality.

4.0 MICROBIAL CONSTITUENTS OF BIOSOLIDS

Wastewater typically contains many millions of microorganisms per 100 ml. Some of these organisms are potentially disease producing, or pathogenic, to humans and other animals; others are harmless. One of the primary purposes of wastewater treatment is to significantly reduce or eliminate pathogenic microorganisms. The anaerobic digestion processes used to treat wastewater solids at King County's West Point Treatment Plant (WPTP) and South Treatment Plant (STP) reduce microbial concentrations from initial levels by up to 95 percent. Properly designed and managed land application programs ensure that proper field conditions exist for the elimination of any potentially remaining pathogens in biosolids, and thereby prevent them from entry into the food chain. In Washington, these conditions include warm, dry, sunny environments during at least part of the year.

The microorganisms in biosolids may be pathogenic or more commonly, indicators of pathogens. While laboratory analysis is not required to meet pathogen reduction standards, the King County Environmental Laboratory routinely analyzes biosolids for the presence of certain indicator microorganisms and pathogens. A brief description of each follows.

4.1 Fecal Coliform Bacteria

These microorganisms, most of which are nonpathogenic, are common to most warm-blooded animals, and include *Escherichia* and *Klebsiella* species. Their presence in high numbers in biosolids does not confirm the presence of pathogens, but suggests the possibility of pathogen presence. Fecal coliforms are the most widely accepted, though not the only indicator of fecal pollution.

4.2 Salmonellae Bacteria

This enteric pathogen is sometimes found in human or animal fecal matter. *Sal-monellae* are associated with outbreaks of gastroenteritis and typhoid, human diseases usually contracted through consumption of contaminated drinking water or food.

Salmonellae survival in a forest or agricultural field is highly unlikely. Pathogenic microorganisms, including *Salmonellae* do not survive the warm, dry periods and the competition by naturally occurring organisms that all biosolids application sites experience (regardless of the time of year the biosolids are actually applied).

4.3 Total Enteric Viruses

Biosolids from WPTP and STP are routinely analyzed for enteroviruses including polioviruses, Coxsackie viruses, and ECHOviruses. Vaccine-strain polioviruses are commonly found in wastewater as a result of oral polio vaccine use. Viruses multiply only within living cells, so their numbers cannot increase in raw wastewater, wastewater

1

solids, biosolids, or the environment. Processing of wastewater to biosolids further reduces the numbers to very low or undetectable levels.

4.4 Parasites

Parasites pose a potential risk to human health due to the existence of resistant stages of the organisms and low infective doses. Routine testing includes Ascaris lumbricoides, Coccidia, Giardia lamblia, Mite-ova, Nematodes, Taenia, viable Helmith ova and Toxocara. Samples are tested quarterly using a sedimentation and centrifugation technique.

Ascaris ova are the most commonly isolated nematode ova and may be the most resistant of the ova or cysts that could be found in biosolids. This makes them a good indicator of the presence of parasites as a group. However, in a recent nation-wide survey of thirty, Class B biosolids samples Ascaris was not detected. This study suggests that health risks from microbial hazards in Class B biosolids have been reduced by implementation of the 503 rule.

5.0 PLANT-ESSENTIAL MICRONUTRIENTS AND MACRONUTRIENTS FOUND IN BIOSOLIDS

Two criteria must be satisfied in order to consider an element essential for plant life. First, an element is considered essential if a plant cannot complete its life cycle in the total absence of the element. Second, an element is considered essential if it forms part of any molecule or constituent of the plant that is itself essential (Epstein, 1972). Following these two criteria, 16 elements are considered essential to plant life. These are divided into two groups on the basis of the tissue concentrations observed in most plants. Macronutrients are essential elements found in plants in concentrations greater than or equal to 1,000 ppm dry weight basis (mg/kg dry). Micronutrients, also referred to as trace elements or minor elements, are found in tissue concentrations equal to or less than 100 ppm dry weight basis.

5.1 Macronutrients

Nine of the sixteen essential elements are considered macronutrients. Arranged in order from greatest to smallest concentration in plant tissue, these are: carbon, oxygen, hydrogen, nitrogen, potassium, calcium, magnesium, phosphorus, and sulfur.

Carbon, oxygen, hydrogen, nitrogen, phosphorus and sulfur are all constituents of amino acids and proteins including enzymes and coenzymes, as well as having other critical functions in plant cells. Potassium is essential as an activator of the enzymes involved in protein synthesis, and for translocation of anions such as NO_3^{-1} and SO_4^{-1} , from one plant part to another. Magnesium is a constituent of chlorophyll molecules and is responsible for the maximum rates of hundreds of enzymatic reactions involving adenosine triphosphate (ATP), for the ability of enzymes to fix CO_2 into organic molecules, and for protein synthesis in cells. Calcium functions to cement plant cell walls together, activates several enzymes, and is important in cell division.

5.2 Micronutrients

Seven elements are currently listed as micronutrients. These include, in descending order of concentration in dry plant tissue, chloride, iron, boron, manganese, zinc, copper, and molybdenum.

Some, but not all, plant species require other elements in micronutrient concentrations to complete their life cycles. These other elements include cobalt, sodium, silicon, selenium, and nickel. Higher animals whose nutritional requirements are obtained directly or indirectly from plants require additional elements in micronutrient concentrations. These include sodium, iodine, cobalt, selenium, nickel, silicon, chromium, tin, vanadium, and fluorine. These elements may be absorbed and stored by plants even though they are not strictly required for completion of their life cycle. Several other elements that may not be universally essential throughout the plant community, but that do contribute to increased growth of some crops, include strontium and barium (Sauchelli, 1969). Barium is another constituent of biosolids. Biosolids are routinely analyzed for most of the above elements except iodine, fluorine and silicon. All elements listed above and for which King County currently tests are detected in biosolids.

Except for iron and sometimes manganese, plant essential micronutrients are usually found in low concentrations in soils, and their availability to plants is also low (Brady, 1990). Brady states, "... even though their (micronutrients) removal by plants is small, the cumulative effects of crop production over a period of years may rapidly reduce the limited quantities of these elements originally present in soils." Biosolids applications to heavily cropped agricultural fields can aid in the replenishment of micronutrients.

The following discussions summarize information from several sources on the importance of micronutrients, their functions in plant growth and development, and known antagonisms. Because biosolids contain all these nutrients, it can be thought of as "complete plant food," especially when compared with commercial fertilizers that focus on N-P-K analysis.

ELEMENT	ESSENTIAL FUNCTION	CROPS HAVING
		A HIGH
		REQUIREMENT
IRON	1. Essential component of the catalyst involved in the	blueberries, nut
	formation of chlorophyll,	trees, cranberries,
	2. Required for oxidation-reduction in respiration	peaches, rhododen-
	processes,	dron, grapes
	3. Constituent of certain enzymes and proteins.	
MANGANESE	1. Acts as a catalyst in several enzymatic and physio-	beans, soybeans,
	logical reactions in plants,	onions, potatoes,
	2. Essential for nitrogen and inorganic acid metabo-	citrus, dates
	lism,	
	3. Essential for carbon dioxide assimilation and break-	
	down of carbohydrates during photosynthesis,	
	4. Needed for the formation of carotene, riboflavin	
	(vitamin B ₂), and ascorbic acid (vitamin C).	
BORON	1. Essential for protein synthesis, nitrogen and carbo-	alfalfa, clover,
	hydrate metabolism,	sugar beets, cauli-
	2. Essential for root system development, fruit and	flower, celery, ap-
	seed formation,	ples, other fruits
	3. Maintains correct water relations within plants.	
ZINC	1. Essential for formulation of growth hormones	citrus and fruit
	(auxins),	trees, soybeans,
	2. Promotes protein synthesis,	corn, beans
	3. Necessary for seed and grain maturation and pro-	
	duction,	
	4. Catalyst for oxidation in plant cells and vital for	
	transformation of carbohydrates,	
	5. Promotes the absorption of water and prevents	
	stunting.	

MOLYBDENUM	 Required for symbiotic nitrogen fixation and protein synthesis, Required for the synthesis of ascorbic acid (vitamin C), Makes iron physiologically available within plants, Alleviates plant injury caused by the presence of excessive amounts of copper, boron, nickel, cobalt, manganese and zinc. 	alfalfa, sweet clo- ver, cauliflower, broccoli, celery
COPPER	 Catalyst for respiration, Required for chlorophyll synthesis, Required for carbohydrate and protein metabolism, Enzyme constituent. Copper has also been used as a fungicide for more than 100 years to control wheat blunt and smut. Cer- tain compounds of copper are still used in organic farming as pesticides. 	citrus and fruit trees, onions, small grains
CHLORIDE	 Role is unclear but it enhances root and top growth of plants, especially when young, Stimulates photosynthesis. 	tomatoes, cotton, buckwheat, barley, lettuce, sugar beets, cabbage, carrots, corn, potatoes
SODIUM	 Improves plant vigor, helps resist disease, Improves the keeping quality of many crops, Imparts color and flavor to vegetable crops, Can substitute for up to 50% of the potassium required by some plants. 	celery, sugar beets, Swiss chard, tur- nips, table beets
COBALT	 Essential for microorganisms involved with the symbiotic fixation of nitrogen in root nodules of legumes, Constituent of vitamin B₁₂ (required by animals, but not by plants). 	all legumes, cotton, mustard
VANADIUM	 May function in biological oxidation-reduction reactions, May substitute for some molybdenum requirement. 	asparagus, rice, let- tuce, barley, corn
CHROMIUM	Required by higher animals and functions in the ac- tion of insulin on cell membranes.	

Known Antagonisms Between Macro and Micronutrients: (from Brady, 1990)

- 1. Excess copper or sulfate may adversely affect the utilization of molybdenum.
- 2. Iron deficiency is encouraged by an excess of zinc, manganese, copper, or molybdenum.
- 3. Excess phosphate may encourage a deficiency of zinc, iron, or copper, but enhances the adsorption of molybdenum.
- 4. Heavy nitrogen fertilization intensifies copper and zinc deficiencies.
- 5. Excess sodium or potassium may adversely affect manganese uptake.
- 6. Excess lime reduces boron uptake.
- 7. Excess iron, copper, or zinc may reduce the adsorption of manganese.

6.0 GLOSSARY

- **anaerobic digestion:** the decomposition of organic matter without the presence of oxygen. Anaerobic digestion of sewage takes place in tanks where 40 to 60 percent of the volatile solids are decomposed by anaerobic bacteria and converted to methane and carbon dioxide. Anaerobic digestion also typically reduces viruses and pathogenic bacterial populations by 90 percent or more. (See also: mesophilic, pretreatment, primary treatment, secondary treatment, tertiary treatment)
- **available nutrient:** that portion of any naturally occurring or fertilizer-borne element or compound in the soil that can be readily absorbed and assimilated by growing plants. (See also: macronutrient, micronutrient)
- **background level:** amounts of nutrients, organisms, or pollutants already existing in the environment before biosolids applications.
- **bacteria:** single-celled microorganisms that lack chlorophyll. Some bacteria are capable of causing human, animal or plant diseases; others are essential for the decomposition of organic matter in soils, in secondary wastewater treatment (see definition below), and in digestive processes in animals. (See also: pathogenic microbe, virus)
- **biosolids:** (Water Environment Federation definition) "primarily organic product produced from the wastewater treatment plant process, that can be beneficially recycled". It contains water, sand, organic matter, microorganisms, trace metals and other chemicals. (See also: Class A Biosolids, Class B Biosolids, exceptional quality biosolids)
- **ceiling limit (or concentration):** refers to federal regulation 40 CFR Part 503.13 (EPA, 1992) Table 1 concentrations of metals in biosolids. The ceiling limit is the maximum concentration of a metal allowed in biosolids in order to be considered exceptional quality and safe for land application. (See also: exceptional quality biosolids, pollutant concentration)
- **Class A Biosolids:** the EPA designation for high quality biosolids that have been treated to reduce pathogens to below detectable levels. Federal regulations require this level of quality for biosolids that are sold or given away in a bag or other container, or applied to lawns or home gardens. (See also: biosolids, Class B Biosolids, exceptional quality biosolids)
- **Class B Biosolids:** the EPA designation for high quality biosolids that have been treated to significantly reduce pathogens to levels that are safe for beneficial use in land application. Federal regulations require site management and access restrictions when biosolids of this quality are land applied, including sites with high potential for public contact. (See also: biosolids, Class A Biosolids, exceptional quality biosolids)

- **dewatering:** any of several processes used to remove water from biosolids in order to reduce its volume prior to recycling. These processes may include evaporation, passage through belt filter presses which squeeze water out of biosolids, or centrifuging which drives water out by spinning, much as water is driven out of clothes during the "spin" cycle of a clothes washing machine.
- **essential element:** an element that is required by all organisms in order to complete their life cycles. (See also: macronutrient, micronutrient, heavy metal, trace metal, available nutrient)
- **exceptional quality biosolids:** common terminology referring to biosolids whose metals concentrations do not exceed standards of federal regulation 40 CFR Part 503.13 (EPA, 1992) Table 1 and Table 3. Exceptional quality biosolids must meet one of the Class A pathogen requirements and one of the vector attraction reduction options. (See also: Class A biosolids, pollutant concentration)
- **hazardous waste:** any material that according to EPA criteria on ignitability, corrosivity, reactivity, or TCLP is a potential hazard to human health and the environment if not properly controlled. (See also TCLP)
- **heavy metal:** metallic elements whose densities are equal to or greater than 5.0 g/cm³ including, but not limited to chromium, lead, zinc, copper, cadmium, mercury, nickel, silver, and iron. Some heavy metals are required in trace concentrations for all animal and plant life. These include manganese, iron, copper, zinc, and molybdenum. Others like cadmium, mercury, and lead can be toxic to living organisms. Still others have no known effects on living organisms. (See also: micronutrient, trace metal)
- **mg/kg:** milligram per kilogram; equivalent to a part per million.
- **macronutrient:** an essential element needed in large amounts by a plant or animal in order to complete its life cycle. Macronutrients are found in dry tissue in concentrations greater than 1,000 ppm. Plant macronutrients include nitrogen, phosphorus, potassium, sulfur, calcium, magnesium, carbon, hydrogen and oxygen. (See also: micronutrient, trace metal)
- **mesophilic digestion:** One of two optimum temperature ranges (85-100°F which equates to 30-38°C) that increases the rate of anaerobic digestion to maximize efficiency and minimize solids retention times. (See also: anaerobic digestion, primary treatment, secondary treatment)
- **micronutrient:** (also called trace element) an essential element needed in extremely small amounts by a plant or animal in order to complete its life cycle. Micronutrients are found in dry tissue in concentrations less than 100 ppm. Plant micronutrients include iron, boron, manganese, zinc, copper, chloride, cobalt, and molybdenum. Micronutrients are often depleted or unavailable in soils that have been cropped

continuously and that have received only applications of nitrogen fertilizers. (See also: macronutrient, trace metal)

- **pathogenic microbe:** any microorganism that has the potential to cause disease. These may include certain bacteria, fungi, and viruses. (See also: bacteria, virus)
- **"pollutant concentration" (or limit):** refers to the 40 CFR Part 503.13 (EPA, 1992) Table 3 concentrations of metals in biosolids. Municipalities whose biosolids meet this limit are exempt from certain recordkeeping and reporting requirements. (See also: exceptional quality biosolids)
- **pretreatment:** the removal of certain pollutants from industrial waste before discharging it to the wastewater treatment system. Pretreatment is required of industries whose wastes fail to comply with local or federal pretreatment standards. This may necessitate the installation of special equipment for pollutant removal. (See also: primary treatment, secondary treatment, tertiary treatment)
- **primary treatment:** the first phase of wastewater treatment in which solids are removed through gravitational settling. (See also: pretreatment, secondary treatment, tertiary treatment)
- **priority pollutants:** a group of chemicals specifically listed in the Code of Federal Regulations (40 CFR 423, Appendix A) given priority for regulatory control.
- **secondary treatment:** the second phase of wastewater treatment that uses aeration and the biological action of bacteria to remove 95 percent or more of the dissolved and suspended organic matter remaining in wastewater after primary treatment. (See also: pretreatment, primary treatment, tertiary treatment)
- **tertiary treatment:** a third phase of wastewater treatment in which most of the remaining pollutants are removed from effluent following secondary treatment. The processes used include among others, sand filtration and ultraviolet light disinfection. (See also: pretreatment, primary treatment, secondary treatment)
- **tilth:** the physical condition of a soil as related to its ease of tillage, fitness as a seedbed, and its impedance to seedling emergence and root penetration.
- **trace metal:** any metallic element detected in biosolids in extremely low concentrations (equal to or less than 100 ppm). The term is also commonly used as a synonym for micronutrient, although not all micronutrients are metals. (See also: essential element, heavy metal, macronutrient, micronutrient)
- **trace organic:** any organic compound detected in biosolids in extremely low concentrations, usually several parts per million (mg/kg) or less.

- **virus:** the smallest of the microorganisms, these are obligate parasites composed of a nucleic acid (RNA or DNA) core and a protein coat. They cannot grow or reproduce outside a host organism. (See also: pathogenic microbe, bacteria)
- **wastewater:** water that has been previously used in homes, businesses or industry and requires treatment before it can be discharged to surface waters (i.e., Puget Sound) or reused.

7.0 REFERENCES

- APHA, AWWA, and WPCF. Standards Methods for the Examination of Water and Wastewater, 17th ed. Washington, D.C.: American Public Health Association, 1989.
- Brady, Nyle C. *The Nature and Properties of Soils*, 10th ed. New York: MacMillan Publishing Company, Inc., 1990.
- Ecology. *Biosolids Management, WAC 173-308*. Olympia, WA: Washington State Department of Ecology, 2007.

_____. Discarded Chemical Products List, WAC 173-303-9903. Olympia, WA: Washington State Department of Ecology, 1986.

_____. Use of Municipal Sewage Sludge, Ecology 82-12. Olympia, WA: Washington State Department of Ecology, 1982.

EPA. Environmental Regulations and Technology: Control of Pathogens and Vector Attraction in Sewage Sludge (Including Domestic Septage) Under 40 CFR Part 503. Washington, D.C.: Environmental Protection Agency, Office of Research and Development, 1992.

____. Standards for the Disposal of Sewage Sludge, 40 CFR 503. Washington, D.C.: Environmental Protection Agency, 1993.

___. Designation of Hazardous Substances, 40 CFR Part 116. Washington, D.C.: Environmental Protection Agency, 1978.

_. Identification and Listing of Hazardous Waste, 40 CFR Part 261, Subpart C, Toxicity characteristic. Washington, D.C.: Environmental Protection Agency, 1993.

____. *Priority Pollutants, 40 CFR Part 423-126, Appendix A.* Washington, D.C.: Environmental Protection Agency, 1996.

___. *Polychlorinated Biphenyls (PCBs)* . . ., 40 CFR Part 761. Washington, D.C.: Environmental Protection Agency, 1996.

- Epstein, Emanuel. *Mineral Nutrition of Plants, Principles and Perspectives*. New York: John Wiley & Sons, Inc., 1972.
- Gilbert, Richard O. *Statistical Methods for Environmental Pollution Monitoring*. New York: Van Nostrand Reinhold Company, 1987.

- Helsel, D. "Less Than Obvious." *Environmental Science Technology*, Vol. 24, No. 12 (1990).
- King County. *Biosolids Quality Summary, 2006.* Biosolids Management Program. King County Department of Natural Resources and Parks, April 2007.
- National Research Council. Use of Reclaimed Water and Sludge in Food Crop Production. Natural Research Counicil, 1996.
- Sauchelli, Vincent. Trace Elements in Agriculture. Van Nostrand Reinhold Co., Inc., 1969.

APPENDIX A

SUMMARY TABLES OF ALL PARAMETERS

- Table A-1: 2007 Summary of Conventional and Microbiological Data for West Point Biosolids
 Table A-2: 2007 Summary of Conventional and Microbiological Data for South Plant Biosolids
- Table A-3: 2007 Summary of Metals Data for West Point Biosolids
- Table A-4: 2007 Summary of Metals Data for South Plant Biosolids
- Table A-5:
 2007 Summary of Trace Organic Compounds Detected in West Point Biosolids
- Table A-6 : 2007 Summary of Trace Organic Compounds Detected in South Plant Biosolids
- Table A-7:
 List of Organic Compounds Analyzed in King County Biosolids

TABLE A-1	l. 2007 Summ	nary of Conv	entional and M	ficrobiological	Data for We	est Point Biosol	ids
		2007	2007		2 101		
		Standard	No. of times	2007	2007	2007	2006
CONVENTIONAL	2007 Mean	Deviation	Detected	Minimum	Median	Maximum	Mean
Total Solids	26.7	1.3	12	25	26.7	29.5	26.7
(% of wet)							
Total Volatile Solids (% of wet)	62	2.78	12	57.2	62.9	65.9	63.3
pH (d)	8.80	0.13	11	8.5	8.82	9	8.90
(std. units)							
Ammonia Nitrogen	9,300	0,900	12	7,680	9,250	10,900	8,500
(mg/kg dry) Organic Nitrogen	50,100	5,800	12	41,900	49,900	63,300	50,100
(mg/kg dry)	50,100	5,800	12	41,900	49,900	05,500	50,100
Total Phosphorus	18,200	2,620	12	13,900	18,000	22,300	19,700
(mg/kg dry)	10,200	2,020	12	10,700	10,000	22,300	19,700
Total Potassium	1,700	130	12	1,500	1,600	1,900	1,700
(mg/kg dry)	· · · ·			<u>-</u>	,	<u> </u>	,
Total Sulfur	11,200	491	12	10,400	11,150	11,900	11,300
(mg/kg dry)					·		
				2007		2007	2006
	2007	2007	2007	No. of times		Geometric	Geometric
MICROBIOLOGICAL	Median	Minimum	Maximum	Detected		Mean	Mean
Fecal Coliform	48,000	17,000	200,000	12		47,000	58,000
(org/g dry)							
Salmonella	0.55	0.27	78	9		0.45	0.63
(org/4g dry)							
Total Enteric Viruses	< 0.29	< 0.29	< 0.58	0		< 0.34	< 0.32
(PFU/4g dry)							
Parasites	NF	-	-	NF		-	-
(no units)							

Note: Test of Statistical Significance indicates a significant increase (i) or decrease (d) between the 2006 and 2007 values at P < 0.05 based on Mann-Whitney U test. NF= none found

ND = not detected

CC = cannot be calculated

PFU= Plaque forming unit

Total Enteric Viruses include: polioviruses, Coxsackie viruses and ECHOviruses.

Parasites include: Ascaris lumbricoides, Coccidia, Giardia lamblia, Mite-ova, Nematodes, Taenia, viable Helmith ova and Toxocara.

TABLE A-2	2. 2007 Sum	mary of Conv	entional and N	Microbiologica	l Data for So	outh Plant Bio	solids
		2007	2007	0			
	2007	Standard	No. of times	2007	2007	2007	2006
CONVENTIONAL	Mean	Deviation	Detected	Minimum	Median	Maximum	Mean
Total Solids	22.4	0.72	12	21.5	22.2	23.6	22
(% of wet)							
Total Volatile Solids	68.6	1.12	12	66.5	68.8	70.4	67.9
(% of wet)							
pH	8.55	0.14	12	8.3	8.6	8.8	8.5
(std. units)							
Ammonia Nitrogen	12,100	1,730	12	8,100	12,200	14,800	12,200
(mg/kg dry)							
Organic Nitrogen	58,700	4,720	12	50,700	58,800	64,800	57,300
(mg/kg dry)							
Total Phosphorus	22,500	2,970	12	18,300	22,000	27,500	24,200
(mg/kg dry)							
Total Potassium (d)	2,200	270	12	1,800	2,300	2,700	2,600
(mg/kg dry)							
Total Sulfur	11,100	670	12	9,750	11,200	12,200	10,500
(mg/kg dry)							
				2007		2007	2006
	2007	2007	2007	No. of times		Geometric	Geometric
MICROBIOLOGICAL	Median	Minimum	Maximum	Detected		Mean	Mean
Fecal Coliform (d)	27,000	10,000	660,000	12		35,200	61,000
(org/g dry)							
Salmonella	0.37	< 0.35	1.4	6		0.46	0.39
(org/4g dry)							
Total Viruses	0.37	< 0.35	< 0.76	1		< 0.37	< 0.37
(PFU/4g dry)							
Parasites	NF	-	-	NF		-	-
(no units)							

Note: Test of Statistical Significance indicates a significant increase (i) or decrease (d) between the 2006 and 2007 values at P < 0.05 based on Mann-Whitney U test.

ND = not detected

CC = cannot be calculated Total Enteric Viruses include: polioviruses, Coxsackie viruses and ECHOviruses.

PFU= Plaque forming unit

NF= none found

Parasites include: Ascaris lumbricoides, Coccidia, Giardia lamblia, Mite-ova, Nematodes, Taenia, viable Helmith ova and Toxocara.

2007
Bioso
lids Qualit
ity Summai
mary

	IAD	200 A-J. 200	or Summal y		Data for Wes	t I UIIIt DI	0501105	
				METALS				
				(mg/kg dry)			40 CFR 503	No. of
	2007	Standard		2007		2006	Regulatory	Times
	Mean	Deviation	Minimum	Median	Maximum	Mean	Limits *	Detected
Arsenic	6.36	0.72	5.04	6.42	7.73	6.95	41	12
Barium	252	20	223	258	288	252		12
Beryllium	< 0.21	0.03	< 0.18	< 0.21	0.26	< 0.20		9
Boron	15.8	1.4	14	16	18	15.2		12
Cadmium	2.95	0.46	2.5	2.82	4.18	3.02	39	12
Chromium	41	5.1	32.9	40.1	49.6	39.7		12
Copper	523	25	471	520	562	561	1,500	12
Iron	18,300	3,140	14,400	17,900	24,600	17,700		12
Lead	101	16	78	102	132	111	300	12
Magnesium	6,150	720	5,280	6,110	7,600	6,390		12
Manganese	741	379	312	660	1,460	714		12
Mercury	1.42	0.39	0.94	1.3	2.26	1.43	17	12
Molybdenum	10.2	0.72	9.29	10.2	11.6	11.5	*	12
Nickel	30.5	4	25.3	29	37.9	30.4	420	12
Selenium	6.92	0.85	5	7	8	6.7	100	12
Silver (d)	16.9	1	15	17	19.1	20.3		12
Zinc	940	41	876	940	1,000	940	2,800	12

Note: Test of Statistical Significance: indicates a significant increase (i) or decrease (d) between the 2006 and 2007 values at P <0.05 based on Mann -Whitney U test.

Note: means and standard deviations are computed on the basis of the twelve monthly samples for 2007, excluding outliers.

Minima, medians, and maxima are determined on the basis of all data collected during the monitoring year, excluding outliers.

< = less than method detection limit. The detection limit may vary depending on the analytical method used.

* 40 CFR 503 Limit for Very High Quality (Table 3) is under reconsideration.

	TABLE A-4. 2007 Summary of Metals Data for South Plant Biosolids										
				METALS							
				(mg/kg dry)			40 CED 502				
	2007 Mean	Standard Deviation	Minimum	2007 Median	Maximum	2006 Mean	40 CFR 503 Regulatory Limits **	No. of Times Detected			
Arsenic	6.21	0.65	5.24	6.15	7.54	6.16	41	12			
Barium	221	15.8	192	224	241	216		12			
Beryllium	< 0.23	0.01	< 0.22	< 0.23	0.25	< 0.23		1			
Boron	14	1.1	13	14	16	13		12			
Cadmium (d)	3.32	0.34	2.81	3.33	4.01	4.75	39	12			
Chromium	44.6	5.3	39	43.3	54.8	41.4		12			
Copper	522	43	436	534	570	507	1,500	12			
Iron	19,200	2,910	15,000	18,600	23,500	19,000		12			
Lead	48	11	35.7	46.2	63.8	59.6	300	12			
Magnesium	8,140	2,188	5,570	7,690	13,100	9,060		12			
Manganese	440	51	350	440	490	450		12			
Mercury	1.19	0.32	0.91	1.1	2.02	1.1	17	12			
Molybdenum (d)	11.3	0.9	9.6	11.4	12.4	14.6	**	12			
Nickel	27.7	2.99	23.4	26.9	33.2	26.4	420	12			
Selenium	7.25	0.78	5.7	7.1	8.8	6.95	100	12			
Silver	11.3	1.32	10	11.1	13.6	12.1		12			
Zinc	912	112	691	899	1,040	866	2,800	12			

Note: Test of Statistical Significance: indicates a significant increase (i) or decrease (d) between the 2006 and 2007 values at P < 0.05 based on Mann-Whitney U test.

Note: means and standard deviations are computed on the basis of the twelve monthly averages for 2007, excluding outliers.

Minima, medians, and maxima are determined on the basis of all data collected during the monitoring year, excluding outliers.

< = less than method detection limit. The detection limit may vary depending on the analytical method used.

** 40CFR 503 Limit for Very High Quality (Table 3) is under reconsideration

Appendix A

Sample		Acius (III	g/kg dry)	Volatiles (mg/kg dry)					
NT 1	Date	Phenol	Benzoic Acid	Acetone	Toluene	2-Butanone	Carbon		
Number						(MEK)	Disulfide		
L42056-1	13-Mar-11	8.25	ND	2.40	0.024	0.47	0.03		
L43442-1	14-Aug-11	6.78	9.37	2.07	0.020	0.43	0.04		
19	996 Min - max	10.9 - 12	ND	0.440 - 3.71	0.051 - 0.139	0.180 - 3.08	0.051-0.172		
				Neutral	s/PAHs (mg/kg	dry)			
Sample	Date	Anthracene *	Benzo(A)	Bis(2-Ethyl-	Chrysene *	Fluoranthene *	Phenanthrene *	Pyrene *	
Number			Anthracene *	hexyl)Phthalate					
L42056-1	13-Mar-11	1.03	1.18	105	1.38	2.23	3.23	3.12	
L43442-1	14-Aug-11	0.59	0.80	74.8	1.00	1.75	2.53	2.14	
19	996 Min - max	0.71 - 0.83	0.77 - 2.37	46 - 156	0.79 - 3.33	1.5 - 4.93	1.57 - 6.35	2.11 - 6.49	
Sample Number	Date	1,4 Dichloro- benzene	Coprostanol	Fluorene *					
L42056-1	13-Mar-11	1.48	2,000	0.63					
L43442-1	14-Aug-11	2.29	1,270	ND					
19	996 Min - max	0.42	ND	0.46 - 0.93					
				PCBs and	Pesticides (mg/	kg dry)			
		Aroclor 1248	Aroclor 1254	Aroclor 1260		Sample Number	Date	Alpha- Chlordane	
Geom	netric mean of					L42056-1	13-Mar-11	0.034	
mo	onthly samples	<0.09 ^g	$< 0.08^{g}$	$< 0.08^{g}$		L43442-1	14-Aug-11	ND	

ND = no data available or the compound was not detected.

* indicates Polynuclear Aromatic Hydrocarbon (PAH) compound

In 2007 two samples were analyzed for all 135 organic compounds, as compared to 1996 when monthly samples were analyzed.

g = geometric mean, monthly samples were analyzed in 2007 for some Polychlorinated Biphenyls (PCBs).

Appendix A

		Acids (mg	/kg dry)		Volatiles (mg/kg	dry)	
Sample	Date	Phenol		Acetone	2-Butanone	Carbon	Toluene
Number					(MEK)	Disulfide	
L42056-2	13-Mar-11	20.4		3.27	0.74	0.037	0.024
L43442-2	14-Aug-11	8.2		1.54	0.58	ND	0.028
	1996 Min - max	10.9-12.0		0.440-3.71	0.180-3.08	0.024-0.203	0.051-0.139
			Neutrals/PA	Hs (mg/kg dry)			
Sample	Date	Bis(2-Ethyl-	Fluoranthene*	Phenathrene*	Pyrene *	1,4 Dichloro-	Coprostano
Number		hexyl)Phthalate				benzene	
L42056-2	13-Mar-11	143	0.905	1.21	0.95	2.16	2,204
L43442-2	14-Aug-11	59.6	ND	ND	ND	2.00	928
	1996 Min - max	46-156	1.5-4.93	1.57-6.35	2.11-6.49	0.43-3.16	ND
	P	CBs and Pesticio	des (mg/kg dry))			
		Aroclor 1248		Sample	Date	Alpha-	
				Number		Chlordane	
Geo	metric mean of			L42056-2	13-Mar-11	ND	
n	nonthly samples	<0.09 ^g		L43442-2	14-Aug-11	0.067	

1996 Min - max 0.176 - 0.635

0.048 - 0.354

* indicates Polynuclear Aromatic Hydrocarbons (PAH) compound

ND = no data available or the compound was not detected.

1996 Min - max = Minimum and maximum detected values for 1996 trace organic compounds to use as comparison for 2006 data. In 2007 two samples were analyzed for all 135 organic compounds, as compared to 1996 when monthly samples were analyzed.

g = geometric mean, monthly samples were analyzed in 2007 for some Polychlorinated Biphenyls (PCBs).

Table A	-7. List of Organic Compour	nds Analyzed in King Coun	ty Biosolids
Pesticides and PCBs	Volatiles	Bases/Neutr	als/Acids
4,4-DDE 4,4-DDT Aldrin Alpha-BHC Arochlor-1016 [†] Arochlor-1221 [†] Arochlor-1232 [†] Arochlor-1242 [†] Arochlor-1248 [†] Arochlor-1260 [†] Beta-BHC Chlordane Delta-BHC Dieldrin Endosulfan 1 Endosulfan 1 Endosulfan 1 Endrin Aldehyde Gamma-BHC Heptachlor Heptachlor Epoxide Methoxychlor Toxaphene	1,1-Dichloroethane 1,2-Dichloroethylene 1,2-Dichloropropane 1,2-Trans-Dichloroethylene 1,1,1-Trichloroethane 1,1,2-Trichloroethane 1,1,2-Trichloroethylene 1,1,2,2-Tetrachloroethane 2-Butanone (MEK) 2-Chloroethylvinyl Ether 2-Hexanone 4-Methyl-2-Pentanone (MIBK) Acetone Acrolein Acrylonitrile Benzene Bromodichloromethane Bromoform Bromomethane Carbon Tetrachloride Chlorobenzene Chlorodibromoethane Chlorodibromoethane Chloroform Chloromethane Cis-1,3-Dichloropropane Ethyl Benzene Methylene Chloride Styrene Tetrachloroethylene Toluene Total Xylenes Trans-1,3-Dichloropropene Trichlorofluoromethane Vinyl Acetate Vinyl Acetate Vinyl Acetate	1,2-Dichlorobenzene 1,2-Diphenylhydrazine 1,3-Dichlorobenzene 1,4-Dichlorobenzene 1,2,4-Trichlorobenzene 2-Chloronaphthalene 2-Chlorophenol 2-Methylnaphthalene 2-Methylphenol 2-Nitroaniline 2-Nitrophenol 2,4-Dichlorophenol 2,4-Dinitrotoluene 2,6-Dinitrotoluene 2,6-Dinitrotoluene 2,4,5-Trichlorophenol 2,4,6-Trichlorophenol 3-Nitroaniline 3,3-Dichlorobenzidine 4-Bromophenyl Phenyl Ether 4-chloro-3-methylphenol 4-Chlorophenyl Phenyl Etser 4-Methylphenol 4-Chlorophenyl Phenyl Ester 4-Methylphenol 4-Nitrophenol 4,6-Dinitro-O-Cresol Acenaphthene * Acenaphthylene * Aniline Anthracene * Benzoic Acid Benzo(a)anthracene * Benzo(b)fluoranthene * Benzo(b)fluoranthene * Benzo(k)fluoranthene *	Benzyl Alcohol Bis(2- chloroethoxy)methane Bis(2-chloroethyl)ether Bis(2-chloroisopropyl)- ether Bis(2-ethylhexyl)phthalate Butyl Benzyl Phthalate Carbazole Chrysene * Di-n-Butyl Phthalate Dibenzo(a,h)anthracene * Dibenzofuran Diethyl Phthalate Dimethyl Phthalate Fluoranthene * Fluorene * Hexachlorobenzene Hexachlorobutadiene Hexachlorocyclopentadiene Hexachlorocthane Indeno(1,2,3-c,d)pyrene * Isophorone N-Nitroso-di-n- propylamine N-Nitrosodimethylamine N-Nitrosodiphenylamine Naphthalene * Nitrobenzene Pentachlorophenol Phenanthrene * Phenol Pyrene *

fO in C V: Jia Tabl T :at 1 A . 1. J : C Di . _ 4.

* Polynuclear Aromatic Hydrocarbons (PAHs) [†] Polychlorinated Biphenyls (PCBs)

APPENDIX B

RAW DATA TABLES OF PARAMETERS

- Table B-1: 2007 Conventionals, Bacteria, and Viruses from West Point Biosolids
- Table B-2: 2007 Conventionals, Bacteria and Viruses from South Plant Biosolids
- Table B-3: 2007 Trace Metals for West Point Biosolids
- Table B-4:
 2007 Trace Metals for South Plant Biosolids

2007 Biosolids Quality Summary

	TAB	LE B-1. 200'	7 Conventio	nals, Bacter	ia, and Viru	uses from Wes	t Point Bi	osolids	
				CONVEN	,				
		Organic-N	NH3-N	Total P	Total K	Total Vol.	Tot. Solids	pH	Total Sulfur
Sample No.	Date	(mg/kg dry)	(mg/kg dry)	(mg/kg dry)	(mg/kg dry)	Solids (%)	%		(mg/kg dry)
L41535-1	23-Jan-11	45,600	9,560	16,700	1,800	58.1	27.2	NA*	10,400
L41697-1	13-Feb-11	51,300	9,700	19,300	1,800	57.2	26.9	8.82	11,900
L42056-1	13-Mar-11	51,200	10,800	18,400	1,900	62.7	25.2	8.90	10,800
L42423-1	17-Apr-11	41,900	9,250	20,600	1,500	64.4	26.7	8.90	10,800
L42709-1	15-May-11	51,500	9,010	22,300	1,600	63	26.2	8.90	11,600
L42952-1	12-Jun-11	48,500	9,240	16,800	1,600	63	26.2	9.00	10,900
L43172-1	17-Jul-11	54,800	7,680	18,700	1,500	63.2	25	8.80	11,300
L43442-1	14-Aug-11	48,600	8,740	16,400	1,500	59.8	28.6	8.50	11,200
L43850-1	19-Sep-11	54,300	9,480	22,200	1,600	64.8	26.7	8.90	11,900
L44169-1	17-Oct-11	63,300	10,900	13,900	1,600	65.9	27	8.70	11,500
L44409-1	7-Nov-11	43,400	9,020	17,500	1,700	62.5	25.6	8.80	11,100
L44867-1	18-Dec-11	46,400	8,410	15,200	1,700	59	29.5	8.80	10,600
			BACTERIA (org/100g wet)		VIRUSES		PARASITES	
Sample No.	Date	Fecal-Coliform		Salmonella		(PFU/100g wet)		(no units)	
L41535-1	23-Jan-11	1,700,000		4		<2		NF	
L41697-1	13-Feb-11	3,000,000		2		NA		NA	
L42056-1	13-Mar-11	500,000		<2		NA		NA	
L42423-1	17-Apr-11	1,300,000		2		<2		NF	
L42709-1	15-May-11	1,100,000		2		NA		NA	
L42952-1	12-Jun-11	1,400,000		4		NA		NA	
L43172-1	17-Jul-11	5,000,000		4		<2		NF	
L43442-1	14-Aug-11	2,800,000		<2		NA		NA	
L43850-1	19-Sep-11	700,000		<2		NA		NA	
L44169-1	17-Oct-11	800,000		2		<4		NF	
L44409-1	7-Nov-11	700,000		4		NA		NA	
L44867-1	18-Dec-11	500,000		4		NA		NA	

PFU = plaque forming units

NA=not analyzed

NF=none found

Viruses designate total enteric viruses such as: polioviruses, Coxsackie viruses, ECHOvirus

Parasites include the following but none were found: Ascaris lumbricoides, Coccidia, Giardia lamblia, Mite-ova, Nematodes, Taenia, Toxocara and viable Helmith ova.

*January sample was not analyzed for pH

		BACTERIA (org/g dry)	SALMONELLA	VIRUSES	PARASITES
Sample No.	Date	Fecal-Coliform	(org/4g dry)	(PFU/4g dry)	(no units)
L41535-1	23-Jan-11	62,000	0.59	<0.29	NF
L41697-1	13-Feb-11	110,000	0.29	NA	NA
L42056-1	13-Mar-11	19,000	< 0.31	NA	NA
L42423-1	17-Apr-11	49,000	0.3	<0.29	NF
L42709-1	15-May-11	46,000	0.33	NA	NA
L42952-1	12-Jun-11	58,000	0.67	NA	NA
L43172-1	17-Jul-11	200,000	0.63	<0.29	NF
L43442-1	14-Aug-11	102,000	<0.29	NA	NA
L43850-1	19-Sep-11	26,000	<0.29	NA	NA
L44169-1	17-Oct-11	29,000	0.29	<0.58	NF
L44409-1	7-Nov-11	29,000	0.65	NA	NA
L44867-1	18-Dec-11	17,000	0.55	NA	NA

PFU = plaque forming units

NA=not analyzed

NF=none found Viruses designate total enteric viruses such as: polioviruses, Coxsackie viruses, ECHOvirus

Parasites include the following but none were found: Ascaris lumbricoides, Coccidia, Giardia lamblia, Mite-ova, Nematodes, Taenia, Toxocara and viable Helmith ova.

Appendix B

2007 Biosolids Quality Summary

	TAB	CONVENTIONALS								
		Organic-N	NH3-N	Total P	Total K	Total Vol.	Tot. Solids	pН	Total Sulfur	
Sample No.	Date	(mg/kg dry)	(mg/kg dry)	(mg/kg dry)	(mg/kg dry)	Solids (%)	%	_	(mg/kg dry)	
L41535-2	23-Jan-11	57,600	13,600	18,300	2,100	66.5	23.6	8.60	9,750	
L41697-2	13-Feb-11	50,700	10,800	26,800	1,900	67.9	22.1	8.60	10,600	
L42056-2	13-Mar-11	53,800	12,700	27,500	2,000	68.8	22.1	8.30	11,200	
L42423-2	17-Apr-11	54,300	14,800	24,400	1,800	68.3	22.1	8.60	10,500	
L42709-2	15-May-11	55,100	12,300	20,500	2,000	66.9	23.6	8.50	11,700	
L42952-2	12-Jun-11	55,900	14,000	21,900	2,200	68.7	22.7	8.50	11,900	
L43172-2	17-Jul-11	63,000	12,000	21,700	2,700	69.4	21.6	8.40	10,600	
L43442-2	14-Aug-11	62,300	8,100	19,100	2,500	69.5	22.3	8.60	11,300	
L43850-2	18-Sep-11	62,000	11,400	20,000	2,400	70.4	23.0	8.40	11,200	
L44169-2	16-Oct-11	64,800	11,200	25,500	2,400	69.3	21.5	8.60	11,300	
L44409-2	6-Nov-11	60,000	12,000	22,200	2,300	69.4	21.6	8.80	12,200	
L44772-2	11-Dec-11	64,600	12,600	22,100	2,400	68.2	22.3	8.70	11,100	
		I	BACTERIA (o	rg/100g wet)		VIRUSES		PARASITES		
Sample No.	Date	Fecal-Coliform		Salmonella		(PFU/100g wet)	(no units)		
L41535-2	23-Jan-11	800,000		<2		<2		NF		
L41697-2	13-Feb-11	700,000		2		NA		NA		
L42056-2	13-Mar-11	300,000		2		NA		NA		
L42423-2	17-Apr-11	230,000		2		<2		NF		
L42709-2	15-May-11	800,000		<2		NA		NA		
L42952-2	12-Jun-11	230,000		<2		NA		NA		
L43172-2	17-Jul-11	3,000,000		<2		2		NF		
L43442-2	14-Aug-11	1,300,000		8		NA		NA		
L43850-2	18-Sep-11	500,000		<2		NA		NA		
L44169-2	16-Oct-11	14,000,000		<2		<4		NF		
L44409-2	6-Nov-11	500,000		2		NA		NA		
L44772-2	11-Dec-11	500,000		2		NA		NA		

PFU = plaque forming units

NA=not analyzed

NF=none found

Viruses designate total enteric viruses such as: polioviruses, Coxsackie viruses, ECHOvirus Parasites include the following but none were found: Ascaris lumbricoides, Coccidia, Giardia lamblia, Mite-ova, Nematodes, Taenia, Toxocara and viable Helmith ova.

		BACTERIA (org/g dry)	SALMONELLA	VIRUSES	PARASITES
Sample No.	Date	Fecal-Coliform	(org/4g dry)	(PFU/4g dry)	(no units)
L41535-2	23-Jan-11	35,000	<0.35	<0.35	NF
L41697-2	13-Feb-11	31,000	0.36	NA	NA
L42056-2	13-Mar-11	14,000	0.36	NA	NA
L42423-2	17-Apr-11	11,000	0.37	< 0.37	NF
L42709-2	15-May-11	35,000	<0.35	NA	NA
L42952-2	12-Jun-11	10,000	<0.35	NA	NA
L43172-2	17-Jul-11	140,000	< 0.37	0.37	NF
L43442-2	14-Aug-11	57,000	1.4	NA	NA
L43850-2	18-Sep-11	22,000	< 0.35	NA	NA
L44169-2	16-Oct-11	660,000	<0.38	<0.76	NF
L44409-2	6-Nov-11	23,000	0.37	NA	NA
L44772-2	11-Dec-11	23,000	0.36	NA	NA

PFU = plaque forming units

NF=none found

Viruses designate total enteric viruses such as: polioviruses, Coxsackie viruses, ECHOvirus

NA=not analyzed

Parasites include the following but none were found: Ascaris lumbricoides, Coccidia, Giardia lamblia, Mite-ova, Nematodes, Taenia, Toxocara and viable Helmith ova.

Appendix B

Sample No.	Date	As	Ba	Be	В	Cd	Ca	Cr	Cu	Fe	Pb
L41535-1	23-Jan-11	9.19	272	0.23	17	2.50	23,600	49.6	471	24,600	132
L41697-1	13-Feb-11	9.11	288	0.26	18	2.84	26,900	49.1	528	23,500	119
L42056-1	13-Mar-11	6.71	268	0.24	14	2.80	24,700	44.0	520	19,800	106
L42423-1	17-Apr-11	6.82	268	0.19	17	2.70	23,400	39.0	506	18,900	103
L42709-1	15-May-11	6.53	276	0.22	17	2.76	24,700	38.1	553	18,000	103
L42952-1	12-Jun-11	5.04	260	< 0.18	15	2.54	23,400	42.0	515	17,700	100
L43172-1	17-Jul-11	5.68	234	< 0.2	14	2.84	22,200	32.9	512	14,400	84
L43442-1	14-Aug-11	6.47	233	0.20	15	2.76	23,000	36.7	531	16,600	78.3
L43850-1	18-Sep-11	5.92	228	0.19	16	3.12	24,100	41.2	562	16,100	83.5
L44169-1	16-Oct-11	6.3	223	0.19	16	2.99	24,100	36.3	552	14,900	86.7
L44409-1	6-Nov-11	6.37	223	< 0.2	16	4.18	23,700	38.1	520	16,300	99.2
L44867-1	18-Dec-11	7.73	256	0.24	14	3.39	21,700	44.4	502	18,700	114
NA = not and	alyzed										
	Т	ABLE B	3. 2007	Trace Me	etals (mg	/kg dry)	for West	Point Bi	osolids		
Sample No.	Date	Mg	Mn	Hg	Мо	Ni	К	Se	Ag	Zn	
L41535-1	23-Jan-11	6,800	1460	1.20	10.1	37.9	1,800	7.0	17.1	901	
L41697-1	13-Feb-11	5,910	1240	1.30	11.2	35.1	1,800	8.8	19.1	981	
L42056-1	13-Mar-11	5,440	802	1.20	9.3	31.0	1,900	7.1	17.0	925	
L42423-1	17-Apr-11	5,430	1090	1.40	9.5	28.2	1,500	7.4	16.4	903	
L42709-1	15-May-11	7,600	996	1.30	10.2	29.0	1,620	7.7	17.5	950	
T 40050 1	12-Jun-11	6,300	641	2.26	10.3	29.0	1,600	5.0	16.4	882	
L42952-1		5,280	464	1.20	9.6	25.3	1,460	7.7	16.6	876	
L42952-1 L43172-1	17-Jul-11				10.0	29.7	1,530	8.0	15.9	934	
	17-Jul-11 14-Aug-11	5,870	416	0.94	10.3	29.1	1,000				
L43172-1		5,870 6,400	416 358	0.94 2.00	10.3 11.6	29.7	1,550	6.7	16.5	981	
L43172-1 L43442-1	14-Aug-11	,					,	6.7 6.3	16.5 17.8	981 1,000	
L43172-1 L43442-1 L43850-1 L44169-1	14-Aug-11 18-Sep-11	6,400 6,670	358 312 430	2.00 1.20	11.6 11.0 10.1	28.2 29.5 28.8	1,550 1,630 1,710	6.3	17.8 17.0	1,000	

	Т	ABLE B4	. 2007	Trace Me	tals (mg/	kg drv)	for South	Plant Bi	osolids		
Sample No.	Date	As	Ba	Be	B	Cd	Ca	Cr	Cu	Fe	Pb
L41535-2	23-Jan-11	7.54	216	< 0.22	14	3.0	28,500	39.3	436	23,500	56.4
L41697-2	13-Feb-11	6.70	221	< 0.23	15	3.6	31,100	54.8	466	22,300	56.1
L42056-2	13-Mar-11	5.57	236	< 0.24	13	4.0	31,500	44.8	516	22,100	62.0
L42423-2	17-Apr-11	6.15	229	< 0.23	13	3.3	31,100	46.6	489	21,800	63.8
L42709-2	15-May-11	6.14	240	0.25	14	3.5	33,300	50.4	521	21,300	57.6
L42952-2	12-Jun-11	5.24	241	< 0.22	14	2.9	33,300	44.9	568	19,200	52.4
L43172-2	17-Jul-11	5.97	203	< 0.23	13	3.1	28,600	41.7	546	16,900	39.0
L43442-2	14-Aug-11	5.70	192	< 0.23	13	2.8	27,300	39.0	552	16,400	36.1
L43850-2	18-Sep-11	5.65	201	< 0.22	14	3.5	29,700	41.4	570	15,000	35.7
L44169-2	16-Oct-11	6.60	217	< 0.23	16	3.4	32,200	39.9	553	16,400	37.7
L44409-2	6-Nov-11	6.34	226	< 0.23	16	3.6	33,000	40.3	556	16,900	39.0
L44772-2	11-Dec-11	6.91	228	< 0.22	13	3.2	29,600	51.6	489	18,000	39.9
NA = not an	alyzed										
	Т	ABLE B4	. 2007	Trace Me	tals (mg/	'kg dry)	for South	Plant Bi	osolids		
Sample No.	Date	Mg	Mn	Hg	Мо	Ni	K	Se	Ag	Zn	
L41535-2	23-Jan-11	8,090	475	1.20	11.4	23.4	2,100	7.6	13.5	691	
L41697-2	13-Feb-11	6,470	489	1.20	10.5	26.3	1,900	8.1	12.5	738	
L42056-2	13-Mar-11	5,570	493	1.60	9.6	28.3	2,000	6.8	11.4	887	
L42423-2	17-Apr-11	6,290	489	0.95	11.0	26.8	1,800	7.2	12.0	873	
L42709-2	15-May-11	7,290	492	1.10	10.5	28.5	2,010	7.6	13.6	996	
L42952-2	12-Jun-11	8,550	458	1.10	11.4	25.0	2,160	5.7	11.3	1,040	
L43172-2	17-Jul-11	11,300	405	1.20	12.3	27.0	2,650	8.8	10.2	884	
L43442-2	14-Aug-11	13,100	419	0.99	11.5	24.7	2,540	7.6	10.0	883	
L43850-2	18-Sep-11	9,220	352	0.91	12.4	31.3	2,410	7.0	10.0	991	
L44169-2	16-Oct-11	8,090	372	1.00	12.3	26.0	2,410	7.0	10.8	1,030	
L44409-2	6-Nov-11	6,810	398	2.02	12.3	31.3	2,320	6.9	10.7	1,020	
L44772-2	11-Dec-11	6,950	407	0.99	10.9	33.2	2,350	6.7	10.0	910	

NA = not analyzed None of these measures were determined using SPSS to be unexplained outliers. Such outliers would be excluded from statistical calculations.

Appendix B