



2003 Drinking Water Infrastructure Needs Survey

Modeling the Cost of Infrastructure

2003 Drinking Water Infrastructure Needs Survey and Assessment

Modeling the Cost of Infrastructure

Prepared for:

U.S. Environmental Protection Agency
Office of Ground Water and Drinking Water
Contract No. 68-C-02-069
Work Assignment No. 1-03

Prepared by:

The Cadmus Group, Inc.
57 Water Street
Watertown, MA 02472

June 2006

2003 Drinking Water Infrastructure Needs Survey and Assessment Modeling the Cost of Infrastructure

In 2003, the U.S. Environmental Protection Agency (EPA) conducted the third Drinking Water Infrastructure Needs Survey and Assessment (DWINSA or Assessment). The Assessment is an important tool of the Drinking Water State Revolving Fund (DWSRF) program. The purpose of the Assessment is to estimate the documented 20-year capital investment needs of public water systems that are eligible to receive DWSRF assistance—approximately 53,000 community water systems and 21,400 not-for-profit noncommunity water systems. The Assessment includes infrastructure needs that are required to protect public health, such as projects to comply with National Primary Drinking Water Regulations or to prevent contamination by preserving the physical integrity of the system.¹ The Safe Drinking Water Act (SDWA) requires EPA to conduct the Assessment every four years and to use the results to allocate DWSRF funds to the States and Tribes.

The approach for the 2003 Assessment was developed by EPA in consultation with a workgroup of State representatives. The workgroup refined the methods used in 1995 and 1999 based on lessons learned from the previous Assessments and options made available from technological advancements in internet-based communications.

The 2003 Assessment used questionnaires to collect infrastructure needs from medium and large water systems. EPA mailed questionnaires to all 1,342 of the nation's largest water systems serving more than 40,000 people, and to a random sample of 2,553 of the 7,759 medium systems serving over 3,300 people. Approximately 96 percent of these systems returned the questionnaire.

Small systems serving fewer than 3,300 people often lack the specialized staff and planning documents needed to respond to the questionnaire. Therefore, for the 1999 Assessment EPA conducted site visits to 599 randomly selected small community water systems and 100 not-for-profit noncommunity water systems to identify and document their infrastructure needs. EPA did not conduct the site visits as part of the 2003 Assessment; instead, it used the 1999 Assessment, updated for inflation to January 2003 dollars.

EPA developed cost models to assign costs to projects for which systems lacked adequate cost documentation (see Acceptable Documentation Box on next page). These models are developed primarily from cost data submitted by systems with available cost documentation. The number of projects submitted without cost documentation increased significantly in 2003 compared to the previous Assessments. Of approximately 105,673 accepted projects, 81 percent were

¹ Also, the scope of the survey is limited to DWSRF eligible needs - thus excluding projects solely related to dams, raw water reservoirs, future growth, and fire flow.

submitted without documentation of cost. This increase required greater reliance on cost modeling than in past Assessments.

The 2003 Assessment used cost models from the 1999 Assessment. In the 1999 Assessment, 59 models were developed to assign costs to over 95 types of infrastructure needs, from replacing broken valves to building new treatment plants. These models were updated to 2003 dollars for use in the 2003 Assessment. In some cases, the 2003 Assessment data were used to supplement the 1999 cost models.

Section 1 of this document describes the general approach for constructing these cost models. It discusses the sources of cost information and the general method for developing and applying the cost models. Section 2 explains how this method was applied in modeling source, treatment, storage, transmission and distribution, and other needs. Appendix A contains the cost models as organized by category of need. Appendix B presents the “Type of Need Dictionary” which provides a definition for each type of need, including typical project components.

Important Note: Although the cost models developed for this Assessment allowed EPA to estimate total needs nationwide, the models do not account for all the factors that may influence the cost of infrastructure. EPA chose to limit the design parameters collected for the questionnaire to minimize the burden on the respondents. The Assessment relied on the voluntary participation of over 4,000 water system owners and operators across the country to supply documented cost data. EPA also recognized that systems with a documented need, but without a documented cost estimate, may lack the information that would be utilized in more complex models.

It also should be noted that while the cost curves are appropriate for developing national estimates of need for the purpose of the Assessment, they were not designed to estimate the cost of specific projects for individual water systems.

Acceptable Documentation

The following types of documents were used to justify the need and/or cost of a project.

For Need and/or Cost Documentation

- Capital Improvement Plan or Master Plan
- Facilities Plan or Preliminary Engineering Report
- Grant or Loan Application Form
- Engineer’s Estimate
- Intended Use Plan/State Priority List
- Indian Health Service Sanitary Deficiency System Printout

For Need Documentation Only

- Comprehensive Performance Evaluation (CPE) Results
- Sanitary Survey
- Source Water Protection Plan
- Monitoring Results
- Signed and dated statement from State, site visit contractor, or system engineer clearly detailing infrastructure needs.

For Cost Documentation Only

- Cost of Previous Comparable Construction

1.0 Methods

1.1 Sources of Cost Information

The data used to develop the cost models generally include comprehensive cost estimates that included materials, construction, design, administrative and legal fees, and contingencies. In addition, the Assessment tried to obtain cost data for systems of all sizes to account for the potential effect of economies of scale (i.e., costs may decrease as system size increases).

Several sources of cost data were available. The cost documentation submitted by water systems on the questionnaire was the sole source of data for 40 of the 59 cost models. However, for some types of need, the data generated from the survey respondents proved inadequate for developing statistical models. Therefore, cost data from other sources, such as state funding agencies, were used to supplement the cost data. EPA obtained cost information from manufacturers, engineering firms, and the Economic Analyses (EAs, previously known as Regulatory Impact Analyses) that the Agency publishes in support of proposed regulations.

1.1.1 Data Collected on Questionnaires

The project costs from the questionnaires were reviewed by states and EPA to ensure that the data were appropriate for building models. The Assessment set rigorous documentation criteria for assessing the validity and scope of project costs. EPA required that each project cost reported on the questionnaire be supported by documentation to indicate that the cost had undergone an adequate degree of professional review. The documentation criteria also allowed EPA to review all of the components of a project that were included in the cost estimate. This review enabled EPA to model portions of the project that were excluded from a cost estimate, or to delete DWSRF-ineligible portions of the cost.

The following criteria were used to determine whether the cost data were appropriate:

- The cost reflected complete project costs (e.g., design, materials, installation costs), but excluded non-capital line items such as interest payments or financing fees.
- The necessary modeling parameters were available. For example, cost data for treatment projects could only be used if the respondent provided the design capacity of the treatment facility (the cost was used for the project, but data was insufficient to use the cost to help build the model.)
- The date of the cost estimate was provided to enable adjustment of the cost to constant dollars. (The models developed in 1999 used cost data adjusted to January 1999 dollars. These models were adjusted to January 2003 dollars for the 2003 Assessment.)
- The project was representative of typical projects needed by other water systems in the survey—cost estimates for unusual or unique projects were accepted for the project but were excluded from the cost models.

Most of the cost models are based on data from the 1999 Assessment. The 1995 Assessment provided data for raw water transmission, finished water transmission, and distribution main projects of all sizes, which were also used for the 1999 survey. The 2003 Assessment updated the transmission line and distribution main models using data from the 2003 survey. The model for meters less than or equal to one inch also were updated using data from the 2003 survey.

1.1.2 Data Collected from Other Sources

Additional sources of cost data from which EPA supplemented the questionnaire data included the following. Cost data from these sources were evaluated using the same criteria that were applied to the questionnaires.

- State funding agencies (Arizona, Colorado, North Carolina, Oklahoma, Pennsylvania, and Texas supplied data). EPA requested cost data from the States for the following types of projects:

| | | | |
|---|---|---|---|
| C | New Spring Collectors producing less than 3 MGD | C | Rehabilitation of Direct Filtration Plants producing less than 2 MGD |
| C | Rehabilitation of Spring Collectors producing less than 3 MGD | C | Rehabilitation of Slow Sand Filtration Plants producing less than 5 MGD |
| C | New Conventional Treatment Plants producing less than 2 MGD | C | Rehabilitation of Lime Softening Plants producing less than 2 MGD |
| C | New Direct Filtration Plants producing less than 2 MGD | C | New Manganese Green Sand facilities treating less than 15 MGD |
| C | Rehabilitation of Manganese Green Sand facilities treating less than 35 MGD (although most new projects to model are less than 3 MGD) | | |

- The 2003 R.S. Means catalog. EPA used the R.S. Means catalog to obtain costs for backflow prevention devices and assemblies. The cost of double check valves was selected as a representative unit for small-diameter projects, while reduced pressure zone backflow prevention devices were used for larger installations.
- EPA’s Economic Analyses. The EA for the Stage 2 Disinfectant/Disinfection Byproduct Rule was the source of costs for ozone projects, while the EA for the proposed Ground Water Rule provided costs for chlorine dioxide projects.

- Product manufacturers and distributors. Product manufacturers and distributors provided cost information for ultraviolet disinfection, chlorine gas scrubbers, streaming current monitors, particle counters, chlorine residual monitors, and turbidity meters.
- Engineering firms. For the 1995 survey, an engineering firm (Robert Peccia and Associates, Inc.) developed costs for well houses, the elimination of well pits, the abandonment of wells, powdered activated carbon, and hydropneumatic storage. These costs were adjusted to January 2003 dollars for this survey.
- The Indian Health Service (IHS). The Indian Health Service provided cost information on cisterns for use in the American Indian portion of the Assessment.

1.2 Developing the Linear Regression Cost Models

Most of the cost models are linear regressions between the project's cost (the dependent variable) and a design parameter (the independent variable). The regressions were run on the natural logarithm of the data. Most models were created with 1999 survey data and calculate costs in January 1999 dollars. An inflation factor is used to update these costs to January 2003 dollars. In general, the models take the form:

$$C = e^{(\$_0 + F^2/2)} D^{\$1} * B$$

where: **C** = the project cost;
D = the design parameter (e.g., design capacity, in millions of gallons per day);
e = the base of natural logarithms;
\$_0, \$1 = coefficients that relate the design parameter to cost, estimated using ordinary least squares regression;
F = the standard error of the regression. **F²/2** is added to the equation to produce consistent estimates on the raw scale; and
B = inflation factor to update the cost from January 1999 dollars to January 2003 dollars.

For example, the model for elevated storage tanks defines cost as a function of a tank's design capacity (in million gallons of water). The cost of the tank is given by:

$$C = e^{(14.082 + 0.484^2/2)} D^{0.671} * 1.096833$$

The predicted cost for an elevated tank with a storage capacity of 1 million gallons therefore is \$1.6 million.

As discussed in Section 2, in some cases the costs for several types of projects were pooled together for the regression analysis and one or more indicator variables were included in the regression to distinguish among projects. When an indicator variable is included, the cost equation takes the form:

$$C = e^{(\beta_0 + \beta_1 I + F^2/2)} D^{\beta_2} B$$

where I is the indicator variable and β_1 is its coefficient, estimated by the regression.

EPA ensured that the data used to construct the models were representative of the types of projects to be modeled. As part of this effort, EPA investigated statistical outliers to exclude projects that involved extraordinary design or installation requirements.

The cost data for a given design parameter may vary by 2 to 4 orders of magnitude. This high level of variability was considered appropriate considering the range of projects to be modeled; similar variability was observed in the models for the 1995 survey. The variability may be reduced if additional parameters are included in the models. For example, the costs of installing a new treatment plant of a specific capacity will vary greatly depending on raw water quality, the plant's configuration, and local conditions. EPA, however, did not request data on these characteristics to reduce the response burden on participants. While their omission increases the standard error of the models, it does not bias the models' estimates of cost. These factors are not correlated with capacity and do not affect which projects in the sample have documented costs. Therefore, EPA assumed the distribution of these factors among projects with documented costs and projects with costs that must be modeled is similar.

To improve the statistical efficiency of the models, EPA tried to eliminate three sources of variability in the data. First, EPA adjusted the cost data using the location factors published by the R.S. Means Company to account for regional variation in construction costs. Second, EPA normalized the cost data to January 1999 dollars using the Construction Cost Index (CCI) published in the *Engineering News-Record* (ENR). This step eliminated the variability introduced by the different dates of the cost estimates that were submitted by water systems. Third, EPA developed separate cost models for the installation and rehabilitation of infrastructure in view of the generally lower costs of rehabilitation.

EPA took the following steps to develop the models:

- Identify the cost data from the questionnaire or a supplemental source.
- Adjust the project costs to January 1999 dollars.
- Normalize the project costs using the location factor. This step involves dividing the cost estimate by the location factor. The first three digits of a water system's zip code were used to assign a location factor to the system.
- Develop the cost curve by performing a log-log regression analysis on the observations.

EPA refined some of the cost models by including dummy variables to account for the influence of system size or project type on the cost. For example, the model used for new well projects includes a statistically significant dummy variable for aquifer storage and recovery (ASR) wells that assigns slightly higher costs to ASR projects.

1.3 Unit Costs Models

For some projects, such as service line replacement or water meters, that were assigned unit costs, EPA developed average costs per unit based on the questionnaire data. These models were developed by applying location factors to the documented cost observations and then averaging the normalized cost observations for a particular equipment size category. For example, the cost estimate for a 6-inch water meter was developed by averaging the cost observations for 6-inch water meter projects. For other projects, such as backflow prevention devices, that also were priced on a per unit basis, EPA used cost data provided by the R.S. Means catalogue, the Indian Health Service, or an engineering firm.

1.4 Applying the Cost Models

EPA used the models to estimate the costs of projects for which systems lacked a documented cost. The basic steps in applying both the linear regression and unit cost models are listed below:

- EPA determined the cost predicted by the model based on the required input, usually design capacity.
- To adjust for regional variability in construction costs, EPA multiplied the normalized cost that was generated from the model by the location factor of the system. The adjustment would increase the cost in States where construction costs are typically higher than average and decrease the cost in States where they are typically lower.
- To adjust the modeled costs from January 1999 dollars to January 2003 dollars, EPA used an inflation factor of 1.096833.
- For transmission and distribution projects, in addition to the above steps, a different unit cost was used for some pipe diameters depending on whether the location of the system lay to the north or south of the nation's frost line. This was done to recognize that projects above the frost line generally have higher installation costs due to the greater depths at which pipe must be buried to avoid freezing.

The total infrastructure need for a system in the survey equaled the sum of the modeled costs that were calculated by EPA plus the sum of the documented costs that were submitted by the system.

2.0 Types of Need For Which Costs May Be Modeled

This section discusses the specific types of need for which EPA developed cost models. To reduce the variability of the models, the cost curves usually distinguish between the installation of new equipment and the rehabilitation of existing infrastructure. EPA generally developed separate cost models for new installation and rehabilitation of existing infrastructure for each type of need. However, in some instances these were modeled together. In addition, some types of projects lacked sufficient cost data and, therefore, these projects were assigned costs using models for other similar types of technologies.

One example may serve to illustrate how one model could be used to assign costs to similar types of infrastructure. Cost data for chemical feed were combined with the less abundant data points available for sequestering, corrosion control, and fluoride addition (all forms of chemical addition) to form one model. Dummy variables for the latter projects were included to reflect the higher or lower costs of these technologies relative to chemical feed. Combining the data made sense because the cost estimates that respondents identified on the questionnaire for chemical feed likely included projects for sequestering, corrosion control, and fluoride addition. In addition, EPA used this model to assign costs to projects for zebra mussel control and the dechlorination of treated water (for both of which EPA lacked data points from the 1999 survey), given that the costs and types of equipment were similar to chemical feed.

For some projects, a single model was used for both the installation of new equipment and the rehabilitation of existing infrastructure. EPA combined the cost data for those technologies where the distinction between new and rehabilitation likely was unclear to the respondents and the difference in cost was small. For example, the cost model for chemical feed represents both new and rehabilitation projects, because many of the projects that systems identified as new were actually rehabilitations of existing equipment and vice versa. The resulting cost data, therefore, represented a mix of new and rehabilitation projects between which it was difficult to distinguish due to the similarity of costs.

2.1 Source

For new and refurbished wells, intakes, spring collectors, and aquifer storage and recovery (ASR) wells, the cost models are a function of design capacity in millions of gallons per day (MGD). For well houses, abandoning wells, and eliminating well pits, costs were assigned on a per unit basis.

The following is the list of models for source needs. The Needs Survey will not include rehabilitation projects for eliminating well pits or abandoning wells.

- | | |
|--------------------------|--|
| C Well House (unit cost) | C Abandoning Well (unit cost) |
| C Well Pump (MGD) | C Raw Water Pump (MGD) |
| C Well (MGD) | C Surface Water Intake or Spring Collector (MGD) |

C Eliminating Well Pit (unit cost)

C Aquifer Storage and Recovery Well (MGD)

2.2 Treatment

For each treatment project, EPA collected information on the type of infrastructure needed and its design capacity. Most of the cost models are a function of the design capacity of the treatment system (in MGD). However, streaming current monitors, particle counters, chlorine residual analyzers, and turbidity meters were assigned a single cost per unit.

Chemical feed, waste handling, and disinfection projects were modeled by the design capacity of the entire treatment system, as opposed to the capacity of the chemical feed pump or volume of the waste stream. This approach alleviated the burden on systems to provide flow data for each component of their treatment train.

The cost models for treatment technologies are listed below with the units for modeling provided in parentheses. Cost models for rehabilitating turbidimeters, particle counters, streaming current monitors, or chlorine residual monitors were not developed because these projects were considered operation and maintenance.

| | | |
|--|---|---|
| C Chlorination and Mixed Oxidant Type Equipment (MGD) | C Sedimentation/ Flocculation (MGD) | C Ion Exchange (used also for Activated Alumina) (MGD) |
| C Chlorine Dioxide and Chloramination (MGD) | C Filters (MGD) | C Manganese Green Sand Filtration (MGD) |
| C Ozonation (MGD) | C Aeration (MGD) | C Lime Softening (MGD) |
| C Ultraviolet Disinfection (MGD) | C Membrane Technology for Particulate Removal (MGD) | C Reverse Osmosis (used also for Electrodialysis) (MGD) |
| C Contact Basin for CT (Clearwell) (MG) | C Chlorine Residual Monitors (unit cost) | C Powdered Activated Carbon (MGD) |
| C Conventional Filter Plant (MGD) | C Turbidity Meters (unit cost) | C Granular Activated Carbon (MGD) |
| C Direct or In-line Filter Plant, Slow Sand, Diatomaceous Earth, and Cartridge or Bag filtration (MGD) | C Streaming Current Monitors (unit cost) | C Chemical Feed, Dechlorination, Fluoride Addition, Sequestering, Corrosion Control, and Zebra Mussel Control (MGD) |
| C Chlorine Gas Scrubber (unit cost by MGD) | C Particle Counters (unit cost) | |
| C Waste Handling and Treatment, Mechanical (MGD) | C Waste Handling and Treatment, Nonmechanical (MGD) | |

2.3 Storage

Survey respondents provided ample cost data for elevated and ground-level storage tanks, and for installing covers on existing finished water reservoirs. Conversely, the paucity of cost data for hydropneumatic tanks required the use of engineering firm data obtained for the 1995 survey. For cisterns, the IHS provided information to develop a unit cost. The models developed for storage needs are listed below. Storage projects have separate cost curves for new and rehabilitation, with the exception of storage covers, which were assigned rehabilitation costs based on rehabilitation of the entire tank.

- | | | |
|--|-------------------------------|----------------------|
| C Elevated Finished/Treated Water Storage (MG) | C Hydropneumatic Storage (MG) | C Storage Cover (MG) |
| C Ground-Level Finished/Treated Water Storage (Includes Presedimentation Basins, Chemical Storage Tanks, and Rehabilitation of Contact Basins for CT) (MG) | C Cisterns (MG) | |

2.4 Transmission and Distribution

Transmission and distribution needs represented the largest category of need in the 2003 Needs Survey. Many factors influence the cost of water main projects, including length and diameter of the pipe, pipe material (e.g., PVC versus cast iron), transportation costs, pressure ratings, depth buried, and soil type. The survey, however, limited the collection of data to diameter and length of pipe to reduce the response burden on water systems.

Several variables for use in the cost models were examined, including the length of pipe for the project, urban and rural project locations, and population density in the project area (as indicated by zip code from the Census Bureau). None of these variables provided a significant improvement to the simpler cost model based only on pipe diameter and length.

Service lines were assigned a unit cost per connection based on survey respondent data. Hydrants, valves, backflow prevention devices, and meters were modeled using the number of units needed and their diameter.

The following types of projects are included in the distribution and transmission category. Most of these projects involve only the installation of new infrastructure (i.e., meters, service lines, hydrants, valves, and backflow prevention devices/assemblies), because rehabilitation of this equipment was considered operation and maintenance.

- | | | |
|--|---|---|
| C Raw Water Transmission (pipe diameter and length) | C Service Lines (number of lines) | C Control Valves (PRVs, altitude, etc.) (number and diameter) |
| C Finished Water Transmission (pipe diameter and length) | C Flushing Hydrants (number and diameter) | C Backflow Prevention Devices /Assemblies (number and diameter) |

C Distribution Mains (pipe diameter and length)

C Valves (gate, butterfly, etc.) (number and diameter)

C Water Meters (number and diameter)

2.5 Pumping

The different types of pumping needs are listed below. EPA developed cost models for pumps and pumping stations as a function of the pumping capacity in MGD. Documented costs for pump controls/telemetry are based on the population served by the system, as this model accounted for more variability in the data than the model using the systems' design capacity.

C Finished Water Pumps (MGD) C Pump Station (MGD)

2.6 Other Needs

Projects in the miscellaneous category of need, called "other," for which costs models were developed include Supervisory Control and Data Acquisition (SCADA) and emergency power. Emergency power was modeled using kilowatts. For SCADA, the costs were modeled using the systems' total design capacity. Chemical storage tanks, categorized as an "other" need, were modeled as ground level storage tanks. The models developed for "other" needs were developed only to assign costs to new projects, because rehabilitation of this equipment was considered operation and maintenance.

C Computer and Automation Costs (SCADA) (system design capacity)

C Pump Controls/Telemetry

C Emergency Power (kilowatts)

Appendix A

Cost Models

Appendix A

Table of Contents

Source

Cost Models

Well: New and Rehabilitation (New only for Aquifer Storage and Recovery Well)
Surface Water Intake and Spring Collectors: New and Rehabilitation

Unit Costs

Well House: New or Rehabilitation
Eliminate Well Pit
Abandon Well

Distribution and Transmission

Cost Models

Distribution and Transmission Mains: Raw and Finished Water, New and Rehabilitation

Unit Costs

Lead Service Lines and Non-Lead Service Lines: New only
Flushing Hydrants: New only
Valves (gate, butterfly, etc.): New only
Control Valves: New only
Backflow Prevention Devices and Assemblies: New only
Water Meters: New only

Treatment

Cost Models

Chlorination and Mixed Oxidant-Type Treatment: New and Rehabilitation as a single model
Chlorine Dioxide and Chloramination: New only
Ozone: New only
Ultraviolet Light Disinfection: New only
Contact Basins For Contact Time: New only (Rehabilitation modeled as Ground Level Storage Tanks)
Conventional Filtration Treatment Plant: New and Rehabilitation
Direct, In-line, Diatomaceous Earth, Slow Sand, or Cartridge/Bag Filtration Plant: New and Rehabilitation
Chemical Feed, Zebra Mussel Control, Dechlorination, Sequestering, Corrosion Control, and Fluoride Addition: New and Rehabilitation as a single model
Sedimentation/Flocculation Basins: New and Rehabilitation
Filters and GAC: New and Rehabilitation as a single model
Membrane Technology: New only

Manganese Green Sand Filtration or Other Oxidation/Filtration Technology: New only (Rehabilitation modeled as Direct Filtration Rehabilitation)
Ion Exchange: New Only (Rehabilitation will be modeled as Rehabilitation of Filters)
Lime Softening: New Only (Rehabilitation will be modeled as Rehabilitation of Conventional Treatment)
Aeration: New and Rehabilitation
Waste Handling and Treatment - Mechanical: New only
Waste Handling and treatment - Non-Mechanical: New and Rehabilitation as a single model

Special Cases

Electrodialysis
Activated Alumina

Unit Costs

Chlorine Gas Scrubber
Streaming Current Monitor
Particle Counter
Turbidity meter
Chlorine Residual Monitor
Powdered Activated Carbon

Storage/Pumping

Cost Models

Elevated Finished/Treated Water Storage: New and Rehabilitation
Ground Level Finished/Treated Water Storage, Presedimentation Basin and Chemical Storage Tanks: New and Rehabilitation
Hydropneumatic Storage: New and Rehabilitation
Cisterns - Unit Cost
Covers for Existing Finished/Treated Water Storage: New Only (Rehabilitation modeled as Rehabilitation of Entire Ground Level Tank)
Pumps for Raw Water, Finished Water, and Wells: New and Rehabilitation
Pump Station: New and Rehabilitation

Other

Cost Models

Computer and Automation Costs, SCADA: New only
Pump Controls/Telemetry: New and Rehabilitation as a single model
Emergency Power: New only

Source

Well

2003 Needs Survey Codes:

- C R1 – Well (complete, including pump and appurtenances, not including a well house).
- C R12 – Aquifer Storage and Recovery Well.

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent data for wells (R1). Medium and large system 1999 survey respondent data for aquifer storage and recovery wells (R12).

Determinants of Cost:

- C Design Capacity in million gallons per day (MGD).

Equations:


C New*: $C = e^{(12.723+0.921*R12+0.814^2/2)} * D^{0.674} * 1.096833$

- C Rehab: $C = e^{(10.682+1.056^2/2)} * D^{0.163} * 1.096833$ for wells (R1) only. Aquifer storage and recovery wells (R12) were not modeled.


* Regression includes data for Aquifer Storage and Recovery Wells (R12), with indicator variable (for Aquifer Storage and Recovery Wells, R12: = 1 if Type of Need = R12, = 0 otherwise).

| | New | Rehab |
|------------------------|------------|--------------|
| Observations | 318 | 257 |
| R-squared | 0.47 | 0.02 |
| Prob>F | 0.000 | 0.046 |
| Cost Floor | \$60,454 | \$16,453 |
| Minimum capacity (MGD) | 0.010 | 0.001 |

New Well



Well Rehabilitation



Surface Water Intake and Spring Collector

2003 Needs Survey Codes:

- C R6 – Surface Water Intake
- C R10 – Spring Collector

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent surface water intake data.

Determinants of Cost:

- C Design Capacity in million gallons per day (MGD).


Equations:

C New: $C = e^{(12.100+0.965^2/2)} * D^{0.715} * 1.096833$


C Rehab: $C = e^{(11.777+0.973^2/2)} * D^{0.550} * 1.096833$

| | New | Rehab |
|------------------------|-------|-------|
| Observations | 43 | 23 |
| R-squared | 0.61 | 0.50 |
| Prob>F | 0.000 | 0.000 |
| Minimum capacity (MGD) | 0.072 | 0.010 |

New Surface Water Intake or Spring Collector



Surface Water Intake or Spring Collector Rehabilitation



**Larger point is outlier excluded from regression.*

Unit Costs for Raw / Untreated Water Source Projects

| Infrastructure Need | Needs Survey Code | Source of Cost Estimate | 2003 Cost Estimate |
|---------------------|-------------------|---|--------------------|
| Well House | R3-New | <i>1995 Needs Survey Unit Cost (developed by an engineering firm) converted to January 2003 dollars</i> | \$ 85,929 |
| Well House | R3-Rehab | | \$ 26,366 |
| Eliminate Well Pit | R4-New Only* | | \$ 14,265 |
| Abandon Well | R5-New Only* | | \$ 6,006 |

* Costs were assigned for construction of new projects only. Elimination of well pits and abandonment of wells are considered one-time projects.

Distribution and Transmission

Distribution and Transmission Mains

2003 Needs Survey Codes:

- C M1 – Distribution Mains
- C X1 – Raw Water Transmission
- C X2 – Finished Water Transmission

Source of Cost Observations:

- C Distribution mains, raw water or finished water transmission from medium and large system 2003 survey respondents.

Determinants of Cost:

- C Distribution mains or transmission lines, pipe diameter, project length (in feet) in frost and non-frost locations.
- C Rehab - An average cost per foot of \$48.92 was used for all sizes.


Table of Data:

- C New and rehab of distribution mains and transmission lines.

Average Cost Per Foot For Pipe in January 2003 Dollars

| Diameter Category | New | | | | Upgrade |
|-------------------|--------------------|--------------------|--------------------|--------------------|---------|
| | Frost | | Non-frost | | |
| | Distribution Mains | Transmission Lines | Distribution Mains | Transmission Lines | |
| # 6 Inches | \$67.45 | | \$50.30 | | \$48.92 |
| 6 - 10 Inches | \$98.21 | \$84.89 | \$87.42 | \$74.10 | \$48.92 |
| 10 - 14 Inches | \$113.78 | \$100.46 | \$102.99 | \$89.67 | \$48.92 |
| 14 - 16 Inches | \$142.73 | \$129.41 | \$131.94 | \$118.62 | \$48.92 |
| 16 - 20 Inches | \$164.92 | \$151.61 | \$154.13 | \$140.82 | \$48.92 |
| 20 - 24 Inches | \$191.03 | \$177.72 | \$180.24 | \$166.93 | \$48.92 |
| 24 - 30 Inches | \$240.11 | | | | \$48.92 |
| 30 - 36 Inches | \$286.31 | | | | \$48.92 |
| 36 - 42 Inches | \$293.06 | | | | \$48.92 |
| 42 - 60 Inches | \$418.00 | | | | \$48.92 |
| 60 - 84 Inches | \$466.94 | | | | \$48.92 |
| 84 - 90 Inches | \$581.32 | | | | \$48.92 |
| 90 - 96 Inches | \$651.52 | | | | \$48.92 |
| 96 - 120 Inches | \$691.00 | | | | \$48.92 |
| > 120 Inches | \$947.66 | | | | \$48.92 |

Distribution Mains and Transmission Lines in frost and Non Frost Areas



Unit Costs for Distribution Projects

| Infrastructure Need | Need Survey Code | Source of Cost Estimate | 2003 Cost Estimate |
|--|------------------|---|--|
| Lead Service Lines and Service Lines other than Lead Lines | M2, M3 | <i>Unit costs derived from 1999 Needs Survey data used on all new projects based on size and converted to January 2003 dollars.</i> | \$1,219 |
| Flushing Hydrants | M4 | | <i>Rehabilitation projects are not allowable and therefore were not modeled.</i> |

Valves

2003 Needs Survey Codes:

C M5 – Valves (gate, butterfly, etc.)

Source of Cost Observations:

C Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:


C Diameter of valve.

Table of Data:

C New valves only, rehabilitation projects not allowed for the Survey.

| Valve Diameter (Inches) | Cost (January 2003 dollars) |
|------------------------------------|--|
| 4.0 | \$ 1,143 |
| 6.0 | \$ 1,247 |
| 8.0 | \$ 1,781 |
| 10 | \$ 4,026 |
| 12 | \$ 5,782 |
| 14-16 | \$ 7,891 |
| 18-20 | \$ 13,056 |
| >20 | \$ 23,571 |

Valves (Gate, Butterfly, etc.) (M5)



Control Valves

2003 Needs Survey Codes:

C M6 – Control Valves (PRVs, altitude, etc.)

Source of Cost Observations:

C Medium and large system 1999 survey respondent data.

Determinants of Cost:


C Diameter of valve.

Table of Data:

C New valves only, rehabilitation projects not allowed for the Survey.

| Valve Diameter (Inches) | Cost (January 2003 dollars) |
|------------------------------------|--|
| ≤ 6.0 | \$ 8,658 |
| 10-12 | \$ 10,938 |
| 14-16 | \$ 21,583 |
| 18-24 | \$ 67,169 |
| 30+ | \$ 129,283 |

Control Valves (PRV, Altitude, etc.) (M6)



Backflow Prevention Devices/Assemblies

2003 Needs Survey Codes:

C M7 – Backflow Prevention Devices/Assemblies

Source of Cost Observations:

C 2000 R.S. Means Cost Data for double check valves up to and including 6-inches in diameter and reduced pressure zone backflow prevention devices for 8 and 10-inch diameter units.

Determinants of Cost:


C Device/Assembly diameter.

Table of Data:

C New devices/assemblies only, rehabilitation projects not allowed for the Survey.

| Diameter of Device/Assembly (inches) | Cost (January 2003 dollars) |
|---|--|
| 0.75 | \$ 671 |
| 1.0 | \$ 701 |
| 1.5 | \$ 802 |
| 2.0 | \$ 996 |
| 3.0 | \$ 1,707 |
| 4.0 | \$ 2,479 |
| 6.0 | \$ 3,892 |
| 8.0 | \$ 9,372 |
| 10 | \$ 13,102 |

Backflow Prevention Devices and Assemblies (M7)



Water Meters

2003 Needs Survey Codes:

- C M8 – Water Meters

Source of Cost Observations:

- C Meters with diameters less than or equal to 1 inch use medium and large system 2003 survey respondent data.
- C Meters with diameters greater than 1 inch use small, medium, and large system 1999 survey respondent data.

Determinants of Cost:


- C Meter diameter.

Table of Data:

- C New meters only, rehabilitation of meters not allowed for the Survey.

| Diameter of Meter (inches) | Average Cost per Meter (January 2003 dollars) |
|---------------------------------------|--|
| 0.625 and 0.7 | \$ 225 |
| 1.0 | \$ 225 |
| 1.5 | \$ 397 |
| 2.0 | \$ 645 |
| 3.0 | \$2,365 |
| 4.0 | \$ 3,320 |
| 6.0 | \$ 5,133 |
| ≥ 8.0 | \$ 11,813 |

Water Meters (M8)



Treatment

Chlorination and Mixed Oxidant Type Equipment

2003 Needs Survey Codes:

- C T1 – Chlorination
- C T5 – Mixed Oxidant Type Equipment

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent data for chlorination (T1). No data from Mixed Oxidant Type Equipment was provided by 1999 survey respondents.

Determinants of Cost:


- C Design Capacity of water to be treated in million gallons per day (MGD).
- C Minimum design capacities were applied when not specified.
- C Minimum cost for new T1 specified as \$73,567.

Equations:

- C New & Rehab: $C = e^{(10.400+1.070^2/2)} * D^{0.684} * 1.096833$

| | New and Rehab |
|-------------------------|----------------------|
| Observations | 95 |
| R-squared | 0.63 |
| Prob>F | 0.000 |
| Minimum capacity(new) | 0.000003 |
| Minimum capacity(rehab) | 0.001 |

New Chlorination System and Mixed Oxidant Type Equipment and Rehabilitation of Existing System



Larger point is outlier excluded from regression.

Chloramination and Chlorine Dioxide

2003 Needs Survey Codes:

- C T2 – Chloramination
- C T3 – Chlorine Dioxide

Source of Cost Observations:

- C Chlorine dioxide costs reported in the Economic Analysis for the Proposed Ground Water Rule.

Determinants of Cost:


- C Design Capacity in million gallons per day (MGD).
- C Minimum design capacities applied when not specified.
- C Cost determined by extrapolating between data points provided in table.

Table of Data:

- C New projects only, no rehabilitation data available.

| Design Capacity (MGD) | Cost (January 2003 Dollars) |
|----------------------------------|--|
| 0.03 | \$ 118,735 |
| 0.1 | \$ 188,209 |
| 0.3 | \$ 213,472 |
| 0.75 | \$ 238,734 |
| 2.2 | \$ 294,313 |
| 7.8 | \$ 488,838 |
| 23.5 | \$ 1,018,097 |
| 81 | \$2,067,773 |

Chloramination and Chlorine Dioxide (T2, T3)



Ozonation

2003 Needs Survey Codes:

C T4 – Ozonation

Source of Cost Observations:

C Ozone costs for new systems reported in the Economic Analysis from the Stage 2 Disinfectants/Disinfection Byproducts Rule.

Determinants of Cost:


C Design Capacity in million gallons per day (MGD); minimum design capacities applied when not specified.

Table of Data:

C New only, rehabilitation projects are modeled as rehabilitation of Chlorination (T1).

| Design Capacity (MGD) | Cost (January 2003 Dollars) |
|------------------------------|------------------------------------|
| 0.024 | \$ 305,568 |
| 0.087 | \$ 370,887 |
| 0.10 | \$ 381,343 |
| 0.27 | \$ 414,356 |
| 0.45 | \$ 504,373 |
| 0.65 | \$ 594,262 |
| 0.83 | \$ 765,589 |
| 1.0 | \$ 872,570 |
| 1.8 | \$ 970,666 |
| 4.8 | \$ 1,338,526 |
| 10 | \$ 1,976,149 |
| 11 | \$ 2,096,574 |
| 18 | \$ 2,905,268 |
| 26 | \$ 3,775,179 |
| 51 | \$ 6,294,739 |
| 210 | \$ 19,575,848 |
| 430 | \$ 36,596,933 |

Ozonation (T4)



Ultraviolet Disinfection

2003 Needs Survey Codes:

- C T6 – Ultraviolet Disinfection

Source of Cost Observations:

- C Costs extrapolated from manufacturer's data for new systems in 1999 and updated to January 2003 dollars.


Determinants of Cost:

- C Design Capacity in million gallons per day (MGD).
- C Minimum design capacities applied when not specified.
- C Rehabilitation projects were not modeled, as there were no rehabilitation projects submitted without costs.

Table of Data:

| Design Capacity (MGD) | Cost (January 2003 Dollars) |
|----------------------------------|--|
| 0.024 | \$ 12,472 |
| 0.087 | \$ 17,018 |
| 0.27 | \$ 23,994 |
| 0.65 | \$ 38,578 |
| 1.8 | \$ 142,186 |
| 4.8 | \$ 208,518 |
| 11 | \$ 291,924 |
| 18 | \$ 333,628 |
| 26 | \$ 383,672 |
| 51 | \$ 639,454 |
| 210 | \$ 1,514,974 |

Ultraviolet Disinfection (T6)



Contact Basin for CT

2003 Needs Survey Codes:

Ⓒ T7 – Contact Basin for CT (new)

Source of Cost Observations:

Ⓒ Medium and large system 1999 survey respondent data.

Determinants of Cost:

Ⓒ Design Capacity in million gallons (MG).


Equations:

Ⓒ New: $C = e^{(14.072+0.464^2/2)} * D^{0.739} * 1.096833$

Ⓒ Rehabilitation projects for contact basins for CT will be modeled as rehabilitations of ground level storage tanks (S2).

| | New |
|------------------|--------|
| Observations | 16 |
| R-squared | 0.84 |
| Prob>F | 0.000 |
| Minimum capacity | 0.0003 |

New Contact Basin for CT



Conventional Filter Plant

2003 Needs Survey Codes:

- C T10 – Conventional Filter Plant
- C T35 – Lime Softening (complete plant rehabilitation)

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent data, and supplemental data from state lending agencies.

Determinants of Cost:

- C Design Capacity in million gallons per day (MGD).

Equations:

- C New*: $C = e^{(14.444+0.537^2/2)*D^{0.593}} * 1.096833$ if design capacity is less than or equal to 1 MGD;

$$C = e^{(14.444+0.537^2/2)*D^{0.881}} * 1.096833 \text{ if design capacity is greater than 1 MGD}$$


- C Rehab**: $C = e^{(13.710+T35*-0.696+1.037^2/2)*D^{0.606}} * 1.096833$

* New projects are modeled as a spline, with the slope changing at 1 MGD.

** The rehabilitation regression includes data for rehabilitation of Lime Softening (T35), with an indicator variable. T35: = 1 if Type of Need is T35, = 0 otherwise.


| | New | Rehab |
|------------------------|------------|--------------|
| Observations | 144 | 151 |
| R-squared | 0.89 | 0.41 |
| Prob>F | 0.000 | 0.000 |
| Minimum capacity (MGD) | 0.072 | 0.072 |

New Conventional Filter Plant



Larger points are outliers excluded from regression.

Conventional Filter Plant and Lime Softening Rehabilitation



**Direct or In-line, Slow Sand, Diatomaceous Earth, or
Cartridge or Bag Filtration Plant**

2003 Needs Survey Codes:

- C T11 – Direct or In-line Filter Plant
- C T16 – Slow Sand Filter Plant
- C T17 – Diatomaceous Earth Filter Plant
- C T19 – Cartridge or Bag Filtration Plant

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent data for direct filtration plants.

Determinants of Cost:

- C Design Capacity in million gallons per day (MGD).


Equations:

C New: $C = e^{(14.472+0.575^2/2)} * D^{0.716} * 1.096833$


C Rehab: $C = e^{(13.219+1.123^2/2)} * D^{0.594} * 1.096833$

| | New | Rehab |
|------------------------|------------|--------------|
| Observations | 28 | 25 |
| R-squared | 0.79 | 0.46 |
| Prob>F | 0.000 | 0.000 |
| Minimum capacity (MGD) | 0.100 | 0.065 |

New Direct Filtration Plant



Direct Filtration Plant Rehabilitation



Dechlorination of Treated Water, Chemical Feed, Sequestering for Iron and/or Manganese, Corrosion Control, Fluoride Addition, and Zebra Mussel Control

2003 Needs Survey Codes:

- C T8 – Dechlorination of Treated Water
- C T13 – Chemical Feed
- C T32 – Sequestering for Iron and/or Manganese
- C T40 – Corrosion Control
- C T43 – Zebra Mussel Control
- C T44 – Fluoride Addition

Source of Cost Observations:

- C Large, medium, and small system 1999 survey respondent data for Chemical Feed (T13), Sequestering (T32), Corrosion Control (T40), and Fluoride Addition (T44).

Determinants of Cost:

- C Design Capacity of water to be treated in million gallons per day (MGD).

Equations:*

- C New & Rehab:

$$C = e^{(10.298 + 1.474 * T32 + 0.352 * T40 - 1.302 * T44 + 1.102^2 / 2)} * D^{0.652} * 1.096833$$

*Regression also included data for Sequestering (T32), Corrosion Control (T40), and Fluoride Addition (T46), with indicator variables:

T32: = 1 if Type of Need is T32, = 0 otherwise


T40: = 1 if Type of Need is T40, = 0 otherwise

T44: = 1 if Type of Need is T44, = 0 otherwise

Equation for Chemical Feed (T13) used for Dechlorination of Treated Water (T8) and Zebra Mussel Control (T43).

| | New and Rehab |
|--------------------------------|----------------------|
| Observations | 64 |
| R-squared | 0.63 |
| Prob>F | 0.000 |
| Minimum capacity (new) (MGD) | 0.004 |
| Minimum capacity (rehab) (MGD) | 0.036 |

Dechlorination of Treated Water, Chemical Feed, Sequestering, Corrosion Control, Fluoride Addition, and Zebra Mussel Control



Sedimentation/Flocculation

2003 Needs Survey Codes:

C T14 – Sedimentation/Flocculation

Source of Cost Observations:

C Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

C Design Capacity in million gallons per day (MGD).


Equations:

C New: $C = e^{(12.754+0.750^2/2)*D^{0.608}} * 1.096833$


C Rehab: $C = e^{(11.347+1.219^2/2)*D^{0.560}} * 1.096833$

| | New | Rehab |
|------------------|------------|--------------|
| Observations | 20 | 41 |
| R-squared | 0.44 | 0.30 |
| Prob>F | 0.001 | 0.000 |
| Minimum capacity | 0.144 | 0.086 |

New Sedimentation/Flocculation



Sedimentation/Flocculation Rehabilitation



Filters and Granular Activated Carbon

2003 Needs Survey Codes:

- C T15 – Filters
- C T31 – Granular Activated Carbon

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

- C Design Capacity in million gallons per day (MGD).


Equations:

C New & Rehab*: $C = e^{(12.634 - 1.821 * Rehab + 0.957^2 / 2)} * D^{0.832} * 1.096833$

*Regression includes data for granular activated carbon (T31), without an indicator variable
 Rehabilitation: = 1 if project is a rehab, = 0 otherwise.

| | New and Rehab |
|-------------------------------|----------------------|
| Observations | 131 |
| R-squared | 0.69 |
| Prob>F | 0.000 |
| Minimum capacity (new)(MGD) | 0.0072 |
| Minimum capacity (rehab)(MGD) | 0.007 |

Filters and Granular Activated Carbon: New and Rehabilitation



Membrane Technology for Particulate Removal and Reverse Osmosis

2003 Needs Survey Codes:

- C T18 – Membrane Technology for Particulate Removal
- C T36 – Reverse Osmosis (complete plant)

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent data for new Membrane Technology for Particulate Removal (T18) and Reverse Osmosis (T36). Small, medium and large system 1999 survey respondent data for rehabilitation of Reverse Osmosis (T36).

Determinants of Cost:

- C Design Capacity in million gallons per day (MGD).

Equations:*

C New**: $C = e^{(14.344+0.797^2/2)} * D^{0.814} * 1.096833$


C Rehab: $C = e^{(13.556+0.455^2/2)} * D^{0.278} * 1.096833$

*Regressions included data for Reverse Osmosis (T36) without an indicator variable.


**New projects with a design capacity < 0.156 MGD are modeled as a Reverse Osmosis (T36) rehabilitation.

| | New | Rehab |
|--------------------------------|------------|--------------|
| Observations | 52 | 5 |
| R-squared | 0.72 | 0.62 |
| Prob>F | 0.000 | 0.113 |
| Minimum capacity (new)(MGD) | 0.0144 | 0.500 |

New Membrane Technology for Particulate Removal and Reverse Osmosis



Membrane Technology for Particulate Removal and Reverse Osmosis Rehabilitation



Larger point is outlier excluded from regression

Manganese Green Sand Filtration or Other Oxidation/Filtration Technology

2003 Needs Survey Codes:

- C T33 – Manganese Green Sand Filtration or other oxidation/filtration technology (complete plant).

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

- C Design Capacity in million gallons per day (MGD).

Equations:

- C New*: $C = e^{(13.377+0.999^2/2)} * D^{0.403} * 1.096833$ if design capacity is less than or equal to 1 MGD

$$C = e^{(13.377+0.999^2/2)} * D^{1.106} * 1.096833 \text{ if design capacity is greater than 1 MGD}$$

- C Rehabilitation projects will be modeled as rehabilitation of Direct or In-Line Filter Plants (T11)

*New projects are modeled as a spline, with the slope changing at 1 MGD

| | New |
|------------------------|------------|
| Observations | 52 |
| R-squared | 0.68 |
| Prob>F | 0.000 |
| Minimum capacity (MGD) | 0.007 |

Ion Exchange

2003 Needs Survey Codes:

Ⓒ T34 – Ion Exchange (complete plant)

Source of Cost Observations:

Ⓒ Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

Ⓒ Design Capacity in million gallons per day (MGD).


Equations:

Ⓒ New: $C = e^{(13.308+0.676^2/2)} * D^{0.789} * 1.096833$

Ⓒ Rehabilitation projects will be modeled as rehabilitation of Filters (T15).

| | New |
|-----------------------------|-------|
| Observations | 34 |
| R-squared | 0.64 |
| Prob>F | 0.000 |
| Minimum capacity (new)(MGD) | 0.014 |

New Ion Exchange



Lime Softening

2003 Needs Survey Codes:

C T35 – Lime Softening (complete plant)

Source of Cost Observations:

C Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

C Design Capacity in million gallons per day (MGD).


Equations:

C New: $C = e^{(14.660+0.465^2/2)} * D^{0.884} * 1.096833$

C Rehabilitation projects for Lime Softening will be modeled as rehabilitations of Conventional Filter Plant (T10).

Note: Rehabilitation data included in Conventional Filter Plant (T10) regression, with an indicator variable (T35: = 1 if Type of Need is T35, = 0 otherwise).

| | New |
|------------------------|------------|
| Observations | 16 |
| R-squared | 0.74 |
| Prob>F | 0.000 |
| Minimum capacity (MGD) | 0.648 |



Aeration

2003 Needs Survey Codes:

C T38 – Aeration

Source of Cost Observations:

C Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

C Design Capacity in million gallons per day (MGD).

Equations:


C New*: $C = e^{(12.647+1.058^2/2)} * D^{0.762} * 1.096833$

C Rehab: $C = e^{(11.931+0.373^2/2)} * D^{0.201} * 1.096833$


*New projects < 0.116 MGD will be modeled as a rehabilitation.

| | New | Rehab |
|------------------------|------------|--------------|
| Observations | 67 | 8 |
| R-squared | 0.44 | 0.67 |
| Prob>F | 0.000 | 0.013 |
| Minimum capacity (MGD) | 0.065 | 0.002 |

New Aeration



Aeration Rehabilitation



Waste Handling and Treatment, Mechanical

2003 Needs Survey Codes:

Ⓒ T41 – Waste Handling and Treatment, Mechanical (not included in another project)

Source of Cost Observations:

Ⓒ Large system 1999 survey respondent data.

Determinants of Cost:

Ⓒ Design Capacity of water treatment facility in million gallons per day (MGD).


Equations:

Ⓒ New: $C = e^{(12.742+1.179^2/2)} * D^{0.494} * 1.096833$

Ⓒ Rehabilitation projects will not be modeled.

| | New |
|------------------------------|-------|
| Observations | 35 |
| R-squared | 0.42 |
| Prob>F | 0.000 |
| Minimum capacity (MGD) (new) | 0.050 |

New Waste Handling and Treatment, Mechanical



Waste Handling and Treatment, Nonmechanical

2003 Needs Survey Codes:

Ⓒ T42 – Waste Handling and Treatment, Nonmechanical (not included in another project).

Source of Cost Observations:

Ⓒ Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:


Ⓒ Design Capacity of water treatment facility in million gallons per day (MGD).

Equations:

Ⓒ New & Rehab: $C = e^{(11.879+1.170^2/2)} * D^{0.562} * 1.096833$

| | New and Rehab |
|--------------------------------|----------------------|
| Observations | 39 |
| R-squared | 0.44 |
| Prob>F | 0.000 |
| Minimum capacity (new) (MGD) | 0.005 |
| Minimum capacity (rehab) (MGD) | 0.005 |

Waste Handling and Treatment, Nonmechanical, New and Rehabilitation



Treatment Projects With Special Modeling Needs

| Infrastructure Need | Needs Survey Code | Number of Projects to be Modeled | New Projects to be Modeled as: | Rehabilitation Projects to be Modeled as |
|----------------------------------|--------------------------|---|---------------------------------------|---|
| Electrodialysis (complete plant) | T37 | 2 New 3 Rehab | Reverse Osmosis (T36) New | Reverse Osmosis (T36) Rehab |
| Activated Alumina | T39 | 3 New 1 Rehab | Ion Exchange (T34) | Filters (T15) |

Unit Costs for Treatment Projects

| Infrastructure Need | Needs Survey Code | Source of Cost Estimate | Cost Estimate (January 2003 Dollars) |
|----------------------------|-------------------|---|---|
| Chlorine Gas Scrubber | T9 | Average of two manufacturers' cost estimates and one engineering firm estimate. | \$32,905 for \leq 3.0 MGD |
| | | | \$98,715 for $>$ 3.0 MGD |
| Streaming Current Monitors | T20 | Average of two manufacturers' cost estimates. | \$ 9,268 |
| Particle Counters | T21 | Average of two manufacturers' cost estimates and 1999 Needs Survey data. | \$ 4,528 |
| Turbidity Meters | T22 | Average of three manufacturers' cost estimates and 1999 Needs Survey data. | \$ 2,356 |
| Chlorine Residual Monitors | T23 | Average of two manufacturers' cost estimates. | \$ 2,755 |
| Powdered Activated Carbon | T30 | Unit cost from 1995 Needs Survey (obtained from an engineering firm). | \$ 161,930 |

- T9 – Chlorine Gas Scrubber [scrubber equipment, installation and monitoring equipment with alarms; assume \leq 3.0 MGD uses scrubbers for 150 pound chlorine gas cylinders and $>$ 3.0 MGD uses scrubbers for 1-ton containers].
- T20 – Streaming Current Monitor [basic unit including a monitor, sensor, and cable].
- T21 – Particle Counters [on-line units for individual filter monitoring; *not* research-grade, bench-top models].
- T22 – Turbidity Meter [on-line units for individual filters, *not* bench-top models].
- T23 – Chlorine Residual Monitors [analyzer/monitor only].

Storage/Pumping

Elevated Finished/Treated Water Storage

2003 Needs Survey Codes:

Ⓒ S1 – Elevated Finished / Treated Water Storage

Source of Cost Observations:

Ⓒ Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

Ⓒ Design Capacity in million gallons (MG).


Equations:*

Ⓒ New: $C = e^{(14.082+0.484^2/2)} * D^{0.671} * 1.096833$


Ⓒ Rehab: $C = e^{(12.420+0.804^2/2)} * D^{0.385} * 1.096833$

| | New | Rehab |
|-----------------------|-------|-------|
| Observations | 479 | 365 |
| R-squared | 0.62 | 0.18 |
| Prob>F | 0.000 | 0.000 |
| Minimum capacity (MG) | 0.025 | 0.002 |

New Elevated Finished/Treated Water Storage



Elevated Finished/Treated Water Storage Rehabilitation



Larger symbols are outliers excluded from regressions

**Ground-level Finished/Treated Water Storage, Contact Basin for CT (Rehabilitation),
Presedimentation Basin, Chemical Storage Tank**

2003 Needs Survey Codes:

- C S2 – Ground-level Finished/Treated Water Storage
- C T7 – Contact Basin for CT (Rehabilitation)
- C T12 – Presedimentation Basin
- C T45 – Chemical Storage Tank

Source of Cost Observations:

- C Small, medium, and large system 1999 survey respondent data for new ground-level storage.
- C Small, medium, and large system 1999 survey respondent data for rehabilitation of ground-level storage and contact basin for CT.

Determinants of Cost:

- C Design Capacity in million gallons (MG).

Equations:


C New: $C = e^{(13.641+0.559^2/2)} * D^{0.694} * 1.096833$

C Rehab*: $C = e^{(11.890+0.976^2/2)} * D^{0.478} * 1.096833$

*Note: rehabilitation regression included data for Contact Basin for CT (T7), without indicator variables.


| | New | Rehab |
|------------------|------------|--------------|
| Observations | 577 | 356 |
| R-squared | 0.77 | 0.30 |
| Prob>F | 0.000 | 0.000 |
| Minimum capacity | 0.000 | 0.001 |

New Ground-Level Finished/Treated Water Storage, Presedimentation Basin, Chemical Storage Tank



Larger symbols are outliers excluded from regressions.

Ground-level Finished/Treated Water Storage, Cover for Existing Finished/Treated Water Storage, Contact Basin for CT, Presedimentation Basin, Chemical Storage Tank Rehabilitation



Hydropneumatic Storage

2003 Needs Survey Codes:

C S3 – Hydropneumatic Storage

Source of Cost Observations:

C 1995 Needs Survey cost model.

Determinants of Cost:

C Design Capacity in million gallons (MG).

C For new tanks greater than 12,000 gallons, the Ground Level Finished/Treated Water Storage model will be used.

C Rehabilitation projects for less than 2,500 gallons will be modeled as new tanks.

Equations:

C New: $C = e^{(14.9667)*D^{0.681}} * 1.209076$

C Rehab: $C = e^{(13.4862)*D^{0.559}} * 1.209076$

Unit Costs for Storage Projects

| Infrastructure Need | Need Survey Code | Source of Cost Estimate | Cost Estimate |
|----------------------------|-------------------------|-----------------------------------|----------------------|
| Cistern | S4 | Indian Health Service information | \$4,936 each |

Cover for Existing Finished/Treated Water Storage

2003 Needs Survey Codes:

Ⓒ S5 – Cover for Existing Finished/Treated Water Storage (New only)

Source of Cost Observations:

Ⓒ Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

Ⓒ Design Capacity in million gallons (MG).


Equations:

Ⓒ New: $C = e^{(12.388 + 0.929^2/2 * D^{0.543})} * 1.096833$

Ⓒ Rehabilitation: Rehabilitations of covers will be modeled as rehabilitation of the entire tank with the model for rehabilitation of ground-level finished/treated water storage (S2).

| | New |
|------------------------|------------|
| Observations | 30 |
| Sigma | 0.929 |
| R-squared | 0.69 |
| Prob>F | 0.000 |
| Minimum capacity (new) | 0.006 |

New Cover for Existing Finished/Treated Water Storage



Pumps

2003 Needs Survey Codes:

- C P1 – Finished Water Pumps
- C R2 – Well Pump
- C R7 – Raw Water Pumps

Source of Cost Observations:

- C Medium and large system 1999 survey respondent data for Finished Water Pumps (P1), Well Pump (R2), and Raw Water Pumps (R7).

Determinants of Cost:


- C Pump design capacity in million gallons per day (MGD).

Equations:

- C New & Rehab: $C = e^{(10.967 - 0.455 * \text{Rehab} + 1.137^2 / 2 * D^{0.713} * 1.096833)}$
(Rehabilitation: = 1 if project is a rehab., = 0 otherwise)

| | New and Rehab |
|--------------------------------|----------------------|
| Observations | 335 |
| R-squared | 0.45 |
| Prob>F | 0.000 |
| Minimum capacity (new) (MGD) | 0.001 |
| Minimum capacity (rehab) (MGD) | 0.005 |

Pumps – New and Rehabilitation



Larger symbol is outlier excluded from regressions.

Pump Station

2003 Needs Survey Codes:

C P2 – Pump Station (booster or raw water pump station including clearwell, pump and housing).

Source of Cost Observations:

C Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

C Design Capacity in million gallons per day (MGD).


Equations:

C New: $C = e^{(12.446+1.077^2/2)} * D^{0.644} * 1.096833$


C Rehab: $C = e^{(11.593+1.120^2/2)} * D^{0.687} * 1.096833$

| | New | Rehab |
|------------------------|------------|--------------|
| Observations | 331 | 201 |
| R-squared | 0.52 | 0.61 |
| Prob>F | 0.000 | 0.000 |
| Minimum capacity (gpm) | 10 | 10 |

New Pump Station



Pump Station Rehabilitation



Other Needs

Computer and Automation Costs (SCADA)

2003 Needs Survey Codes:

Ⓒ W2 – Computer and Automation Costs (SCADA)

Source of Cost Observations:

Ⓒ Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

Ⓒ System design capacity in million gallons per day (MGD).

Equations:

Ⓒ Model is the following system of equations:

$$(1) \quad \ln(\text{Cost}) = \beta_0 + \beta_1 \ln(\text{Design Capacity})$$

$$(2) \quad \ln(\text{Design Capacity}) = \beta_0 + \beta_1(\text{Population})$$

Cost as a Function of Design Capacity (equation 1)

$$\text{New: } C = e^{(10.770+1.484^2/2)} * D^{0.578} * 1.096833$$

$$\text{Rehab: } C = e^{(10.657+1.280^2/2)} * D^{0.481} * 1.096833$$


Design Capacity as a Function of Population (equation 2)

$$\text{New: } C = e^{(-6.886+0.666^2/2)} * \text{Pop}^{0.902} * 1.096833$$


$$\text{Rehab: } C = e^{(-8.000+0.377^2/2)} * \text{Pop}^{1.006} * 1.096833$$

| | Structural Model | | | |
|--------------|---|--------------|--|--------------|
| | Cost as Function of System Design Capacity | | System Design Capacity as Function of Population Served | |
| | New | Rehab | New | Rehab |
| Observations | 252 | 80 | 252 | 80 |
| R-squared | 0.20 | 0.29 | 0.82 | 0.95 |
| Prob>F | 0.000 | 0.000 | 0.000 | 0.000 |

New Computer and Automation Costs (SCADA)



Computer and Automation Costs (SCADA) Rehabilitation



Pump Controls/Telemetry

2003 Needs Survey Codes:

Ⓒ W3 – Pump Controls/Telemetry

Source of Cost Observations:

Ⓒ Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:


Ⓒ Population served by the system as a means of estimating system complexity.

Equations:

Ⓒ New & Rehab: $C = e^{(7.973+1.312^2/2)} * Pop^{0.318} * 1.096833$

| | New and Rehab |
|--------------|----------------------|
| Observations | 173 |
| R-squared | 0.13 |
| Prob>F | 0.000 |

Pump Controls/Telemetry



Emergency Power

2003 Needs Survey Codes:

Ⓒ W4 – Emergency Power

Source of Cost Observations:

Ⓒ Small, medium, and large system 1999 survey respondent data.

Determinants of Cost:

Ⓒ Design Capacity in kilowatts.


Equations:*

Ⓒ New: $C = e^{(6.942+0.748^2/2)} * D^{0.831} * 1.096833$

Ⓒ Rehabilitation projects are not modeled.

| | New |
|--------------|-------|
| Observations | 140 |
| R-squared | 0.61 |
| Prob>F | 0.000 |

New Emergency Power



Appendix B

Type of Need Dictionary

TYPE OF NEED DICTIONARY

Possible Project Components

The following describes the general scope of projects for which each of the Type of Need codes in List 1 of the Lists of Codes apply. It is not intended to be an exclusive list. Rather, it conveys the spectrum of possible elements of a related project. Some projects using a particular code may include all of the elements listed. Others may be more limited in scope and include only one of the items. Assume all projects include installation, engineering design, and contingency costs and all treatment projects include waste-stream handling, if appropriate.

| Code | Type of Need | Possible Components | Parameters required for Modeling Cost |
|-------------------------------------|----------------------|---|--|
| RAW / UNTREATED WATER SOURCE | | | |
| R1 | Well | Siting, drilling, and developing a well to completion; including installation of a pump and appurtenances such as sample tap, meter, air release, pressure gauge, shut-off valve, electrical controls, and limited discharge piping. | Design Capacity in MGD. |
| R2 | Well Pump | Pump and electrical controls. | Design Capacity in MGD. |
| R3 | Well House | Site work, slab, building structure sized to accommodate on-site disinfection. Projects may span significance from constructing a small building to more elaborate facilities with a chemical feed room with ventilation, etc. | n/a (A unit cost will be assigned) |
| R4 | Eliminate Well Pit | Extend casing, install pitless adapter, modify piping connections, fill pit, grade site. Does not include well house. | n/a (A unit cost will be assigned) |
| R5 | Abandon Well | Fill casing with appropriate material, cap well. | n/a (A unit cost will be assigned) |
| R6 | Surface Water Intake | Intake structure, piping, valves; does not include pumps or impoundment structures. May include a wet well (small storage tank for raw water to be pumped to the treatment plant). | Design Capacity in MGD. |
| R7 | Raw Water Pump | Pump and electrical controls. | Design Capacity in MGD. |
| R8 | Dam/Reservoir | Construction of a dam or impoundment to inhibit flow of a naturally occurring stream, river, or other flowing body of water for the purposes of storing raw water for future use. Does not include intake structure. | n/a (these projects are not allowable for the Needs Survey) |

| Code | Type of Need | Possible Components | Parameters required for Modeling Cost |
|---------------------------------|-----------------------------------|--|--|
| R9 | Off-Stream Raw Water Storage | Storage basin off the stream channel, constructed as a part of the treatment process, providing no more than 3 days detention time. Purpose is to address water quality issues, not water quantity issues. | Cost must be provided. |
| R10 | Spring Collector | Spring box or other collection device, including overflow, meter, sample tap, valves, and limited piping connection to a transmission main. Assume gravity flow; does not include pumps. | Design Capacity in MGD. |
| R11 | De-stratification | Some method of water circulation or aeration of a raw water source to avoid stratification of the water body. | Cost must be provided. |
| R12 | Aquifer Storage and Recovery Well | Wells used to inject water into an aquifer for later recovery and use as a source of drinking water. These wells may also be used for aquifer recharge without subsequent recovery from the same wellhead. Components may include well construction, pump, appurtenances, and limited transmission main. | Design Capacity in MGD |
| TREATMENT - DISINFECTION | | | |
| T1 | Chlorination | Gas or hypochlorite system with chemical mixing and injection systems, safety-related components. Does not include gas scrubber. | Capacity of the water to be treated in MGD. |
| T2 | Chloramination | Chemical mixing and injection systems, safety-related components. Does not include gas scrubber. | Capacity of the water to be treated in MGD. |
| T3 | Chlorine Dioxide | Chemical mixing and injection systems, safety-related components. | Capacity of the water to be treated in MGD. |
| T4 | Ozonation | Ozone generation and injection equipment, off-gas controls and related safety equipment. | Capacity of the water to be treated in MGD. |
| T5 | Mixed Oxidant Type Equipment | Disinfectant generation equipment, injection system, safety-related components. | Capacity of the water to be treated in MGD. |
| T6 | Ultraviolet Disinfection | UV lights, pipes, valves, controls, and intensity monitors. | Capacity of the water to be treated in MGD. |
| T7 | Contact Basin for CT | Baffled clearwell-type contact tank with overflow, drain and access (if appropriate), or serpentine piping for contact time. Includes valves. | Volume in MG. |
| T8 | Dechlorination of Treated Water | Chemical mixing and injection system, on-line chlorine residual monitoring equipment. | Capacity of the water to be treated in MGD. |

| Code | Type of Need | Possible Components | Parameters required for Modeling Cost |
|---|--|---|---|
| T9 | Chlorine Gas Scrubber | Gas scrubber equipment, installation, and monitoring equipment with alarms. | Capacity of the water to be treated in MGD. |
| TREATMENT - FILTRATION (surface or ground water) | | | |
| T10 | Conventional Filter Plant (complete plant) | Complete conventional plant with flocculation, sedimentation, filtration, waste handling, and the building. Includes all raw water and finished water pumps, chemicals and mixing, unit processes, clearwell, disinfection, process control system, and building. This code will also be used for systems using contact adsorption clarifier (CAC) technologies for the flocculation/sedimentation process. | Capacity of the water to be treated in MGD. |
| T11 | Direct or In-line Filter Plant (complete plant) | Complete direct or in-line filtration plant, including all raw water and finished water pumps, chemicals and mixing, unit processes, clearwell, disinfection, waste handling, process control system, and the building. This code is also used for pressure filtration systems. | Capacity of the water to be treated in MGD. |
| T12 | Pre-sedimentation Basin | Presedimentation basin, including any required berms, walls, chemical feed equipment, and on-site sludge removal equipment. | Capacity of the water to be treated in MGD (not volume of basin in MG). |
| T13 | Chemical Feed | Chemical handling equipment, mixers, injection systems, and limited piping. Includes in-line mixers, chemical injectors, chemical diffusers, and other rapid-mix technologies. | Capacity of the water to be treated in MGD. |
| T14 | Sedimentation/ Flocculation | Sedimentation basin (including lamella plates, tube settlers, etc.), flocculation basin with flocculators, sludge removal, and necessary valves. Includes a Contact Adsorption Clarifier unit process. | Capacity of the water to be treated in MGD. |
| T15 | Filters | Complete filters, including media, air scour and/or surface wash, underdrain, effluent troughs, and backwash equipment. | Capacity of the water to be treated in MGD. |
| T16 | Slow Sand Filter Plant (complete plant) | Complete plant including filters, all raw water and finished water pumps, disinfection, and buildings. | Capacity of the water to be treated in MGD. |
| T17 | Diatomaceous Earth Filter Plant (complete plant) | Complete plant and building including all raw water and finished water pumps, chemical and body-feed equipment, mixing and injection, filter, backwash equipment, disinfection, waste handling, and building. | Capacity of the water to be treated in MGD. |

| Code | Type of Need | Possible Components | Parameters required for Modeling Cost |
|--|--|--|--|
| T18 | Membrane Technology for Particulate Removal (complete plant) | Complete plant including pre-filtration, membrane filtration equipment, waste-stream handling, all raw water and finished water pumps, disinfection, monitoring equipment, controls, and building. Also may include caustic and other cleaning-chemical feed components. | Capacity of the water to be treated in MGD. |
| T19 | Cartridge or Bag Filtration Plant (complete plant) | Complete plant including connective piping, filter housing, all raw water and finished water pumps, disinfection, monitoring equipment and building. | Capacity of the water to be treated in MGD. |
| T20 | Streaming Current Monitors | On-line monitor with or without chemical feedback loop. | Number of monitors needed. List on third table. |
| T21 | Particle Counters | Bench-top or in-line particle counter. | Number of particle counters needed. List on third table. |
| T22 | Turbidity Meters | Bench-top or in-line meter, recording charts, and limited piping for installation. | Number of meters needed. List on third table. |
| T23 | Chlorine Residual Monitors | Bench-top or in-line chlorine residual monitor. | Number of monitors needed. List on third table. |
| TREATMENT - OTHER TREATMENT NEEDS | | | |
| T30 | Powdered Activated Carbon | PAC handling facility, chemical feeders, and safety equipment. | Capacity in MGD of the water to be treated. |
| T31 | Granular Activated Carbon | GAC filter media with or without underdrains, backwash system, air scour or surface wash, and effluent troughs. Does not include regeneration facility. Includes GAC caps for filters and carbon columns. | Capacity in MGD of the water to be treated. |
| T32 | Sequestering for Iron and/or Manganese | Chemical mixing and feed system, injection system. Does not include disinfection. | Capacity in MGD of the water to be treated. |
| T33 | Manganese Green Sand (complete plant) | Complete plant including all raw water and finished water pumps, waste-stream handling, monitoring equipment, chemical feed, disinfection, and building. | Capacity in MGD of the water to be treated. |
| T34 | Ion Exchange (complete plant) | Complete ion exchange treatment plant including all raw water and finished water pumps, final disinfection, and building. | Capacity in MGD of the water to be treated. |

| Code | Type of Need | Possible Components | Parameters required for Modeling Cost |
|-------------|---|--|--|
| T35 | Lime Softening (complete plant) | Complete lime softening plant including all raw water and finished water pumps and building. | Capacity in MGD of the water to be treated. |
| T36 | Reverse Osmosis (complete plant) | Complete plant including pre-filtration, membrane filtration equipment, waste-stream handling, all raw water and finished water pumps, building and monitoring equipment, and controls. | Capacity in MGD of the water to be treated. |
| T37 | Electrodialysis (complete plant) | Electrodialysis plant complete with building. Includes all raw water and finished water pumps. | Capacity in MGD. |
| T38 | Aeration | Complete packed tower or counter-current tower aeration facility including disinfection, or cascading-type tray aeration. | Capacity in MGD. |
| T39 | Activated Alumina (complete plant) | Complete activated alumina plant including all raw water and finished water pumps, disinfection and building. | Capacity of water to be treated in MGD. |
| T40 | Corrosion Control | Chemical mixing and injection system. Does not include disinfection. | Capacity of water to be treated in MGD. |
| T41 | Waste Handling/ Treatment: Mechanical | Mechanical treatment plant including sludge handling/drying equipment complete. | Capacity of plant in MGD. |
| T42 | Waste Handling/ Treatment: Non-mechanical or Connection to a Sanitary Sewer (not included in another project) | Ponds or lagoons for storing, recycling, and/or evaporating process wastewater; or lift station and force main or gravity main to sanitary sewer. | Capacity of plant in MGD. |
| T43 | Zebra Mussel Control | Chemical mixing and injection of oxidant at raw water intake. | Capacity of the plant in MGD. |
| T44 | Fluoride Addition | Chemical mixing and injection system. | Capacity in MGD of the water to be treated. |
| T45 | Chemical Storage Tank | Tank only. Use other codes as needed for chemical mixing and injection systems. | Cost must be provided. |
| T46 | Type of Treatment Unknown | Use this code when treatment is necessary but the type of treatment to be applied is unknown. The State or EPA will assign a treatment type based on Best Available Treatment (BAT) technologies for the contaminant of concern. | Capacity of water to be treated in MGD. |

| Code | Type of Need | Possible Components | Parameters required for Modeling Cost |
|--|---|---|---|
| T47 | Other | Use if none of the other treatment codes apply. Please include an explanation of the type of treatment. | Cost must be provided. |
| TRANSMISSION - These codes are used for any mains that transport raw water to the treatment plant, or treated water from the plant to the distribution system grid. | | | |
| X1 | Raw Water Transmission | Mains, trenching, bedding, backfill site work, easements, typical road repair, control valves, air release valves. | Pipe diameter (in inches) and pipe length (in feet). |
| X2 | Finished Water Transmission | Mains, trenching, bedding, backfill site work, easements, typical road repair, control valves, air release valves. | Pipe diameter (in inches) and pipe length (in feet). |
| DISTRIBUTION | | | |
| M1 | Distribution Mains | This code should be used for any mains that transport water through a piping grid serving customers. Components include mains, trenching, bedding, backfill, hydrants, valves, site work, road repair, easements and service leads from the main to the curb stop. Does not include "transmission mains." | Pipe diameter (in inches) and pipe length (in feet). |
| M2 | Lead Service Lines | Service lines from the curb-stop to the building. | Number of service lines. |
| M3 | Service Lines (other than lead service lines) | Service lines from the curb-stop to the building. (Applies to Alaska Native and American Indian surveys only) | Number of service lines. |
| M4 | Flushing Hydrants | Hydrant lead to the transmission or distribution main, drain, hydrant, and auxiliary valve. | Number of hydrants and diameter (in inches). |
| M5 | Valves | Includes purchase price of the butterfly, ball, air release, or other related valve and installation. | Number of valves and diameter (in inches). |
| M6 | Control Valves | Includes pressure reducing valves (PRVs), flow control, filter effluent control valves, and altitude valves. | Number of valves and diameter (in inches). |
| M7 | Backflow Prevention Devices/Assemblies | Device or assembly, including installation. | Number of assemblies and diameter (in inches). |
| M8 | Water Meters | Individual domestic or industrial units of either manual or remote read-methods. | Number of meters, and diameter (in inches - converted to a decimal for data entry). |

| Code | Type of Need | Possible Components | Parameters required for Modeling Cost |
|---|--|--|--|
| FINISHED / TREATED WATER STORAGE | | | |
| S1 | Elevated/ Finished Water Storage | Complete elevated storage facility with appurtenances such as altitude valves and isolation valves. | Volume in MG. |
| S2 | Ground-level Finished/ Treated Water Storage | Complete ground level storage facility with appurtenances such as altitude valves and isolation valves. | Volume in MG. |
| S3 | Hydro- pneumatic Storage | Complete hydropneumatic storage tank and recharge/control system and building (for larger installations) | Volume in MG. |
| S4 | Cisterns | Finished water storage for individual homes. | Volume in MG. |
| S5 | Cover for Existing Finished/ Treated Water Storage | Construction of a concrete, wood, or other cover on an existing finished/treated water storage tank. | Volume of the tank in MG. |
| PUMPING STATION AND PUMPS | | | |
| P1 | Finished Water Pumps | Pump and electrical controls. | Capacity in MGD. |
| P2 | Pump Station | Booster or Raw Water. Includes clearwell, pumps, and building. | Capacity in MGD. |
| OTHER INFRASTRUCTURE NEEDS | | | |
| W1 | Laboratory Capital Costs | Limited to laboratory equipment, buildings, and facilities owned by the system. | Cost of equipment and facility must be provided. |
| W2 | Computer and Automation Costs (SCADA) | Computer control systems and SCADA control systems. Does not include computer software. | Cost must be provided. |
| W3 | Pump Controls/ Telemetry | Basic telemetry system of telephone-wire based signals or radio signal controls. Does not include SCADA systems (use W2 for SCADA). | Cost must be provided. |
| W4 | Emergency Power | Standby power generators including on-site and movable units with associated fuel tanks. | Kilowatts or horsepower must be provided. |
| W5 | Security | Project necessary to improve or maintain security of system. Must be used in conjunction with another type of need code. | Refer to parameter for accompanying code. |
| W6 | Other | Includes needs for which none of the other type of need codes applies. Examples include fencing or runoff diversion structures. Please include an explanation. | Cost must be provided. |

