

Mercury Capture in a Circulating Fluidized Bed Dry Scrubber at AES Greenidge Unit 4

Daniel P. Connell and James E. Locke, *CONSOL Energy Inc. Research & Development, South Park, PA*
Douglas J. Roll, *AES Greenidge LLC, Dresden, NY*

Project Background

- Part of U.S. Department of Energy's Power Plant Improvement Initiative
- Participants
 - CONSOL Energy Inc. (administration, testing, reporting)
 - AES Greenidge LLC (host site, operations)
 - Babcock Power Environmental Inc. (EPC contractor)
- Funding
 - U.S. Department of Energy, National Energy Technology Laboratory (43.8%)
 - AES Greenidge LLC (56.2%)
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x, SO_x, mercury, acid gases (SO₂, HCl, HF), and particulate matter from smaller coal-fired EGUs

Motivation

- There are ~ 440 existing coal-fired units in the United States that are not equipped with FGD, SCR, or Hg control systems
 - Represent ~ 60 GW installed capacity
 - Greater than 80% are located east of the Mississippi River
 - Most have not announced plans to retrofit
- It is difficult to retrofit these smaller units for deep emission reductions
 - Large capital costs
 - Space limitations
- These units are increasingly vulnerable to retirement or fuel switching because of progressively more stringent environmental regulations
 - CAIR, CAMR, CAVR, state regulations
- Hence, there is a need to commercialize technologies designed to meet the environmental compliance requirements of these units
- The Greenidge Project seeks to demonstrate an innovative combination of technologies that are designed to satisfy this need by affording deep emission reduction capabilities, low capital costs (~\$340/kW), small space requirements (~0.5 acre*), applicability to high-sulfur coals (2-4%*), low maintenance requirements, and operational flexibility

Host Site AES Greenidge Unit 4 (Boiler 6)


- Dresden, NY
- Commissioned in 1953
- 107 MW_e (net) reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern U.S. bituminous coal
 - Biomass (waste wood) – up to 10% of total heat input
- Existing emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD - mid-sulfur coal to meet permit limit of 3.8 lb SO₂/mmBtu

Technology

- Combustion Modifications (low-NO_x burners, overfire air)
- Hybrid Selective Non-Catalytic Reduction / Selective Catalytic Reduction (SNCR/SCR) System
 - SNCR includes 3 zones of urea injection; it is designed to reduce NO_x by ~42% and provide NH₃ for the downstream SCR reactor
 - SCR is an in-duct design with a single layer of catalyst (1.3 m deep); it is fed entirely by NH₃ slip from the SNCR and designed for ~30% NO_x removal efficiency
- Powdered Activated Carbon Injection System
 - Projected injection rate for 90% Hg capture: 0 – 3.5 lb/mmBtu
- Turbosorp® Circulating Fluidized Bed Dry Scrubber
 - Water and dry hydrated lime injected separately; operating temperature ~ 160 °F, nominal Ca/S ~ 1.6 mol/mol for 2.5% sulfur coal; designed to accommodate coals containing up to 4.0% sulfur
 - Lime hydration system installed as part of project for onsite production of Ca(OH)₂ from pebble lime
- Baghouse
 - 8-compartment pulse jet fabric filter; nominal air-to-cloth ratio = 3 (ft³/min)/ft²
 - ~95% of baghouse solids are recycled to Turbosorp® scrubber using air slides
 - Booster fan installed downstream of baghouse to overcome pressure drop



Design Features Contributing to Mercury Control



Guarantee Testing Results

March – May 2007, 2.4-3.2% Sulfur Eastern U.S. Bituminous Coal

Parameter	Performance Target	Measured Performance
NO _x emission rate	≤ 0.10 lb/mmBtu	0.10 lb/mmBtu*
SO ₂ removal	≥ 95%	96%
SO ₃ removal	≥ 95%	97%
HCl removal	≥ 95%	97%
HF removal	≥ 95%	Indeterminate*


*Although the target of 0.10 lb/mmBtu was demonstrated in short-term testing, the plant routinely has had to operate at < 0.13 lb/mmBtu to maintain acceptable particulate characteristics. Lower temperatures, and alternate slip "Concentrations at both the inlet and outlet of the Turbosorp® scrubber were less than the detection level"

Mercury Testing Methodology


- All sampling and analysis performed by CONSOL Energy Research & Development
- All flue gas Hg measurements conducted using the Ontario Hydro Method (ASTM D 6784-02)
 - Liquid samples analyzed by cold vapor atomic absorption spectroscopy (March 2007) or cold vapor atomic fluorescence spectroscopy (October 2007)
 - Particulate samples analyzed in accordance with ASTM D 6414 or ASTM D 6722
- Coal samples (composite of all feeders) collected at the beginning and middle of each test and analyzed for Hg by ASTM D 6722
- Solid and liquid process samples (e.g., ash, lime, urea, water) and plant operating data also collected during each test to assess process performance
- QA/QC
 - Pre- and post-test leak checks performed for each test
 - O₂ concentration monitored continuously at meter exhaust
 - Blank sampling trains analyzed to check for contamination
 - Laboratory procedures included use of independent calibration verification standards, duplicate or triplicate analyses, matrix spikes, digestion duplicates, and digestion spikes, with a 10% relative percent difference criterion for duplicates/triplicates and a 100±10% recovery criterion for standards and spikes
 - Material balances performed for each of the March tests to ensure that the total mercury output from the process agreed reasonably well with the total mercury input to the process (material balances for the October tests have not yet been completed)

Mercury Testing Results To-Date

Results of March and May 2007 Test Series



Comparison with Baseline Tests (November 2004)



Process Economics

	Constant 2005 Dollars		
	Capital Cost	Fixed & Variable O&M Cost (\$/MWh)	Total Levelized Cost (\$/ton removed)
NO _x Control	106	1.19	\$3,290 / ton NO _x
SO ₂ Control	229	5.23	\$513 / ton SO ₂
Hg Control (Incremental)*	0	0	0

Assumptions: Plant size = 107 MW_e, Capacity factor = 80%, Coal sulfur = 4.0 lb SO₂/mmBtu, Steamline NO_x emission rate = 0.30 lb/mmBtu, SNCR nominal stoichiometric ratio = 1.5, Ca/S = 1.6, Quinoline = 5.1 lb/ton, Urea (50% urea) = 5.1 lb/ton, Waste disposal = \$10/ton, Plant life = 20 years, Fixed charge factor = 13.0%. Other assumptions based on common estimating practices and current market prices. *Based on performance testing results to date.

Conclusions

- The multi-pollutant control system being demonstrated at AES Greenidge Unit 4 is uniquely designed to meet the needs of smaller coal-fired units
 - Has demonstrated deep reductions in SO₂ emissions (> 95%) and NO_x emissions (> 60%) while requiring a capital investment of only \$340/kW and a footprint of < 0.5 acre for a 107 MW unit
 - Deep SO₂ and HCl removal and reduced PM emissions are zero cost co-benefits
- Testing results thus far have shown the system to be very effective in achieving deep Hg removal efficiency
 - Greater than 90% Hg removal efficiency (coal-to-stack) observed in all 15 tests conducted to-date
 - Average demonstrated removal efficiency (96%) represents 94% reduction over baseline
- Based on results to-date, projected incremental cost to achieve 90% Hg capture is \$0
 - Ten tests have shown >90% Hg capture in the circulating fluidized bed dry scrubber and baghouse without any activated carbon injection

Future Plans

- Testing and evaluation will continue at AES Greenidge Unit 4 through October 2008
- Additional Hg tests will focus on:
 - Hg removal at reduced boiler loads
 - Hg removal with biomass co-firing
 - Role of the in-duct SCR in oxidizing Hg
 - Hg removal as a function of fly ash unburned carbon content, fuel, and scrubber operating conditions
 - Stability of the captured Hg in the scrubber solids / ash