

Bay Area Air Quality Management District
Risk Screening Assessment, A# 7310
Daly City Fire Department, P# 13328
April 24, 2003

This document describes the basis for the health risk screening assessment prepared for Daly City Fire Department, 18 Bepler Street, Daly City, California. This facility wishes to operate a new emergency standby generator diesel engine. In order to do this, the facility must get a permit from the Bay Area Air Quality Management District (BAAQMD). The BAAQMD, as a routine part of the evaluation of a permit application, prepared this screening risk assessment.

Particulates from diesel engine exhaust, a toxic air contaminant and a carcinogen, will be emitted during the operation of the engine. BAAQMD staff evaluates the possible impact of the diesel exhaust particulate emissions that will occur during routine operation of the diesel engine. The diesel exhaust particulate impact is expressed in terms of the increased risk of contracting cancer by individuals who live or work near the proposed engine.

The estimated increase in diesel exhaust particulate emission that can be expected from this source are 4.22 pounds per year for 170 hours per year of operation. Ambient air concentrations of diesel exhaust particulate were predicted using the ISCST3 air dispersion computer model. This model uses information about the facility and the emission rates of toxic air contaminants to estimate what concentrations would be expected in the air at various locations around the site. The estimated concentrations of diesel exhaust particulate are used to calculate the possible cancer risk that might be expected to arise from this exposure.

The potential cancer risk was calculated using standard risk assessment methodology. For residents, they include the assumptions that exposures are continuous for 24 hours per day, 7 days per week for 70-years. For students the assumptions include higher breathing rates for children and that exposures are for 36 weeks per year over a 9-year period. The cancer risk is based on the "best estimates" of plausible cancer potencies as determined by the California Office of Environmental Health Hazard Assessment (OEHHA). The actual cancer risk, which cannot be determined, may approach zero. This type of analysis is considered to be health-protective.

The potential for noncancer health effects is evaluated by comparing the long-term exposure level to a Reference Exposure Level (REL). A REL is a concentration level or dose at or below which no adverse health effects are anticipated. RELs are designed to protect the most sensitive individuals in the population. Comparisons to RELs are made by determining the hazard index, which is the ratio of the estimated exposure level to the REL.

The proposed operation would result in an increased maximum cancer risk of 10 chances in a million and a hazard index of 0.007 for residences near the facility. For the students who attend Our Lady of Perpetual Help and Woodrow Wilson Elementary Schools, the increased maximum cancer risk is 0.062 and 0.0085 chances in a million respectively. The hazard index is 0.00026 and 0.00017 respectively. These health risk values, presented in the table below, meet the criteria for acceptable levels established in the BAAQMD's Risk Management Policy.

Health Risk Results		
Receptor	Increased Maximum Cancer Risk	Hazard Index
Residential	10 chances in a million	0.007
Lady of Perpetual Help Elementary School	0.062 chances in a million	0.002
Woodrow Wilson Elementary	0.0085 chances in a million	0.00017

School address:

Our Lady of Perpetual Help
80 Wellington Avenue
Daly city, CA 94014

Woodrow Wilson Elementary School
43 Miriam Street
Daly City, CA 94014