

Bay Area Air Quality Management District
Risk Screening Assessment, A# 7370
Webcor Builders; P# 15353
May 19, 2003

This document describes the basis for the health risk screening assessment prepared for Webcor Builders, 20488 Stevens Creek Blvd., Cupertino, California 95014. This facility wishes to operate a new emergency standby generator diesel engine. In order to do this, the facility must get a permit from the Bay Area Air Quality Management District (BAAQMD). The BAAQMD, as a routine part of the evaluation of a permit application, prepared this screening risk assessment.

Particulates from diesel engine exhaust, a toxic air contaminant and a carcinogen, will be emitted during the operation of the engine. BAAQMD staff evaluates the possible impact of the diesel exhaust particulate emissions that will occur during routine operation of the diesel engine. The diesel exhaust particulate impact is expressed in terms of the increased risk of contracting cancer by individuals who live or work near the proposed engine.

The estimated increases in diesel exhaust particulate emissions that can be expected from this source are 13.641 pounds per year. Ambient air concentrations of diesel exhaust particulate were predicted using the ISCST3 air dispersion computer model. This model uses information about the facility and the emission rates of toxic air contaminants to estimate what concentrations would be expected in the air at various locations around the site. The estimated concentrations of diesel exhaust particulate are used to calculate the possible cancer risk that might be expected to arise from this exposure.

The potential cancer risk was calculated using standard risk assessment methodology. They include the assumptions that exposures are continuous for 24 hours per day, 7 days per week for 70-years. The cancer risk is based on the "best estimates" of plausible cancer potencies as determined by the California Office of Environmental Health Hazard Assessment (OEHHA). The actual cancer risk, which cannot be determined, may approach zero. This type of analysis is considered to be health-protective.

The potential for noncancer health effects is evaluated by comparing the long-term exposure level to a Reference Exposure Level (REL). A REL is a concentration level or dose at or below which no adverse health effects are anticipated. RELs are designed to protect the most sensitive individuals in the population. Comparisons to RELs are made by determining the hazard index, which is the ratio of the estimated exposure level to the REL.

The proposed operation would result in an increased maximum cancer risk of 6.9 chances in a million and a hazard index of 0.046 for residences near the facility. For the students who attend St. Joseph of Cupertino Elementary School, the increased maximum cancer risk is 0.16 chances in a million and the hazard index is 0.0058. These health risk values, presented in the table below, meet the criteria for acceptable levels established in the BAAQMD's Risk Management Policy.

Health Risk Results		
Receptor	Increased Maximum Cancer Risk	Hazard Index
Residential	6.90 chances in a million	0.0066
St. Joseph of Cupertino Elementary School	0.16 chances in a million	0.0058

School address: ST. Joseph of Cupertino Elementary School
10120 North Deanza Blvd.
Cupertino, Ca. 95014