ATMOSPHERIC CORROSION CONTROL INSPECTION

FORM 13

COMPANY: _____

Location: _____

Inspector: _____ **Date:** _____

This form is to be completed when above ground piping is inspected for corrosion from atmospheric conditions or corrosive conditions that cannot be controlled by cathodic protection. Inspect all exposed piping every three years for atmospheric corrosion per §§192.479, 192.481 and 192.491.

Designation of Line: **Transmission ( )** **Distribution ( )** **Service ( )**

Line Size: _____

Area of Corrosion: **Pipe ( )** **Meter Set ( )** **Fitting ( )**
Regulator ( ) **Support ( )** **Vent ( )**
Other (describe): _____

Corrective Measures Taken: **Painted:** _____ **Coated:** _____
Other (describe): _____

Type of Paint or Coating Used: _____

If General Painting of Exposed Piping is Undertaken, List Addresses Below:

_____ _____
_____ _____
_____ _____
_____ _____
_____ _____
_____ _____
_____ _____
_____ _____
_____ _____
_____ _____
_____ _____
_____ _____
_____ _____