

From: Whitcomb, Wayne [mailto:wayne.whitcomb@boeing.com]
Sent: Friday, February 15, 2008 2:34 PM
To: Duff, Rebecca M.
Subject: RE: ENERGY STAR Draft 1 Server Specification

Rebecca,

Thank you for providing an opportunity to review and comment on this document. I like the idea of basing all testing for efficiency and energy use on a single voltage, but would suggest that 208 vac would be a better value than the proposed 230 vac. As this document is intended to represent servers that are operated in typical data centers (primarily in the USA), the most common voltage delivered to the equipment comes from 3-phase systems at 120/208 vac. Although any consistent voltage level would suffice for comparison among various pieces of equipment, 208 vac would more closely represent real world conditions. Thank you for considering this issue.

Wayne Whitcomb, PE
Principal Electrical Engineer, Kent Data Center
tel (253)773-6759 cel (253)740-9809