



FACSIMILE COVER SHEET

FAX # 954-345-5329

If there is a problem  
call 954-825-0612

DATE: 7/1/03

Total Number Pages 4

TO: Jack Foster (301) 415-3647

Fax#: 301-415-3131

FROM: Judith Dorfman

Message

Per your request following  
are the letters dated  
February 24, 2003.

10 CER PART 21

Sincerely

Initial Notifications

regarding:

- Type TD-5 Relays

- Type KLF/KLF-Relays

- Type COV-8/COV-9 RELAYS

Received By Jack Foster @ 7/01/03 1:10pm.

ABB Inc.

JKF19  
Add: Jack Foster  
e-riids



February 24, 2003

NRC Operations Center  
Fax 301-816-5151

Subject: Initial Notification of Potential Defect per 10CFR Part 21  
Type TD-5 Relay

Provided By: ABB Inc.  
Automation Technologies Products Division  
4300 Coral Ridge Drive  
Coral Springs, FL 33065

This letter is the initial notification of a deviation concerning our Class 1E relay type TD-5. The deviation concerns the difference between the original zero period acceleration value and the recent zero period acceleration value as reported to us by an independent dedicating entity.

Details will be provided in our written notification forthcoming within the next thirty days.

  
\_\_\_\_\_  
Russ W. Gonnam  
Quality Manager


  
\_\_\_\_\_  
Marilinda Ruiz  
Site Manager

ABB Inc.



February 24, 2003

NRC Operations Center  
Fax 301-816-5151

Subject: Initial Notification of Potential Defect per 10CFR Part 21  
Type KLF / KLF-1 Relay

Provided By: ABB Inc.  
Automation Technologies Products Division  
4300 Coral Ridge Drive  
Coral Springs, FL 33065

This letter is the initial notification of a deviation concerning our Class 1E relay type KLF / KLF-1. The deviation concerns a mechanical failure that occurred during re-qualification testing provided to us by an independent dedicating entity.

Details will be provided in our written notification forthcoming within the next thirty days.

  
\_\_\_\_\_  
Russ W. Gonnam  
Quality Manager


  
\_\_\_\_\_  
Marilinda Ruiz  
Site Manager

ABB Inc.



February 24, 2003

NRC Operations Center  
Fax 301-816-5151

Subject: Initial Notification of Potential Defect per 10CFR Part 21  
Type COV-8 / COV-9 Relay

Provided By: ABB Inc.  
Automation Technology Products Division  
4300 Coral Ridge Drive  
Coral Springs, FL 33065

This letter is the initial notification of a deviation concerning our Class 1E relay type COV-8 / COV-9. The deviation concerns a mechanical failure that occurred during re-qualification testing provided to us by an independent dedicating entity.

Details will be provided in our written notification forthcoming within the next thirty days.

  
Russ W. Gonnam  
Quality Manager


  
Marilinda Ruiz  
Site Manager

ABB Inc.