

DEPARTMENT OF HEALTH

News Release

LINDA LINGLE GOVERNOR

> CHIYOME LEINAALA FUKINO, M.D., DIRECTOR Phone: (808) 586-4410 Fax: (808)- 586-4444

For Immediate Release: October 24, 2006

06-67

DOH CITES KAILUA WASTEWATER TREATMENT PLANT FOR AIR POLLUTION VIOLATIONS

HONOLULU - The Hawaii State Department of Health Clean Air Branch has issued a Notice of Violation against the City and County of Honolulu, Kailua Wastewater Treatment Plant (Kailua WWTP) located at 95 Kaneohe Bay Drive.

The Notice of Violation was issued for exceeding the hydrogen sulfide (H_2S) emissions concentration permit limit of 0.25 parts per million at the odor control systems intermittently from January 31 through July 4, 2006; for exceeding the H_2S emissions permit limit of 0.025 parts per million at the fence line intermittently from February 3 through June 24, 2006; for simultaneously taking both the primary and headworks odor control systems out of service on June 6, 2006; and for failing to conduct the daily checks of scrubber solution pH and reduction and oxidation capacity on May 12, 2006. The City reported these exceedances and failures to DOH as required by its permit.

The Kailua WWTP provides primary and secondary treatment of municipal wastewater. The plant has an extensive odor control system that includes covering and ventilating all major treatment units where odors are captured and treated. One of the main air pollutants emitted from the plant is H_2S , a gaseous compound formed by the decomposition of organic matter which has an odor of rotten eggs.

A penalty of \$177,600 has been assessed by the DOH. The City has twenty days to contest the Notice of Violation, and if it does so, the case will be scheduled for a hearing.

For information contact: Jill Stensrud Clean Air Branch Phone: (808) 586-4200 ###