

**TABLE 5**  
**(OAR 333-535-0300)**

**STATION OUTLETS FOR OXYGEN, VACUUM (SUCTION) AND MEDICAL AIR SYSTEMS**

(NUMBER OF OUTLETS ACCESSIBLE TO EACH BED, UNLESS OTHERWISE NOTED.)

<b>LOCATION</b>	<b>OXYGEN</b>	<b>VACUUM</b>	<b>AIR</b>
Patient Rooms (Medical and Surgical)	<u>1</u>	<u>1</u>	---
Examination/Treatment (Inpatient Medical, Surgical, and Ante-partum Postpartum Care)	<u>1</u>	<u>1</u>	---
All Critical Care (General)	<u>2</u>	<u>3</u>	<u>1</u>
Newborn Intensive Care	<u>2</u>	<u>2</u>	<u>2</u>
Newborn Nursery (Full Term)	1/8 cribs	1/8 cribs	1/8 cribs
Pediatric and Adolescent Patient Rooms	<u>1</u>	<u>1</u>	<u>1</u>
Psychiatric Patient Rooms	—	—	—
General Operating Room, Trauma Rooms used for Surgery	2	4	<u>2</u>
Special Procedures	1	3	<u>2</u>
Surgical Cysto. and Endo.	1	3	<u>0</u>
Cardio, Ortho, Neurological	2	3	—
Post-Anesthetic Care Unit	1	3	1
General and Outpatient Recovery	1	3	1
Stage II (Step Down) Recovery	1	1	—
Caesarean/Delivery Room	2	4	2
Labor Room	1	1	1
Labor/Delivery/Recovery (LDR/LDRP)	2	3	0
First Aid and Emergency Treatment	1	1	1
Orthopedic and Cast Room	1	1	1
Cardiac Catheterization Lab	1	2	2
Autopsy Room	—	1 per <u>work station</u>	1 per

NOTE:

1/ Vacuum outlets required are in addition to any that might be used as part of a scavenging system for removal of anesthetizing gases (also see NFPA 99).

2/ Free standing hospital outpatient facilities, except ambulatory surgical care facilities, are exempt from these requirements.

3/ If separate areas are provided for the mother and baby, provide 1 oxygen and 2 vacuum for mother and 1 oxygen and 1 vacuum for baby.