

The Greenidge Multi-Pollutant Control Project: Key Technical and Economic Features of a New Approach for Reducing Emissions from Smaller Coal-Fired Units

Daniel P. Connell

CONSOL Energy Inc. Research & Development

Douglas J. Roll, P.E., and William B. Rady

AES Greenidge LLC

Richard F. Abrams

Babcock Power Environmental Inc.

Wolfe P. Huber, P.E.


U.S. Department of Energy, National Energy Technology Laboratory

Greenidge Multi-Pollutant Control Project

- Part of U.S. DOE's Power Plant Improvement Initiative
- Participants
 - CONSOL Energy Inc. (administration, testing, reporting)
 - AES Greenidge LLC (host site, operations)
 - Babcock Power Environmental Inc. (EPC contractor)
- Funding
 - U.S. Department of Energy, National Energy Technology Laboratory
 - AES Greenidge LLC
- Goal: Demonstrate a multi-pollutant control system that can cost-effectively reduce emissions of NO_x, SO₂, mercury, acid gases (SO₃, HCl, HF), and particulate matter from smaller coal-fired power plants

Existing U.S. Coal-Fired EGUs

50-300 MW_e



Existing U.S. Coal-Fired EGUs

50-300 MW_e

- ~ 440 units not equipped with FGD, SCR, or Hg control
 - Represent ~ 60 GW of installed capacity
 - Greater than 80% are located east of the Mississippi River
 - Most have not announced plans to retrofit
- Increasingly vulnerable to retirement or fuel switching because of progressively more stringent environmental regulations
 - CAIR, CAMR, CAVR, state regulations
- Difficult to retrofit for deep emission reductions
 - Large capital costs
 - Space limitations
- Need to commercialize technologies designed to meet the environmental compliance requirements of these units

AES Greenidge Unit 4 (Boiler 6)


- Dresden, NY
- Commissioned in 1953
- 107 MW_e reheat unit
- Boiler:
 - Combustion Engineering tangentially-fired, balanced draft
 - 780,000 lb/h steam flow at 1465 psig and 1005 °F
- Fuel:
 - Eastern U.S. bituminous coal
 - Biomass (waste wood) – up to 10% heat input
- Existing emission controls:
 - Overfire air (natural gas reburn not in use)
 - ESP
 - No FGD - mid-sulfur coal to meet permit limit of 3.8 lb SO₂/MMBtu



Design Objectives

- Deep emission reductions
- Low capital costs
- Small space requirements
- Applicability to high-sulfur coals
- Low maintenance requirements
- Operational flexibility

Multi-Pollutant Control Process



Performance Targets

Fuel: 2-4% sulfur bituminous coal, up to 10% biomass

Parameter	Goal
NO _x	≤ 0.10 lb/mmBtu (full load)
SO ₂	≥ 95% removal
Hg	≥ 90% removal
SO ₃ , HCl, HF	≥ 95% removal

Hybrid NO_x Control

■ Combustion Modifications

- Replace coal, combustion air, and overfire air nozzles
- Improve fuel/air mixing, burner exit velocity, secondary airflow control, and upper furnace mixing; reduce CO
- Reduce NO_x to 0.25 lb/MMBtu


■ SNCR

- Three zones of urea injection
- Reduce NO_x by ~ 42.5% (to 0.144 lb/MMBtu)

■ SCR


- Single-bed, in-duct design
- Fed by ammonia slip from SNCR
- Reduce NO_x by > 30% (to ≤ 0.10 lb/MMBtu)

SNCR for Hybrid System



- SNCR operates at lower temperature than stand-alone SNCR
 - Enables greater NO_x reduction and better urea utilization by SNCR
 - Provides ammonia slip for additional NO_x reduction by SCR


Single-Bed, In-Duct SCR



Same as Conventional SCR, EXCEPT:

- Compact design
 - Bed depth ~ 1.3 m
 - Cross section ~ 45' x 14'
- No ammonia injection grid
- Designed for lower NO_x removal efficiency


Turbosorp[®] Circulating Fluidized Bed Dry Scrubber



Different From a Spray Dryer:

- Completely dry (no slurries)
- Separate control of reagent, water, and recycled solid injection
- Applicable to high-sulfur coals
- High solids recirculation
- 15-25% lower reagent consumption

Turbosorp[®] System



Advantages Over Wet FGD

- Requires less space
- Carbon steel construction
- Uses existing stack
- Better SO₃ removal
- Less maintenance requirements
 - Fewer moving parts
 - No slurries
 - No dewatering

~0.4 acre


12/08/2006

Mercury Control

- System design favors high baseline Hg removal without activated carbon injection
 - Hg oxidation across in-duct SCR catalyst
 - Low temperature (~170 °F) in scrubber / baghouse
 - High residence time for fly ash and $\text{Ca}(\text{OH})_2$ in scrubber / baghouse
 - Similar to SCR / SDA / FF with bituminous coal
 - Field sampling shows 90% Hg removal often achieved with no ACI
- To ensure $\geq 90\%$ Hg removal, demonstration at AES Greenidge includes an activated carbon injection system
 - Turbosorp[®] system expected to enable better carbon utilization than simple duct injection
 - Projected activated carbon requirement: 0.0 – 3.5 lb/MMacf

Turndown Capabilities

NOx Control




SO₂, Acid Gas, and Hg Control

- Flue gas recycle enables continued operation to 42 MW_g (minimum load)

Economics

AES Greenidge Unit 4 – Design Case



SCR + Wet FGD modeled using Integrated Environmental Control Model with technical assumptions from Greenidge design basis; both systems modeled using common set of economic assumptions

Economics

AES Greenidge Unit 4 – Design Case

- Advantages of Greenidge multi-pollutant control system over SCR / wet FGD for an ~110 MW unit
 - ~25% lower levelized annual costs
 - ~40% lower capital costs
 - Significantly lower fixed O&M costs
 - Includes new baghouse for improved PM control
 - Better SO₃ (and possibly Hg) removal performance
- Drawbacks of Greenidge multi-pollutant control system relative to SCR / wet FGD
 - Slightly lower NO_x and SO₂ removal efficiency
 - Variable O&M costs are nearly 2 times as great

Trade-off is consistent with the needs of many smaller units

Initial Performance Testing Results

Fuel: 2.5-3.0% sulfur eastern U.S. bituminous coal

Parameter	Target	Measured
NO _x emissions	≤ 0.10 lb/mmBtu	0.10 lb/mmBtu (Stack CEM, 3/28/07)
SO ₂ removal	≥ 95%	96% (Stack CEM, 3/29/07)
Hg removal Without ACI With ACI	≥ 90%	≥ 95% (Ontario Hydro, 3/28/07) ≥ 94% (Ontario Hydro, 3/30/07)
SO ₃ removal	≥ 95%	97% (Controlled Condensation, 5/2/07)
HCl removal	≥ 95%	97% (EPA Method 26, 5/4/07)

Operating Experience

- Emissions reduction performance has been encouraging
 - Currently evaluating reagent utilization, effects of fuel and unit operating conditions
- Accumulation of large particle ash on surface of in-duct SCR hampered operation for first few months
 - Screen has since been installed to alleviate problem
- Ammonia slip
 - Target was 2 ppmvd @ 3% O₂
 - Measured values have been 2-5 ppmvd @ 3% O₂
 - Effects on performance will be evaluated

Conclusions

Key Technical & Economic Features of the Greenidge Multi-Pollutant Control System

- Deep emission reductions
 - NO_x to ≤ 0.10 lb/MMBtu
 - SO_2 and acid gases by $\geq 95\%$
 - Hg by $\geq 90\%$
 - Initial performance tests indicate these are achievable
- Low capital costs
 - TPC is $\sim \$340/\text{kW}$ for a 110 MW unit, or $\sim 40\%$ less than cost of SCR + wet FGD
- Small space requirements
 - < 0.5 acre for a 110 MW unit

Conclusions

Key Technical & Economic Features of the Greenidge Multi-Pollutant Control System

- **Applicability to high-sulfur coals**
 - Separate injection of water and lime
 - Greenidge system being demonstrated with 2-4% S coal
- **Low maintenance requirements**
 - Does not require slurry handling or dewatering
 - Costs projected to be substantially less than for SCR + wet FGD
- **Operational flexibility**
 - Hybrid NO_x control system has load-following capability
 - Flue gas recycle enables turndown of Turbosorp[®] system to minimum stable generator load
 - Can accommodate wide range of fuels and SO₂ removal efficiencies

Disclaimer

This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.