

Bay Area Air Quality Management District
Risk Screening Assessment
Application# 5991; Site# 13471
Pacific Bell Corporation
December 11, 2002

This document describes the basis for the health risk screening assessment prepared for Pacific Bell Corporation, 525 Kelly Avenue, Half Moon Bay, California 94019. This facility wishes to operate a new emergency standby generator diesel engine. In order to do this, the facility must get a permit from the Bay Area Air Quality Management District (BAAQMD). The BAAQMD, as a routine part of the evaluation of a permit application, prepared this screening risk assessment.

Particulates from diesel engine exhaust, a toxic air contaminant and a carcinogen, will be emitted during the operation of the engine. BAAQMD staff evaluates the possible impact of the diesel exhaust particulate emissions that will occur during routine operation of the diesel engine. The diesel exhaust particulate impact is expressed in terms of the increased risk of contracting cancer by individuals who live or work near the proposed engine.

The estimated increase in diesel exhaust particulate emissions that can be expected from this source are 27.6 pounds per year. Ambient air concentrations of diesel exhaust particulate were predicted using the ISCST3 air dispersion computer model. This model uses information about the facility and the emission rates of toxic air contaminants to estimate what concentrations would be expected in the air at various locations around the site. The estimated concentrations of diesel exhaust particulate are used to calculate the possible cancer risk that might be expected to arise from this exposure.

The potential cancer risk was calculated using standard risk assessment methodology. They include the assumptions that exposures are continuous for 24 hours per day, 7 days per week for 70-years. The cancer risk is based on the "best estimates" of plausible cancer potencies as determined by the California Office of Environmental Health Hazard Assessment (OEHHA). The actual cancer risk, which cannot be determined, may approach zero. This type of analysis is considered to be health-protective.

The potential for noncancer health effects is evaluated by comparing the long-term exposure level to a Reference Exposure Level (REL). A REL is a concentration level or dose at or below which no adverse health effects are anticipated. RELs are designed to protect the most sensitive individuals in the population. Comparisons to RELs are made by determining the hazard index, which is the ratio of the estimated exposure level to the REL.

The proposed operation would result in an increased maximum cancer risk of 6 chances in a million for residences near the facility. The risks for the students who attend schools in the vicinity of the source are tabulated below. These health risk values, presented in the table below, meet the criteria for acceptable levels established in the BAAQMD's Risk Management Policy.

Health Risk Results		
Receptor	Increased Maximum Cancer Risk	Hazard Index
Residential	6 chances in a million	0.004
Industrial and Commercial Receptors	3.9 chances in a million	0.0026
Alvin S. Hatch Elementary School	0.2 in a million	0.00014
Pilarcito High School	0.72 in a million	0.000482
Kings Mountain Primary School	0.72 in a million	0.000482
Manual F. Cunha Intermediate School	0.72 in a million	0.000482

School Addresses:

Alvin S. Hatch Elementary School
 490 Miramonte Avenue
 Half Moon Bay, Ca. 94019

Pilarcito High School
 498 Kelley Avenue
 Half Moon Bay, CA 94019-1636

Kings Mountain Primary School
 498 Kelley Avenue
 Half Moon Bay, CA 94019-1636

Manual F. Cunha Intermediate School
 498 Kelley Avenue
 Half Moon Bay, CA 94019-1636