


Browns Ferry 2

2Q/2005 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Unplanned scrams	0	0	0	0	2.0	0	0	0
Critical hours	2208.0	1962.0	2184.0	2183.0	2143.7	2209.0	1905.0	1812.5
Indicator value	0.9	0.9	0	0	1.7	1.6	1.7	1.7

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Scrams	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs



Thresholds: White > 6.0

Notes


Unplanned Power Changes per 7000 Critical Hrs	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Unplanned power changes	2.0	0	0	0	0	1.0	0	1.0
Critical hours	2208.0	1962.0	2184.0	2183.0	2143.7	2209.0	1905.0	1812.5
Indicator value	4.3	2.6	1.6	1.6	0	0.8	0.8	1.7

Licensee Comments: none

Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2184.00	2184.00	2208.00	2208.00	2160.00	2184.00
Train 6								
Planned unavailable hours	6.30	2.09	58.30	0.76	2.68	1.55	1.21	8.89
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2184.00	2184.00	2208.00	2208.00	2160.00	2184.00
Train 7								
Planned unavailable hours	4.44	2.02	1.85	2.32	3.59	10.61	1.30	8.14
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2184.00	2184.00	2208.00	2208.00	2160.00	2184.00
Train 8								
Planned unavailable hours	3.86	1.29	1.18	1.39	1.05	2.33	5.73	1.28
Unplanned unavailable hours	0	0	89.95	0	0	0	0	0
Fault exposure hours	0	0	378.67	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	2209.00	2184.00	2184.00	2208.00	2208.00	2160.00	2184.00
Indicator value	0.8%	0.9%	1.1%	1.1%	1.1%	1.1%	1.1%	0.9%

Licensee Comments: none

Safety System Unavailability, High Pressure Injection System (HPCI)




Thresholds: White > 4.0% Yellow > 12.0% Red > 50.0%

Notes

Safety System Unavailability, High Pressure Injection System (HPCI)	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Train 1								
Planned unavailable hours	0	0	0	0	0	0	4.60	0
Unplanned unavailable hours	0	11.69	0	0	0	0	5.12	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	1942.05	2184.00	2184.00	2208.00	2208.00	1910.10	1803.75
Indicator value	1.4%	1.4%	1.1%	1.1%	1.1%	0.9%	1.0%	1.0%

Licensee Comments: none

Safety System Unavailability, Heat Removal System (RCIC)



Thresholds: White > 4.0% Yellow > 12.0% Red > 50.0%

Notes


Safety System Unavailability, Heat Removal System (RCIC)	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Train 1								
Planned unavailable hours	1.00	8.35	0	8.58	0.33	22.80	0.58	0.43
Unplanned unavailable hours	0	0	0	0	0	0	0	0
Fault exposure hours	0	0	0	0	0	0	0	0
Effective Reset hours	0	0	0	0	0	0	0	0
Required hours	2208.00	1942.05	2184.00	2184.00	2208.00	2208.00	1910.10	1803.75
Indicator value	0.9%	1.0%	0.9%	0.8%	0.8%	0.9%	0.9%	0.9%

Licensee Comments: none

Required hours	2208.00	2209.00	2184.00	2183.00	2208.00	2209.00	1913.20	2014.60
Indicator value	0.5%	0.7%	0.8%	0.8%	0.8%	0.8%	0.9%	1.5%

Licensee Comments: none

Safety System Functional Failures (BWR)




Thresholds: White > 6.0

Notes

Safety System Functional Failures (BWR)	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Safety System Functional Failures	0	0	0	0	0	0	1	1
Indicator value	1	1	1	0	0	0	1	2

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	7/03	8/03	9/03	10/03	11/03	12/03	1/04	2/04	3/04	4/04	5/04	6/04
Maximum activity	0.000107	0.000109	0.000098	0.000119	0.000134	0.000184	0.000092	0.000200	0.000092	0.000114	0.000087	0.000114
Technical specification limit	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	7/04	8/04	9/04	10/04	11/04	12/04	1/05	2/05	3/05	4/05	5/05	6/05
Maximum activity	0.000128	0.000081	0.000110	0.000095	0.000102	0.000037	0.000046	0.000040	0.000036	0.000033	0.000046	0.000038
Technical specification limit	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2	3.2
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	7/03	8/03	9/03	10/03	11/03	12/03	1/04	2/04	3/04	4/04	5/04	6/04
Maximum leakage	3.380	3.320	3.360	3.340	1.780	1.750	1.710	1.720	1.810	2.040	1.880	1.800
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	11.3	11.1	11.2	11.1	5.9	5.8	5.7	5.7	6.0	6.8	6.3	6.0
Reactor Coolant System Leakage	7/04	8/04	9/04	10/04	11/04	12/04	1/05	2/05	3/05	4/05	5/05	6/05
Maximum leakage	1.860	1.870	1.910	1.870	1.820	1.700	1.830	1.730	1.880	2.160	2.060	2.020
Technical specification limit	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Indicator value	6.2	6.2	6.4	6.2	6.1	5.7	6.1	5.8	6.3	7.2	6.9	6.7

Licensee Comments: none

Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

Notes

Drill/Exercise Performance	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Successful opportunities	19.0	51.0	6.0	6.0	7.0	67.0	0	16.0
Total opportunities	20.0	52.0	6.0	6.0	7.0	70.0	0	16.0
Indicator value	98.5%	98.3%	98.3%	98.3%	98.3%	97.3%	97.1%	97.2%

Licensee Comments: none

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Participating Key personnel	49.0	50.0	47.0	51.0	48.0	49.0	71.0	71.0
Total Key personnel	49.0	50.0	48.0	53.0	50.0	50.0	72.0	71.0
Indicator value	100.0%	100.0%	97.9%	96.2%	96.0%	98.0%	98.6%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
Successful siren-tests	594	1098	596	883	694	994	794	896
Total sirens-tests	600	1100	600	900	700	1000	800	900
Indicator value	98.9%	99.4%	99.5%	99.1%	99.1%	99.0%	99.0%	99.4%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
High radiation area occurrences	0	0	1	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	1	1	1	1	0	0

Licensee Comments: none

RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	3Q/03	4Q/03	1Q/04	2Q/04	3Q/04	4Q/04	1Q/05	2Q/05
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: August 3, 2005