


# Nine Mile Point 1

## 1Q/2008 Performance Indicators

Licensee's General Comments: none

### Unplanned Scrams per 7000 Critical Hrs




Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

### Notes

Unplanned Scrams per 7000 Critical Hrs	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
Unplanned scrams	0	0	0	0	0	0	0	0
Critical hours	2146.8	2208.0	2209.0	1801.6	1740.3	2208.0	2209.0	2183.0
Indicator value	0.8	0	0	0	0	0	0	0

Licensee Comments: none

# Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

## Notes

Unplanned Power Changes per 7000 Critical Hrs	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
Unplanned power changes	1.0	0	0	0	1.0	2.0	0	0
Critical hours	2146.8	2208.0	2209.0	1801.6	1740.3	2208.0	2209.0	2183.0
Indicator value	1.6	0.8	0.8	0.8	0.9	2.6	2.6	2.5

Licensee Comments: none

# Unplanned Scrams with Complications




Thresholds: White > 1.0

## Notes

Unplanned Scrams with Complications	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
Scrams with complications			0	0	0	0	0	0
Indicator value						0.0	0.0	0.0

Licensee Comments: none

# Safety System Functional Failures (BWR)




Thresholds: White > 6.0

## Notes

Safety System Functional Failures (BWR)	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
Safety System Functional Failures	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

# Mitigating Systems Performance Index, Emergency AC Power System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Emergency AC Power System	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
UAI (ΔCDF)	2.60E-07	2.20E-07	4.40E-08	4.40E-08	4.50E-08	4.50E-08	4.50E-08	3.70E-08
URI (ΔCDF)	-2.40E-06	-5.80E-07	-7.90E-08	-9.10E-08	-8.80E-08	-8.80E-08	-8.60E-08	-2.10E-07
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-2.14E-06	-3.60E-07	-3.50E-08	-4.70E-08	-4.30E-08	-4.30E-08	-4.10E-08	-1.73E-07

Licensee Comments: none

# Mitigating Systems Performance Index, High Pressure Injection System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, High Pressure Injection System	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
UAI ( $\Delta$ CDF)	-2.00E-08	-3.90E-08	-4.10E-08	-4.10E-08	-5.20E-08	-5.20E-08	-5.20E-08	-5.20E-08
URI ( $\Delta$ CDF)	6.30E-08	1.30E-07	6.60E-08	6.90E-08	-1.70E-08	-1.70E-08	-1.70E-08	-1.60E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	4.30E-08	9.10E-08	2.50E-08	2.80E-08	-6.90E-08	-6.90E-08	-6.90E-08	-6.80E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Heat Removal System




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Heat Removal System	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
UAI ( $\Delta$ CDF)	-5.20E-08	-4.10E-08	-2.50E-08	-2.40E-08	-2.40E-08	-3.70E-08	-3.00E-08	-2.50E-09
URI ( $\Delta$ CDF)	-1.50E-08	-2.10E-08	-1.20E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08	-1.30E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-6.70E-08	-6.20E-08	-3.70E-08	-3.70E-08	-3.70E-08	-5.00E-08	-4.30E-08	-1.55E-08

Licensee Comments: none

# Mitigating Systems Performance Index, Residual Heat Removal System



Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4


## Notes

Mitigating Systems Performance Index, Residual Heat Removal System	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
UAI ( $\Delta$ CDF)	-7.80E-08	-7.40E-08	-3.50E-08	-3.50E-08	-3.50E-08	-3.50E-08	-3.50E-08	-3.50E-08
URI ( $\Delta$ CDF)	-9.10E-09	-1.30E-08	-8.30E-09	-8.90E-09	-8.80E-09	-8.70E-09	-8.70E-09	-8.90E-09
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-8.71E-08	-8.70E-08	-4.33E-08	-4.39E-08	-4.38E-08	-4.37E-08	-4.37E-08	-4.39E-08

Licensee Comments: none



# Mitigating Systems Performance Index, Cooling Water Systems




Thresholds: White > 1.00E-6 Yellow > 1.00E-5 Red > 1.00E-4

## Notes

Mitigating Systems Performance Index, Cooling Water Systems	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
UAI ( $\Delta$ CDF)	-1.40E-07	-1.30E-07	-7.20E-08	6.30E-09	-5.80E-09	-6.30E-09	-6.30E-09	-2.00E-08
URI ( $\Delta$ CDF)	6.30E-08	6.90E-08	5.20E-08	4.80E-08	-3.70E-08	-3.70E-08	-3.70E-08	-3.70E-08
PLE	NO	NO	NO	NO	NO	NO	NO	NO
Indicator value	-7.70E-08	-6.10E-08	-2.00E-08	5.43E-08	-4.28E-08	-4.33E-08	-4.33E-08	-5.70E-08

Licensee Comments: none

# Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Activity	4/06	5/06	6/06	7/06	8/06	9/06	10/06	11/06	12/06	1/07	2/07	3/07
Maximum activity	0.000081	0.000076	0.000093	0.000067	0.000068	0.000071	0.000049	0.000065	0.000224	0.000117	0.000152	0.000080
Technical specification limit	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0
Reactor Coolant System Activity	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07	1/08	2/08	3/08
Maximum activity	0.000138	0.000069	0.000067	0.000053	0.000080	0.000147	0.000179	0.000156	0.000161	0.000172	0.000124	0.000177
Technical specification limit	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5	9.5
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

# Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

## Notes

Reactor Coolant System Leakage	4/06	5/06	6/06	7/06	8/06	9/06	10/06	11/06	12/06	1/07	2/07	3/07
Maximum leakage	5.250	5.900	7.500	5.100	4.850	4.900	4.950	5.000	4.900	4.800	4.800	5.000
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	21.0	23.6	30.0	20.4	19.4	19.6	19.8	20.0	19.6	19.2	19.2	20.0
Reactor Coolant System Leakage	4/07	5/07	6/07	7/07	8/07	9/07	10/07	11/07	12/07	1/08	2/08	3/08
Maximum leakage	5.200	5.200	4.850	4.750	4.800	5.100	4.750	4.800	5.000	4.700	4.700	4.700
Technical specification limit	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Indicator value	20.8	20.8	19.4	19.0	19.2	20.4	19.0	19.2	20.0	18.8	18.8	18.8

Licensee Comments: none

# Drill/Exercise Performance




Thresholds: White < 90.0% Yellow < 70.0%

## Notes

Drill/Exercise Performance	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
Successful opportunities	20.0	129.0	109.0	41.0	27.0	35.0	318.0	31.0
Total opportunities	20.0	138.0	113.0	43.0	30.0	39.0	318.0	34.0
Indicator value	97.9%	94.6%	95.1%	95.1%	95.0%	94.4%	96.8%	96.6%

Licensee Comments: none

# ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

## Notes

ERO Drill Participation	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
Participating Key personnel	99.0	93.0	84.0	97.0	97.0	94.0	93.0	90.0
Total Key personnel	99.0	94.0	89.0	97.0	97.0	95.0	93.0	90.0
Indicator value	100.0%	98.9%	94.4%	100.0%	100.0%	98.9%	100.0%	100.0%

Licensee Comments: none

# Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

## Notes

Alert & Notification System	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
Successful siren-tests	221	294	295	296	221	296	257	296
Total sirens-tests	222	296	296	296	222	296	259	296
Indicator value	99.9%	99.7%	99.6%	99.6%	99.6%	99.8%	99.7%	99.7%

Licensee Comments: none

# Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

## Notes

Occupational Exposure Control Effectiveness	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
High radiation area occurrences	0	0	0	0	0	0	0	0
Very high radiation area occurrences	0	0	0	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

# RETS/ODCM Radiological Effluent



Thresholds: White > 1.0 Yellow > 3.0

## Notes

RETS/ODCM Radiological Effluent	2Q/06	3Q/06	4Q/06	1Q/07	2Q/07	3Q/07	4Q/07	1Q/08
RETS/ODCM occurrences	0	0	0	0	0	0	0	0
Indicator value	0	0	0	0	0	0	0	0

Licensee Comments: none

[Physical Protection](#) information not publicly available.

▲ [Action Matrix Summary](#) | [Inspection Findings Summary](#) | [PI Summary](#) | [Reactor Oversight Process](#)

Last Modified: April 30, 2008