

January 14, 2003

LICENSEE: Rochester Gas and Electric Corporation (RG&E)
FACILITY: R. E. Ginna Nuclear Power Station
SUBJECT: SUMMARY OF DECEMBER 17, 2002, MEETING WITH RG&E REGARDING
THE PROPOSED FATIGUE MONITORING PROGRAM AT THE R. E. GINNA
NUCLEAR POWER STATION

The Nuclear Regulatory Commission staff and representatives of RG&E held a meeting on December 17, 2002, to discuss RG&E's use of an automated fatigue monitoring system, Fatigue Pro. The discussion concerned the methodology the applicant plans to use to quantify fatigue calculations for the pressurizer surge line (as well as for the pressurizer lower head heater penetrations) for the period of extended operation, including the effect of environmentally assisted fatigue.

The applicant intends to perform a fatigue reanalysis of selected components, as well as the pressurizer surge line, using actual plant transient data recorded via the plant process computer to calculate actual fatigue effects based on transfer functions developed in Fatigue Pro for every transient having thermal fatigue effects. The actual number of such cycles will be determined and projected out to 60 years of operation using a weighted-average technique. The per-cycle fatigue effects and the total number and severity of fatigue cycles will be combined, environmental effects per NUREG/CR-5704 will be considered, and the end of life cumulative usage factor (CUF) will be calculated for the locations in order to demonstrate that the CUF is acceptable for the period of extended operation.

The applicant has had an opportunity to review and comment on this summary. A meeting handout and a list of the meeting attendees are enclosed.

/RA/

Russell Arrighi, Project Manager
License Renewal Section
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket No.: 50-244

Enclosures: 1. Participants in Meetings
2. Fatigue Monitoring Handout

cc w/enclosures: See next page

LICENSEE: Rochester Gas and Electric Corporation (RG&E)

FACILITY: R. E. Ginna Nuclear Power Station

SUBJECT: SUMMARY OF DECEMBER 17, 2002, MEETING WITH RG&E REGARDING THE PROPOSED FATIGUE MONITORING PROGRAM AT THE R. E. GINNA NUCLEAR POWER STATION

The Nuclear Regulatory Commission staff and representatives of RG&E held a meeting on December 17, 2002, to discuss RG&E's use of an automated fatigue monitoring system, Fatigue Pro. The discussion concerned the methodology the applicant plans to use to quantify fatigue calculations for the pressurizer surge line (as well as for the pressurizer lower head heater penetrations) for the period of extended operation, including the effect of environmentally assisted fatigue.

The applicant intends to perform a fatigue reanalysis of selected components, as well as the pressurizer surge line, using actual plant transient data recorded via the plant process computer to calculate actual fatigue effects based on transfer functions developed in Fatigue Pro for every transient having thermal fatigue effects. The actual number of such cycles will be determined and projected out to 60 years of operation using a weighted-average technique. The per-cycle fatigue effects and the total number and severity of fatigue cycles will be combined, environmental effects per NUREG/CR-5704 will be considered, and the end of life cumulative usage factor (CUF) will be calculated for the locations in order to demonstrate that the CUF is acceptable for the period of extended operation.

The applicant has had an opportunity to review and comment on this summary. A meeting handout and a list of the meeting attendees are enclosed.

/RA/

Russell Arrighi, Project Manager
License Renewal Section
License Renewal and Environmental Impacts Program
Division of Regulatory Improvement Programs
Office of Nuclear Reactor Regulation

Docket No.: 50-244

Enclosures: 1. Participants in Meetings
2. Fatigue Monitoring Handout

cc w/enclosures: See next page

DISTRIBUTION:
See next page

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML030140503.wpd

OFFICE	PM:RLEP:DRIP	LA:RLEP:DRIP	SC:DE:EMEB	SC:RLEP:DRIP
NAME	RArrighi	HBerilla	KManoly	SLee
DATE	1/14/2003	1/14/2003	1/14/2003	1/14/2003

OFFICIAL RECORD COPY

DISTRIBUTION: Summary of December 17, 2002, Meeting between NRC and RG&E, Dated:
January 14, 2003, Package: ML030140450

HARD COPY

RLEP RF

R. Arrighi

E-MAIL:

PUBLIC

J. Johnson

W. Borchardt

D. Matthews

F. Gillespie

RidsNrrDe

R. Barrett

E. Imbro

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

C. Holden

H. Nieh

G. Holahan

H. Walker

S. Black

B. Boger

D. Thatcher

C. Li

J. Fair

J. Moore

R. Weisman

M. Mayfield

A. Murphy

W. McDowell

S. Smith (srs3)

T. Kobetz

R. Assa

RLEP Staff

R. Clark

B. Platchek (RI)

A. Fernandez (OGC)

M. Kotzalas

K. Chang

RG&E/NRC EQ MEETING
ATTENDANCE LIST
DECEMBER 17, 2002

<u>NAME</u>	<u>ORGANIZATION</u>
JOHN FAIR	NRR/DE/EMEB
KEN CHANG	NRR/DE/EMEB
RUSSELL ARRIGHI	NRR/DRIP/RLEP
WINSTON LIU	NRR/DRIP/RLEP
GERRY GEIKEN	RG&E
LEE ROCHINO	RG&E
TIM GILMAN	RG&E
GEORGE WROBEL	RG&E
JON HORNBUCKLE	SOUTHERN NUCLEAR
DEANN RALEIGH	LIS SCIENTECH
DAVID GERBER	STRUCTURAL INTEGRITY ASSOCIATES

R.E. Ginna Nuclear Power Plant

cc:

Kenneth Kolaczyk, Sr. Resident Inspector
R.E. Ginna Plant
U.S. Nuclear Regulatory Commission
1503 Lake Road
Ontario, NY 14519

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. William M. Flynn, President
New York State Energy, Research,
and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Daniel F. Stenger
Ballard Spahr Andrews & Ingersoll, LLP
601 13th Street, N.W., Suite 1000 South
Washington, DC 20005

Ms. Thelma Wideman, Director
Wayne County Emergency Management
Office
Wayne County Emergency Operations
Center
7336 Route 31
Lyons, NY 14489

Ms. Mary Louise Meisenzahl
Administrator, Monroe County
Office of Emergency Preparedness
1190 Scottsville Road, Suite 200
Rochester, NY 14624

Dr. Robert C. Mecredy
Vice President, Nuclear Operations
Rochester Gas and Electric Corporation
89 East Avenue
Rochester, NY 14649

Mr. Paul Eddy
New York State Department of
Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223

Mr. Alan P. Nelson
Nuclear Energy Institute
1776 I Street, N.W., Suite 400
Washington, DC 20006-3708
APN@NEI.ORG

George Wrobel
Manager, License Renewal
R.E. Ginna Nuclear Power Plant
1503 Lake Rd.
Ontario, NY 14519

Mr. Denis Wickham
Sr. Vice President Transmission & Supply
Energy East Management Corporation
P.O. Box 5224
Binghamton, NY 13902

Mr. David F. Wilson
R.E. Ginna Nuclear Power Plant
1503 Lake Rd.
Ontario, NY 14519