REQUIRED SIGNS MATRIX

	Compressed Gas storage rooms or cabinets	Stationary compressed gas containers, cylinders and tanks on welding carts	Dipping/Solvent Operations (Flammable Liquids)	Flammable and Combustible Storage Rooms/Warehouses	Flammable and Combustible Spraying Areas	Liquid Storage Cabinets/Flammable Storage Cabinets	Storage Areas For TPU's, HEMTT, 5K	Aboveground Storage Tanks (AST)	Hazardous Waste Accumulation Areas	Motor Vehicle Fuel Dispensing Areas	Satellite Accumulation Areas	Paint Storage Rooms	Used Oil Containers/Tanks
NO SMOKING	X	X	X	X	X	X	X	X	X	X	X	X	X
COMPRESSED GAS	X												
NFPA 704	X	X	X	X	X	X	X	X	X		X	X	X
DANGER-FLAMMABLE LIQUIDS KEEP FIRE AND FLAME AWAY			X	X				X		X			
DANGER FLAMMABLE-KEEP FIRE AWAY						X							
NO WELDING			X		X							X	
LABEL OR PLACARD PLACED ON THE VEHICLE THAT DESCRIBES ITS CONTENTS							X						
STOP VEHICLE ENGINES										X			
WARNING - It is unlawful and dangerous to dispense gasoline into unapproved containers										X			
In Case of Fire, Spill or Release										X			
DANGER KEEP FIRE AND FLAME AWAY									X		X		
Satellite Accumulation Area Sign											X		
Hazardous Waste Accumulation Area Sign									X				
USED OIL													X