

DOE/SF/19168--T23

RECEIVED
JAN 26 1996
OSTI

Hawaii Energy Strategy - Project 3

Renewable Energy Resource Assessment And Development Program

November 1995

prepared for:

State of Hawaii
Department of Business, Economic Development & Tourism
335 Merchant Street, Room 110
Honolulu, Hawaii 96813
(808) 587-3800

prepared by:

RLA Consulting
18223 102nd Avenue NE, Suite A
Bothell, Washington 98011
(206) 488-0848

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MASTER

1947-1948
REG. OF. MAIL
1948-49

1947-1948

1947-1948

RENEWABLE ENERGY RESOURCE ASSESSMENT PLAN

Phase 1: Renewable Energy Resource Assessment And Development Program

November 1995

Prepared for:

State of Hawaii
Department of Business, Economic Development & Tourism
335 Merchant Street, Room 110
Honolulu, Hawaii 96813
(808) 587-3800

Prepared by:

RLA Consulting
18223 102nd Ave. NE, Suite A
Bothell, Washington 98011
(206) 488-0848



TABLE OF CONTENTS

| Section | Page |
|----------------------------------------------------------------------------|------|
| SUMMARY | 1 |
| SECTION 1. INTRODUCTION..... | 3 |
| SECTION 2. IDENTIFICATION OF POTENTIAL RENEWABLE ENERGY PROJECT SITES..... | 5 |
| APPROACH AND METHODOLOGY | 5 |
| Resource Intensity | 5 |
| Land Zoning | 6 |
| Terrain Suitability | 8 |
| Competing Uses..... | 8 |
| Owner Acceptance..... | 10 |
| Utility Access and Impact..... | 10 |
| Environmental and Cultural Sensitivity..... | 10 |
| Public Acceptance | 11 |
| RENEWABLE ENERGY PROJECT LISTS FOR THE STATE OF HAWAII..... | 11 |
| Hawaii..... | 11 |
| Wind..... | 12 |
| Solar..... | 14 |
| Biomass..... | 15 |
| Hydro | 17 |
| Wave, OTEC, and Geothermal | 17 |
| Maui..... | 18 |
| Wind..... | 18 |
| Solar..... | 20 |
| Biomass..... | 21 |
| Hydro | 22 |
| Wave and OTEC..... | 23 |
| Molokai and Lanai..... | 23 |
| Wind..... | 23 |
| Solar..... | 25 |
| Biomass..... | 25 |
| Hydro | 26 |
| Wave and OTEC..... | 26 |
| Oahu..... | 26 |
| Wind..... | 27 |
| Solar..... | 28 |
| Biomass..... | 30 |
| Hydro | 30 |
| Wave and OTEC..... | 30 |
| Kauai..... | 31 |
| Wind..... | 31 |
| Solar..... | 33 |
| Biomass..... | 33 |
| Hydro | 34 |
| Wave and OTEC..... | 35 |

SECTION 3. MONITORING PLAN 36

MONITORING STATIONS 36

 Hawaii..... 38

 Maui..... 38

 Molokai and Lanai..... 38

 Oahu..... 38

 Kauai 38

DATA COLLECTION METHODOLOGY 45

 Wind Resource Measurement Plan 45

 Field Measurement Equipment Selection..... 45

 Field Equipment Testing and Initial Calibration..... 45

 Field Equipment Installation..... 45

 Siting 45

 Installation..... 45

 Field Equipment Maintenance..... 46

 Data Collection and Quality Verification..... 46

 Data Processing 46

 Solar Resource Measurement Plan..... 46

 Field Measurement Equipment Selection..... 47

 Field Equipment Programming, Testing, and Initial Radiometer Calibration..... 47

 Field Equipment Installation..... 47

 Siting 47

 Installation Procedures and Practices 47

 Field Equipment Maintenance..... 48

 Data Collection and Quality Verification..... 48

 Data Summarization and Delivery..... 48

REFERENCES 49

APPENDICES

- A Preliminary Land Zoning Maps
- B Preliminary Land Ownership Maps
- C Electric Utility Information
- D Environmental and Cultural Ratings of Potential Project Sites
- E Hawaii Site Maps
- F Maui Site Maps
- G Molokai and Lanai Site Maps
- H Oahu Site Maps
- I Kauai Site Maps
- J Biomass Project Maps
- K Equipment Specifications and Quotes
- L Characteristics of Existing Data Sets

LIST OF FIGURES

| Figure | Page |
|------------------------------------------------------------------|------|
| Figure 1. Hawaii Project Sites..... | 12 |
| Figure 2. Maui Project Sites | 19 |
| Figure 3. Molokai and Lanai Project Sites..... | 24 |
| Figure 4. Oahu Project Sites | 27 |
| Figure 5. Kauai Project Sites | 32 |
| Figure 6. Existing and Planned Monitoring Sites for Hawaii | 39 |
| Figure 7. Existing and Planned Monitoring Sites for Maui..... | 40 |
| Figure 8. Existing and Planned Monitoring Sites for Molokai..... | 41 |
| Figure 9. Existing and Planned Monitoring Sites for Lanai | 42 |
| Figure 10. Existing and Planned Monitoring Sites for Oahu | 43 |
| Figure 11. Existing and Planned Monitoring Sites for Kauai | 44 |

LIST OF TABLES

| Table | Page |
|-------------------------------------------------------|------|
| Table 1. Hawaii Wind Projects..... | 13 |
| Table 2. Hawaii Solar Projects | 14 |
| Table 3. Hawaii Biomass Projects | 16 |
| Table 4. Hawaii Hydro Projects | 17 |
| Table 5. Hawaii Wave and OTEC Projects | 18 |
| Table 6. Maui Wind Projects | 18 |
| Table 7. Maui Solar Projects | 20 |
| Table 8. Maui Biomass Projects | 22 |
| Table 9. Maui Hydro Projects..... | 22 |
| Table 10. Molokai and Lanai Wind Projects | 23 |
| Table 11. Molokai and Lanai Solar Projects..... | 25 |
| Table 12. Molokai and Lanai Biomass Projects..... | 26 |
| Table 13. Oahu Wind Projects | 28 |
| Table 14. Oahu Solar Projects..... | 28 |
| Table 15. Oahu Biomass Projects | 30 |
| Table 16. Oahu Wave and OTEC Projects..... | 31 |
| Table 17. Kauai Wind Projects..... | 31 |
| Table 18. Kauai Solar Projects | 33 |
| Table 19. Kauai Biomass Projects | 34 |
| Table 20. Kauai Hydro Projects..... | 35 |
| Table 21. Equipment Costs per Monitoring Station..... | 36 |
| Table 22. Monitoring Equipment Cost Summary..... | 37 |

LIST OF ACRONYMS

| | |
|--------|-----------------------------------------------------------|
| ACI | Augustyn & Company, Inc. |
| ALISH | Agricultural Lands of Importance to the State of Hawaii |
| DBEDT | Department of Business, Economic Development & Tourism |
| DNI | direct normal (broad band) irradiance |
| DVS | data verification system |
| GHI | global horizontal (broad band) irradiance |
| HELCO | Hawaiian Electric Light Company |
| HES | Hawaii Energy Strategy |
| HNEI | Hawaii Natural Energy Institute |
| HNRIS | Hawaii Natural Resources Information System |
| HSPA | Hawaiian Sugar Planters' Association |
| NELH | Natural Energy Laboratory of Hawaii |
| NREL | National Renewable Energy Laboratory |
| OTEC | ocean thermal energy conversion |
| PICHTR | Pacific International Center for High Technology Research |
| RLA | RLA Consulting |
| RSR | rotating shadow band radiometer |
| SRIC | short-rotation intensive culture |
| WMO | World Meteorological Organization |

SUMMARY

RLA Consulting (RLA) has been retained by the State of Hawaii Department of Business Economic Development & Tourism (DBEDT) to conduct a Renewable Energy Resource Assessment and Development Program. This report summarizes the results of Phase 1 of this program. The purpose of Phase 1, entitled Development of a Renewable Energy Resource Assessment Plan, is to better define the most promising potential renewable energy projects and to establish the most suitable locations for project development in the state. In addition, a monitoring plan was developed to obtain additional wind and solar resource data in areas with development potential. Future work on this program will include the collection of the data, the quantification of the costs and annual energy output for these projects, and the development of resource supply curves.

In order to identify possible renewable energy project sites with significant development potential, RLA determined constraints and requirements for renewable energy projects for six different renewable energy resources: wind, solar, biomass, hydro, wave, and ocean thermal. Consideration of geothermal energy was added to this investigation under a separate contract with DBEDT. A screening process was used to identify the most promising project locations based on factors such as resource intensity, land availability, environmental constraints, utility interconnection, zoning, and public acceptance. For this phase of the project, the emphasis for project identification was on utility-scale, grid-connected renewable energy projects, however, potential applications for small, distributed uses were identified where appropriate.

Hawaii has an abundance of renewable energy resources. For most renewable energy technologies, a sufficient resource exists on each island to warrant consideration of an energy project. With few exceptions, issues other than the resource were the determining factor in identifying projects with development potential. Because these other issues (e.g., public acceptance, land availability, land ownership, utility grid size) are subject to change over time, the project lists identified in this report should be considered in the context of existing conditions. Future developments may either enhance or decrease the opportunities for renewable energy projects. For example, utility interconnection of the islands or significant load growth could increase potential project sizes. However, the land uses associated with the reasons for load growth may conflict with potential renewable energy projects. Other examples of factors that could impact project development in the future include the changing nature of the military presence, which may free up large parcels of land, and increased public acceptance of the visual impact of wind turbines.

Despite the limitations noted below, a significant number of renewable energy projects that have substantial development potential were identified on each island. As a result of the elimination process, the projects represent realistic opportunities for developing renewable energy in the State of Hawaii. These projects would result in renewable energy making a significant contribution to Hawaii's energy mix. Quantifying this contribution is the subject of future phases of this program.

A review of the existing wind and solar data and the potential project sites that were identified for these technologies was the basis for developing a monitoring plan for additional data collection. Existing, high-quality data sets and monitoring stations were identified and these data will be incorporated into the monitoring program. Ten additional wind monitoring stations and six additional solar monitoring stations were recommended.

One of the largest factors in eliminating potential projects from consideration is the availability of land without conflicting or competing land uses. Only on Hawaii and the lightly populated islands of Lanai and Molokai were sites identified in which the potential for competing land uses were not considered to be an issue. This is not to say that development of projects is impossible on the other islands; only that the demand for land is high and the impact of an energy project on a particular site will be weighed against other potential uses for that land as well as any potential impacts on activities on

surrounding lands. Primary competing land uses include urban expansion (primarily housing and light industry), conservation, and agriculture.

The total generating capacity of the utility grid on each island also limits potential development, particularly of intermittent generating technologies. Changes in the operating characteristics of the utilities, incorporation of energy storage, widespread use of electric vehicles, or island interconnection are factors that could alter this condition. As a result, projects were not eliminated from consideration on this basis. Nonetheless, the small grid capacity and growth projections of Lanai and Molokai preclude large-scale project development in the near future. Small-scale renewable energy projects (less than 50 kW) are best suited for these islands, either through demand side or dispersed generation applications. Given the relatively high energy cost on these islands, small-scale renewable energy projects should be economical on a widespread basis and have the potential to make a significant contribution to reducing petroleum dependency. On the other islands, utility-scale projects (1 MW or larger) are technically feasible. Although small-scale renewable energy applications are also likely to be possible at many locations on these islands, larger projects will make a more substantial contribution.

On Maui, Kauai, and Oahu, the majority of the mountainous land is restricted to either parks or forest reserves and the coastlines are either restricted from development or developed for urban uses or tourism. As a result, land-intensive energy projects are difficult to site in areas other than those used for agricultural purposes. Most of the biomass energy crop projects assume replacement of existing crops with an energy crop. A number of the wind and solar project sites also displace existing agricultural land uses. The likelihood of these projects depends heavily on market trends for the existing crops, particularly sugar. The sugar industry in Hawaii is on the decline with only a few economically viable plantations remaining. In many cases, land previously devoted to the production of sugarcane in these areas could be used for biomass crops or other renewable technologies.

The OTEC, hydro, and wave energy projects may require the use of highly protected shorelines or streams. Public acceptance of these projects is expected to be a major hurdle. However, the public perception of all energy projects is difficult to quantify and subject to change. For example, in Europe, wind turbines are often sited in highly populated areas that might be considered unacceptable in the United States. As these technologies become more common, public perception of their use, particularly in terms of visual impacts, are likely to change.

SECTION 1. INTRODUCTION

RLA Consulting (RLA) has been retained by the State of Hawaii Department of Business, Economic Development & Tourism (DBEDT) to conduct a Renewable Energy Resource Assessment and Development Program. This three-phase program is part of the Hawaii Energy Strategy (HES), which is a multi-faceted program intended to produce an integrated energy strategy for the State of Hawaii. The purpose of Phase 1 of our project, Development of a Renewable Energy Resource Assessment Plan, is to better define the most promising potential renewable energy projects and to establish the most suitable locations for project development in the state. In order to accomplish this goal, RLA has identified constraints and requirements for renewable energy projects from six different renewable energy resources: wind, solar, biomass, hydro, wave, and ocean thermal. These criteria were applied to areas with sufficient resource for commercial development and the results of Phase 1 are lists of projects with the most promising development potential for each of the technologies under consideration. Consideration of geothermal energy was added to this investigation under a separate contract with DBEDT. In addition to the project lists, a monitoring plan was developed with recommended locations and a data collection methodology for obtaining additional wind and solar data. This report summarizes the results of Phase 1.

The technologies considered in this project were prioritized based on their commercial status and their ability to contribute to Hawaii's energy mix. For this phase of the project, the emphasis for project identification was on utility-scale, grid-connected renewable energy projects. Although small-scale, demand-side or small-scale, dispersed-generation projects have the potential to reduce Hawaii's oil dependency, their application is more difficult to quantify because, in most cases, their adoption is based on subjective factors such as a home owner's willingness to invest capital. Also, the factors that were considered in this phase of the program, such as land availability, environmental constraints, utility interconnection, and zoning, do not generally apply to small-scale systems. However, these types of projects are included in the project list and their contribution and economics will be considered in greater depth in later phases of the program.

Biomass and hydroelectric are the most commercially proven renewable technologies available in Hawaii and, in relation to their potential, both of these have been used extensively in the state. In this project, the investigation of additional hydroelectric projects was fairly limited because most potential hydroelectric projects have been previously identified. In addition, the majority of these potential projects are fairly limited in capacity and the likelihood of implementing new hydroelectric projects is small due to strong opposition to new projects, a complex permitting process, and a pending policy from the State of Hawaii Office of State Planning regarding the classification of Hawaii's streams and development guidelines.

Biomass, through the sugar industry in Hawaii, has been used extensively throughout the state. Additional opportunities exist in terms of both the use of crops for energy (for either transportation fuels or conversion to electricity) and municipal solid waste. For biomass, Phase 1 of this project concentrated on identifying the most appropriate energy crop for the available agricultural lands and quantifying the municipal solid waste.

Wind and solar technologies have more recently entered the commercial market and, although the power output from these sources tends to be intermittent, their energy potential remains largely untapped. Additional resource assessment work for these technologies offers the most potential for promoting an increase in the use of renewable energy sources in Hawaii. As a result, identifying appropriate development sites for large-scale projects for these technologies and recommending additional monitoring sites was a primary objective of Phase 1. Of these technologies, wind is the most mature, and a number of wind energy developers have proposed projects in the state.

Wave and ocean thermal energy projects have considerable long-term potential in Hawaii, and several sites have been identified as potential locations for commercial projects. The commercial status of these technologies, however, does not at this time justify an in-depth analysis of potential sites at this time beyond what has already been completed. As the technology matures for these resources, the requirements and constraints may change considerably. For example, more than fifty different wave energy conversion technologies have been developed worldwide in the last decade [1]. Evaluating the range of possibilities for the most economical and best-suited technologies for potential project sites is beyond the scope of this report. For ocean thermal projects, future commercial power plants are envisioned as floating facilities. The impacts and requirements of such systems are not yet clearly defined. As a result, limited effort was expended on siting these technologies in Phase 1. A more in-depth analysis of their status and economics will be completed in future phases.

Geothermal energy conversion from high-temperature, water dominated resource areas is a mature technology that has been commercially deployed since the 1960's. Significant technological advances are not expected by the year 2005. One geothermal project has recently been installed on the Island of Hawaii in the Kilauea east rift zone. Even though this project was the subject of intense public opposition, further expansion in this same area is expected to be the most likely option for increased geothermal power development in the state.

The following sections describe the screening process that was used to identify the most promising renewable energy project sites, present the project lists for each technology, and describe the monitoring plan for additional wind and solar resource data.

SECTION 2. IDENTIFICATION OF POTENTIAL RENEWABLE ENERGY PROJECT SITES

APPROACH AND METHODOLOGY

For each of the technologies under consideration, a potential project list was developed based on an elimination process of the available land on each of the six major Hawaiian islands: Hawaii, Maui, Molokai, Lanai, Oahu, and Kauai. For each island, geographic areas were identified in which resource potential exists and an in-depth screening process was conducted that included consideration of factors such as land ownership, zoning, current and planned land uses, technology-specific development requirements, utility access and impact, environmental constraints, and public acceptance. For wind and solar, the project lists are the basis for the recommended monitoring plan. The following sections describe the approach and methodology for identifying project sites in terms of the screening factors.

RESOURCE INTENSITY

For each technology, geographic areas were identified in which sufficient resource was believed to exist to permit commercial development. The resource intensity was based on the best data currently available, either direct measurements or extrapolations from related information.

Wind: The areas with significant wind energy resource were identified based on a previously created wind atlas for the state of Hawaii, miscellaneous wind studies throughout the state, and RLA's independent assessment of the available data [2,3,4]. In addition, RLA considered areas in which data were not currently available but for which a significant resource was suspected to exist based on terrain or vegetation indicators. Field visits were performed at all potential resource areas to verify the available information and note any factors that could not be identified otherwise. The average annual wind speed, the wind speed distribution, and the height at which prior measurements were taken were considered in determining whether the resource was sufficient for commercial development.

Solar: Areas with significant solar resources were identified based on previously created solar maps (based primarily on Hawaiian Sugar Planters' Association data), miscellaneous solar studies throughout the state, RLA's independent assessment of the available data, and the average direct insolation estimated for various locations as compared to a long-range station at the University of Hawaii at Manoa [5]. All potential resource areas were surveyed during the field visits. Both global and direct (when available) solar radiation data were considered in determining whether the resource was sufficient for commercial development.

Biomass: Two types of biomass energy crops were considered: short-rotation intensive culture (SRIC) tropical hardwoods, and grass crops specifically cultivated as a biomass feed stock. The biomass energy wood crop resource was estimated as expected crop yields per acre of land based on information from the Hawaii Natural Resources Information System (HNRIS) geographical information system and database developed by the University of Hawaii. HNRIS considers both the soil and climatic conditions for individual areas to determine the crop yields for specific plant species.

For grass crops, the assumption was made that each existing sugar plantation has the potential to be the location of a grass crop plantation because it is highly likely that an energy grass crop would be closely related to sugar itself. However, short rotation grass crops, tailored specifically for biomass to energy conversion are easier to grow, easier to harvest, and less cumbersome to transport than sugarcane. The potential for grass crop yield was estimated based on historical yields from the plantations as published by the HSPA. These estimates are expected to be conservative since the species of grass crop for biomass-to-energy facilities will be chosen to optimize yield at the specific location while sugarcane is grown specifically for sugar production. In comparison to sugarcane, grass crops can be

expected to be faster growing, yield a higher dry weight per acre, have a lower water content, and be easier to harvest and process for use. While the yield was based on actual sugarcane production values, costs for the installation and operation of the facilities was based on techniques consistent with biomass-for-energy facilities. On Molokai, a banagrass crop was considered. Information on areas of planted cane and annual harvested amounts of cane were derived from the 1992 Hawaiian Sugar Manual. The information concerning a banagrass crop on Molokai was obtained from Dr. Charles Kinoshita, Hawaii Natural Energy Institute.

Another biomass technology considered was converting organic waste material to energy and other by-products. The resource for organic waste conversion is the number of tons of organic waste per year for each island or region within an island. Data for organic waste generation were obtained from a recent survey of Hawaii's organic waste potential that was completed for DBEDT by Unisyn [6]. The energy end-product that is converted from trees, grass, or organic waste can be methanol, ethanol, or electricity.

Hydroelectric: All significant streams and irrigation ditches were considered as potential hydroelectric resources. The resource potential for this technology is based on the available head and annual stream flow. Areas with development potential were determined based on a survey of all of Hawaii's streams and rivers [7]; however, due to the difficulty involved in siting hydroelectric facilities, locations investigated were restricted to existing or currently proposed hydroelectric facilities [8,9]. Final project sites were selected based on the predicted availability of projects to successfully complete the permitting and public review process.

Wave and OTEC: The wave and OTEC resource for tropical islands, and specifically for the Hawaiian islands, has been shown to be virtually boundless [1]. The ocean thermal resource is determined largely by the bathymetry of the ocean. The wave resource is defined by the wave spectrum for various sea states. Because of the commercial status of these technologies, however, project locations were restricted to the locations that have been previously evaluated and for which detailed resource information is currently available. No attempts were made to evaluate the resource availability in areas that have not been previously identified. For OTEC, the resource locations and potential project sites were based on work conducted by the Natural Energy Laboratory of Hawaii (NELH) and Pacific International Center for High Technology Research (PICHTR) [10,11]. For wave energy, the resource locations and potential project sites were based on a wave resource assessment study conducted for DBEDT [1].

Geothermal: The Hawaiian islands are a volcanic island chain. The volcanic structures are an obvious source of a potential geothermal resource. While the theoretical geothermal energy potential in the state is virtually boundless, development of such projects has been seen to be highly controversial. Since future development is likely to be highly restricted, this study examines the cost and performance of new power generation projects in the immediate vicinity of the recently completed facility in the Kilauea east rift zone. The most accessible, developable geothermal resource in the Kilauea east rift zone is characteristically a high-temperature, water-dominated resource area.

LAND ZONING

The state-wide system of land zoning defines land districts as either Urban, Rural, Agricultural, or Conservation. The Conservation district is further divided into areas of General, Limited, Special, and Protective subzones. In addition, land may be further classified as Shoreline. Each of these land use districts and subzones has specific regulations as to the allowable land uses and permitting processes required. The boundaries of these districts are periodically reviewed by the Office of State Planning. While modifications are made, the practices allow the state to encourage or discourage various land use activities (i.e., policy or legislative changes could make more land available for renewable energy development). Projects were identified in this report based on current zoning practices. Preliminary zoning maps were developed based on the information contained in the HNRIS database (see Appendix A). Within each of the geographic areas identified as having resource potential, RLA

verified the land zoning and determined the subzoning based on the most currently available zoning maps from the State Land Use Commission and the Conservation Division of the Department of Land and Natural Resources. For each of the resources under consideration, land was screened as follows:

Wind: There is specific wording that allows wind energy development in Agricultural districts, and it is anticipated that, barring conflicting land uses, wind energy will be allowable in Rural districts. It is foreseeable that, with some permitting requirements, wind energy projects could be developed in Conservation district subzones labeled as Resource and General. The elimination criteria used for wind sites are as follows:

1. No reasonable expectation of development in the following areas: Urban districts and Protective, Limited, and Special Conservation subzones. (Note: Federal land used for military purposes that is zoned urban was not necessarily eliminated if current land use practices permit consideration of a renewable energy project.)
2. Limited expectations of development in the following areas: Resource and General Conservation subzones.
3. No explicit land use barriers in the following areas: Rural and Agricultural districts.

Solar: It is anticipated that, barring conflicting land uses, solar energy will be allowable in Rural districts. It is foreseeable that solar energy projects could be developed in Agricultural districts where the soil is of quality C, D, E, or U, (denotes limited value for agricultural use) according to the ALISH system (Agricultural Lands of Importance to the State of Hawaii) and in Conservation district subzones labeled as Resource and General. The elimination criteria used for utility-scale solar sites are:

1. No reasonable expectation of development in the following areas: Urban districts and Protective, Limited, and Special Conservation subzones. (Note: Federal land used for military purposes that is zoned urban was not necessarily eliminated if current land use practices permit consideration of a renewable energy project.)
2. Limited expectations of development in the following areas: Resource and General Conservation subzones, and Agricultural Districts (where soil is of C, D, E, or U quality; county approval is required).
3. No explicit land use barriers in the following areas: Rural Districts.

Biomass: Only land currently zoned for Agriculture was considered for energy crop biomass projects. The land availability scheme for biomass plantations was previously developed for use with the HNRIS system [12]. For this study, land availability was considered for the islands of Kauai, Maui, Molokai, and Hawaii. Previous work completed by the University of Hawaii indicated that land-intensive biomass energy crop projects would not be feasible on Oahu or Lanai. On Lanai, the sole landowner has committed to tourist development and, mainly because of the limited demand, is not interested in pursuing an energy crop project. However, both the state and the city and county of Honolulu are interested in maintaining parts of Oahu as a green belt. One potential biomass project was considered on Oahu based on the conversion of current sugarcane land.

For organic solid waste projects, land zoning was not considered as a criteria for eliminating projects. The land requirements for a processing facility will be driven by the location of the waste stream, and, with the exception of protected conservation land, this type of facility should be feasible to site within any zoning category.

Hydro, Wave, OTEC, and Geothermal: These technologies are not land intensive, and, as such, were not eliminated based on land zoning. The majority of the hydro resource is located within conservation districts. Land-based wave and ocean thermal energy conversion facilities, by definition, are located in areas classified as shoreline. Due to the value of this limited land resource, sites for further development are likely to be based on the existing land use conditions rather than zoning. The proposed location for geothermal projects is in a previously identified resource area where recent project construction was completed but not with extensive public opposition. Further development anywhere in the state will likely be difficult.

TERRAIN SUITABILITY

In general, flat land is acceptable for any type of project. For the land-based technologies considered, steep, mountainous terrain or heavily forested land is not suitable for project development. In the state of Hawaii, most such lands were eliminated from consideration by zoning for resource conservation. Technology-specific terrain requirements such as slope, vegetation cover, and soil characteristics were also used as a criteria for eliminating land areas and ranking project sites. Wind energy and parabolic dish solar energy projects are relatively insensitive to topography, although the terrain may dictate the spacing and configuration of the array of units. Solar troughs and photovoltaic arrays for utility-scale applications require a more even slope. For example, solar trough technology, in particular, is best suited to areas where the slope is less than 2% and the soil is easily manipulated. As a result, a number of sites that were eliminated for solar trough projects were retained as potential solar dish or photovoltaic projects. Biomass crop requirements are similar to the existing needs of sugar cane or pineapple fields. Because these agricultural lands were the only lands considered for this study, terrain suitability is likely.

COMPETING USES

Land uses competing with energy production in Hawaii are related to the state's major industries: agriculture and tourism. The value of an energy project on a plot of land must be compared to the value of using that plot of land for a different purpose, without the energy project. The more significant land uses competing with energy projects include housing projects, golf courses, tourist resorts, crop farming, grazing, and environmental preservation. In some cases, land may be used for multiple purposes.

Current and planned land use were determined through a field survey of the areas under consideration, discussions with landowners, and discussions with county land use planners. In addition, the State Land Use District Boundary Review reports for each island were reviewed to determine the rationale for any potential land use re-classifications that may be undertaken by the State [13-16]. During the field surveys, areas with obvious land use conflicts (i.e., existing development) were eliminated from further consideration. The majority of the large landowners in Hawaii have long-term land use plans for the lands under their control. These plans, along with any long-term leases or contracts that impact land use, were discussed with the landowners as well as their positions on utilizing portions of their land for renewable energy projects. A common concern among landowners is the impact of a renewable energy project on other existing or planned uses on their land, particularly tourist development and agriculture. Another factor to consider when replacing existing agricultural crops with more industrial energy projects is that the agricultural lands are often seen as a buffer between urban developments and areas used for conservation and tourism.

The majority of the land that is preserved or protected (i.e., parks, watershed, forest reserves) was previously eliminated based on zoning. Land slated for urban expansion or tourism development was also eliminated. The following additional factors were considered in screening for conflicting uses:

Wind: Wind energy is compatible with some agricultural uses, as the turbine foundations physically occupy only a small fraction of the project site's land area. The area between turbine foundations can be used for grazing or, in some cases, crop cultivation. In Hawaii, the two main crops, sugar, and pineapples, require harvesting techniques that are not as compatible with wind energy as other crops.

Although there is no technical incompatibility with these crops, landowners and plantation managers have indicated that it may make their typical harvesting techniques more difficult. With pineapple cultivation, for example, the periodic location of wind turbine towers would greatly interfere with the equipment used to harvest pineapples. The burning of cane fields may also affect wind turbines. For this study, these agricultural uses were not used to eliminate land from consideration as a wind energy site unless the landowner specifically indicated that he would not consider development on his land. Grazing is considered to be compatible with wind energy, as has been demonstrated on the island of Hawaii, at the Lalamilo Wells wind farm and at Kahua Ranch.

Solar: Due to its land-intensive nature, solar energy conversion is incompatible with most agricultural uses. For this reason, the siting of solar projects was generally not considered in Agricultural districts that have been identified as either prime or unique according to the ALISH system unless the landowner indicated that he would consider the replacement of agricultural crops with this type of project if it was economical. Dish sterling solar technology may be compatible with some grazing uses. In addition, the reflection from solar projects must be considered so that it does not interfere with nearby activities.

Biomass: The ability to cultivate energy crops will depend largely on factors in the sugar, pineapple, and oil markets. For our study, a methodology was used to evaluate land availability based on five levels of land use sensitivity [12]. Only land parcels in the two most favorable land use sensitivity classes were considered to be available for SRIC tropical hardwood plantations. Land suitability for energy crops was based on both the intrinsic and manageable environmental conditions of a given site required by a given species to achieve a targeted yield. To determine land suitability for *Eucalyptus grandis*, *eucalyptus saligna*, and *Leucaena leucocephala* production, data were assembled from field experiments in Hawaii conducted by other investigators who are evaluating the performance of these species and provenances in different environments [17-24]. Information recorded for each experiment included growth age, mean diameter at breast height, mean height, initial planting density, survival rate, amount of nitrogen fertilizer applied, plot aspect (slope and direction), and elevation. Site variables included in the analysis were elevation, mean daily temperature, mean annual rainfall, mean daily solar radiation, soil nitrogen content, and soil Ph value. These site data were obtained from the literature or from the HNRIS database. For this study, all agricultural land with sufficient soil and climate conditions to provide acceptable yields were considered even if they were currently planted in another crop.

Energy production from organic waste conversion, as mentioned before, is not land intensive and is not impacted in the same way by competing land uses. Depending on the technology employed, the by-products from organic waste processing may be desirable for agricultural purposes, and it may be favorable to locate waste-to-energy conversion facilities near to, or on, agricultural lands. For organic waste, the transportation of the waste is a primary consideration and facilities are likely to be centrally located near existing landfills to take advantage of the in-place waste disposal transportation strategies.

Hydro: The main land use competing with hydroelectric power development is environmental preservation and recreation. Public opposition due to these factors is a primary consideration for siting hydro projects, and the primary factor likely to limit additional development in the State.

Wave and OTEC: The primary conflicting land use for any land-based ocean energy system is access and use of the shoreline. The island shorelines are very valuable for tourism, and other ocean access activities, so the future development of wave and OTEC projects is likely to meet with considerable competition unless there is a drastic increase in both the economic value of energy production and the cost of generating electricity from other sources.

The sites evaluated for this study were chosen to minimize any competing land use issues. As the technologies become more cost effective, competing land use issues will demand more attention.

Geothermal: The Kilauea east rift zone is zoned for both agricultural and conservation uses in about equal proportions. There is a minor amount of urban land. The conservation land occurs mainly on the western portion of the Kilauea east rift zone including the Hawaii Volcanoes National Park. The middle and lower zones are predominantly agricultural. Ownership in the lower zone includes state land and others. This area has been designated as a Geothermal Resource Subzone.

OWNER ACCEPTANCE

After completing the above screening process, the possibility of a renewable energy project was discussed with the landowners of the remaining land areas that appeared suitable. Preliminary land ownership classifications were determined from HNRIS (see Appendix B). Tax key maps were reviewed for more detailed information regarding ownership of specific parcels and private land. The likelihood of the development of an energy project is highly dependent on how it will affect the overall income of the landowner. The cost of producing energy must not only compare favorably with the price obtained by selling the energy, the project will also be judged on how it affects the profitability of planned land uses of surrounding lands. Most power generating technologies are not directly compatible with tourism activities due to visual impact, so a landowner that plans a vacation resort will often be unwilling to site an energy project on nearby land. In the case of wind energy, several landowners have even indicated the concern that the visible presence of wind turbines may imply that their resort is frequently windy and deter patrons from making reservations. In contrast, other landowners planning resort areas have even expressed an interest in renewable energy projects on their property as part of diversified land use planning. In some areas, renewable energy projects have been viewed as tourist *attractions*.

Because of the concerns of private landowners, state or federal lands are particularly attractive as potential energy project sites. Although these lands generally require more permitting for project development, lower lease rates may make these lands more favorable than private lands.

UTILITY ACCESS AND IMPACT

Access to utility transmission lines was the primary factor considered in project identification relating to utilities. Because it is possible to upgrade or build new lines to support projects, sites were not necessarily eliminated due to limited transmission access or distance from transmission lines. In some cases, however, it became obvious that the expense and/or distance of new transmission lines was excessive and these projects were dropped from further consideration.

Appendix C includes more specific information on the Hawaiian utilities, including transmission and distribution maps, expansion plans, and diurnal and seasonal load characteristics.

In addition to electrical access, solar thermal projects require a method of disposing of a certain amount of waste water. Biomass conversion technologies have considerably more waste removal requirements than other renewable energy technologies; however, in many instances the "waste" byproducts may be desirable for agricultural uses and can be sold to various plantations, thus eliminating the need for utility waste removal.

ENVIRONMENTAL AND CULTURAL SENSITIVITY

All project sites were screened for the preexistence of biologically significant native ecosystems or rare species, as well as the existence of culturally valuable archaeological sites, and the ability to mitigate against disturbances in areas that were found to be sensitive. While this screening was conducted by persons closely associated with the Nature Conservancy and familiar with the Hawaiian islands, it does not preclude the possibility that some biological or cultural feature may have been overlooked. Any site for proposed development in the state of Hawaii should be carefully surveyed and evaluated before proposed construction.

In this study, the environmental and cultural sensitivity of a potential project site was used to rank the projects. In most cases with environmental or cultural conflicts, possible resolution can be obtained by restricting the project size or using appropriate siting practices.

For the environmental screening, information regarding rare and endangered species was acquired from various sources, including the Hawaii Environmental Risk Ranking Project's Risks to Ecosystems Report, the Nature Conservancy's Hawaii Heritage Program, U.S. Fish and Wildlife Service Hawaiian Waterbird Recovery Plan, the Hawaii Stream Assessment, and personal communications with scientists and land managers in Hawaii.

For the purposes of this report, cultural resources include prehistoric, historic, and modern elements. In Hawaii, prehistoric resources generally refer to those prior to the arrival of Captain James Cook in 1778. Elements of historic, or post-contact, resources include sites listed on the State of National Register of Historic Places, historic districts, fishponds, and a variety of site types studied by the Historic Preservation Division under the Department of Land and Natural Resources. The Historic Preservation Division provided broad scale information on historic and archaeological data. Since the 1970s, archaeological surveys have been included for developments due to the Historic Preservation Law. Information from these surveys, as well as information from the University of Hawaii and Bishop Museum projects, was also incorporated into the report to the extent possible. Appendix D contains an environmental and cultural rating for each of the proposed project sites.

PUBLIC ACCEPTANCE

The assessment of public acceptance is critical in all modern development projects as public opposition to development puts significant investments at risk. While it was not appropriate in this preliminary stage to address the public at large about concerns relating to the development of specific renewable energy projects, during site visits, every attempt was made to identify areas of concern at the local level. This was accomplished through interviews with landowners, public planning officials, and past experience from renewable energy developers in Hawaii. Specific areas of concern are addressed in the following discussion of project sites.

RENEWABLE ENERGY PROJECT LISTS FOR THE STATE OF HAWAII

Following the completion of the above screening processes, project lists were developed for each technology. In the following sections, the project lists are presented by island. An overall map that identifies the general location of the potential project sites is provided for each island. A brief discussion of each project site by resource type follows. Site-specific maps are included in Appendixes E through J. Note that the majority of the site-specific maps identify representative, not exact, locations for projects and are provided for general information only. Exact project siting will require negotiations with the landowner and detailed resource assessment. Although in some cases, the landowner has identified a specific parcel for development, the majority of the landowners have only agreed to consider the possibility of a project and have not agreed to the specific sites located on the maps. The location of biomass energy crop projects are based on mill site locations, although the land area of the projects would extend well beyond the mill site location.

For the sake of completeness, small-scale applications are listed on each of the project lists for wind and solar. There are a number of small-scale, demand-side or small-scale, dispersed-generation projects utilizing wind and solar energy that are suitable for wide-spread use in Hawaii; however, identifying specific sites for these applications is beyond the scope of this work. In future phases of this program, the economics for these types of systems will be evaluated for representative locations that could be replicated throughout the islands. The lack of detailed discussion of these applications should not diminish their potential value. Small-scale, demand-side or small-scale, dispersed-generation projects utilizing solar and wind include applications such as solar hot water heating, solar or wind for off-grid remote applications, wind water pumping, distributed photovoltaics to defer utility upgrades, and solar desalination.

HAWAII

There is abundant available land on the island of Hawaii suitable for renewable energy development projects. Vast areas with sufficient resources for development were identified after the screening process. The value of renewable energy projects is more limited by the size of the utility load than by any other factor. The peak annual load in 1992 was 150 megawatts. Due to the large amount of available land, and the low apparent demand, only a limited number of possible projects were chosen for discussion and they do not necessarily represent the island's maximum potential. In addition, broader regions were identified for project sites rather than specific locations and a number of potential projects may be possible within a given region. The projects that are presented, however, are representative of the types of projects that are available to develop in Hawaii and it is anticipated that additional projects that may be proposed would have similar characteristics. Potential renewable energy projects for each technology are discussed in the following section. The general locations of potential project sites are shown in Figure 1.




Figure 1. Hawaii Project Sites

WIND

On Hawaii, Mauna Loa and Mauna Kea, the two tall volcanoes on the island, represent significant barriers to the trade winds. As a result, the wind on this island is diverted to the north of Mauna Kea and accelerated through the Waimea saddle and over the Kohala Mountains, producing a several areas of significant wind resource. To the south of Mauna Loa, the diversion of the wind produces a smaller

area of significant wind resource at the southern point of the island. Potential projects were identified as shown in Table 1.

Table 1. Hawaii Wind Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------------------|
| HAWAII | WIND | W1 | LALAMILO WELLS |
| HAWAII | WIND | W2 | NORTH KOHALA |
| HAWAII | WIND | W3 | KAHUA RANCH |
| HAWAII | WIND | W4 | SOUTH POINT |
| HAWAII | WIND | N/A | SMALL-SCALE APPLICATIONS |

W1: Lalamilo Wells. Located in the plains between Kohala and Mauna Kea, the Lalamilo Wells area is the site of an existing 2.3 MW wind farm made up of 39 Jacobs 17 kW and 81 Jacobs 20 kW wind turbines. There are no publicly available resource data at this site; however, a number of wind energy developers have monitored the area and have proposed projects, which testifies to its value as a potential project site. The land is zoned for agriculture and currently used primarily for grazing. It is owned by the state and a portion of the land has been leased to the County of Hawaii Department of Water Supply for wells. (The County currently purchases the energy from the wind farm.) The terrain is gently sloping and poses no problems for development or operation. The existing transmission line limits additional development to less than 3 MW; however, an upgrade to the line, or a new line could be installed for a project without severely penalizing the economics of a potential project. Another benefit to this project location is that it is centrally located in the area of the island projected for the fastest load growth in the future and generation projects on this side of the island are desirable for the utility. In addition, because the water department is satisfied with their existing contract to purchase the wind energy, the possibility of selling energy to a third party exists in this area. No major conflict is expected with biological resources and the existing wind farm is not visible from any tourist areas. Some of this area has been targeted by the Division of Historic Preservation for preservation because it is part of the early Hawaiian Waimea field system and remnants of agricultural terracing and habitation are abundant. At a minimum, replacement of the existing wind farm should be permitted. In addition, neighboring landowners such as Parker Ranch, are open to consideration of a wind energy project. A map of one potential location for a project in this vicinity is provided in Appendix E.

W2: North Kohala. The North Kohala area has long been considered to have good wind resources despite a lack of high-quality data. This area is owned by Chalon International and their current land use plan has set aside land parcels for renewable energy development. This land is currently zoned for agriculture. Other planned development in the area includes tourist resorts, housing, and golf courses. The Department of Water Supply has also identified this area as the most likely location for the near-term installation of additional water wells to support the anticipated growth in the Kona and Waikoloa areas. Although there is limited utility access at this time, the development of these other projects will require an additional transmission line. The proposed site is located in the lowland area of North Kohala, away from significant biological resources. A Marine Conservation District, Lapakahu State Park, is located on the coast but should not be affected by the proposed project. There are cultural sites in the vicinity, including King Kamehameha's birthplace, but no conflict is foreseen. Because of the resource and transmission uncertainty, this project is ranked below Lalamilo Wells. Appendix E provides a map that shows the land parcels which have been set aside for renewable energy development.

W3: Kahua Ranch. Located on the Kohala ridge line, Kahua Ranch is also the site of a small existing wind farm. A larger wind farm was recently removed due to the poor reliability of the equipment.

The area has been shown to exhibit exceptional wind resources. The terrain consists of rolling hills and the location of the previous wind turbines is situated between two cinder cones. Kahua Ranch is a diversified ranch that includes carnation growing, grazing, and wind energy. The potential project site is currently used for grazing. The land is zoned for agriculture; however, the state has proposed re-zoning to conservation because of biological resources. The landowner is a long-time advocate of wind energy and has argued against the re-zoning on the basis that the land has long been used for grazing. The existing transmission is limited to approximately 5 MW; however, an upgrade to this line has been discussed by the utility primarily to service proposed tourist development and water pumping wells at the end of the peninsula. It is unclear at this time who will pay for this transmission line upgrade. Public acceptance is not considered to be a problem in this area. Although this site has excellent resources and strong interest by the landowner, it is ranked below the North Kohala site because of the potential for re-zoning. A map of the site is provided in Appendix E.

W4: South Point. The South Point area is the location of the existing Kamaoa wind farm on land owned by the Bishop Estate and zoned for agriculture. Non-public data have also been collected on nearby property belonging to the Campbell Estate. The wind resource in this area is significant and the terrain is relatively flat. The power generation potential at South Point is substantial; however, the main transmission line into which the Kamaoa wind farm is connected is planned for use in delivering power from the geothermal power plant in the east (Puna area) to the loads in west Hawaii, which leaves no surplus transmission capacity. There are no transmission upgrades planned for this line, so further projects at South Point are unlikely unless the power can be used on location. There is little anticipated load growth in this area. An additional complication for this area is the significant amount of cultural and biological resources. Hawaiian Homes owns the land to the south of the existing wind farm and they have indicated that they would not consider any additional development under any circumstances. As a result of these factors, additional wind energy development at South Point is not likely to occur before the previously discussed projects on Hawaii. A map of the South Point area showing the location of the existing project is provided in Appendix E.

SOLAR

Solar resources for Hawaii are concentrated on the western side of the island. The potential project sites for large-scale solar applications are presented in Table 2 and discussed below. Other areas that were considered and eliminated included South Point (limited transmission and environmental conflicts), Kau Desert (competing land use), and the Humuula saddle (endangered species, volcanic hazards).

Table 2. Hawaii Solar Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------------------|
| HAWAII | SOLAR | S1 | WAIKOLOA |
| HAWAII | SOLAR | S2 | KEAHOLE POINT |
| HAWAII | SOLAR | S3 | NORTH KOHALA |
| HAWAII | SOLAR | N/A | SMALL-SCALE APPLICATIONS |

S1: Waikoloa. This broad regions includes the Waikoloa general vicinity from Lanuipuaa to Kawaihae along the coast and inland toward Waimea. The better sites are towards the coast; however, significant tourist development on the coast may make inland sites more feasible. There is an excellent solar resource in the entire area that has been documented by a number of data sources, including both global and direct radiation data. Land zoning is a mixture of agriculture, urban, and conservation. The terrain is relatively flat near the coast with slopes as great as 5% further inland. A map showing the Waikoloa area is provided in Appendix E. An exact project site has not been identified because there are numerous large parcels of undeveloped land that would be suitable for development in this area. There are numerous landowners in this vicinity including the Parker Ranch, Transcontinental

Development Corporation, and the State. New generation on this side of the island is desirable due to the significant load growth. HELCO is planning generation additions in this area and there are several 69 kV transmission lines and substations within the general area. From a transmission standpoint, this area is currently the most desirable location on the island to add capacity. The Waikoloa area is well known for abundance of rare anchialine pools; however, it should be possible biological conflicts to avoid through siting. There are a number of cultural sites on the makai side of the highway. These can also be avoided through appropriate siting.

S2: Keahole Point. This area is north of Kona and south of the Waikoloa area. The Natural Energy Laboratory of Hawaii (NELH) is located in the Keahole Point Area. There is a long period of record of measured global horizontal and diffuse horizontal solar radiation data maintained by the NELH that indicates that the direct insolation is 13% higher than at Manoa. There is land zoned urban in the vicinity of NELH and surrounding land is zoned conservation. The majority of the land is owned by the State. In the immediate vicinity, possible competing uses for the land include the expansion of the Kona airport, additional development at NELH, or the leasing of the land near NELH for aquaculture tenants. Should these potential developments occur, however, there is additional land in the broader area that is likely to be available. The terrain is fairly level and suited to all types of solar development. However, land grading and development costs can be high in this area and this may affect project siting and costs. An additional benefit for solar trough technology is that NELH has the ability to provide sea water for cooling. There are existing transmission lines in the vicinity and, as previously, discussed, generation on this side of the island is desirable. No biological or cultural conflicts are foreseen. A map of the area with one potential project site identified is provided in Appendix E.

S3: North Kohala. North Kohala area is thought to have the highest insolation of the three solar sites considered on Hawaii. Its steep slope makes it undevelopable for parabolic trough systems, but parabolic dish concentrating systems or photovoltaics are possible. As discussed for wind energy projects, Chalon International, one of the landowners in this area, has set aside parcels of land for renewable energy development. Other landowners include Kohala Ranch, the Queen's medical center, Parker Ranch, the State, and Hawaiian Homes. At present, the 69 kV transmission line ends at the Kohala Ranch substation, about 8 miles south of Mahukona. However, additional load growth at the northern end of the peninsula is planned and a transmission line brought in to serve this load could be used for any renewable energy project. Although biological and cultural resources exist, conflict should be avoidable through appropriate siting. A map of the parcels set aside for renewable development is provided in Appendix E.

BIOMASS

Potential biomass projects are classified into two categories based on the source of the biomass: energy crops and organic waste. Future work will further categorize projects based on the conversion technology that is utilized and the end energy product, either transportation fuels or electricity. For Phase 1, potential projects mean (1) that there is an area of land available and suitable for the production of a biomass energy crop or (2) that there are available and potentially collectable organic waste products not currently being converted into an energy end-product. Because the processing facilities were generally assumed to be located at existing mill sites, it was also assumed that transmission lines to the sites were adequate. However, in many cases new processing facilities or modifications may be required for biomass crops other than sugarcane. Similarly, because of the existing agricultural use of the land, environmental and cultural conflicts or public opposition are not likely to develop based on changing the type of crop at the site or using existing processing facilities. Table 3 summarizes the characteristics of the potential biomass projects identified for Hawaii. These projects are discussed in more detail below. Maps showing the location of the proposed energy crop projects for various species are included in Appendix J.

B1: Paaukau. One of the most likely energy crop projects in the state is the use of these lands that were previously used for sugar by Hamakua Sugar Co. Because of Hamakua's recent bankruptcy, the

Table 3. Hawaii Biomass Projects

TREE CROPS

| LOCATION | COMPANY | ACRES CONSIDERED | PRODUCTIVITY | ACRES | ANNUAL PRODUCTION (DRY TON/YR) |
|----------|----------------------------|---------------------|--------------------------|--------|--------------------------------------|
| | | | RANGE (DRY/TON/AC/YR) | | |
| PAAUKAU | HAMAKUA SUGAR Co. | 41,794 | 13-18 | 5,671 | 87,010 |
| | | | 11-13 | 1,132 | 13,510 |
| | | | 8-11 | 4,631 | 43,040 |
| PEPEEKEO | MAUNA KEA AGRIBUSINESS Co. | 32,246 | 13-18 | 37 | 560 |
| | | | 11-13 | 5,995 | 68,240 |
| | | | 8-11 | 13,042 | 124,990 |
| PAHALA | KA'U AGRIBUSINESS Co. | 20,007 | 13-18 | 1,831 | 32,670 |
| | | | 11-13 | 0 | 0 |
| | | | 8-11 | 358 | 3,240 |

GRASS CROPS

| LOCATION | COMPANY | CANELAND ACRES | ACRES HARVESTED | PRODUCTION (DRY TON) | ANNUAL |
|----------|----------------------------|-------------------|--------------------|-------------------------|-------------------------------|
| | | | | | PRODUCTION (DRY TON/AC/YR) |
| PAAUKAU | HAMAKUA SUGAR Co. | 27,837 | 7,586 | 190,790 | 12.6 |
| PEPEEKO | MAUNA KEA AGRIBUSINESS Co. | 14,683 | 5,793 | 120,740 | 10.4 |
| PAHALA | KA'U AGRIBUSINESS Co. | 12,559 | 4,374 | 123,180 | 14.1 |

NOTE: GRASS PRODUCTION ESTIMATES BASED ON ACTUAL SUGARCANE HARVESTS, BIOMASS TO ENERGY CROP CHOICE WOULD LIKELY BE CUSTOM SUITED TO THE APPLICATION. SHORT ROTATION GRASS CROPS OTHER THAN SUGARCANE MAY BE VIABLE ALTERNATIVES.

ORGANIC WASTES

| REGION | GEOGRAPHIC AREA | ORGANIC WASTE (DRY TON/YEAR) | PRIMARY COMPONENTS |
|--------------|--------------------------------|---------------------------------|-------------------------------------------|
| REGION G & H | NORTHWEST SIDE OF THE ISLAND | 71,550 | 95% OF TOTAL IS DAIRY, GREEN, & FOODWASTE |
| REGION I | NORTHEAST CORNER OF THE ISLAND | 124,480 | UNKNOWN |

land will be available for other crop considerations, and, as such, it is the highest ranking biomass project on Hawaii. The climate and soil conditions are particularly good for tree crops; however, grass crops were also considered at this site. Due to the bankruptcy, ownership and future plans are unclear at this time.

B2: Pepeekeo. This area, also considered for both tree and grass crops, also has particularly favorable climatic and soil conditions for a tree crop. The landowner, C. Brewer and Co., Ltd., is interested in developing 7,000 acres for a tree project to make particle board.

B3: Pahala. The third energy crop project considered, Pahala, is owned by Ka'u Agribusiness Co. (C. Brewer and Co., Ltd.). This is the least productive tree crop land, but the most productive sugar crop land on Hawaii. Although this area has significant potential, it is ranked third because it is currently a productive facility and not presently under consideration for an energy crop.

Organic Waste. There are two plausible areas with enough resource of organic waste to support organic waste processing facilities on the big island, one in the west and one in the east. Regions G and H comprise the western coastal areas from South Kona to Kohala. Regions I and J comprise the northeastern area of the island from greater Hilo to the Hamakua Forest.

HYDRO

There are a significant number of small hydro facilities operating on Hawaii and a new 10 MW project was recently put on-line. The hydro resource on this island is concentrated in the Kohala area and the Hamakua coast. Upgrading some of the existing or abandoned facilities and ditch systems has been evaluated by HELCO and others; however, at this time, additional upgrades were determined not to be feasible above those either recently completed or in process. A hydro project on Hawaii on the Honolii Stream was denied a permit in the late 1980s due to concerns over potential effects on surfing conditions and aquatic life. Although resource potential exists on this stream, it is not considered to have development potential because of the denied permit. Several new potential hydro projects were recently proposed by the same company that developed the new 10 MW project in the Hamakua coast area. Although they are expected to face public opposition, they are presented below as potential projects and summarized in Table 4.

Table 4. Hawaii Hydro Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|---------------------------|
| HAWAII | HYDRO | H1 | UMAUMA |
| HAWAII | HYDRO | H2 | KAWAINUI |
| HAWAII | HYDRO | H3 | KOHOLAELE, LUAHALA, KAULA |

H1: Umauma. The Umauma Stream is located on the Hamakua coast and drains just north of Hakalau. It is anticipated that a project of approximately 15 MW could be installed at this location. This project has not been previously proposed and because of its size and because public acceptance is anticipated to be more likely at this location than other proposed projects, it is the most likely of the hydro projects on Hawaii to be developed.

H2: Kawainui. The Kawainui Stream is also located on the Hamakua coast south of the Umauma project. It is anticipated that a project of approximately 6 MW could be installed at this location. This project has not been previously proposed.

H3: Koholaele, Lauhala, Kaula. These three potential projects are located on the Hamakua coast and they drain between the towns of Paauilo and Ookala. They are less likely to be developed than the two previously discussed on Hawaii because, in order to be developed, it will be necessary to reach an agreement with parties that use the water for irrigation.

WAVE, OTEC, AND GEOTHERMAL

No specific wave energy projects were identified on the island of Hawaii in this phase of the project. Additional investigation of this technology will be considered in future phases of this work. A single project site was chosen for further analysis of OTEC systems at Keahole Point (Table 5). The project site was chosen based on the existing location of the Hawaii Natural Energy Laboratory, which is the site of a currently operating experimental OTEC facility. The area is zoned urban and the site was chosen because of its proximity to deep ocean waters that are a requirement for OTEC technology. The geographical features and existing installed equipment make it a natural choice for further expanded efforts to bring OTEC to the reality of utility-scale power generation. A single project site was also chosen for geothermal power development, the Kilauea east rift zone. It is assumed that the potential sites will be chosen in areas of gentle to moderate terrain.

For OTEC, additional resource areas for the deployment of the technology have been identified off the Puna coast on the eastern side of Hawaii and near South Point. Transmission constraints and environmental and cultural conflicts are likely to prevent development near South Point. The northeast

Table 5. Hawaii Wave and OTEC Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|------------------------|
| HAWAII | OTEC | O1 | KEAHOLE POINT |
| HAWAII | GEOTHERMAL | G1 | KILAUEA EAST RIFT ZONE |

coastline of the island has also been identified as having significant wave energy resources. Due to the protected nature and limited transmission access on the northern portion of this coastline, potential development is likely to be more suitable for the Hilo area, despite the lower resource.

MAUI

The land availability screening process eliminated the vast majority of Maui's land from consideration; however, on the limited amount of suitable land, a number of potential renewable energy projects that appear to have significant development potential were identified. The mountain regions of Maui are zoned conservation and are largely national park and forest reserve lands. These and most other conservation lands are inaccessible for energy project development. The south side of Haleakala to the coast and the northeast side of the West Maui Mountains were eliminated due to terrain constraints and lack of utility access. The majority of Maui's remaining coastline is developed for tourism. Potential renewable energy projects are discussed for each technology in the following section. The general locations of potential project sites are shown in Figure 2.

WIND

The primary wind resource on Maui lies in the central valley where the trade winds accelerate between the barriers of Haleakala and the West Maui mountains. Wind potential also exists in the north western slope of the West Maui Mountains and of lower Haleakala. A number of wind energy project sites with significant development potential are summarized in Table 6 and discussed below.

Table 6. Maui Wind Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------------------|
| MAUI | WIND | W1 | WEST MAUI |
| MAUI | WIND | W2 | MCGREGOR POINT |
| MAUI | WIND | W3 | PUUNENE |
| MAUI | WIND | W4 | NW HALEAKALA |
| MAUI | WIND | N/A | SMALL-SCALE APPLICATIONS |

W1: West Maui. Zond Systems, a wind energy developer, has negotiated a lease with the landowner, Maui Land and Pineapple, for a 10 MW wind energy project in this area. Although there is additional land in this area that may be suitable for wind energy, the landowner is reluctant to consider any additional leases for wind energy because of existing and planned tourist development. In fact, Zond's original project site was moved further inland because the landowner was concerned about its proximity to a planned golf course. Expansion may be possible in the future if the first 10 MW project proves to have little affect on other planned land uses. The land is zoned for agriculture and is currently used for grazing. The terrain is fairly complex; however, no problems are anticipated with construction or maintenance. Other land in the area is zoned for conservation (part of the West Maui Forest Reserve). Transmission lines from the northwestern slope of west Maui have remaining capacity to accommodate a project of up to 20 MW. Despite the landowner's concerns, the project is unlikely to be noticeable from the coastline developments and little public opposition is anticipated. Although this area of Maui is rich in biological resources and many cultural sites are known to exist




Figure 2. Maui Project Sites

here, a correctly sited development is likely to have little environmental impact. The map of the approximate project location is provided in Appendix F.

W2: McGregor Point. The highest average wind speed recorded on Maui is at the southwestern corner of the isthmus at McGregor Point. The coastal lands in that area are not available for consideration of energy projects; however, the land rising up, away from the water is zoned resource and general conservation land and could be developed for a wind energy project. The land is owned by the state and currently leased for grazing. This location is close to Maui Electric's Maalaea generating stations and there is available transmission capacity and land for a project of at least 10 MW in size. The terrain is also fairly complex; however, no problems are anticipated with construction and maintenance. In fact, Maui Electric recently constructed a transmission line over the ridge line under consideration and a potential wind project would likely be located near this line. There are no known biological or cultural resources in the vicinity that would be impacted by a wind energy project. The project would, however, be highly visible from the main road from the airport to the tourist developments in West Maui. For this reason, it is ranked lower than the West Maui project. The higher on the ridge the project is installed, the less visible it will be. A map of the approximate project location is provided in Appendix F.

W3: Puunene. The old airport site near Puunene is located in the center of the Maui isthmus approximately four miles south of Kahului on land that is zoned for agriculture. The actual level of wind resource available at this site is uncertain, although its location suggests that there is significant

potential. This land is also owned by the state and the majority of the land is currently planted in sugar cane. The state, along with Maui County, is currently developing a master plan for the 1000 acre site. Due to its central location, the state is considering several potential uses for the land, including a waste water treatment plant, light industry, and tourist activities. In addition, the state would like to maintain some agricultural land in this area to serve as a buffer between Kahului and the tourist developments in Kihei. Despite these other considerations, it appears that sufficient land may still be available for a wind energy project. The land is flat and there are sufficient existing transmission lines in the vicinity to support a 10 MW project. In addition to the 23 kV transmission line and substation adjacent to the site, it is likely that transmission improvements will be incorporated into the master plan for the site. There is no foreseeable conflict regarding environmental or cultural sensitivity. Due to its location, the project will be fairly visible. For this reason and because of possible conflicts with other plans for the land and uncertainty regarding the resource, it is ranked lower than the first two projects. A map showing the state-owned land is provided in Appendix F.

W4: NW Slope of Haleakala. The northwestern side of Haleakala represents vast expanses of windy land zoned for agriculture and planted in sugar. The terrain is gently sloped and would offer no particular challenges for construction or operation of a wind energy project. The major landowner in this area, HC&S, is a large power consumer and would consider a wind energy project if it proved to be more economical than the existing land use. Note, however, that HC&S is one of the most profitable sugar producers in Hawaii and not likely to remove productive lands from sugar in the near future. For this reason, this project received the lowest ranking of the Maui wind energy projects. Nonetheless, the potential exists for a suitably sited project, perhaps on less productive land, and there is flexibility in locating an exact project site. Existing transmission lines to this area are sufficient for a project of approximately 10 MW. There are no foreseeable environmental or cultural concerns in this area. The project will not be visible to the majority of the island residents or tourists. A map showing the general area and one of many potential project locations is provided in Appendix F.

SOLAR

Maui's solar resources are concentrated on the leeward side of the island and in the central isthmus. Land with solar resources often conflicts with tourist developments. The potential project sites, shown in Table 7, were identified for large-scale solar energy applications and are discussed below. Additional areas that were considered and were eliminated included the Lahaina area due to competing uses and the tourist nature of the area.

Table 7. Maui Solar Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------------------|
| MAUI | SOLAR | S1 | PUUNENE |
| MAUI | SOLAR | S2 | KIHEI |
| MAUI | SOLAR | S3 | KAHULUI AIRPORT |
| MAUI | SOLAR | N/A | SMALL-SCALE APPLICATIONS |

S1: Puunene. This site is the same as identified above for wind energy. There is existing global radiation data that indicate a significant resource, although there are no direct data available. A solar trough project may be feasible for this site and it may integrate well with the proposed waste-water treatment facility by providing the option of waste water effluent re-use for power plant cooling purposes. The site is also suitable for other solar technologies, including photovoltaic and solar dishes. As discussed above, the terrain and soil conditions are suitable for development, there are no cultural or environmental constraints, and there is existing transmission line in the vicinity. A solar project would be less visible than a wind project at this site; however, a solar project would occupy

more land. In conjunction with the development of a waste-water treatment plant, little public opposition is anticipated. A map of the site is provided in Appendix F.

S2: Kihei. This area includes the lower southwestern slopes of Haleakala, above the tourist developments of Kihei, including the Research & Technology Center which is the location of the PVUSA site. The solar resource in this area is generally considered to be better than at Puunene, but there are also no direct radiation data available. Because of the tourist development along the coast and the growth anticipated for this region, any project development would likely be above the developed coastal band of land. The largest landowner in this area is Haleakala Ranch and they are willing to consider the use of their land for a solar energy project. The majority of the land is zoned for agriculture and used for grazing. The terrain has a much greater slope than Puunene (3-6% at best increasing to 10% or more to the south and further inland) and the soil conditions are less favorable. As a result, development of a project with solar trough technology may be more difficult than photovoltaic or solar dish technology and it is considered to be a slightly less desirable location than Puunene. There are transmission lines in the vicinity and, due to the projected load growth, this is a desirable location for new generating capacity additions. Although there are known biological resources in this general area, they are scattered. As a result, environmental conflicts should be avoidable by appropriate siting. A map of the general area and one potential project site is provided in Appendix F.

S3: Kahului Airport. This site covers the area to the south and east of the Kahului airport. The land is currently planted in sugar and zoned for agriculture. The majority of the land is owned by Alexander and Baldwin Sugar Co., Inc. Reported high winds in this area may indicate a difficulty in developing solar concentrating projects, which depend on focus for high efficiency. Replacing the sugar land with a solar project is unlikely unless it proved to be significantly more economical than the current use. The land is relatively flat and suitable for all types of solar development. There are existing transmission lines in the vicinity due to the proximity of the Kahului power plant. There are no known environmental or cultural impacts. Due to competing uses in the present as well as the future, this site is ranked below the first two. A map showing the general area and one potential project site is provided in Appendix F.

BIOMASS

Table 8 summarizes the anticipated production for the biomass projects identified on Maui and they are discussed in more detail below. Maps showing the location of the proposed energy crop projects for various species are included in Appendix J.

B1: Paia. These lands are owned by HC&S and are currently planted in sugar. Approximately 12,000 hectares were considered for use, with a processing facility located at the site of the existing mill. Of the three energy crops considered on Maui, the Paia project has the highest production per hectare for tree crops. At present, the long-term plans for this land are to continue sugar cultivation. As previously discussed, any replacement of sugar would have to show a significant economic benefit in order to be considered by the landowner. A portion of this land was also considered suitable for grass crops. It receives the highest ranking for a biomass energy crop project on Maui because of its high productivity.

B2: Puunene. Approximately 23,500 acres, also owned by HC&S and planted in sugar, were considered for use in the Puunene area. The same comments for the Paia site apply to Puunene. Because both the Paia and Puunene projects are owned by HC&S, they were considered together for grass crops.

B3: Lahaina. The third energy crop project considered for Maui is located on land owned by Pioneer Mill Co., Ltd. Although this project was also considered to be suitable for both tree crops and grass crops, it receives a lower ranking because the land is situated in a location in which a number of other potential uses would compete with a potential energy crop should this land go out of sugar production.

Table 8. Maui Biomass Projects

| <u>TREE CROPS</u> | | | | | |
|-------------------|---------------------------------|---------------------|--------------------------|-------|--------------------------------------|
| LOCATION | COMPANY | ACRES CONSIDERED | PRODUCTIVITY | | ANNUAL PRODUCTION (DRY TON/YR) |
| | | | RANGE (DRY/TON/AC/YR) | ACRES | |
| PAIA | HAWAIIAN COMMERCIAL & SUGAR CO. | 29,516 | 13-18 | 2,174 | 34,690 |
| | | | 11-13 | 2,693 | 31,200 |
| | | | 8-11 | 6,686 | 61,850 |
| PUUNENE | HAWAIIAN COMMERCIAL & SUGAR CO. | 23,291 | 13-18 | 0 | 0 |
| | | | 11-13 | 1,159 | 13,150 |
| | | | 8-11 | 9,078 | 82,300 |
| LAHAINA | PIONEER MILL CO. | 15,283 | 13-18 | 17 | 240 |
| | | | 11-13 | 1,265 | 14,520 |
| | | | 8-11 | 3,726 | 35,290 |

GRASS CROPS

| LOCATION | COMPANY | CANELAND ACRES | ACRES HARVESTED | PRODUCTION (DRY TON) | ANNUAL |
|--------------|---------------------------------|-------------------|--------------------|-------------------------|-------------------------------|
| | | | | | PRODUCTION (DRY TON/AC/YR) |
| PAIA/PUUNENE | HAWAIIAN COMMERCIAL & SUGAR CO. | 35,857 | 17,340 | 519,030 | 15.0 |
| LAHAINA | PIONEER MILL CO. | 6,648 | 2,013 | 62,810 | 15.6 |

NOTE: GRASS PRODUCTION ESTIMATES BASED ON ACTUAL SUGARCANE HARVESTS, BIOMASS TO ENERGY CROP CHOICE WOULD LIKELY BE CUSTOM SUITED TO THE APPLICATION.

Organic Waste. All regions of Maui, with the exception of the eastern portions of Haleakala (which are dominated by the National Park and several forest reserves), can be combined to merit the siting of a single waste-to-energy facility in central Maui. Much of the waste from these regions is currently hauled to a central landfill so there are no real additional transportation costs to be associated with transportation for an organic waste conversion facility on Maui.

HYDRO

There are currently several small hydro facilities operating in Maui. Evaluation of these facilities did not indicate that any substantial upgrades were feasible above those either recently completed or in process. Only one potential new hydro project (summarized in Table 9) was identified on Maui that appeared to have some development potential and it is discussed in more detail below. As previously discussed, all hydro projects are expected to face strong public opposition.

Table 9. Maui Hydro Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|-------------|
| MAUI | HYDRO | H1 | WAILUA IKI |

H1: Wailua Iki. Located on the northeastern region of Maui, a hydro project was proposed for this area by Bonneville Pacific in the 1980s, and it was strongly opposed for environmental reasons. It is anticipated that a project of approximately 3 MW could be installed at this location. Although opposition to a potential project in this area is still likely, it may be more acceptable than the majority of other potential hydro locations in the state.

WAVE AND OTEC

No specific project sites for either wave or ocean thermal on Maui were identified in this phase of the project. Previous work on the siting of OTEC projects, conducted by PICHTR, indicate that there is sufficient resource (i.e., appropriate bathymetry) for two to three floating OTEC plants off the northeast coast of Maui near Hana. The scenic beauty and protected resources of this area will likely result in significant public opposition to any land-based systems. For wave energy, the resource on Maui is concentrated on the northeastern coastline. Outside of the urban area surrounding Kahului, it is anticipated that a wave energy project would face public opposition. In addition, transmission access is limited.

MOLOKAI AND LANAI

Molokai and Lanai are both small in relation to the other Hawaiian islands and are relatively low in population density as well as the size of the island utilities. Large areas with development potential for renewable energy projects were determined to exist on each island following the land availability screening process; however, there is insufficient demand to justify a large-scale project. In addition, due to the small size of the utilities, very little intermittent power generation is likely to be valuable. Renewable energy projects on these islands can be more appropriately incorporated through demand-side (i.e., solar hot water heaters) or small-scale, dispersed generation projects (i.e., water pumping). However, because both islands exhibit significant renewable energy resources, potential utility-scale projects are discussed here on a limited basis. The utility-scale projects identified for these islands are more likely to be valuable in the event that the island populations grow, or the island utilities become interconnected. Potential projects are discussed in the following sections for each technology. The general locations of potential project sites are shown in Figure 3.

WIND

Molokai is unique among the major Hawaiian islands in that it lies almost parallel to the prevailing trade winds. Exposed areas on most of the island are estimated to have significant wind resources with the most substantial wind resource being located in the northwestern corner. Lanai lies partly in the wind shadow of western Maui. Nevertheless, there appears to be some wind resource on the northwestern third of this island. Potential wind energy project sites for these islands are summarized in Table 10 and discussed below.

Table 10. Molokai and Lanai Wind Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|---------|------------|--------------|----------------------------------------|
| MOLOKAI | WIND | W1 | WEST MOLOKAI |
| MOLOKAI | WIND | N/A | MISCELLANEOUS SMALL-SCALE APPLICATIONS |
| LANAI | WIND | W1 | INLAND FROM SHIPWRECK BEACH |
| LANAI | WIND | N/A | MISCELLANEOUS SMALL-SCALE APPLICATIONS |

W1: West Molokai. Eastern Molokai is largely zoned conservation and difficult to access; however, the wind resource of west Molokai is much more accessible and well documented. Most of the non-coastal lands of west Molokai are agricultural lands with acceptable zoning for wind energy development. There are no problems anticipated with potential development in this area with respect to terrain, landowner, or public acceptance. Environmental and cultural resources exist in this area; however, there is a large amount of land with significant wind resource available and with appropriate siting, conflicts should be avoidable. There is a small wind project currently operating in West Molokai. It is therefore unlikely, under current conditions, that any further development of intermittent energy resources will take place on this island in the near future other than small-scale projects. Small-scale projects are particularly suited to Molokai because of the cost of electricity to residential and commercial customers is high enough to make such ventures economical. Appendix G contains a map that shows the approximate location.




Figure 3. Molokai and Lanai Project Sites

W1: Inland from Shipwreck Beach. The available wind resource on Lanai is uncertain. Contour maps of surface trade winds indicate an annual average surface wind speed approximately equivalent to that of west Maui. Limited by the small generating capacity of the utility, there is more than adequate land available to site a wind project on the non-coastal land above Shipwreck Beach. However, there are no existing transmission lines in this vicinity and projected load growth is on the opposite side of the island. As a result, it is unreasonable to consider wind energy as a potential generating source for Lanai unless demand increases significantly above its projected levels. Like Molokai, small-scale projects are particularly suited for Lanai because of high energy prices. Because the wind resource is located away from the energy demand areas on Lanai, only limited possibilities for wind, such as water pumping for livestock, are likely. Appendix G contains a map that shows the approximate location.

SOLAR

Solar resources for Molokai are concentrated on the western half of the island. On Lanai, the solar resources are concentrated on the southwestern portion of the island. Potential project sites for solar applications are listed in Table 11 and discussed below.

Table 11. Molokai and Lanai Solar Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|---------|------------|--------------|--------------------------|
| MOLOKAI | SOLAR | S1 | WEST MOLOKAI |
| MOLOKAI | SOLAR | N/A | SMALL-SCALE APPLICATIONS |
| LANAI | SOLAR | S1 | MANELE BAY |
| LANAI | SOLAR | N/A | SMALL-SCALE APPLICATIONS |

S1: West Molokai. With the exception of the rugged eastern portion of the island, good solar resources exist for most of Molokai. The best solar resource is on the southwest corner of the island; however, this area is not currently developed, and as such there are no load or transmission lines. Potential resort development in this area may change this situation. In the more populated areas of the island, small-scale applications are particularly well suited for Molokai because of the high cost of energy. As with wind, any utility-scale projects are not likely in the near future due to the limited utility size.

S1: Manele Bay. For Lanai, a solar project is possible in the future in the southeastern region of the island near Manele Bay because demand in this area is likely to grow due to resort development and plans for luxury homes. However, if the demand grows to a sufficient level to support a commercial solar utility project, conflicting land uses and public acceptance may become a problem. There are significant opportunities in this area for small-scale applications, however, due to the abundant solar resource and the high cost of energy.

BIOMASS

Table 12 summarizes the characteristics of a potential biomass project for the island of Molokai. The project is discussed in more detail below. Maps showing the location of the proposed energy crop projects for various species are included in Appendix J. Biomass projects were not considered for Lanai. The organic waste generated on both Molokai and Lanai is not enough to merit the construction of a waste-to-energy plant on the island.

B1: Palaau. The available land area identified as suitable for biomass crop agricultural uses has been identified as capable of producing a mixed resource of both tree and grass crops. Relative to other biomass projects on other island, this project has relatively low productivity. A processing facility would likely be located in the Palaau area near existing generation and transmission lines.

Table 12. Molokai and Lanai Biomass Projects

TREE CROPS

| LOCATION | REGION | ACRES CONSIDERED | PRODUCTIVITY | ACRES | ANNUAL PRODUCTION |
|----------|---------------------------|---------------------|--------------------------|-------|----------------------|
| | | | RANGE (DRY/TON/AC/YR) | | (DRY TON/YR) |
| PALAAU | CENTRAL AGRICULTURAL AREA | 3,786 | 13-18 | 89 | 1,323 |
| | | | 11-13 | 54 | 673 |
| | | | 8-11 | 586 | 4,785 |

GRASS CROPS

| LOCATION | REGION | TOTAL ACRES | ESTIMATED YIELD (DRY TON/AC/YR) | PRODUCTION (DRY TON) |
|----------|---------------------------|----------------|------------------------------------|----------------------|
| PALAAU | CENTRAL AGRICULTURAL AREA | 5,500 | 18-24 | 99,000-132,000 |

HYDRO

No potential hydro projects were identified on Molokai at this time. Although resource potential exists on the Halawa Stream, the landowner has indicated that he is not interested in developing the resource or providing access.

WAVE AND OTEC

No project sites for either wave or ocean thermal on Molokai are recommended at this time for further analysis in this study. Previous work on the siting of OTEC projects, conducted by PICHTR, indicate that there is sufficient resource (i.e., appropriate bathymetry) for a small OTEC plant that could meet all water and power requirements on Molokai. For Lanai, it would be more cost effective to supply power from Maui via an underwater cable than to consider OTEC. The proposed Molokai OTEC site would be off the northern coast close to the Kalaupapa peninsula. Because of the proposed designation of this area for a National Park, any land-based facilities would have to be located in another area.

The wave energy resource for Molokai is also centered on the northern coastline. To the northeast of the Kalahulu peninsula, no development is considered to be permissible. To the northwest, it may be possible to site the land-based support for a wave energy project; however, for either wave or OTEC projects in this area, substantial transmission upgrades will be required.

OAHU

The land availability screening process eliminated the vast majority of Oahu's land from consideration. The island of Oahu contains the largest population of any of the Hawaiian islands and, as such, there are significant competing uses for any available land. Associated with its large population, tourist industry, and industrial sector, is by far, the largest island electrical utility system. Because of its large load, penetration of intermittent generating sources should not cause any problems. Even with a conservative assumption of 10% of peak load, the near-term practical penetration limit for intermittent technologies for the island is 128 MW of capacity, of which there are now approximately 13 MW installed. However, because of competition for land and protected natural features, it is much more difficult to identify available land for renewable energy projects on Oahu than on the other islands. As a result, the interpretation of the siting criteria was broadened for Oahu to allow consideration of a number of projects with unique features such as the location of projects on military lands. In addition, the potential for projects on land that is already or planning to be developed is considered (i.e., combining solar applications on rooftops with industrial development). These types of projects may also have applications on other islands; however, their evaluation on Oahu will be representative because site-specific features are not important considerations. Potential renewable energy projects are discussed in the following section for each technology. The general locations of potential project sites are shown in Figure 4.




Figure 4. Oahu Project Sites

WIND

On Oahu, the Koolau mountains and the Waianae Range enhance the trade winds. The northeastern (Kahuku), southeastern (Koko Head), and northwestern (Kaena Point) tips of Oahu have areas of substantial wind resource. The combination of land available for wind development and valuable wind resource is mostly concentrated in the Kahuku area. Although two other potential project areas are discussed, they are likely to have strict limitations on land use. Potential wind energy projects on Oahu are listed in Table 13 and described below.

WI: Kahuku Hills. Kahuku Hills is the location of an existing wind farm which at one time included fifteen 600 kW Westinghouse turbines and the 3.2 MW MOD-5B, a total of 12.2 MW of installed capacity. The existing transmission line has been shown to be capable of handling about 15 MW of installed wind capacity, leaving little room for expansion; however a new transmission line is planned for the late 1990s. Based on the existing plans, the new line could handle another 10-15 MW of installed wind capacity from the Kahuku area, either in the hills or on the flats nearer the ocean. There is sufficient land in this area for a much larger project, however, and an additional upgrade or a change in the current plans is possible. Potential wind energy projects as large as 100 MW have been proposed in the vicinity. The terrain is complex; however, no problems are anticipated with construction or operation. The land is owned by Campbell Estates and the land leased to the existing wind farm is also used as an army training ground. Although the landowner is not opposed to additional development, the U.S. Army has indicated that it is against additional development. As a result, there is a potential conflict on this land. Nonetheless, it represents the only large area with

Table 13. Oahu Wind Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------------------|
| OAHU | WIND | W1 | KAHUKU HILLS |
| OAHU | WIND | W2 | KAHUKU FLATS |
| OAHU | WIND | W3 | KAENA POINT |
| OAHU | | | SMALL-SCALE APPLICATIONS |

significant potential for development on the island. In the hills, there are no known biological or cultural conflicts. The existing project is visible from the coastal tourist developments in the area, but additional development is unlikely to face additional opposition. A map showing the approximate location of the existing project sites is provided in Appendix H.

W2: Kahuku Flats. The Kahuku flats are likely to be somewhat more difficult to develop than the hills. This area is also owned by the Campbell Estate and the potential project site is within the area designated for aquaculture. Some of the area in the flats is off-limits to development because of environmental restrictions, and the visual impact of turbines installed in this area will need to be given careful consideration. There are scattered wetlands in the vicinity and the James Campbell National Wildlife Refuge is an important biological resource area that provides a habitat for all four endangered Hawaiian waterbirds. The Hawaii Statewide Trail and Access System plans to develop a trail along the beach. This trail is listed as high priority because the Kahuku shoreline is one of the last undeveloped coastal wilderness areas remaining on Oahu. Although this is a relatively unpopulated area, there are tourist developments including hotels and golf courses nearby. Even with the obvious restrictions stated, expanding wind power generation in the Kahuku area is the most likely place for wind power development on Oahu. Appendix H includes a map showing the location of a potential project on the Kahuku Flats.

W3: Kaena Point. The higher ground of Kaena Point has also been identified as a high wind area. The land is owned by the state and currently zoned for agriculture. This site is limited by severe environmental restrictions near the shoreline, although some development may be possible in the higher, more exposed areas. A portion of this area is used by the military as a communications facility. There is limited transmission in the vicinity and an additional line would have to be added for any project greater than 2 MW. Public opposition is likely due to the remote, undeveloped nature of the area. As a result of these factors, this project is considered to be significantly less likely than additional development in the Kahuku area. A map showing a potential project site is provided in Appendix H.

SOLAR

Oahu's solar resource is concentrated on the leeward side of the island, primarily in areas of urban development. Potential project sites are listed below. Other areas that were considered and eliminated include Kahuku Point (wind and conflicting land uses) and Waialua (low insolation). Table 14 lists the potential solar projects for Oahu.

Table 14. Oahu Solar Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------------------|
| OAHU | SOLAR | S1 | PEARL HARBOR BLAST ZONE |
| OAHU | SOLAR | S2 | LUALUALEI |
| OAHU | SOLAR | S3 | NORTH EWA |
| OAHU | SOLAR | S4 | EWA PLAIN |
| OAHU | | | SMALL-SCALE APPLICATIONS |

S1: Pearl Harbor Blast Zone. Although the southern region of Oahu is recognized as having significant solar resources, existing urban development prohibits the consideration of a large solar facility. The Blast Zone, the area within a radial distance of 7,405 feet of the munitions magazines located on the West Loch of Pearl Harbor, is largely undeveloped due to the Navy's restriction that no occupied structures be constructed in that area. A solar energy conversion facility could be constructed in this area, with the control facility located beyond the borders; however, the Navy's position regarding the construction of a solar energy conversion facility on this land has not yet been ascertained. The entire area is nearly level and zoned for agriculture. Existing land uses in the vicinity include sugar cultivation and a golf course. The site is centrally located to HECO's load and a number of 46 kV transmission lines exist in the vicinity; however, they are heavily loaded and a transmission upgrade may be necessary for project development to occur. The area provides an important ecosystem for waterbirds, but a solar facility is unlikely to have a significant impact. Due to the developed nature of the region, public opposition is unlikely. Despite the complications of developing a project on military land, this site is ranked highest of the Oahu solar sites because of its central location and good resource. A map of the area is provided in Appendix G.

S2: Lualualei. The Lualualei area is a large flat valley situated to the west of the Honouliuli Mountains. The most extensive tracts of open land that offer the potential for economical solar generation facilities are on land that is under Navy control at the Navy Radio Transmission facility. It is unlikely that most of these areas would be available for development. The land is relatively flat and zoned for agriculture. Land closer to the water is owned by the Hawaiian Homes trust. At present, conflicting land uses may be an issue for either of the two owners. Changes in military land use may make this a desirable location in the future. There are several 46 kV transmission lines in the valleys, although new generation is expected to require some transmission line additions. Little biological, cultural, or public acceptance conflicts are anticipated. This site is ranked below Pearl Harbor because of its more remote location. A map of the area is provided in Appendix H.

S3: North Ewa Plain. This region includes agricultural sugar fields north of Ewa, particularly those north of Highway H1, along Highway 750. Although the solar resource in this area is lower than the coastal areas, land is perceived to be more readily available for a project of this type than land closer to the coast where the resource is greater. As previously discussed, the replacement of sugar lands would be considered only if the project was significantly more economical. Other competing land uses include urban expansion. The majority of the terrain is gently sloped and the land is owned by the Campbell Estate and the State of Hawaii. There are transmission lines in the vicinity; however, they are heavily loaded. There are no biological or cultural conflicts known to exist. Although this site does not have the complications of development on military land, it is ranked below the first two projects due to its lower resource and the potential for competing land uses in the future. A map showing one potential project site in this area is provided in Appendix H.

S4: Ewa Plain. This site region includes land adjacent to Barber's Point N.A.S. to the east over the entire Ewa Plain. Physically, this is the best area on Oahu for solar development because of excellent solar resources, flat land, and good transmission access. However, the area is slated for major urban expansion, including plans by the landowner, the Campbell Estate, for a major new city. Due to the many proposed conflicting land uses, this site is ranked the lowest of potential solar development areas. Of all choices of land use, a solar facility is perhaps the least valuable; however, the incorporation of a large-scale solar facility into an industrial application is possible despite the lack of available land. Because land has not been identified in this area that could be developed for a solar project, this site is ranked last. However, because the use of solar energy for industrial or commercial applications will be evaluated in later phases of the project, this project was not eliminated. The evaluation of this type of project in this area of Oahu is considered to be representative of projects of this type that could be incorporated in areas throughout the islands.

BIOMASS

Table 15 summarizes the anticipated production for the biomass projects identified on Oahu and they are discussed in more detail below. On Oahu, the many competing uses for potentially available land may limit possibilities for biomass crop projects. However, one biomass project was considered based on the potential conversion of an existing sugarcane plantation.

Table 15. Oahu Biomass Projects

GRASS CROPS

| LOCATION | COMPANY | CANELAND ACRES | ACRES HARVESTED | PRODUCTION (DRY TON) | ANNUAL PRODUCTION (DRY TON/AC/YR) |
|----------|-------------------|-------------------|--------------------|-------------------------|--------------------------------------|
| WAIALUA | WAIALUA SUGAR CO. | 12,054 | 5,800 | 127,750 | 11.0 |

ORGANIC WASTES

| REGION | GEOGRAPHIC AREA | ORGANIC WASTE (DRY TON/YR) | PRIMARY COMPONENTS |
|----------|----------------------------|-------------------------------|-----------------------------------------------|
| REGION C | WEST QUARTER OF THE ISLAND | 317,500 | 83% OF TOTAL IS DAIRY, FOODWASTE, AND FEEDLOT |

B1: Waialua Sugar. This is the site of the Waialua Sugar Plantation. Both the State of Hawaii and the City and County of Honolulu have expressed an interest in maintaining green spaces on the island and a 4,000 acre biomass plantation has been considered in this area. The production of the proposed project site assumes that all of the active, productive acreage of the Waialua Sugar Plantation are converted to biomass grass-crop cultivation.

Organic Waste. There is currently an organic waste processing facility operating in Waimanalo, Oahu. It draws from organic wastes generated in regions A, B, and F, which collectively comprise most of southern and southeastern Oahu. Region C also produces enough organic waste resource to support the successful operation of an organic waste processing facility. Region C represents southwestern Oahu from the Ewa plain stretching to Kaena point, west of the Waianae mountain range.

HYDRO

No potential hydro projects were identified on Oahu.

WAVE AND OTEC

In this phase, a single project site was chosen for further analysis of wave energy systems on the island of Oahu at the Makapuu Head/Waimanalo area. The project site was chosen based on the existence of resource data with sufficient characteristics for potential development. The area is zoned urban and the site was chosen because of its proximity to a load center. The wave resource has been identified on the northeast and northwest areas of Oahu. Due to the fame of the surfing conditions and the protected shoreline on the northeast coast, it is unlikely that any land-based support for a wave energy project would be permitted. Although the resource is lower, development is more likely to be feasible on western coastline, closer to the load centers and transmission access.

Due to a number of factors including current land use, near shore bathymetry (depth measurement), and location both in terms of ocean access and proximity to utility power generation plants, Kahe Point has been studied as the next potential location of research and demonstration projects for OTEC technology. In addition to this site, potential locations for OTEC facilities have been identified off the northeast coast near Kaneohe.

The wave and OTEC sites are listed in Table 16.

Table 16. Oahu Wave and OTEC Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|-------------|
| OAHU | WAVE | WV1 | WAIMANALO |
| OAHU | OTEC | O1 | KAHE POINT |

KAUAI

The land availability screening process eliminated the vast majority of Kauai's land from consideration. The central mountain regions of Kauai are zoned conservation and are largely park and forest reserve lands. These and most other conservation lands are inaccessible for energy project development. The majority of the north side of the island was eliminated due to zoning, terrain constraints, and no utility access. The majority of Kauai's remaining land is coastal areas with either urban or tourist development. The population density of Kauai is highest at Lihue and Kapaa on the eastern side of the island, and the majority of the land in this area is committed to other uses. As a result, locating energy projects near the energy load is difficult.

Due to the impact of Hurricane Iniki, it is also more difficult to project the future electricity demand in Kauai than for most of the other islands. Also, other than for biomass and hydroelectricity, the use of renewable energy for electric power remains largely unexplored and limited resource data are available. Although Kauai appears to have sufficient resources, it was difficult to find acceptable project sites for development of renewable energy projects. Potential renewable energy projects are discussed in the following section for each technology. The general locations of potential project sites are shown in Figure 5.

Due to overloading conditions that occurred prior to Hurricane Iniki along the transmission line passing through southern Kauai, there is a plan to upgrade the transmission capacity in this area by installing a 69 kV transmission line. So, while there is not currently any surplus transmission capacity, it is anticipated that the addition of a new transmission line will allow additional installed capacity in southern Kauai. The transmission line that runs across northern Kauai is also a 57.1 kV line with a planned upgrade to 69 kV. Based on information from before the hurricane, there is some limited available capacity for power generation additions along the northern transmission corridor.

WIND

On Kauai, the trade winds are forced to flow around the central mountain mass of the island. The prime wind resource appears to be on the southeastern and northeastern coasts of the island. However, there has been limited wind resource assessment on Kauai. Unfortunately, the coastal areas are either developed for tourism or planned for urban expansion. As a result, there is very limited land available for potential renewable energy projects to be developed on Kauai. Potential wind energy projects are listed in Table 17 and discussed below.

Table 17. Kauai Wind Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------------------|
| KAUAI | WIND | W1 | N. OF HANAPEPE |
| KAUAI | WIND | W2 | S. OF KILAUEA/ANAHOLA |
| KAUAI | WIND | W3 | PORT ALLEN |
| KAUAI | WIND | N/A | SMALL-SCALE APPLICATIONS |




Figure 5. Kauai Project Sites

W1: N. of Hanapepe. North of Port Allen and Hanapepe, there are mountain gorges that are thought to act as funnels, concentrating the effect of wind in a local area. The land in this area is zoned as agricultural land, but due to the terrain and soil type, is of little value for agricultural purposes. The land is owned by Gay and Robinson. Although the landowner is considering possible ecotourist activities in the vicinity, planned uses are not yet determined. The terrain is fairly complex and potential project sites are between 3 and 5 miles from the nearest transmission line. There are no known environmental or cultural conflicts and the project is unlikely to be visible from any tourist or populated areas. A map showing a potential project site is provided in Appendix I.

W2: S. of Kilauea/Anahola. High winds have been measured at the Kilauea Point Coast Guard Station; however, a nearby bird sanctuary and existing homes eliminate this vicinity from consideration for a wind energy project. There are no other wind data in this general area. Although it is suspected that the wind drops off considerably further inland, there may be sufficient wind for a project in some locations to the south of Kilauea and to the east of Kilauea in the Anahola area. Although the land in this area is zoned for agriculture, most of it is developed for luxury homes. The only land that was determined to be available for consideration of a wind energy project was several inland parcels owned by C. Brewer and Co., Ltd. and the Hawaiian Homes land near Anahola. At this time, the resource is unknown on these land parcels; however, should sufficient resource exist, they appear to be developable in terms of terrain, transmission access, and environmental and cultural conflicts. Maps showing the areas are provided in Appendix I.

W3: Port Allen. The Salt Pond Beach Park and Port Allen Airport are located on a peninsula that is zoned as an urban district, but adjacent to the airport is sufficient undeveloped land to site a small wind energy project. The airport is currently used for helicopter flights. The wind resource is estimated to be at the low end of the acceptable range for wind energy conversion; however, due to the limited number of potential projects on Kauai, the evaluation of this site will be considered further. A map is provided in Appendix F.

SOLAR

Southern Kauai exhibits good solar resources; however, there is a limited amount of land available in the Lihue-Poipu-Hanapepe area due to tourist development and urban housing. Only one site was considered for large-scale solar development. It is summarized in Table 18 and discussed below.

Table 18. Kauai Solar Projects

| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------------------|
| KAUAI | SOLAR | S1 | BARKING SANDS |
| KAUAI | SOLAR | N/A | SMALL-SCALE APPLICATIONS |

S1: Barking Sands. The only location on the island of Kauai where data indicate that the solar resource sufficient to consider utility-scale solar energy conversion and sufficient land is available is in west Kauai in the vicinity of the Barking Sands Pacific Missile range. Toward the mountains, but still on the plain, the land is zoned for agricultural use. Some of the agricultural land is of limited value as cropland, and so, may be suitable for solar development. In addition, although the federal property of the missile range is zoned as limited conservation, the fact that there is an existing commercial-scale solar water heating unit on the property makes it likely that some kind of solar power station could be developed there as well. The area is a flat sedimentary plain with a high water table, which would have to be considered for any type of development. The Missile range is federally owned and the remaining property in the area is owned by the State. A transmission line runs through the area; however, there is very little existing or projected load growth. As a result, the utility does not consider this to be a desirable location for a generating facility on Kauai. In addition, there are significant biological (primarily waterbird habitat) and cultural (burial grounds) areas in the vicinity that may result in public opposition. Nonetheless, there is a significant amount of land in the vicinity, and a number of potential conflicts should be avoidable through flexible siting. A map showing the general area and one potential project site is included in Appendix I.

BIOMASS

Table 19 summarizes the characteristics of the potential biomass projects identified on Kauai. The projects are discussed in more detail below. Maps showing the location of the proposed energy crop projects for various species are included in Appendix J.

B1: Lihue Plantation. Although this project site is currently planted in sugar, it has fairly low productivity and thus, more probability of considering alternate crops for cultivation. The site is also located near a deep water harbor which may be beneficial for potential transportation fuel projects. The land is owned by Amfac Inc./JMB Hawaii. This is one of two projects on Kauai that was considered for both grass and tree crops.

B2: Olokele Sugar. This site is owned by C. Brewer and Co., Ltd. and located near Kaumakani on the southwest region of Kauai. It is currently planted in sugar. It is also located fairly close to a barge port at Port Allen; however, the land is less productive than the Lihue Plantation for trees. The site was also considered for grass crops. Gay and Robinson land, which is used for sugar but does not have a processing facility, was also considered for a grass crop but was combined with Olokele

Table 19. Kauai Biomass Projects

TREE CROPS

| LOCATION | COMPANY | ACRES CONSIDERED | PRODUCTIVITY | ACRES | ANNUAL PRODUCTION (DRY TON/YR) |
|-----------|--------------------------|---------------------|--------------------------|-------|--------------------------------------|
| | | | RANGE (DRY/TON/AC/YR) | | |
| LIHUE | THE LIHUE PLANTATION CO. | 24,050 | 13-18 | 0 | 0 |
| | | | 11-13 | 7,223 | 82,920 |
| | | | 8-11 | 8,777 | 83,120 |
| KAUMAKANI | OLOKELE SUGAR CO. | 32,261 | 13-18 | 0 | 0 |
| | | | 11-13 | 2,367 | 26,650 |
| | | | 8-11 | 6,815 | 59,260 |

GRASS CROPS

| LOCATION | COMPANY | CANELAND | ACRES | PRODUCTION | ANNUAL |
|-----------|--------------------------|----------|-----------|------------|-------------------------------|
| | | ACRES | HARVESTED | (DRY TON) | PRODUCTION (DRY TON/AC/YR) |
| LIHUE | THE LIHUE PLANTATION CO. | 11,220 | 6,971 | 119,100 | 8.5 |
| KAUMAKANI | OLOKELE SUGAR CO. | 4,716 | 2,305 | 70,400 | 15.3 |
| | GAY & ROBINSON, INC. | 2,716 | 1,324 | 46,170 | 17.4 |
| KEKAHA | KEKAHA SUGAR CO. | 8,294 | 3,589 | 98,830 | 13.8 |
| ELEELE | MCBRYDE SUGAR CO. | 7,015 | 5,208 | 93,270 | 17.9 |

ORGANIC WASTES

| REGION | GEOGRAPHIC AREA | ORGANIC WASTE (DRY TON/YEAR) | PRIMARY COMPONENTS |
|-----------------|----------------------------|---------------------------------|--------------------------------------------|
| REGION M, N & O | EASTERN HALF OF THE ISLAND | 80,265 | 90% OF TOTAL IS GREEN , FOODWASTE, & DAIRY |

because they currently use Olokele mill and it was assumed that this arrangement would continue if another crop was cultivated.

B3: Kekaha Sugar. This project is located in the southwest region of Kauai near Kekaha. Only grass crops were deemed to be suitable for this site. The land is owned by Amfac Inc./JMB. The grass crop sites were ranked lower than the projects that have more flexibility in species production (tree and grass crops).

B4: McBryde. This project site is also located in the southwest region of Kauai near Eleele. It is currently planted in sugar and owned by Alexander and Baldwin, Inc. Only grass crops were considered at this site and it was ranked lower than Kekaha because of its lower productivity.

Organic Waste. It is estimated that collecting and combining the organic waste generated in the eastern half of Kauai would provide enough waste to be processed to make an organic waste processing facility a viable option on the island of Kauai. An additional option for organic waste that has been explored on Kauai is the use of the boilers at sugar facilities for the burning of waste products. Although this is technically viable, the Department of Health has expressed concerns over the emissions. As an alternative, several plantations have examined the possibility of burning only green waste, which should be considered as a biomass product under their existing permits. Work in this area is in progress and the results will be included in our future work.

HYDRO

Kauai currently produces more hydroelectricity than all the other Hawaiian islands combined. Additional resource potential exists in the river valleys of the northern and eastern portion of the island; however, all proposed projects have been strongly opposed. According to Kauai County planners, all of the remaining streams in Kauai are likely to be designated as special streams, which will prohibit development, with the exception of the Wailua River. On Kauai, most of the existing

hydro facilities have been evaluated or are under study for potential upgrades and additional upgrades were determined to not be feasible above those either recently completed or in process. Because all the new hydro proposed for Kauai have been denied permits, it is unlikely that any additional hydro will be allowed on Kauai. However, two potential projects are still attempting development: one on the Wailua River and one on the Hanalei River. Although it is expected to face public opposition, the most likely of these to be developed is shown in Table 20 discussed in more detail below.

Table 20. Kauai Hydro Projects


| ISLAND | TECHNOLOGY | RANKING CODE | DESCRIPTION |
|--------|------------|--------------|--------------|
| KAUAI | HYDRO | H1 | WAILUA RIVER |

H1: Wailua River. Potential hydro projects have been proposed for both the upper and lower Wailua River. The upper Wailua River is dependent on the Hanalei River, however, which is likely to be designated as a special stream by the State of Hawaii. Only the lower Wailua is considered to have any development potential. Development of this project may conflict with existing recreational uses of the river. Until stream designations and development standards are determined, any hydro potential is likely to be stalled. It is expected that a facility with a capacity of approximately 6 MW could be installed.

WAVE AND OTEC

No specific project sites for either wave or ocean thermal on Kauai were identified in this phase of the project. Previous work on the siting of OTEC projects, conducted by PICHTR, indicate that there is sufficient resource (i.e., appropriate bathymetry) for two to three floating OTEC plants off the northern and southern coastlines. One proposed location, near Hanalei is likely to face substantial public opposition. Projects sites near Lihue and Port Allen are more centrally located relative to the load centers and more likely to be developable.

A wave resource has been shown to exist along the northern shore of Kauai. The scenic beauty and protected resources of this area will likely result in significant public opposition to any land-based systems. In addition, limited transmission access exists in this area. Potential for wave energy facilities may be easily sited near Kapaa on the eastern coastline.



SECTION 3. MONITORING PLAN

The purpose of this monitoring plan is to develop a high-quality database that characterizes the wind and solar energy resources in the State of Hawaii in areas that appear to have project development potential. This goal is to be accomplished by identifying potentially developable project sites as described in the previous section, utilizing existing data to the fullest extent practical to characterize these sites, and installing and operating meteorological data monitoring stations where high-quality data are not available. The monitoring stations are to be operated for a minimum of one year.

The approximate equipment costs associated with this monitoring plan total \$61,804, which includes 9 wind monitoring stations, 6 solar monitoring stations, and the hardware and software to transfer the data to an IBM PC. The breakdown of costs per monitoring station, and the overall cost for new equipment are shown in Tables 21 and 22. Equipment specifications and cost quotes from the equipment manufacturers for the monitoring equipment recommended for this program are included in Appendix K.

MONITORING STATIONS

In a previous study for the DBEDT entitled *Comprehensive Review and Analysis of Hawaii's Renewable Energy Resource Assessments*, RLA identified, characterized, and compiled the available wind and solar resource data throughout the State of Hawaii. Existing data and currently active

Table 21. Equipment Costs per Monitoring Station

| WIND STATION | 90' TOWER |
|-----------------------------------|----------------|
| EQUIPMENT DESCRIPTION | NRG 9200-21 |
| LOGGER WITH SPEED & DIRECTION [1] | \$1,610 |
| SECOND ANEMOMETER (CALIBRATED) | NC |
| EXTRA EPROM (256K) | \$40 |
| SHELTER BOX | \$85 |
| TOWER (STAINLESS STEEL) | \$1,650 |
| GROUND KIT | \$50 |
| SUBTOTAL PER STATION | \$3,435 |
| DISCOUNT | 25% |
| TOTAL PER STATION | \$2,576 |

[1] CONFIGURED WITH CALIBRATED ANEMOMETER(S) AND 256K HIP(S).

SOLAR STATION

| EQUIPMENT DESCRIPTION | ASCENTION TECHNOLOGY |
|-----------------------|----------------------|
| RSR UNIT | \$5,700 |
| TRIPOD | \$275 |
| MISC. MATERIALS | \$115 |
| SHIPPING | \$190 |
| TOTAL PER STATION | \$6,280 |

Table 22. Monitoring Equipment Cost Summary

| <u>EQUIPMENT DESCRIPTION</u> | <u>NRG 9200-21 [1]</u> |
|----------------------------------------------------|------------------------|
| 90' WIND STATIONS (2 ANEMOMETERS) - 9 SITES [2] | \$25,051 |
| DIRECT RADIATION STATIONS - 5 SITES [3] | \$31,400 |
| CHIP READER AND ANALYSIS SOFTWARE | \$970 |
| TOTAL EQUIPMENT COST | \$57,421 |
| OPTIONAL LANAI STATIONS - GLOBAL RADIATION STATION | \$1,440 |
| SUBTOTAL WITH OPTIONAL EQUIPMENT [4] | \$58,861 |
| FEE AT 5% | \$2,943 |
| TOTAL EQUIPMENT COST | \$61,804 |

- [1] COST INCLUDES 2 EXTRA EPROMS FOR PROJECT.
- [2] ONE STATION DOES NOT REQUIRE A TOWER.
- [3] QUOTES ARE PER J. AUGUSTYN FOR ASCENSION TECHNOLOGIES EQUIPMENT.
- [4] ALL VALUES INCLUDE THE 25% DISCOUNT AND SHIPPING COSTS.

monitoring stations were identified based on both that review and continued research to identify additional data sets that were not available when the review was compiled. The location of monitoring stations with high-quality data were compared to the wind and solar project sites identified with development potential in order to determine recommend sites where additional monitoring efforts would be useful in characterizing the performance of a project in these sites.

The data sets identified as useful for this study in characterizing the resource of potential project sites are not necessarily inclusive of all data collected in the vicinity of these locations. Many short-term studies have been conducted that document site wind or solar resource characteristics; however, in cases where the data quality was questioned, these data were not considered to be sufficient for accurate energy projection estimates. In some cases, data exist that represent the renewable energy resource at a site, but they are not available to the public. In these cases, the value of further data collection was assessed based on the ability of the data to increase the understanding of the site resource and increase the likelihood that the site will be developable in the future. In recommending locations for additional monitoring sites, the main criterion considered was whether additional data would promote the development of a renewable energy project in the future.

Existing high-quality data sets were obtained from a variety of sources including the Hawaiian Sugar Planters' Association, National Climatic Data Center, Hawaiian electric utility companies, the University of Hawaii, project developers, and private landowners. A summary of the characteristics of the existing data that are planned to be incorporated into this program is contained in Appendix L. In some cases, data collection is no longer continuing. However, if several years of high-quality data were available, additional monitoring in a specific location was generally not recommended. In cases where data collection is continuing, the historical data will be obtained as will the data collected during the planned monitoring program. The intent is to make available to the public high-quality data sets from both the existing and proposed monitoring stations near developable land sites.

The following sections describe the recommended monitoring plan on an island by island basis. Figures 6 through 11 contain maps depicting the potential project sites for wind and solar resource assessment and the locations of existing and proposed monitoring sites that will be incorporated into this program. The associated tables summarize the existing and proposed data sets to be used for wind and solar resource assessment. Detailed site maps for each project site can be found in the appendices of this report.

HAWAII

The existing and proposed monitoring sites for Hawaii are shown and described in Figure 6. Four potential wind energy development sites were identified for Hawaii in the previous section. Of these, additional monitoring is recommended at two sites: North Kohala and Lalamilo. There are no suitable wind data currently available at North Kohala. At Lalamilo, data are being collected by private developers; however, they are not publicly available. The proposed monitoring station at this site is recommended for a location further upwind than the current wind farm to further quantify the resource in that area. For the other two project sites, sufficient data were determined to exist and it appears likely that these data will be available to incorporate into the program.

Three potential solar project sites have been identified. Six existing solar monitoring stations are shown in Figure 6, of which four are currently collecting both global and direct solar radiation data. As a result, additional solar monitoring is recommended only at North Kohala. RLA will ensure that the existing monitoring stations are calibrated and will obtain past data sets as well as collect data on a continuing basis.

MAUI

The existing and proposed monitoring sites for Maui are shown and described in Figure 7. Four potential wind energy development sites were identified for Maui. Of these, additional monitoring is recommended at three sites. Monitoring is not recommended at the West Maui site because the site has been extensively monitored by a private developer. Even though these data may not be publicly available, additional data in this location will not serve to further project development. To represent the northwest slope of Haleakala, monitoring is recommended at the NifTAL facility site so as to use an existing tower and reduce equipment expenses.

Figure 7 depicts three existing data sets of global solar radiation data useful for this project. At the PVUSA satellite project, RLA proposes to supplement the existing global radiation data collection efforts by obtaining direct and diffuse radiation data. Solar monitoring is also proposed for the old Maui airport site at Puunene.

MOLOKAI AND LANAI

The existing monitoring sites for Molokai are shown and described in Figure 8. No additional monitoring sites are proposed for Molokai. One existing wind station provides information as to west Molokai's wind resource, and global and direct solar data have been collected near Palaau.

The existing monitoring sites for Lanai are shown and described in Figure 9. Existing data include global solar data collected at two locations on central Lanai. No additional monitoring sites are proposed for Lanai.


OAHU

The locations of existing and proposed monitoring locations for Oahu are shown and described in Figure 10. Three potential wind energy project sites were identified on Oahu. In the Kahuku Hills, additional data collection was not recommended because a large amount of private data already exists. The publicly available Opana data will be used to estimate production in this area. Additional monitoring was recommended at the two other potential wind energy project locations.

Solar monitoring stations are proposed to represent the Pearl Harbor Blast Zone area near the West Loch. Existing solar data will be used to represent the other identified project sites.

KAUAI

The locations of existing and proposed monitoring locations for Kauai are shown and described in Figure 11. There has been very little resource assessment data collection activity in the past. Three potential wind energy projects were identified and two are recommended for additional monitoring.




HAWAII WIND

| PROJECT SITE | DATA SITE | TIME PERIOD | ANEMOMETER HEIGHT | CONTACT ORGANIZATION |
|----------------|----------------|-----------------|-------------------|----------------------|
| LALAMILO WELLS | KAWAIHAE | 12/90 TO 8/92 | 10,37, &64 METERS | HECO |
| | LALAMILO WELLS | PROPOSED | 90 FEET | |
| NORTH KOHALA | NORTH KOHALA | PROPOSED | 90 FEET | CHALON |
| KAHUA RANCH | KAHUA RANCH | 4/92 TO PRESENT | 90, 140 FEET | KAHUA RANCH |
| SOUTH POINT | SOUTH POINT | 6/87 TO PRESENT | | KAMAOA WIND FARM |

HAWAII SOLAR

| PROJECT SITE | DATA SITE | TIME PERIOD | DATA TYPE | CONTACT ORGANIZATION |
|---------------|-------------------|-------------------|-----------------|----------------------|
| WAIKOLOA | KAWAIHAE | 12/90 TO 8/92 | GLOBAL | HECO |
| | PUUANAHULU | 1/92 TO PRESENT | GLOBAL | HECO |
| | KIHOLO BAY | MID 91 TO PRESENT | GLOBAL; DIRECT | BAKKEN |
| | WAIMEA | 4/93 TO PRESENT | GLOBAL; DIRECT | BAKKEN |
| | MAUNA LANI RESORT | 4/93 TO PRESENT | GLOBAL; DIRECT | BAKKEN |
| KEAHOLE POINT | KEAHOLE | 3/93 TO PRESENT | GLOBAL; DIFFUSE | HECO |
| | KEAHOLE | 1985 TO 1993 | GLOBAL; DIFFUSE | NELH |
| NORTH KOHALA | KAHUA RANCH | 1985 TO PRESENT | GLOBAL | KAHUA RANCH |
| | NORTH KOHALA | PROPOSED | DIRECT; DIFFUSE | CHALON |

Figure 6. Existing and Planned Monitoring Sites for Hawaii




MAUI WIND

| PROJECT SITE | DATA SITE | TIME PERIOD | ANEMOMETER HEIGHT | CONTACT ORGANIZATION |
|--------------------|----------------|-----------------|-------------------|----------------------|
| WEST MAUI | WEST MAUI | 1/92 TO 6/93 | 90, 140 FEET | ZOND |
| MCGREGOR POINT | MAALAEA | 2/93 TO PRESENT | 10, 37, 64 METERS | HECO |
| PUUNENE | MCGREGOR POINT | PROPOSED | 90 FEET | HECO |
| | PUUNENE | 5/92 TO PRESENT | 10 METER | |
| NW SLOPE HALEAKALA | OLD AIRPORT | PROPOSED | 90 FEET | HECO |
| | NIFTAL TOWER | PROPOSED | 90 FEET | |

MAUI SOLAR

| PROJECT SITE | DATA SITE | TIME PERIOD | DATA TYPE | CONTACT ORGANIZATION |
|--------------|--------------|-----------------|-----------------|----------------------|
| PUUNENE | OLD AIRPORT | PROPOSED | DIRECT; DIFFUSE | HECO |
| | PUUNENE | 5/92 TO PRESENT | GLOBAL | |
| KIHEI | PVUSA | 1989 TO PRESENT | GLOBAL | PVUSA |
| | PVUSA | PROPOSED | DIRECT; DIFFUSE | |
| KAHULUI | MAUI QUARRY | 5/92 TO PRESENT | GLOBAL | HECO |
| | MAUINET #107 | 1983 TO 1991 | GLOBAL | |

Figure 7. Existing and Planned Monitoring Sites for Maui




MOLOKAI WIND

| PROJECT SITE | DATA SITE | TIME PERIOD | ANEMOMETER HEIGHT | CONTACT ORGANIZATION |
|--------------------|--------------|-----------------|-------------------|----------------------|
| SMALL APPLICATIONS | WEST MOLOKAI | 2/92 TO PRESENT | 90 FEET | ZOND/DBED |

MOLOKAI SOLAR

| PROJECT SITE | DATA SITE | TIME PERIOD | DATA TYPE | CONTACT ORGANIZATION |
|--------------------|-----------|-----------------|-----------|----------------------|
| SMALL APPLICATIONS | PALAAU | 6/92 TO PRESENT | GLOBAL | HECO |
| | PALAAU | 1/84 TO 6/86 | DIRECT | HECO |


Figure 8. Existing and Planned Monitoring Sites for Molokai



LANAI SOLAR

| PROJECT SITE | DATA SITE | TIME PERIOD | DATA TYPE | CONTACT ORGANIZATION |
|--------------------|------------|---------------------|-----------|----------------------|
| SMALL APPLICATIONS | LANAI CITY | 2/92 TO PRESENT | GLOBAL | HECO |
| | MIKI BASIN | 10/90 TO PRESENT | GLOBAL | HECO |
| | MANELE BAY | PROPOSED (OPTIONAL) | GLOBAL | HECO |

Figure 9. Existing and Planned Monitoring Sites for Lanai




OAHU WIND

| PROJECT SITE | DATA SITE | TIME PERIOD | ANEMOMETER HEIGHT | CONTACT ORGANIZATION |
|--------------|--------------|--------------|-------------------|----------------------|
| KAHUKU HILLS | OPANA | 3/76 TO 2/83 | 37 FEET | UHMET |
| KAHUKU FLATS | KAHUKU FLATS | PROPOSED | 90 FEET | |
| KAENA POINT | KAENA POINT | PROPOSED | 90 FEET | |

OAHU SOLAR

| PROJECT SITE | DATA SITE | TIME PERIOD | DATA TYPE | CONTACT ORGANIZATION |
|--------------|---------------------|-----------------|----------------|----------------------|
| PEARL HARBOR | PEARL HARBOR | PROPOSED | DIRECT;DIFFUSE | |
| N. EWA PLAIN | KUNIA | 1989 TO 1990 | GLOBAL | HSPA |
| EWA PLAIN | CAMPBELL INDUSTRIAL | 4/91 TO PRESENT | GLOBAL | HECO |
| LUALUALEI | KAHE POINT | 1/86 TO 5/87 | GLOBAL | HECO |

Figure 10. Existing and Planned Monitoring Sites for Oahu



KAUAI WIND

| PROJECT SITE | DATA SITE | TIME PERIOD | ANEMOMETER HEIGHT | CONTACT ORGANIZATION |
|------------------------|----------------|--------------|-------------------|----------------------|
| N. OF HANAPEPE | GAY & ROBINSON | 7/85 TO 4/88 | APPROX. 20 FEET | GAY & ROBINSON |
| | N. OF HANAPEPE | PROPOSED | 90 FEET | |
| S. OF KILAUEA/ ANAHOLE | S. OF KILAUEA | PROPOSED | 90 FEET | KECO |
| | PORT ALLEN | 2/92 TO 1/93 | 30 FEET | |

KAUAI SOLAR

| PROJECT SITE | DATA SITE | TIME PERIOD | DATA TYPE | CONTACT ORGANIZATION |
|---------------|---------------|-----------------|----------------|----------------------|
| BARKING SANDS | BARKING SANDS | PROPOSED | DIRECT;DIFFUSE | McbRYDE SUGAR Co. |
| | MCBRYDE | 1/91 TO PRESENT | GLOBAL | |

Figure 11. Existing and Planned Monitoring Sites for Kauai

An existing wind monitoring station that measured high average wind speeds at Kilauea Point is not shown because it is thought not to be representative of developable wind sites in the area. Additional solar monitoring is recommended at Barking Sands.

DATA COLLECTION METHODOLOGY

WIND RESOURCE MEASUREMENT PLAN

To achieve the objective of a reliable resource assessment, the wind resource database developed in this activity must be highly reliable and accurate and consistent in nature across all sites. The wind data will be collected in a manner consistent with the American Wind Energy Association's *Standard Procedure for Meteorological Measurements at a Potential Wind Turbine Site and Recommended Practice for the Siting of Wind Energy Conversion Systems* [25,26].

In order to accurately predict the performance of potential wind energy projects, it is desirable to have data concerning wind speed, direction, and wind shear (change in speed with height above the ground). For nine of the proposed wind monitoring stations, a 90 ft mast tower with data collection at two heights is recommended. Cup anemometers (one at each height) and a single wind vane will be used. A 30 ft tower is recommended for Kaneohe.

FIELD MEASUREMENT EQUIPMENT SELECTION

In order to determine the most appropriate equipment to use for the monitoring program, quotes and product literature were obtained and discussed with well-known manufacturers. Criteria used to decide on the recommended equipment included costs, accuracy, reliability, durability, ease of use, and support from the manufacturer. As a result of this analysis, NRG9200-21 data loggers with two NRG40C calibrated anemometers and one NRG200P direction vane are recommended for use in this project. The data logger and sensors will be mounted on NRG90TT 90 ft or 30 ft tall towers. Hourly average wind speed and most frequent direction will be reported with a resolution of 0.1 mph and 1 direction sector. Data sampling accuracy are +1 -0 mph and ± 4 degrees.

FIELD EQUIPMENT TESTING AND INITIAL CALIBRATION

The equipment will be delivered to Hawaii calibrated and ready for installation. Before installation, the sensors will be inspected to verify that they are in proper functioning condition.

FIELD EQUIPMENT INSTALLATION

Siting

Towers will be located at sites representative of the overall resource of the potential project site and consider factors such as prevailing wind direction and surrounding land forms. Measurements will be taken in an open area, free from heavy vegetation and structures. Nominal anemometer heights will nearly be 30 and 90 ft (actual anemometer heights will be measured and recorded).

Installation

Meteorological measurement sites will be installed according to the manufacturer's instructions regarding field installation, including grounding, sensor wire shielding, and weatherproofing the installation. Particular attention should be paid to ensure that the guy wire anchors are appropriate for the soil conditions. An anemometer is mounted at the top, with an associated wind vane oriented so that a "North" indication of the wind vane indicates true-north rather than magnetic north. The 30 ft anemometer will be mounted on a cross-arm attached to the tower at a distance of at least six tower diameters from the tower into the prevailing trade wind direction. The data logger will be attached to the tower at a height that reduces the likelihood of damage from horses or grazing animals, and will be kept locked at all times that it is left unattended. Barbed wire will be used on the guy wires in grazing areas to dissuade cattle or horses from disturbing the equipment.

FIELD EQUIPMENT MAINTENANCE

During each site visit, the following activities will be performed, and information will be recorded on a Maintenance Report Post Card that will be mailed to RLA:

- Record the date, time, and the name of the person conducting the site visit, and the site visited.
- Visually inspect the physical condition of the entire installation and of the general functioning of the sensors for proper appearance and operation. Record/correct any irregularities.
- Visually inspect the tower assembly, including the guy wire tensions, the vertical trueness of the mast, and the condition of the grounding system. Record/correct any irregularities.
- Check the battery voltage. Replace the batteries as needed, per the logger manufacturer's instructions. Record any changes.
- Check the data logger operation according to the manufacturer's instructions.
- Document any other observations and actions taken under the "Comments" portion.

Site maintenance frequency will initially be at bi-weekly intervals. Because the necessary site maintenance frequency depends on site-specific conditions, data from each site inspection will be carefully analyzed to see if less frequent visits can be made without loss of accuracy. In no event will site maintenance visits be made less frequently than once per month.

DATA COLLECTION AND QUALITY VERIFICATION

Data will be collected from site locations on a monthly basis. A back-up copy of the data chip will be made at the time of data collection. Both chips will be labeled with the monitoring site name, date, and time of collection. One chip will be mailed to RLA. The backup chip will be stored until the next month when it will again be used to back-up the data. In the event that the first chip is lost or damaged, there is a backup.

After receiving the chip at RLA, data will be transferred to an IBM computer in ASCII format. The data will be examined for completeness and reasonableness. Any irregularities will be reported to site personnel immediately, whereupon a site inspection and maintenance visit will be performed in order to ensure a high rate of data recovery and high data quality.

High correlation of wind speeds is expected from the two anemometers on each wind monitoring station. In the event that the monthly record from one of the anemometers experiences a low data recovery rate, accurate estimates should be obtained through extrapolation of data from the other anemometer. The use of two anemometers provides redundancy and ensures accuracy as well as providing wind shear information.

DATA PROCESSING

On a monthly basis, RLA personnel will produce data summaries using NRG's EEREADER software. These summaries will include hourly average wind speeds, wind speed distribution, tabulated wind rose, diurnal wind speed variation, information about turbulence, maximum peak gust, and sustained wind speeds.

SOLAR RESOURCE MEASUREMENT PLAN

The goal of this solar resource measurement effort is to develop a high-quality database of solar irradiance measurements at selected sites over a one year period. In a later project phase, these data will be used as the basis on which to compare and assess the potential of certain renewable energy technologies in different areas of the State. In order to predict station performance, data need to be collected for both direct normal (broad band) irradiance (DNI), and global horizontal diffuse (broad

band) irradiance (DHI), as well as the more commonly and easily measured total global horizontal (broad band) irradiance (GHI).

To achieve the objective of a reliable technology assessment, the solar radiation database developed in this activity must be highly reliable and accurate and consistent in its nature across all sites. The resulting data must also be of known measurement quality, and be directly traceable to World Meteorological Organization (WMO) radiometric reference standards.

These goals will be met through adherence to the following practices and methods:

FIELD MEASUREMENT EQUIPMENT SELECTION

Several possible equipment types were evaluated for collecting solar data. It was determined that use of LICOR Model 200S pyranometers, fitted with automated rotating shadow band mechanisms that allow direct measurement of GHI and DHI, with DNI directly and accurately calculated, offered the best option with regards to cost and accuracy. Selected overall measurement systems must achieve a total measurement uncertainty within $\pm 7.5\%$ for all three broad band components: DNI, DHI, and GHI. Achievement of desired measurement uncertainties are possible with this equipment provided that accurate initial calibrations are performed, and proper installation and maintenance procedures are followed.

FIELD EQUIPMENT PROGRAMMING, TESTING, AND INITIAL RADIOMETER CALIBRATION

Campbell Scientific Model CR10 data loggers will be used to read and store sensor scans and control the rotating shadow band mechanisms. The CR10's will be programmed to measure GHI and DHI and compute DNI once per minute, and to store averages of these parameters every 15 minutes. All time references will be made in local standard time.

Upon receipt of the data loggers and rotating shadow band radiometer (RSR) units, the LICOR 200S pyranometers associated with each unit will be calibrated at Augustyn & Company, Inc.'s (ACI) radiometer calibration test facility in Albany, California. This calibration test will employ the continuous shaded component summation calibration technique drawn from techniques defined in ASTM test standards E816-81 and E913-82 as further refined by the staff of the Solar Resource Assessment Project at the National Renewable Energy Laboratory (NREL) in Golden, Colorado. This technique provides direct traceability to WMO radiometric reference standards via ACI's and NREL's reference instruments. The minimum calibration uncertainty achievable by the ACI calibration facility is $\pm 2.2\%$ for DNI measurements, and approximately 3.5% for GHI measurements. New calibration factors will be derived for each of the new LICOR 200S pyranometers to be used in this project as a result of this initial calibration.

FIELD EQUIPMENT INSTALLATION

Siting

Field measurement equipment will be located so as to preclude or minimize full or partial direct beam shading of the radiometers at any time of day or year. Also, siting will minimize blockage of the diffuse sky dome by any adjacent structures, objects, or local airborne (optical) contaminants. A detailed description of the site will be provided in the report that will accompany the final data delivery. This report will document any site features that might have affected the readings.

Installation Procedures and Practices

In addition to strict adherence to all manufacturer's instructions regarding field installation, including grounding, sensor wire shielding, and weatherproofing the installation, particular attention will be paid to ensuring that the equipment will be mounted to a very secure base to avoid the possibility that the sensor will drift out of level during the course of the measurement period.

FIELD EQUIPMENT MAINTENANCE

Periodic site maintenance activities will include:

- Visual inspection of the physical condition of the entire installation and of the general functioning of the rotating mechanism for proper appearance and operation.
- Visual inspection and written notes on the appearance of the sensor surface.
- Cleaning the sensor surface with distilled or deionized water and a soft cloth or tissue.
- Completing and mailing a Maintenance Report Post Card, documenting observations and date and time of cleaning.

Site maintenance frequency will initially be at one week intervals. Because the necessary site maintenance frequency depends on site-specific conditions, data from each site inspection will be carefully analyzed to see if less frequent visits can be made while maintaining our overall goal for measurement uncertainty. In no event will site maintenance visits be made less frequently than once per month.


DATA COLLECTION AND QUALITY VERIFICATION

Each monitoring station will be equipped with a telephone modem and phone line. Data will be retrieved automatically each night from each site by a computer in ACI's Albany, California, office. The retrieved data files will then be run through ACI's Data Verification Systems (DVS), which will perform a variety of tests to assess data quality and proper functioning of the site units. Included in these tests will be the two- and three-component solar irradiance data quality control test devised by NREL called "SERI QC." DVS will assign a multi-component data quality flag to each data value retrieved, indicating both the results of tests made and the exact nature of any modification made to a data value. Data will be delivered both with and without data quality flags as generated by DVS.

Once DVS has completed its automatic data quality screening, ACI personnel will review the results, and immediately contact site maintenance personnel if any remedial action is necessary. Daily, automated data collection and quality assessment will therefore minimize the total amount of missing or lost data.

DATA SUMMARIZATION AND DELIVERY

On a monthly basis, ACI personnel will produce data summaries using DVS. These will include daily totals and maximums for each irradiance parameter for each day of the month. Data for all sites will be delivered on diskette on a quarterly basis in ASCII files in MSDOS format. For each site, two files will be delivered, one will contain both the data and the associated data quality flags assigned by DVS, while the second file will contain the data without the flags.




REFERENCES


1. Hagerman, George (SEASUN Power Systems). *Wave Energy Resource and Economic Assessment for the State of Hawaii*. Prepared for the State of Hawaii Department of Business, Economic Development & Tourism, June 1992.
2. Schroeder, T.A., A.M. Hori, D.L. Elliott, W.R. Barchet, and R.L. George. *Wind Energy Resource Atlas: Vol. 11 - Hawaii and Pacific Islands Region*. Pacific Northwest Laboratory, PNL-3195 WERA-11 UC-60, 1981.
3. Elliott, D.L., C.G. Holladay, W.R. Barchet, H.P. Foote, and W.F. Sandusky. *Wind Energy Resource Atlas of the United States*. DOE/CH 10093-4, October 1986.
4. R. Lynette & Associates. *Comprehensive Review and Analysis of Hawaii's Renewable Energy Assessments*. Prepared for the State of Hawaii Department of Business, Economic Development & Tourism. April 1992.
5. Kearney & Associates. *Solar Electric Generating System (SEGS) Assessment for Hawaii - Draft Final Report*. State of Hawaii Contract #32639, prepared for the State of Hawaii Department of Business, Economic Development & Tourism. December 1992.
6. Unisyn Biowaste Technology. *Feasibility Study of Organic Waste Conversion Facilities in Hawaii -- Draft Report*. Prepared for the Department of Business, Economic Development & Tourism, 1993.
7. Hawaii Cooperative Park Service Unit, Western Region Natural Resources and Research Division, National Park Service. *Hawaii Stream Assessment, A Preliminary Appraisal of Hawaii's Stream Resources*. Prepared for the Commission for Water Resource Management, State of Hawaii, Report R84, December 1990.
8. *State Energy Resource Coordinator's Annual Report, Fiscal Year 1988-1989*. Department of Business, Economic Development & Tourism.
9. Department of Business, Economic Development & Tourism Memo from MHK to LSM & RAU, November 9, 1990.
10. General information and discussions with NELH personnel.
11. General information and discussions with PICHTR personnel.
12. Singh, D., V.D. Phillips, R.A. Merriam, M.A. Khan, and P.K. Takahashi. "Identifying Land Potentially Available for Biomass Plantations in Hawaii." *Agricultural Systems*. Elsevier Science Publishers Ltd. 0308-521X/92. 1992.
13. State of Hawaii, Office of the Governor, Office of State Planning. *State Land Use District Boundary Review, Executive Summary, Oahu*. 1992.
14. State of Hawaii, Office of the Governor, Office of State Planning. *State Land Use District Boundary Review, Executive Summary, Hawaii*. 1992.
15. State of Hawaii, Office of the Governor, Office of State Planning. *State Land Use District Boundary Review, Executive Summary, Kauai*. 1992.

16. State of Hawaii, Office of the Governor, Office of State Planning. *State Land Use District Boundary Review, Executive Summary, Maui*. 1992.
17. Skolmen, R.G. *Performance of Australian provenances of Eucalyptus grandis and Eucalyptus saligna in Hawaii*. Research Paper PSW-181. USDA Forest Service, Pacific Southwest Forest and Range Experiment Station, Berkeley, California, 1986.
18. Whitesell, C.D., D.S. DeBell, T.H. Schubert, R.F. Strand, and T.B. Crabb. *Short-Rotation Management of Eucalyptus: Guidelines for Plantations in Hawaii*. Gen. Tech. Rep. PSW-GTR-137. Albany, California: Pacific South Research Station, Forest Service, U.S. Department of Agriculture, 1992.
19. Yost, R.S., D.S. DeBell, C.D. Whitesell, and S.C. Miyasaka. "Early growth and nutrient status of *Eucalyptus saligna* as affected by nitrogen and phosphorus fertilization." *Australian Forestry Research*, 17, 203-214, 1987.
20. BioEnergy Development Corporation. "*Eucalyptus* Plantations for Energy Production in Hawaii." Annual reports to the U.S. Department of Energy, 1980-1986.
21. Crabb, T.B. "*Eucalyptus* plantations for energy in Hawaii: ten years later." BioEnergy Development Corporation story, 1988.
22. DeBell, D.S., C.D. Whitesell, and T.H. Schubert. "Using N₂-fixing albizia to increase growth of *Eucalyptus* plantations in Hawaii." *Forest Science*, 35, 64-75, 1989.
23. Dudley, N.S. *Performance and Management of Fast Growing Tropical Trees in Diverse Hawaii Environments*. MS thesis, Agronomy and Soil Science Department, University of Hawaii at Manoa, 1990.
24. Osgood, R.V. and N.S. Dudley. *Establishment of biomass-to-energy research facilities*. In Hawaii Integrated Biofuels Research Program - Phase III Annual Report. Subcontract No. XN-0-19164-1. Hawaii Natural Energy Institute, University of Hawaii at Manoa, 1990.
25. Wind Energy Procedures for Meteorological Measurements at a Potential Wind Turbine Site (AWEA 8.1-1986)
26. Recommended Practice for the siting of Wind Energy Conversion Systems (AWEA 8.2 - 1993)

APPENDIX A

PRELIMINARY LAND ZONING MAPS





LAND ZONING
ON MOLOKAI

- Conservation
- Urban
- Agriculture
- Rural

21° 15' 0"

21° 7' 30"

21° 0' 0"


157° 16' 0"


157° 8' 30"


157° 1' 0"


156° 53' 30"

156° 46' 0"










APPENDIX B

PRELIMINARY LAND OWNERSHIP MAPS


LAND OWNERSHIP
ON HAWAII

- State
- Hawaiian Homes Comm.
- Federal
- Private



20° 15'
20° 5'
19° 55'
19° 45'
19° 35'
19° 25'
19° 15'
19° 5'
18° 55'

156° 5' 155° 55' 155° 45' 155° 35' 155° 25' 155° 15' 155° 5' 154° 55' 154° 45'




LAND OWNERSHIP
ON MOLOKAI

- State
- Hawaiian Homes Comm.
- Federal
- Private

21° 15' 0"

21° 7' 30"

21° 0' 0"



157° 16' 0"

157° 8' 30"


157° 1' 0"

156° 53' 30"

156° 46' 0"

LAND OWNERSHIP
ON OAHU

- State
- Hawaiian Homes Comm.
- Federal
- Private



21° 39' 0"

21° 31' 30"


21° 24' 0"

21° 16' 30"

158° 15' 0" 158° 7' 30" 158° 0' 0" 157° 52' 30" 157° 45' 0"

LAND OWNERSHIP
ON KAUAI

- State
- Hawaiian Homes Comm.
- Federal
- Private



22° 7' 30"

22° 0' 0"

21° 52' 30"

159° 45' 0"

159° 37' 30"


159° 30' 0"

159° 22' 30"


APPENDIX C

ELECTRIC UTILITY INFORMATION


The following appendix contains information concerning the State of Hawaii's electric utilities, including system transmission maps, diurnal load diagrams, graphs of peak monthly demand, and tables describing the utilities' system resource plans.



HAWAII ELECTRIC LIGHT CO., INC. TRANSMISSION LINES



HELCO Typical Daily Load Profiles by Season (based on projected 1990 data)



HELCO Peak Demand by Month (based on projected 1990 data)

HELCO System Resource Plan

| Year | System Peak (MW) | System Capacity (MW) | Reserve Margin (%) | Unit | Capacity Modifications | |
|------|------------------|----------------------|--------------------|-----------------------------------------|------------------------|------------|
| | | | | | Retired (MW) | Added (MW) |
| 1991 | 145 | 161.80 | 10.8 | - | - | - |
| 1992 | 152 | 186.80 | 22.9 | PGV Geothermal | - | 25.00 |
| | | 206.80 | 36.1 | Puna CT-3 | - | 20.00 |
| | | 197.80 | 30.1 | Kanoelehua CT-1 | 9 | - |
| 1993 | 163 | 197.00 | 20.9 | Waimea D-8 | 0.80 | - |
| | | 196.10 | 20.3 | Waimea D-9 | 0.90 | - |
| | | 195.10 | 19.7 | Waimea D-10 | 1.00 | - |
| 1994 | 171 | 215.10 | 25.8 | CT-4 | - | 20.00 |
| 1995 | 180 | 211.70 | 17.6 | Shipman 1 | 3.40 | - |
| | | 209.70 | 16.5 | Kanoelehua D-11 | 2.00 | - |
| | | 206.95 | 15.0 | Waimea D-12 | 2.27 | - |
| 1996 | 186 | 226.95 | 22.0 | CT-5 | - | 20.00 |
| 1997 | 194 | 215.95 | 11.3 | Waimea D-13, 14 & Kanoelehua D-15, 16 | 11.00 | - |
| 1998 | 202 | 231.95 | 14.8 | Convert CT-4 & CT-5 to Combined-cycle-1 | - | 16 |
| | | 229.20 | 13.5 | Kanoelehua D-17 | 2.75 | - |
| 1999 | 209 | 249.20 | 19.2 | CT-6 | - | 20.00 |
| | | 243.70 | 16.6 | Keahole D-18, 19 | 5.50 | - |
| 2000 | 215 | 271.70 | 26.4 | Combined-cycle 2 ph 1 | - | 28.00 |
| | | 260.70 | 21.3 | Keahole D-20, 21, 22, 23 | 11.00 | - |
| 2001 | 226 | 260.70 | 15.4 | - | - | - |
| 2002 | 234 | 288.70 | 23.4 | Combined-cycle 2 Ph2 | - | 28.00 |
| 2003 | 243 | 288.70 | 18.8 | - | - | - |
| 2004 | 253 | 288.70 | 14.1 | - | - | - |
| 2005 | 262 | 316.70 | 20.9 | Combined-cycle 3 Ph1 | - | 28.00 |
| | | 309.20 | 18.0 | Shipman 3 | 7.50 | - |
| 2006 | 272 | 337.20 | 24.0 | Combined-cycle 3 Ph2 | - | 28.00 |
| 2007 | 283 | 337.20 | 19.2 | - | - | - |
| 2008 | 293 | 329.50 | 12.5 | Shipman 4 | 7.70 | - |
| 2009 | 304 | 349.50 | 15.0 | CT-7 | - | 20.00 |
| 2010 | 316 | 377.50 | 19.5 | Combined-cycle 4 Ph1 | - | 28.00 |
| 2011 | 325 | 377.50 | 16.2 | - | - | - |


Maui Electric Company (MECO) - System Transmission Map


MAUI ELECTRIC CO., LTD.

ISLAND OF MAUI


Scale: 1 inch = 1 mile
 Date: 1958
 Project: MECO System Expansion
 Drawing No. ME-1000

LEGEND
 (Symbol) Description
 (Symbol) Description
 (Symbol) Description






MECO Typical Daily Load Profiles by Season (based on projected 1990 data)




MECO Peak Demand by Month (based on projected 1990 data)


MECO System Resource Plan

| Year | System Peak (MW) | System Capacity (MW) | Reserve Margin (%) | Unit | Capacity Modifications | |
|------|------------------|----------------------|--------------------|-----------------------|------------------------|------------|
| | | | | | Retired (MW) | Added (MW) |
| 1991 | 149 | 159.3 | 6.9 | - | - | - |
| 1992 | 162 | 179.3 | 10.7 | Maalaea Unit 14 | - | 20 |
| 1993 | 171 | 199.3 | 16.5 | Maalaea Unit 16 | - | 20 |
| | | 215.3 | 25.9 | Maalaea Unit 15 | - | 16 |
| 1994 | 179 | 215.3 | 20.3 | - | - | - |
| 1995 | 187 | 235.3 | 25.8 | 56MW DTCC #2 Ph 1 | - | 20 |
| 1996 | 194 | 232.6 | 19.9 | Maalaea Unit 1 | 2.75 | - |
| 1997 | 200 | 252.6 | 26.3 | 56MW DTCC #2 Ph 2 | - | 20 |
| | | 247.1 | 23.5 | Maalaea Unit 2 & 3 | 5.5 | - |
| 1998 | 207 | 263.1 | 27.1 | 56MW DTCC #2 Ph 3 | - | 16 |
| | | 257.2 | 24.2 | Kahului Unit 1 | 5.9 | - |
| 1999 | 213 | 277.2 | 30.1 | Combustion Turbine #3 | - | 20 |
| | | 271.2 | 27.3 | Kahului Unit 2 | 6 | - |
| | | 255.2 | 19.8 | HC&S 16MW Contract | 16 | - |
| 2000 | 220 | 283.2 | 28.7 | 56MW DTCC #3 Ph 1 | - | 28 |
| 2001 | 228 | 283.2 | 24.2 | - | - | - |
| 2002 | 235 | 311.2 | 32.4 | 56MW DTCC #3 Ph 2 | - | 28 |
| 2003 | 243 | 298.8 | 23.0 | Maalaea Units 4&5 | 12.32 | - |
| 2004 | 251 | 318.8 | 27.0 | Combustion Turbine #4 | - | 20 |
| | | 306.1 | 22.0 | Kahului Unit 3 | 12.7 | - |
| 2005 | 259 | 334.1 | 29.0 | 56MW DTCC #4 Ph 1 | - | 28 |
| | | 321.8 | 24.3 | Maalaea Units 6&7 | 12.32 | - |
| 2006 | 268 | 321.8 | 20.1 | - | - | - |
| 2007 | 277 | 349.8 | 26.3 | 56MW DTCC #4 Ph 2 | - | 28 |
| | | 343.6 | 24.1 | Maalaea Unit 8 | 6.16 | - |
| 2008 | 286 | 337.5 | 18.0 | Maalaea Unit 9 | 6.16 | - |
| 2009 | 295 | 357.5 | 21.2 | Combustion Turbine #5 | - | 20 |
| | | 343.7 | 16.5 | Maalaea Unit 10 | 13.75 | - |
| 2010 | 305 | 371.7 | 21.9 | 56MW DTCC #5 Ph 1 | - | 28 |
| | | 358.0 | 17.4 | Maalaea Unit 11 | 13.75 | - |
| 2011 | 315 | 386.0 | 22.5 | 56MW DTCC #5 Ph 2 | - | 28 |






— 34KV LINE



MOECO Typical Daily Load Profiles by Season (based on historical data for 1989)




MOECO Peak Demand by Month (based on projected 1991 data)

HEI Hawaiian Electric Industries, Inc.
HAWAIIAN ELECTRIC CO., INC.
ISLAND OF OAHU

LEGEND


- POWER LINES
- TELEPHONE LINES
- WATER MAINS
- SEWER MAINS
- GAS MAINS
- RAILROADS
- HIGHWAYS
- AIRWAYS
- CANALS
- DRAINAGE CANALS
- FLOOD CONTROL CANALS
- IRRIGATION CANALS
- TRENCHES
- DITCHES
- EROSION CONTROL
- LANDSLIDE CONTROL
- FLOOD CONTROL
- OTHER

- 10 AMP
- 5 AMP
- 2 AMP
- 1 AMP
- 0.5 AMP
- 0.2 AMP
- 0.1 AMP




8403E

© 1988 Hawaiian Electric Industries, Inc.




HECO Typical Daily Load Profiles by Season (based on projected 1990 data)



HECO Peak Demand by Month (per Forecast Planning Committee's 1990 peak load forecast, 5/11/90)


Hawaiian Electric Company (HECO) System Resource Plan

| Year | System Peak (MW) | System Capacity (MW) | Reserve Margin (%) | Unit | Capacity Modifications | |
|------|------------------|----------------------|--------------------|----------------------|------------------------|------------|
| | | | | | Retired (MW) | Added (MW) |
| 1991 | 1141 | 1440 | 26.2 | | | |
| 1992 | 1217 | 1620 | 33.1 | AES | - | 180 |
| | | 1666 | 36.9 | H-POWER | - | 46 |
| 1993 | 1254 | 1666 | 32.9 | - | - | - |
| 1994 | 1285 | 1610 | 25.3 | Honolulu 8 | 56 | - |
| | | 1553 | 20.9 | Honolulu 9 | 57 | - |
| 1995 | 1309 | 1620 | 23.8 | Barbers Point 1, Ph1 | - | 70 |
| | | 1620 | 29.1 | Barbers Point 1, Ph2 | - | 70 |
| 1996 | 1340 | 1750 | 30.6 | Barbers Point 1, Ph3 | - | 60 |
| 1997 | 1378 | 1750 | 27.0 | - | - | - |
| 1998 | 1406 | 1827 | 29.9 | Combustion Turbine 1 | - | 77 |
| 1999 | 1435 | 1827 | 27.3 | - | - | - |
| 2000 | 1464 | 1827 | 24.8 | - | - | - |
| 2001 | 1488 | 2027 | 36.2 | Fluidized Bed 1 | - | 200 |
| 2002 | 1513 | 2027 | 34.0 | - | - | - |
| 2003 | 1538 | 2027 | 31.8 | - | - | - |
| 2004 | 1563 | 2027 | 29.7 | - | - | - |
| 2005 | 1589 | 2027 | 27.6 | - | - | - |
| 2006 | 1617 | 2027 | 25.4 | - | - | - |
| 2007 | 1646 | 2227 | 35.3 | Fluidized Bed 2 | - | 200 |
| 2008 | 1675 | 2175 | 29.9 | Waiiau 9 | 52 | - |
| | | 2125 | 26.9 | Waiiau 10 | 50 | - |
| 2009 | 1705 | 2202 | 29.1 | Combustion Turbine 2 | - | 77 |
| 2010 | 1736 | 2153 | 24.0 | Waiiau 3 | 49 | - |
| | | 2104 | 21.2 | Waiiau 4 | 49 | - |
| 2011 | 1767 | 2181 | 23.4 | Combustion Turbine 3 | - | 77 |




CITIZENS UTILITIES COMPANY
 KAUI ELECTRIC DIVISION
 ELECTRIC POWER SYSTEM
 ISLAND OF KAUI


KAUI



- STATION CODE**
- 57KV TRANSMISSION LINE
 - FUTURE 57KV TRANS. LINE
 - POWER PLANT
 - SUBSTATION - KE
 - SUBSTATION - OTHER
 - * LOAD



KE Typical Daily Load Profiles by Season (based on historical data for 1990)



KE Peak Demand by Month (based on historical data for 1990)

Kauai Electric System Resource Plan

| Year | System Peak (MW) | System Capacity (MW) | Reserve Margin (%) | Unit | Capacity Modifications | |
|------|------------------|----------------------|--------------------|------------|------------------------|------------|
| | | | | | Retired (MW) | Added (MW) |
| 1991 | 69.8 | 108.3 | 55.2 | | | |
| 1992 | 73.7 | 108.3 | 46.9 | - | - | - |
| 1993 | 78.7 | 108.3 | 37.6 | - | - | - |
| 1994 | 83.6 | 108.3 | 30.0 | - | - | - |
| 1995 | 87.6 | 123.9 | 41.4 | additions* | - | 15.6 |
| 1996 | 91.5 | 123.9 | 35.4 | - | - | - |
| 1997 | 95.5 | 123.9 | 29.7 | - | - | - |
| 1998 | 99.4 | 123.9 | 24.6 | - | - | - |
| 1999 | 103.4 | 139.5 | 34.9 | additions | - | 15.6 |
| 2000 | 107.3 | 139.5 | 30.0 | - | - | - |
| 2001 | 111.3 | 139.5 | 25.3 | - | - | - |
| 2002 | 115.2 | 139.5 | 21.1 | - | - | - |
| 2003 | 118.2 | 155.1 | 31.2 | additions | - | 15.6 |
| 2004 | 123.1 | 155.1 | 26.0 | - | - | - |
| 2005 | 127.1 | 155.1 | 22.0 | - | - | - |
| 2006 | 131.0 | 155.1 | 18.4 | - | - | - |
| 2007 | 135.0 | 170.7 | 26.4 | additions | - | 15.6 |
| 2008 | 138.9 | 170.7 | 22.9 | - | - | - |
| 2009 | 142.9 | 170.7 | 19.5 | - | - | - |
| 2010 | 146.8 | 170.7 | 16.3 | - | - | - |

* system capacity total includes a 12 MW firm power contract with the Lihue Power Plant

APPENDIX D

**ENVIRONMENTAL AND CULTURAL RATINGS
OF POTENTIAL PROJECT SITES**

Table of Environmental/Cultural Conflict Levels for Potential Renewable Energy Sites

| Project Identification | | | | Conflict Level | Environmental Concerns | Cultural Concerns |
|------------------------|---------|-------|-----------------------|----------------|--------------------------------------|-----------------------------|
| W1 | Hawaii | Wind | Lalamilo Wells | 2 | | agricultural terraces |
| W2 | Hawaii | Wind | North Kohala | 4 | | nearby cultural sites |
| W3 | Hawaii | Wind | Kahua Ranch | 2 | rare native communities | agricultural terraces |
| W4 | Hawaii | Wind | Southpoint | 1 | anchialine pools | known cultural sites |
| S1 | Hawaii | Solar | Waikoloa | 3 | anchialine pools & lava caves | many sites makai of highway |
| S2 | Hawaii | Solar | Keahole Point | 4 | | nearby cultural sites |
| S3 | Hawaii | Solar | North Kohala | 4 | | nearby cultural sites |
| O1 | Hawaii | OTEC | Keahole Point | 4 | coral reef communities | |
| W1 | Maui | Wind | West Maui | 3 | rare & endangered species | known cultural sites |
| W2 | Maui | Wind | McGregor Point | 5 | | |
| W3 | Maui | Wind | Puunene (old airport) | 5 | | |
| W4 | Maui | Wind | NW slope-Haleakala | 5 | | |
| S1 | Maui | Solar | Puunene (old airport) | 5 | | |
| S2 | Maui | Solar | Kihei | 3 | rare plants & lava tubes | |
| S3 | Maui | Solar | Kahului Airport | 5 | | |
| W1 | Molokai | Wind | West Molokai | 5 | | |
| S1 | Molokai | Solar | West Molokai | 5 | | burial grounds, adze quarry |
| W1 | Lanai | Wind | Shipwreck Beach | 4 | rare & endangered species | |
| S1 | Lanai | Solar | Manele Bay | 3 | native plants | scattered sites |
| W1 | Oahu | Wind | Kahuku Hills | 3 | endangered waterbirds | |
| W2 | Oahu | Wind | Kahuku Flats | 3 | endangered waterbirds | known cultural sites |
| W3 | Oahu | Wind | Kaena Point | 2 | endangered waterbirds | |
| W4 | Oahu | Wind | Kanoeha | n/a | not available | not available |
| S1 | Oahu | Solar | Pearl Harbor | 4 | endangered waterbirds | early fishponds |
| S2 | Oahu | Solar | Lualualei | n/a | not available | not available |
| S3 | Oahu | Solar | N. Ewa Plain | 5 | | |
| S4 | Oahu | Solar | Ewa Plain | 4 | endangered plants & anchialine pools | |
| O1 | Oahu | OTEC | Kahe Point | 3 | coral reef communities | |
| W1 | Kauai | Wind | N. of Hanapepe | 4 | rare species | |
| W2 | Kauai | Wind | S. of Kilauea/Anahola | 3 | endangered waterbirds | |
| W3 | Kauai | Wind | Port Allen | 1 | native species | burial sites |
| S1 | Kauai | Solar | Barking Sands | 2 | endangered waterbirds | known cultural sites |

Conflict Levels:

- 1 high conflict, resolution highly unlikely
- 2 high conflict, resolution likely with extensive adjustments
- 3 medium conflict, resolution likely with minor adjustments
- 4 minor conflict, resolution likely with no adjustments
- 5 no foreseeable conflict


Notes:

All biomass projects considered acceptable (level 5) because of siting on current agricultural land.
 All hydroelectric projects considered to have the highest level of conflict (level 1)
 The conflict levels assigned here reflect the opinion of R. Lynette & Associates based on current levels of research and investigation. Further input from Hawaiian communities near the potential project sites would likely alter the currently assessed rating levels.

APPENDIX E

HAWAII SITE MAPS

| | |
|---------------------------|-----------------------|
| Hawaii W1 | Lalamilo Wells |
| Hawaii W2 & S3 | North Kohala |
| Hawaii W3 | Kahua Ranch |
| Hawaii W4 | South Point |
| Hawaii S1 | Waikoloa |
| Hawaii O1 & S2 | Keahole Point |






Hawaii W2 & S3 -- North Kohala
Quad Maps: Mahukona, Hawi





Scale 1:24,000


Miles: 1/2

Zoning: Agriculture
 Land Owner: Chalton

-  Potential Wind & Solar Site
-  Proposed Wind Monitoring
-  Proposed Solar Monitoring (Global and Diffuse)











Hawaii W4 -- Southpoint
 Quad Maps: Kahuku Ranch, Ka Lae

Scale 1:24,000

Miles: 

Zoning: Agriculture
 Land Owner: Bishop/Campbell


-  Existing Wind Site
-  Existing Wind Monitoring




APPENDIX F

MAUI SITE MAPS


| | |
|-------------------------|------------------------------|
| Maui W1 | West Maui |
| Maui W2 | McGregor Point |
| Maui W3 | NW Slope of Haleakala |
| Maui W4 & S1 | Puunene |
| Maui S2 | Kihei |
| Maui S3 | Kahului Airport |









Maui W2 -- McGregor Point
 Quad Maps: Maalaea


Scale 1:24,000


Miles: 

Zoning: Conservation (R,G)
 Land Owner: State

-  Potential Wind Area
-  Proposed Wind Monitoring
-  Existing Wind Monitoring










Maui S2 -- Kihei
 Quad Maps: Puu O Kali

Scale 1:30,000


Miles: 

Zoning: Agriculture
 Land Owner: Haleakala Ranch

 Potential Solar Site
 (representative)

 Existing and Proposed Solar
 Monitoring (Global & Diffuse)
 PVUSA

↑
N



Maui S3 -- Kahului Airport

Quad Maps: Paia

Scale 1:24,000

Miles:

Zoning: Agriculture

Land Owner: HC&S

Potential Solar Site


Existing Solar Monitoring (Global)

APPENDIX G

MOLOKAI AND LANAI SITE MAPS

Molokai W1 & S1
Lanai W1


West Molokai
Shipwreck Beach





APPENDIX H


OAHU SITE MAPS


| | |
|----------------|--------------------------------|
| Oahu W1 | Kahuku Hills |
| Oahu W2 | Kahuku Flats |
| Oahu W3 | Kaena Point |
| Oahu S1 | Pearl Harbor Blast Zone |
| Oahu S2 | North Ewa Plain |
| Oahu S3 | Lualualei |
| Oahu O1 | Kahe Point |




















APPENDIX I


KAUAI SITE MAPS


| | |
|-----------------|--------------------------|
| Kauai W1 | North of Hanapepe |
| Kauai W2 | Anahola |
| Kauai W3 | South of Kilauea |
| Kauai S1 | Barking Sands |











Kauai S1 -- Barking Sands


Quad Maps: Kekaha


Scale 1:30,000

Miles: 




Zoning: Agriculture, Conservation (L)
Land Owner: Federal


 Potential Solar Site
(representative)


 Proposed Solar Monitoring


APPENDIX J


BIOMASS PROJECT MAPS

















E. saligna YIELD
(dry Mg/ha)
CENTRAL AGRICULTURE AREA

2000 trees/ha
0.15 kg FN/tree
6 years

-  108 - 144 237 ha
-  144 - 180 22 ha
-  180 - 240 36 ha
-  Power Plant

MOLOKAI

21° 22' 30"

21° 15' 0"

21° 7' 30"

21° 0' 0"


157° 16' 0"


157° 8' 30"

157° 1' 0"

156° 53' 30"

156° 46' 0"






HAWAII

REGIONAL ESTIMATES OF ORGANIC WASTE PRODUCTION (tons per year)

Source: Unisyn Biowaste Technology, 1993.


| REGION SURVEYED | OPPORTUNITY |
|-----------------|-------------|
| G | 9,249 |
| H | 25,044 |
| I | 118,115 |
| J | 11,570 |
| K | 13,618 |
| Z* | 3,250 |
| | 28,564 |
| | 41,519 |
| | 122,306 |
| | 49,656 |
| | 16,048 |
| | 12,240 |

* (not assigned to any one region)



MAUI REGIONAL ESTIMATES of ORGANIC WASTE PRODUCTION (tons per year)

Source: Unisyn Biowaste Technology, 1993.




CITY & COUNTY of HONOLULU

REGIONAL ESTIMATES of ORGANIC WASTE PRODUCTION (tons per year)

Source: Unisyn Biowaste Technology, 1993.

| REGION | SURVEYED | OPPORTUNITY |
|--------|----------|-------------|
| A | 35,782 | 282,214 |
| B | 58,669 | 137,160 |
| C | 272,141 | 346,046 |
| D | 40,019 | 89,812 |
| E | 5,842 | 18,121 |
| F | 46,430 | 131,424 |
| Z* | 22,311 | 38,520 |

* (not assigned to any one region)





KAUAI

REGIONAL ESTIMATES of ORGANIC WASTE PRODUCTION (tons per year)

| REGION | SURVEYED | OPPORTUNITY |
|--------|----------|-------------|
| L | 5,000 | 9,095 |
| M | 19,946 | 30,203 |
| N | 3,680 | 14,396 |
| O | 26,469 | 35,553 |
| P | 96 | 5,136 |
| Z* | 0 | 6,840 |

* (not assigned to any one region)

Source: Unisyn Biowaste Technology, 1993.



APPENDIX K

EQUIPMENT SPECIFICATIONS AND QUOTES



110 Commerce Street, Hinesburg, VT 05461 USA • (802) 482-2255 • FAX (802) 482-2272 • TELEX 650-313-4621 MCI UW

DATE: May 28, 1992

TO: Robert Poore
R. LYNETTE & ASSOCIATES
15042 NE 40th Street
Suite 206
Redmond
WA

FAX #: 206-881-8468
PHONE #: 206-885-0206

FROM: Gregory Erdmann, International Sales

NUMBER OF PAGES INCLUDING COVER: 1

SUBJECT: NRG SYSTEM-1

Robert,

Please excuse the lateness of this fax, I had been waiting on better shipping prices to Hawaii. There are two reasons why I write this letter to you:

1) NRG Systems hereby grants R. Lynette and Associates a 10% discount on all equipment bought directly through us. You may add the standard quantity discounts as well as the usual 5% prepayment discount on top of this.

2) A "ballpark" figure on your two request for complete NRG Systems wind measuring stations with the option of two different heights:

- a) Shipping 10 SYSTEM-1 (10 Meter Tall Towers) to Honolulu, Hawaii: Approximately: \$625.00
- b) Shipping 10 SYSTEM-1 (30 Meter Tall Towers) to Honolulu, Hawaii: Approximately: \$1850.00

Please notice the next page for a description of our SYSTEM-1, it is basically what you requested. If you need a more detailed quotation, I will happy to send one to you. In fact, I would prefer to send you an official quotation when you decide on your exact requirements.

I look forward to hearing from you,

Sincerely,

Gregory S. Erdmann
International Sales Director



110 Commerce Street, Hinesburg, VT 05461 USA • (802) 482-2255 • FAX (802) 482-2272 • TELEX 650-313-4621 MCI UW

NRG SYSTEMS PRICE LIST: U.S.A. & CANADA

October 1992

9200 Series NRG Loggers

All 9200 NRG Loggers include (2) 9V batteries, (1) 64K DataChip, 60' cable per sensor, and mounting stub masts. All speed and direction sensors are included according to model number. Please specify cable length requirements.

| MODEL # | | PRICE |
|---------|----------------------------------------------------------|----------|
| 9200-00 | NO SENSORS | \$950.00 |
| 9200-01 | 1 SPEED | 1050.00 |
| 9200-11 | 1 SPEED, 1 DIRECTION | 1220.00 |
| 9200-21 | 2 SPEED, 1 DIRECTION | 1320.00 |
| 9200-22 | 2 SPEED, 2 DIRECTION | 1480.00 |
| PAK-2 | DATALOG2 DATA ANALYSIS SOFTWARE WITH EEREADER2 | 970.00 |
| PAK-1 | DL9200 BASIC READING SOFTWARE | 500.00 |

Options:

Add \$120.00 per #40C Calibrated Anemometer
 Add \$25.00 per logger configured for 256K DataChip

9300 Series Advanced Data Acquisition Systems

All #9300 NRG Loggers include (1) 256K Byte FLASH card, 6 pulse counting channels, and 6 analog channels. Please add the appropriate sensors below to configure your particular system.

| MODEL# | | PRICE | |
|---------|----------------------------------------------------------------------------------------|-----------|----------------------------------------------------------------------------------------------------------|
| 9300SA | Stand Alone Logger | \$1490.00 | Includes (2) 9V alkaline batteries, (1) 256K Byte FLASH Card, no sensors |
| 9300 CL | CELLogger Cellular Data Logger | \$2470.00 | Includes internal 12V battery, 5 Watt PV panel, (1) 256K Byte FLASH Card, steel shelter box, no sensors. |
| PAK-3 | BaseStation Data Management Software with CardReader for 9300 Series Loggers | \$ 800.00 | |
| MODEM24 | Internal PC modem for 9300CL CELLogger | \$ 00.00 | |

Sensors

| MODEL # | | PRICE |
|----------|--------------------------------------------------------------|--------|
| 40 | WIND SPEED ANEMOMETER with rubber boot | 75.00 |
| 40C | CALIBRATED ANEMOMETER with rubber boot | 195.00 |
| 40H | HALL EFFECT ANEMOMETER with rubber boot | 90.00 |
| 200P | NRG PRECISION WIND DIRECTION VANE with rubber boot | 145.00 |
| 05103 | R.M. YOUNG Wind Monitor PROP VANE | 675.00 |
| 100S | NRG TEMPERATURE PROBE WITH RADIATION SHIELD | 175.00 |
| LI-200SA | LI-COR RADIATION SENSOR (PYRANOMETER) | 290.00 |
| BP15A | NRG BAROMETRIC PRESSURE SENSOR | 250.00 |
| RH-5 | NRG HUMIDITY SENSOR | 300.00 |
| 50202 | R.M. YOUNG HEATED PRECIPITATION GAUGE | 810.00 |
| 260-200 | NOVALYNX TIPPING BUCKET RAIN GAUGE | 350.00 |

Accessories

| MODEL # | | PRICE |
|-----------|-----------------------------------------------------------------------------|--------|
| DC84K | 64K DATACHIP (for 9200 NRG Logger) | 15.00 |
| DC256K | 256K DATACHIP (for 9200 NRG Logger) | 40.00 |
| 256KB | 256K BYTE FLASH CARD (for 9300 NRG Logger) | 125.00 |
| RB1 | EXTRA RUBBER BOOTS for speed and direction sensors | 3.50 |
| B9VA-DPAK | 5 YEAR BATTERY PACK | 30.00 |
| SBOX2-* | STEEL SHELTER BOX (9200) *Please specify tower diameter. | 85.00 |
| SBOX3-* | STEEL SHELTER BOX (9300) *Please specify tower diameter. | 110.00 |
| SMB1-* | SIDE MOUNT BOOM *Please specify tower diameter. | 50.00 |
| 2C | 2 CONDUCTOR CABLE | .30/FT |
| 3C | 3 CONDUCTOR CABLE | .30/FT |
| CAW08 | BARE COPPER WIRE FOR LIGHTNING SPIKE *Please specify tower height. | .30/FT |
| GKIT/S | GROUNDING KIT WITH LIGHTNING SPIKE *Please specify tower diameter | 50.00 |
| WKIT | ELECTRIC (12 V) WINCH KIT | 375.00 |
| 8120 | POWER CURVE MONITOR | 970.00 |



110 Commerce Street, Hinesburg, VT 05461 USA • (802) 482-2255 • FAX (802) 482-2272 • TELEX 650-313-4621 MCI UW

NRG TALLTOWER PRICE LIST (U.S.A. & CANADA)

October 1992

| Part # | Price (U.S. Dollars) |
|---------------------|----------------------|
| 30TT..... | \$ 385.00 |
| 30TT-SS..... | 485.00 |
| 30TT-XP..... | 605.00 |
| 50TTC..... | 710.00 |
| 50TTC-SS..... | 950.00 |
| 50TTC-XP..... | 1190.00 |
| 70TTC..... | 890.00 |
| 70TTC-SS..... | 1125.00 |
| 70TTC-XP..... | 1410.00 |
| 90TTC..... | 1280.00 |
| 90TTC-SS..... | 1650.00 |
| 90TTC-SS-XP..... | 2060.00 |
| 90TTC-HD4.5..... | 1690.00 |
| 90TTC-HD4.5-SS..... | 2100.00 |
| 90TTC-HD4.5-XP..... | 2630.00 |
| 110TTC..... | 2170.00 |
| 110TTC-SS..... | 2720.00 |
| 110TTC-XP..... | 3410.00 |
| 110TTC-HD6..... | 2820.00 |
| 110TTC-HD6-SS..... | 3540.00 |
| 110TTC-HD6-XP..... | 4420.00 |
| 140TTC..... | 2870.00 |
| 140TTC-SS..... | 3580.00 |
| 140TTC-XP..... | 4475.00 |
| 140TTC-HD6..... | 3740.00 |
| 140TTC-HD6-SS..... | 4675.00 |
| 140TTC-HD6-XP..... | 5200.00 |
| 165TTC..... | 4930.00 |
| 165TTC-SS..... | 5970.00 |
| 165TTC-XP..... | 7200.00 |

If ginpole not needed, subtract:

\$150.00 (50', 70', 90')

\$250.00 (90'HD4.5, 110', 140')

\$375.00 (165')

TT= NRG TallTower

C= Complete with ginpole: ginpole not required for 30TT. Please note that a single ginpole can be used for multiple tower installations. Please call NRG for details.

HD= Heavy Duty: 4.5" or 6" tower tube diameter

SS= Stainless steel guy wires and hardware (not tower tube)

XP= Extra Protection: epoxy coated tower tube with stainless steel guy wires & hardware for marine environments

**Actual installed height of tower is slightly less due to overlap of tube section joints.*

PRICES ARE F.O.B. HINESBURG, VT, U.S.A. AND SUBJECT TO CHANGE.



Consulting Engineers
 1029 Solano Avenue
 Albany, California 94706
 510 525 0484
 510 525 9410 FAX

Augustyn + Company

FAX TRANSMITTAL 2 page(s)

June 8, 1993

Karen Conover
 R. Lynette & Associates
 15042 N.E. 40th Street, Suite 206
 Redmond, WA 98052

**SUBJECT: Renewable Energy Resource Assessment and Development Program
 Department of Business, Economic Development & Tourism, Hawaii**

The field measurement equipment we propose to use for the 5 new sites is as follows:

- 1 - Ascension Technology RSS Unit - \$5,700 each, f.o.b. Waltham, MA. Estimated shipping cost to ACI for calibration is \$40, and from ACI to each site island is \$75. This device consists of:
 - a. the RSP "Head Unit" containing a LI-COR 200SB pyranometer & the rotating band mechanism.
 - b. a Campbell CR10 datalogger, wiring panel, and DC112 modem mounted within a Campbell model weatherproof enclosure. The CR10 will be programmed to control the rotating shadow band mechanism and to perform necessary calculations to derive direct normal irradiance from total global horizontal and diffuse horizontal irradiance measurements.
 - c. a 12 volt rechargeable lead acid battery (to be mounted in the datalogger enclosure), charge controller, and photovoltaic panel used to provide power for the datalogger and rotating shadow band mechanism. All these will be provided with hardware to mount on a 1-1/4 inch pipe.


- 1 - Campbell model CM6 tripod assembly - \$275 each, f.o.b. Logan UT. estimated shipping cost directly to the site island is \$75. This device will be used as a base on which to mount the RSR unit if no easier and cheaper means of mounting is available (such as mounting on the parapet wall of a building's roof or other solid structure.

1 set - miscellaneous materials at \$100.

So for each site, field equipment costs will be:

| | |
|------------------|-----------------------------------------------------------------------------|
| RSR: | \$ 5,700 |
| RSR shipping: | 115 |
| Tripod | 275 |
| Tripod shipping: | 75 |
| Misc materials | 100 |
| Total | \$ 6,265.....times 5 sites = \$ 31,325 which I rounded to \$ 31,400. |

I have attached a quotation from Ascension Technology to hold the \$5,700 price for 5 units firm for 90 days. They didn't get the site names straight, but that shouldn't matter. Let me know if you need more.

Sincerely,

 Jim Augustyn

JUN-08-1993 17:26 FROM ASCENSION TECHNOLOGY

TO

15105259410

P.01/01

Ascension Technology, Inc.
Proposal/Quotation
8 June 1993

To: Mr. James Augustyn
 Augustyn + Company
 Consulting Engineers
 1029 Solano Avenue
 Albany, CA 94706

Ref: Solar Resource Monitoring for Photovoltaic Generation Studies, dated May 1993.

Ascension Technology is pleased to provide this quotation for solar energy resource monitoring equipment to Augustyn + Company. We will ship five Ascension Technology Rotating Shadowband Pyranometer Systems to you at your Albany, CA address for your installation at locations in the Hawaiian Islands. At your request we will ship these directly to a receiving point(s) in Hawaii. Instrument specifications and their operation are described in the referenced document, a copy of which I believe you have.




Figure 1 Possibly Solar Monitoring Locations

| | |
|------------------------------------------------------|-------------|
| Five (5) Rotating Shadowband Pyranometers @ \$5,700. | \$28,500.00 |
|------------------------------------------------------|-------------|

| | |
|---------------|--------------------|
| Total: | \$28,500.00 |
|---------------|--------------------|

Terms: FOB Waltham, MA, Net 30 days


NRG Systems

NRG | LOGGER 9000 SERIES

LOGGER 9000 S E R I E S

SERIAL DATA LOGGER

THE LOGGER 9000 SERIES real-time serial data logger was designed to meet the needs of our customers in the fields of wind energy, air quality monitoring and meteorology. The Logger Series has proven successful in global applications, incorporating the most-requested functions at a realistic price. The system is simple to operate, maintains high reliability, provides easily transferred data to the user's own PC-based system and only requires standard, locally available 9 volt batteries. Data and system variables may be reviewed manually using the keypad and LCD display, or read automatically from the removable data chip. Combined with the NRG EEREADER data chip hardware, associated DATALOG software for PCs and the NRG TallTower™ instrumentation mast, the Logger 9000 series offers a total data gathering system, all from one manufacturer.



NRG Systems

1955 Church Hill Road ■ Charlotte, VT 05445 USA ■ (802) 425-3468 ■ FAX 802-425-3712 ■ Telex 650 313 4621 MCI UW

NRG Systems

NRG Systems: A Respected Name in the Wind Power Industry.

NRG Systems specializes in wind instrumentation and related equipment. Services include: complete siting studies, custom electronic, electrical and mechanical design and manufacturing.

NRG Systems' wind direction sensors, instruments and TallTowers™ are in use on all major wind farms and many monitoring sites in the United States and around the globe, including Antarctica, Australia, Africa, the Caribbean, Egypt, Greece, India, Israel and South America. The number of installations continues to grow as NRG's expertise and complete packages provide simple installation, ensured compatibility and value.

NRG's use of the latest CAD design tools, state of the art circuit technology and proprietary equipment indicate the depth of our commitment to quality and innovation.

Configurations and Options

The LOGGER 9000 SERIES is offered as the #9000 (single speed/single direction and the #9000-2 (dual speed/single direction). These two versions deliver flexible monitoring, providing the ability to measure wind shear in complex terrain. Both

versions of the LOGGER 9000 come complete with sensors, cable, sensor mounts, batteries, data chip and instruction manual.

The sensors are widely used in wind studies and turbine control. The Maximum #40 anemometer continues to be a consistent performer. The NRG 200P direction vane was developed to stand up to the rigors of harsh wind energy sites. The potentiometer is rugged and sealed with a teflon dust barrier. The shielded sensor cable is terminated with lugs; sensor mounts are anodized aluminum aircraft tubing. 9-volt lithium batteries are now supplied as standard equipment.

Optional equipment and accessories available include: steel shelter box, mounting hardware, extra sensor cable, R.M. Young wind sensors for air quality measurements and the popular NRG TallTower™ instrumentation masts.

EEREADER and DATALOG Software


The EEREADER module includes a plug-in short card for PCs and compatibles with a cable and EEPROM data chip socket holder. The hardware, when coupled with the datalog software, allows the operator to read data chips, store data to disk files, print data, print reports and erase data chips for the next use.

Data is available in ASCII format with date and time stamps for use by the customer's own software for detailed analysis. DATALOG software can be used to generate reports. Printouts include: sequential wind-speed/direction/standard deviation report; windspeed/direction and diurnal distributions.

The sequential printout clearly shows the wind data at any time during the recording period, with date and time indicated. A unique velocity/direction/turbulence intensity report provides a wealth of information about the site in one printout. The diurnal distribution gives velocity, direction and turbulence intensity summaries for each hour of the day for the period of data recording.

Far Left: The Logger 9000 comes complete with sensors, cable and sensor mounts.
Left: Reading the data chip with a PC.





Left: A complete mountain top logging station featuring the TallTower™ from NRG.

NRG Systems

- Four user-selectable averaging periods—5, 10, 30 and 60 minute periods for versatile operation.
- All operating parameters (time, date, serial number, model number, site, battery voltage, etc.) are stored on the data chip for review on a PC.
- Real-time serial data is stored in a removable data chip for offsite transfer to an IBM PC or compatible computer for data reduction.
- Easy to operate—can be set up in your office or lab and activated on site. Data changes are simple and quick; push one key, pull data chip, insert new data chip, push the key again and you're finished. A 6 key data entry pad and a 6 digit LCD display makes setup straightforward.
- Initial parameters remain in memory. No need to reset parameters after changing data chips. Greatly reduces the chance of data retrieval error. Parameters may be changed at any time if desired.
- Data chip can be changed at ANY TIME without losing data. The logger continuously records data irrespective of whether the EEPROM data chip is in place.
- Meets or exceeds all siting standards of the American Wind Energy Association.
- Very reliable operation, low integrated circuit count reduces complexity, cost. Leading edge technology provides consistent performance. All ICs and internal connections soldered in and coated with a military spec. moisture barrier.
- Turbulence intensity (standard deviation/mean velocity) is calculated based on all 1 second samples over the averaging interval. Turbulence intensity is a standard indicator of turbulence. Wind turbine's power production, mechanical stress levels and life may be affected by turbulence.

FEATURES:

- Ultra-low power consumption—operates on two 9-volt lithium batteries for over 12 months. Readily available standard 9-volt batteries may be used. A battery voltmeter is built in. Two batteries allow continuous operation when changing batteries, operation of the logger is never interrupted.
- Redundant data memory—data stored on internal RAM in addition to the EEPROM data chip. Copy function may be used to back-up data chip; prevents lost data.

Right: The optional R.M. Young "Wind Monitor." K-8



MECHANICAL SPECIFICATIONS:

Enclosure:

NEMA type 4, 4x & 13 IEC: IP65 weatherproof fiberglass with stainless steel & polyester hardware. Hasp for padlock and quick release latches.

Size:

17cm high x 20cm wide x 14cm deep (6.5in. x 8in. x 5.5in.)

Weight:

2.3kg (5lbs.)

Shipping Weight:

4kg (9lbs.)

SYSTEM OPERATIONS:

Time Base and Real-Time Clock:

Accuracy: +/-3 minutes per month.
Software Programmable clock via keypad.
Automatic leap year correction.

Power Requirements:

Battery Voltage: 9 volt nominal, 5.6 volt minimum.
Operating Current: Less than 200 uA (0.2 ma) average.

Battery Life:

Over 1 year with 9 volt lithium batteries; standard alkaline batteries may be used.

Data Storage:

Permanent Removable Storage: 2864 EEPROM (commercial temperature rated) in protective data chip carrier.
Maximum Storage: 85 days of hourly data (42 days on 9000-2).
Fixed On-Board Storage: CMOS SRAM redundant memory.

Data Sampling and Display:

6 digit, 13mm (0.5in.) LCD
Wind Speed: 1 second update, count integrated.
Resolution: +/- 1 MPH (0.45 m/s)
Range: 0-128 MPH (0-57.6 m/s)
Accuracy: +1, -0 MPH (+0.45, -0 m/s)
Wind Direction: 2 second update, software compensated for vane deadband.
Resolution: approx. 1 deg (internal A/D converter); Sixteen points of compass (22.5 degrees) displayed.
Accuracy: +/- 4 degrees

Ordering Information:

Logger (single speed/direction)—complete.....Cat. No. 9000
Logger (dual speed/single direction)—complete.....Cat. No. 9000-2

Sensors:

* On 9000-2, model: two anemometers are used. All low pass filtered and electrostatic discharge protected.
Wind Speed: Interfaces directly to Maximum #40, or R.M. Young Sentry™AC anemometer (60hz = 102 MPH (45.9m/s).
Wind Direction: Interfaces directly to NRG #200P or R.M. Young Sentry™ potentiometer type wind vane (resistance = 10k).

FUNCTIONS:

Peak Wind Gust:

Peak wind gust updated every second, Peak Gust, direction of gust, time and date recorded.
Range: 0-255 MPH (0-116 m/s)
Resolution: 1 MPH (0.45 m/s)
Accuracy: +1, -0 MPH (+0.45, -0 m/s)

Average Windspeed/

Prevailing Wind Direction:

Average speed and most frequent direction calculated for each time interval (5, 10, 30 or 60 minutes).
Range: 0-127.9 MPH (0-58.1 m/s), 0-15 direction sectors.
Resolution: 0.1 MPH (0.05 m/s), 1 direction sector.
Accuracy: +/- .5 direction sectors.

Windspeed Standard Deviation (for turbulence intensity):

* On 9000-2 models: the standard deviation is calculated for only one anemometer.
True standard deviation with 1 second intervals.
Resolution: 0.1 MPH (0.05 m/s)
Accuracy: +/- 0.1 MPH (0.05 m/s)

Battery Voltmeter:

Battery voltage updated every 2 seconds.
Range: 5.5 to 9.95 volts
Resolution: .05 volts

Averaging Interval:

Dip switch selected.
Range: 5, 10, 30 and 60 minutes


LOGGER
9000
S E R I E S
SERIAL DATA LOGGER

SPECIFICATIONS MAY CHANGE WITHOUT NOTICE

©1988 NRG Systems, Inc. Printed in USA

NRG Systems

NRG Systems



THE TALL TOWER

MAST SYSTEM

THE NRG TALLTOWER™ is a highly versatile, easy to erect, tilt-up tower suitable for many instrumentation applications. NRG TallTowers™ have become an industry standard for wind resource assessment; more than 500 units have been sold for use as meteorological masts in wind farm and remote site installations. New TallTower™ models are constantly being developed, and existing models continuously updated to incorporate improvements. (For example, NRG now offers special heavy service tower systems in heights up to 110' for use in extreme conditions such as rime ice accumulation.) We take great pride in the quality, durability and innovation you'll find in every NRG product. The TallTower™ line and our custom tower services perfectly complement our selection of fine instruments. Available in many standard heights from 30' to 140' (10 to 40 meters).

NRG Systems

NRG Systems

Take the guesswork out of measuring wind speeds at turbine hub height.

There's only one truly accurate way to estimate a wind turbine's energy output: measure the wind speed at the turbine's hub height. Extrapolation from measurements made from shorter towers is, at best, an educated guess; if you're dealing with local obstructions or varying terrain, it may become nearly useless.

NRG's TallTower™ wind measurement mast systems are available in many standard heights from 30' to 140'. Wind power professionals can now monitor wind speeds at heights approaching 140'...accurately, economically.

If you're testing for air quality, you shouldn't have to worry about the quality of your equipment, too.

As the need for the monitoring of both local and larger areas for scientific uses increases, the need for inexpensive, portable, easily erected masts also increases. NRG has supplied many 10M masts for this purpose and will continue to fill the growing demand for air quality equipment.

We can supply many types of mounting hardware for your sensors, or adapt your existing equipment for more dependable operation.

Screw-in earth anchors are easily installed...no concrete is required.



If you're looking for high-quality, low-cost monitoring equipment, look to NRG Systems for equipment you can depend on...for years to come.

Antennas go up safer, easier and economically.

The TallTower's™ light weight and tubular construction make the mast ideal for installations in confined spaces. The tower is easily raised and lowered to provide safe access; antenna mounts are easily attached and wires may be run internally, affording protection from the elements. NRG quality and an installation cost far less than that of comparable guyed towers have made the TallTower™ the choice for antenna installations.


Now you won't have to cut costs at the expense of accuracy, economy or safety.

Before the TallTower™ system's introduction, erecting a mast of 10' or more was costly, time-consuming and labor-intensive. In the past, excavation for anchor holes, poured concrete for anchor pads and base footings, and the large crews required all contributed to making mast erections expensive—and often dangerous. With NRG's Talltower™ towers are installed safely, quickly and economically. When greater efficiency is at stake, an NRG Tall-Tower™ is an investment that really makes sense.

Tilt-up installation means no climbing...all work is done at ground level.



NRG Systems



TESTED ATOP MOUNT WASHINGTON!


Shown at left is a test model of the 70' TallTower™ undergoing field testing at the summit of Mount Washington, N.H. in the fall of 1983. Despite winds exceeding hurricane force and rime ice build-up (visible on the guy wires in this photo), the TallTower™ stood its ground. NRG supplies a full line of special heavy service mast systems for such extreme conditions.

The professional tower that takes the headaches out of installation.

Despite all its professional-level qualities, the TallTower™ system from NRG features the most easily-erected masts available today. Two people can handle the complete installation, with the aid of only a small winch or hoist and a minimum of common hand tools. Mast sections slide together without the use of clamps or bolts, and the unique hinged base plate allows assembly on the ground, permitting both the

tower and ginpole to pivot into erected position. (The hoist isn't included, but any lifting device with a working load of 2000 lbs. is adequate.) The screw-in earth anchors are suitable for use in nearly any type of soil. Arrowhead anchors and drive rods available for hard or rocky soils. Also available are 12 VDC electric winches for erection.

A crew of two can handle most installations...only simple tools are required.



Simple guywire attachment method eliminates hardware, speeds assembly.



SPECIFICATIONS:

GENERAL:

- Tubular tower, guyed in 4 directions, tilt-up from ground level
- Galvanized steel tower tubes, 3 m (10 ft) sections
- Galvanized aircraft cable guywires
- Guywires are pre-cut, rolled on spools and swaged to guy rings
- Maximum design windspeed: 55 m/s (120 mph) [13 mm (0.5 in) ice max. per EIA spec.]
- Baseplate, guy rings and hardware hot-dipped galvanized
- Detachable gin-pole for erecting
- Screw-in earth anchors for "normal" soils
- Complete kit, ready to install—with gin-pole, anchors, baseplate, guywires, hardware and instructions
- Special TallTowers™ available for severe environments
- Non-standard heights also available
- Arrowhead and rock anchors are optional

10 to 20 meter, 30' to 70' TallTowers™:

- Tower tubes of 73 mm (2.88 in) diameter, 15 gauge
- Guywire is 3.2 mm (0.125 in) diameter
- 20 m, 50' and 70' with 6 m (20 ft) ginpole
- Screw-in anchors with 10 cm (4 in) plate, 107 cm (42 in) long
- Erected heights: 10 m - 10 meters, 20 m - 20 meters, 30' - 29 feet, 50' - 48.5 feet, 70' - 68 feet

30 meter, 90' and 110' TallTowers™:

- Tower tube of 89 mm (3.5 in) diameter, 15 gauge
- Guywire is 3.2 mm (0.125 in) diameter
- All with 7.6 m (25 ft) ginpole
- Screw-in anchors with 15 cm (6 in) plate, 122 cm (48 in) long
- Erected heights: 30 m - 30 meters, 90' - 87 feet, 110' - 106 feet

40 meter and 140' TallTowers™:

- Tower tube of 114 mm (4.5 in) diameter, 14 gauge
- Guywire is 4.8 mm (0.188 in) diameter
- All with 9 m (30 ft) ginpole
- Screw-in anchors with 15 cm (6 in) plate, 122 cm (48 in) long
- Erected heights: 40 m - 40 meters, 140' - 132 feet

Ordering Information:

| | | |
|------------------------------------|---------------|-------------------|
| 30' TallTower™—complete | Cat. No. 30TT | 51 kg (112 lbs) |
| 50' TallTower™—complete | 50TT | 110 kg (242 lbs) |
| 70' TallTower™—complete | 70TT | 139 kg (306 lbs) |
| 90' TallTower™—complete | 90TT | 200 kg (441 lbs) |
| 110' TallTower™—complete | 110TT | 244 kg (536 lbs) |
| 140' TallTower™—complete | 140TT | 471 kg (1036 lbs) |
| 10 meter TallTower™—complete | 10MTT | 54 kg (119 lbs) |
| 20 meter TallTower™—complete | 20MTT | 139 kg (306 lbs) |
| 30 meter TallTower™—complete | 30MTT | 240 kg (528 lbs) |
| 40 meter TallTower™—complete | 40MTT | 471 kg (1036 lbs) |

SPECIFICATIONS MAY CHANGE WITHOUT NOTICE

©1988 NRG Systems, Inc. Printed in USA

NRG Systems

1955 Church Hill Road ■ Charlotte, VT 05445 USA ■ (802) 425-3468 ■ FAX 802-425-3712 ■ Telex 650 313 4621 MCI UW

THE TALL TOWER


MAST SYSTEM

THE MAXIMUM TYPE 40 ANEMOMETER has proven to be rugged, reliable and highly accurate. Over 50,000 units are now in use in wind tunnels, on mountain-tops and in thousands of household, wind energy and institutional installations. Maximum cup anemometers have recorded wind to 97 m/s (214 mph). Their low moment of inertia and unique bearings permit very rapid response to gusts and lulls. The black Lexan cups (virtually shatterproof) have thermal properties which resist and shed icing far more effectively than metal assemblies. Because of their output linearity, these sensors are ideal for use with various data retrieval systems and controllers. The unique bearing system ensures that wind-blown dirt and moisture will not destroy the bearings or degrade performance. The #40 has three conical cups molded in one continuous piece. Cup rotation induces a AC sinewave voltage in a single coil by a four pole magnet. Two sine wave cycles are produced for each revolution of the cups with the frequency directly proportional to windspeed. The unbeatable combination of high accuracy, stable bearings, simple yet rugged construction and very low cost make the Type #40 the first choice for professionals in all fields.

NRG Systems

NRG Systems

**TYPE
40
MAXIMUM
ANEMOMETER**



APPLICATIONS

- Anemometer for wind resource assessment instrumentation
- Research measurements in environmental studies
- Engineering studies on wind effects on bridges, skyscrapers
- Sensing wind speeds at sporting events (i.e. Olympics)

FEATURES:

- Very simple, elegantly engineered construction
- Dirt and water resistant, modified Teflon bearing system
- All corrosion resistant materials
- All 3 cups molded in one piece for repeatable performance
- Frequency output for ease of filtering and long cable runs
- Professional qualities at a minimum price

SPECIFICATIONS:**Mechanical:**

3 cups of conical cross-section, 51 mm (2 in) diameter

190 mm (7.5 in) swept diameter of rotor

51 mm (3.2 in) overall assembly height

Moment of inertia of rotor assembly = $68 \times 10^{-6} \text{S-ft}^2$

Mounting—(using a cotter pin) on a 13 mm (0.50 in) diameter mast with a #35 hole 11 mm (.35 in) from the top.

Materials: Cups—one piece injection-molded black polycarbonate (Lexan)

Body—housing is black ABS plastic.

Shaft—beryllium copper—fully hardened

Bearing—modified Teflon, self-lubricating. Rated Pv factor of 20,000
(at 15 mph, Pv is approx. 500; at 100 mph PV is approx. 2,000.)
Upper bearing is centered in the plane of cup thrust for optimal loading.

Permanent magnet—Indox 1, 25 mm (1 in) dia., 13 mm (0.5 in) long,
4 poles

Threshold: Starting threshold—1.1 m/s (2.5 mph)

Cup distance constant (63% recovery)—3.0 m (10 ft)

Environmental: Operating temperature -55°C to 60°C (-67 to 150 F)

Operating humidity range 0 to 100% RH

Weight: 0.1 kg (0.2 lbs)

Shipping Weight: 0.5 kg (1 lb)

Electrical:

Single coil, bobbin wound, 4100 turns of #41 wire

Voltage is a sine wave with frequency changing linearity with wind speed—

60 Hz = 102 mph

Voltage is 2.0 VAC at 60 cycles

Ordering Information:

#40 Anemometer.Cat. No. 40


SPECIFICATIONS MAY CHANGE WITHOUT NOTICE

©1988 NRG Systems, Inc. Printed in USA

NRG Systems

1955 Church Hill Road ■ Charlotte, VT 05445 USA ■ (802) 425-3468 ■ FAX 802-425-3712 ■ Telex 650 313 4621 MCI UW

TYPE
40
MAXIMUM
ANEMOMETER



THE 200 SERIES WIND DIRECTION VANE is a professional quality wind sensor, designed for and proven effective in some of the world's largest wind power plants. Its many qualities also make the 200 Series ideal for use in many other areas, including applications in environmental testing and meteorology. Although moderately priced, these sensors offer a level of quality and reliability often found only at a very high premium. The thermoplastic and stainless steel components resist corrosion, and contribute to a high strength-to-weight ratio. As with all NRG Systems products, the 200 Series Vane is elegantly engineered, employing a minimum number of parts while maximizing functional performance. The vane is directly connected to a precision conductive plastic potentiometer located in the main body. An analog voltage output directly proportional to the wind direction is produced when a constant DC excitation voltage is applied to the potentiometer.

NRG Systems


NRG Systems

200

S E R I E S

WIND VANE

WIND DIRECTION SENSOR



APPLICATIONS

- Wind direction sensor for wind data loggers
- Yaw control on wind turbines
- Environmental monitoring instrumentation

FEATURES:

- Simple mechanical construction
- Long life, professional quality potentiometer
- No slip rings or brushes result in high reliability & low cost
- Corrosion resistant materials
- Multiple mechanical and contact seals
- Completely balanced sensor vane
- No setscrews to vibrate loose
- Very stable and smooth response to wind changes
- Fully balanced sensor vane

SPECIFICATIONS:

Mechanical:

Range: Direction—360° mechanical, continuous rotation

Sensitivity: approx. 1.4 m/s (3 mph)

Materials: Direction vane and housing—black u.v. stabilized injection molded polycarbonate

Balance weight—stainless steel

Terminals—three #4-40 solid brass studs with nuts

Potentiometer—stainless steel shaft in two shielded precision grade, stainless steel ball bearings, conductive plastic potentiometer element mounted in a machined aluminum housing.

Hardware—all of stainless steel construction

Dimensions: Overall length—21 cm (8.3 in)

Swept diameter—27 cm (10.5 in)

Overall height—12 cm (4.3 in)

Vane size—6 cm high x 10 cm long (2.3 in x 3.8 in)

Main housing diameter—5 cm (2 in)

Mounting—13 mm (0.5 in) diameter mast

Weight: 0.1 kg (0.25 lb.)

Shipping Weight: 0.5 kg (1 lb.)

Electrical:

Range: Direction—340° electrical (20° open)—#200
352° electrical (8° open)—#200 P

Signal: Analog DC voltage from conductive plastic potentiometer resistance
1K—#200, 10K—#200P, linearity 1.0%, life expectancy of 50 million revolutions (4-6 years normal operation).

Power Requirements: Regulated potentiometer excitation of 5 to 15 VDC.

Ordering Information:

Wind direction vane—1KCat. No. 200

Precision wind direction vane—10K.....Cat. No. 200P


SPECIFICATIONS MAY CHANGE WITHOUT NOTICE

©1988 NRG Systems, Inc. Printed in USA

NRG Systems

1955 Church Hill Road ■ Charlotte, VT 05445 USA ■ (802) 425-3468 ■ FAX 802-425-3712 ■ Telex 650 313 4621 MCI UW
K-17


200
S E R I E S
WIND VANE






CR10 Measurement & Control System



CR10
MEASUREMENT AND
CONTROL MODULE
S/N 09115

 **CAMPBELL
SCIENTIFIC
INC.** MADE IN USA




CAMPBELL SCIENTIFIC, INC.

CR10 Measurement and Control System

A Rugged, Operational Instrument with Research Grade Performance

The CR10 combines a micro-computer, clock, multimeter, calibrator, scanner, timer, frequency counter, and controller in a compact, sealed, stainless steel package.




CR10 Measurement and Control Module with Wiring Panel and Keyboard Display.


TABLE OF CONTENTS

| | |
|-----------------------------------------------------|----|
| System Description | 1 |
| Applications | 2 |
| Data Storage and Transfer | 4 |
| Channel Expandability | 5 |
| Programming | 6 |
| Enclosures, Power Supplies, and Towers | 8 |
| Specifications | 9 |
| Assurance of Quality/ Customer Support | 10 |


Campbell Scientific data acquisition systems deliver accurate, reliable measurement and control capability, even in extreme environments. Our systems have collected data on every continent and in space.




Meteorologic data collection at the Sphinx will determine an appropriate course for preservation and restoration. Photo courtesy The Getty Conservation Institute.



Performance monitoring at Daytona Speedway, FL.



Remote installation telemeters data to an adjacent valley (Bear River Range, Wasatch Mountains, UT).



Wave height spectra are determined and data telemetered via satellite (Bering Sea, AK). Photo courtesy Brown & Caldwell.

Cover Photos: At left: CR10 Measurement and Control Module. From top right: (INDUSTRY) Turbine performance and hook load testing, photo courtesy Aerospatiale Helicopters, Inc.; (RESEARCH) NASA CELSS Research Lab, Utah State University, Logan, UT; (AGRICULTURE) Agriculture Research Plots, Logan, UT; (HYDROLOGY) Weir in Reynolds Creek Drainage, southeast of Boise, ID.


System Description

The primary components of the CR10 are the Measurement and Control Module and the detachable Wiring Panel. The CR10 Keyboard Display is recommended for on-site communication, station setup and trouble shooting, but may be replaced by a computer where environmental conditions allow.

12 Analog Inputs - (single-ended channels, each pair differential*) Five software selectable input voltage ranges. Resolution is $0.33 \mu\text{V}$ on the 2.5 mV range (0.006°C on type E thermocouple). An AM416 multiplexer provides additional inputs. Vibrating wire sensors may be read with any analog input.

8 Digital Inputs/Outputs for output control, sensing status, or reading SDM peripherals or SDI-12 sensors.

9-Pin Serial I/O Port for connection of data storage, retrieval and telecommunications peripherals.



2 Pulse Counting Channels are software selectable for switch closures, high frequency pulses or low level AC measurement.

3 Switched Excitation Channels for precision excitation of sensors or short-term actuation of external devices. Excitation is programmable over a $\pm 2500 \text{ mV}$ range.

Power and Ground Connections for 12 VDC external batteries or peripherals.

CR10 MEASUREMENT AND CONTROL MODULE

Protected in a sealed, rugged, stainless steel canister, the programmable module provides sensor measurement, timekeeping, communication, data reduction, data/program storage and control functions. A multitasking operating system allows simultaneous communication and measurement functions. Operating temperature range is -25° to $+50^\circ\text{C}$, standard; -55° to $+85^\circ\text{C}$, on request.

The standard CR10 instruction set includes 30 measurement instructions, 43 processing/math instructions, and 15 program control instructions. Optional instructions are available for specialized measurement or processing capabilities.

The CR10's standard memory configuration allows storage of 29,900 data points in two Final Storage areas. The SM192 and SM716 Storage Modules provide additional on-site data storage, if required.

The Measurement and Control Module interfaces with the Wiring Panel via two D-style connectors. The CR10's electronics are RF shielded and glitch protected by the sealed, stainless steel packaging. A "watchdog" hardware reset function restores normal microprocessor function if lost due to an input transient or intermittent component failure.

WIRING PANEL

The stainless steel Wiring Panel consists of a top panel and end bracket. The top panel includes screw terminals for sensor connections and a 9-pin serial I/O port; the end bracket attaches the Wiring Panel to the Control Module and to an enclosure-mounted

or free-standing baseplate. The Control Module easily disconnects from the Wiring Panel for quick field replacement thus avoiding the need to rewire sensors. All wiring panel connections are protected with spark gaps or transzorbors.

CR10KD KEYBOARD/DISPLAY

The portable CR10KD is used to program the CR10, manually initiate data transfer, and display sensor readings, stored values, or flag/port status. One CR10KD may be carried from station to station in a CR10 network. The CR10KD features an 8-character LCD and a 16-character keyboard. Operating temperature range is -25° to $+50^\circ\text{C}$. The CR10KD is powered by the CR10's power supply.

10TCRT THERMOCOUPLE REFERENCE

The 10TCRT thermistor provides a temperature reference in thermocouple applications. It requires one single-ended analog input. Overall accuracy is typically better than $\pm 0.2^\circ\text{C}$ over the range -33° to $+48^\circ\text{C}$.

PERIPHERALS

The CR10 must be powered by a 9.6 to 16 VDC supply and housed in a weather resistant enclosure (page 8). Measurement, control, and data storage/transfer peripherals are optional depending upon the user's application (pages 4 and 5).


*A differential measurement measures the difference in voltage between two inputs. A single-ended measurement measures the input with respect to ground. All inputs must be within the $\pm 2.5 \text{ V}$ common mode range of the CR10.

Applications

The CR10's combination of measurement precision, flexibility, long-term reliability and economical price has resulted in its widespread use in scientific, commercial and industrial applications. Popular applications are discussed below.

METEOROLOGY

The CR10 is designed for long-term climatological monitoring, meteorological research, and routine weather measurement applications. Standard CR10 outputs include wind vector averaging, sigma theta, vapor pressure from wet/dry bulb temperatures, saturation vapor pressure, and histograms.



A CR10 mounted on a 10m tower monitors conditions at a proposed site for the 1998 Winter Olympics (Summit County, UT).

Typical meteorologic measurements:

- WIND SPEED is measured with voltage, photo-chopped, switch closure, or magnetic pulse type anemometers. Expansion peripherals allow wind profile studies.
- WIND DIRECTION is measured by a precision potentiometer wind vane.
- SOLAR RADIATION is measured with a silicon cell or thermopile pyranometer.
- TEMPERATURE sensors include thermistors, thermocouples, RTD's, or silicon types.
- RELATIVE HUMIDITY is measured with wet/dry bulb psychrometers, AC resistive sensors, strain gage or capacitive sensors. Capacitive probes include signal conditioning.
- DEWPOINT is calculated from temperature and relative humidity data or measured by cooled mirror or lithium chloride sensors. Dew point sensors require external power.
- PRECIPITATION data is provided by a tipping bucket switch closure rain gage or a weighing gage.

- EVAPORATION is measured with standard pans or lysimeters fitted with a potentiometer or strain gage.
- BAROMETRIC PRESSURE is sensed by capacitance or strain gage pressure transducers.
- SOIL WATER POTENTIAL is obtained using AC conductivity moisture blocks or analog output tensiometers.
- LEAF WETNESS is detected by a resistance grid.

Specialized applications include:


WIND POWER - WECS performance and site evaluation processing includes standard deviations, frequency distributions, wind speed and power histograms. Direct measurements of strain gages and pressure transducers are used to monitor turbines.

AIR QUALITY applications use the CR10's automatic control of calibration sequences and conditional averaging where invalid data taken during power failures, calibration intervals, or other conditions are excluded.

AGRICULTURE

In addition to meteorological monitoring, the CR10's versatility allows measurement of agricultural processes and equipment in applications such as:


- plant water research
- canopy energy balance
- crop management decisions
- irrigation scheduling
- integrated pest management
- erosion studies
- machinery performance
- food processing/storage
- frost prediction
- plant pathology



The automated 012 Weather Station is designed for routine climatological monitoring. Features include a modular design, prewired sensors, and a standard program (Franklin County, ID).

HYDROLOGY

The CR10 is well-suited to remote, unattended monitoring of hydrologic conditions. Many hydrologic sensors interface directly to the CR10, including the new SDI-12 compatibles.



Gaging station equipped with CR10-controlled sampler takes samples based on flow (Little Platte River, WI).


Typical hydrologic measurements:

- **WATER LEVEL** is read directly with an incremental shaft encoder, strain gage or vibrating wire pressure transducer. Some shaft encoders require a QD-1 Interface. Vibrating wire transducers require an AVW1 or AVW4 Interface.
- **WELL DRAW-DOWN TESTS** use a pressure transducer measured either logarithmically or at a rate based on incremental changes in water level.
- **IONIC CONDUCTIVITY** measurements use the AC excitation from one of the CR10's three switched excitation ports.
- **WATER QUALITY** samplers are controlled by the datalogger as a function of time, water level thresholds, or rate of change.
- **ALARM AND PUMP ACTUATION** is controlled through any of the eight digital I/O ports which operate external relay drivers.

INDUSTRY

The growing number of applications where the CR10 can inexpensively automate data collection and improve productivity and quality include:

- HVAC systems
- Vehicle/machinery testing
- Transportation
- Process control
- Water and sewage treatment
- Regulatory compliance
- Routine operations and maintenance
- Structural or fatigue analysis
- Energy management/conservation
- Environmental testing



The heating and cooling of Campbell Scientific's factory is controlled by a CR10 and peripherals (Logan, UT).

More specifically, the CR10 can:

MEASURE input from

- load cells
- strain gages
- flow sensors
- speed sensors
- humidity sensors
- v/mV transducers
- temperature probes
- pressure transducers
- 4-20 mA transducers*

MONITOR conditions of

- valves
- filters
- boilers
- generators
- engines
- refrigerators
- appliances
- vehicles
- compressors
- turbines
- chillers
- pumps
- batteries
- transformers
- weighing scales


CONTROL based on time or measured parameters

- pumps
- solenoids
- motors
- resistive loads
- relays
- alarms

VEHICLE TESTING

The CR10 is ideal for applications requiring compact packaging such as:

- engine test cell monitoring
- durability testing
- fleet monitoring
- solar vehicle "C-studies"
- vehicle performance verification



Datalogger monitors and records pressure on hydraulic rams of haulage trucks (Kennecott Copper Mine, Oquirrh Mtns., UT).


Common parameters for vehicle monitoring and durability testing are listed below:

- **TEMPERATURE** sensors include thermocouples and infrared (IR) detectors. The linearization for K-type thermocouples extends from -50° to 1370°C, allowing measurements from ambient to extreme exhaust temperatures.
- **PRESSURE, FORCE, TORQUE, AND ACCELERATION** measurements are accomplished with strain gage transducers.
- **FUEL FLOW, ENGINE RPM, AND VEHICLE SPEED** usually require magnetic pulse transducers or incremental encoders, either of which connect directly to the CR10 pulse counter inputs.
- **THROTTLE POSITION** is measured with potentiometers.
- **TIMING EVENTS** are output to the datalogger in period, pulse width, frequency, counts, or time intervals with the SDM-INT8 Interval Timer.
- **FREQUENCY DISTRIBUTION HISTOGRAMS** allow data compression over extended performance tests.
- **RAINFLOW COUNTING HISTOGRAMS** allow fatigue analysis tests.

*Contact Campbell Scientific for proper wiring configuration.

Data Storage and Transfer

Up to 29,900 raw or processed data points can be stored in the CR10's memory. Data are transferred to a computer via one or more communications options including multidrop or short-haul modems, radios, phone lines, or satellite. On-site data retrieval options include direct line, storage module, cassette tape, display, or printer.



SOFTWARE

PC208 Datalogger Support Software supports telecommunications, programming, and data processing functions. With an appropriate communication link, PC208 provides two-way communication between Campbell dataloggers and IBM-PC or compatible computers. A Monitor mode allows real-time display of datalogger measurements.

DISPLAY

The CR10KD Keyboard/Display provides on-site review of data values and program instructions. On-site connection to a terminal or computer is also possible (Direct Line Options).


STORAGE MODULES

Rugged, battery-backed RAM storage modules reliably store data over a -35° to $+65^{\circ}\text{C}$ (extended values on request) temperature range. The SM192 or SM716 Storage Module (96K or 358K data values, respectively) can be left connected to the CR10 or carried to the field to retrieve data from the CR10's memory. Up to eight storage modules can be connected to one CR10. The SC532 Interface is used to transfer data or programs between the storage module and an MS-DOS computer. Consult Campbell Scientific if data playback to a non-MS-DOS computer is required.


CASSETTE TAPE

The RC35 Recorder stores 180K data values on one side of a C60 cassette over a 0° to $+40^{\circ}\text{C}$ temperature range. Transfer of data from the CR10 to the RC35 requires the SC92A Interface.

Data transfer from tape to a computer is accomplished through either the PC201 Card or the C20 Cassette-Computer Interface. The PC201 requires an IBM PC/XT/AT or compatible computer. The C20 can be used with any computer having an RS-232 serial port.



Record temperature of -69°F was monitored via radio telemetry (Peter Sinks, UT).



Data from a remote site is monitored via telecommunications and PC208 Software.

DIRECT LINE OPTIONS

Direct Datalogger-to-Computer Interface

The SC32A RS-232 Interface supplies an optically isolated connection between the CR10 and a computer over distances up to 100 feet.

Short Haul Modems

Short haul modems provide local communication between the CR10 and a computer with an RS-232 serial port. The modem transmits data up to 6.5 miles over four-wire unconditioned line (two twisted pairs).

Coax Network

The MD9 Multidrop Interface links a central computer to over 200 dataloggers on a single coaxial cable. Total coax cable length can be up to three miles.

RADIO FREQUENCY (RF) COMMUNICATION

Campbell Scientific's RF communication system uses the RF95 modem and a low-powered transceiver at the remote station(s), and a transceiver connected to an RF232 Base Station at the computer site. Up to 255 stations can be interrogated over a single UHF or VHF frequency. Any station can serve as a repeater to extend the line-of-sight transmission of the base station.

TELEPHONE NETWORKS

Telephone communication links require a DC112 modem at the CR10 site and a Hayes-compatible 300 or 1200 baud modem at the calling end. Remote RF or MD9 networks are also accessible by telephone.

Channel Expandability

The following peripherals expand CR10 measurement or control capability. Contact Campbell Scientific regarding the suitability of these peripherals for your application.

SYNCHRONOUS DEVICES FOR MEASUREMENT (SDM's)


SDM's are addressable peripherals that expand digital control ports, analog output ports, and datalogger measurement capabilities. Up to 16 SDM's may be connected to three control ports on one CR10. SDM operation is controlled by datalogger instructions 101-104.

SDM-A04 Four Channel Continuous Analog Output Module provides four independent continuous analog outputs for proportional control or strip chart recording.

SDM-CD16 Control Port Module has 16 digital control ports with drivers to activate external relays, solenoids, or resistive loads. A manual override toggle switch is provided for each port.

SDM-INT8 Eight Channel Interval Timer expands the number of pulse count channels in the system and outputs processed timing data to the datalogger. Timing events are captured with ± 1 microsecond resolution over a maximum range of 16.77 seconds. Output options include period, pulse width, frequency, counts, and interval time.

SDM-SW8A Pulse Counter is an 8-channel pulse count expansion for switch closure measurements. Channels can be individually configured for single-pole double-throw (SPDT), single-pole single-throw (SPST), or voltage pulse measurements. Output options include signal state, duty cycle, or counts.



The expansion peripherals are: AM416, SDM-SW8A, SDM-CD16, SDM-A04 and SDM-INT8

MULTIPLEXER

The AM416 Relay Multiplexer increases the number of sensors that can be measured by a CR10. The AM416 sequentially multiplexes sixteen groups of four lines at a time (a total of sixty-four lines). Compatible sensors include thermistors, thermocouples, potentiometers, load cells, strain gages, vibrating wires, and soil moisture blocks. Multiple AM416's can be controlled by a single CR10.


The Datalogger Program

The CR10's ability to make measurements, calculations, logical decisions, and phone calls stems from its internal program. The CR10's program can be extremely powerful, yet is composed of simple instructions. Knowledge of a high level programming language, such as FORTRAN or BASIC, is not required.

PROGRAM DEVELOPMENT

A CR10 program consists of a series of instructions designed to perform measurement, data processing, data storage, and logical control functions. To construct a program, the user selects application-specific instructions from a library of PROM-based instructions. These instructions, developed for data acquisition and control, allow the CR10 to measure most sensor types without the need for external signal conditioning.

Program development can be accomplished with a prompt sheet and a CR10KD keyboard. In addition, a prompt-driven, computer-based datalogger program editor (EDLOG) is available in Campbell Scientific's PC208 Datalogger Support Software.



Programs can be entered or edited and system performance verified on-site with a CR10KD.

INSTRUCTION FORMAT

Each CR10 program instruction is identified by a number. For example, Instruction 1 controls single-ended voltage measurements, Instruction 55 applies a 5th order polynomial to incoming data, Instruction 83 sets up an if/then statement, and Instruction 101 controls operation of an SDM device (SDM-INT8). The variety of instructions allows the user to select measurement, processing, data storage and control sequences that precisely fit his application.

The CR10's instructions can be grouped into four functional categories. A listing of the standard CR10 instruction set follows; more detailed information is available in the CR10 manual and prompt sheet.

INPUT/OUTPUT INSTRUCTIONS are primarily for sensor measurement, but also control and communicate with external devices. Some internal functions, such as control of the CR10's timer, are also classified as I/O instructions. Specific examples include:

- Single-Ended (SE) Volts
- Differential (DIFF) Volts
- Pulse Count
- Excite, Delay, SE Volts
- AC Half Bridge
- Full Bridge
- Three-Wire Half Bridge
- Excite, Delay, DIFF Volts
- Full Bridge with Measured Excitation
- Battery Voltage
- 107 Temperature Probe
- 207 RH Probe
- Thermocouple Temperature (SE)

- Thermocouple Temperature (DIFF)
- Platinum RTD Temperature
- Internal Temperature
- Time
- Signature
- Set Digital Ports
- Read Digital Ports
- Burst
- Excitation With Delay
- Timer
- Period Interval Measurement
- Vibrating Wire Measurement
- Set/Control External Device (e.g. SDM's)

PROCESSING INSTRUCTIONS allow data reduction, entry of simple algorithms, or conversion of raw data into engineering units. In the following instructions, X, Y, and Z are Input Locations where incoming data values or processed results are temporarily stored; F refers to a fixed value (constant).

- Z = F
- Z = X
- Z = Z+1
- Z = X+Y
- Z = X+F
- Z = X-Y
- Z = X*Y
- Z = X*F
- Z = X/Y
- Z = SQRT(X)
- Z = LN(X)
- Z = EXP(X)
- Z = 1/X
- Z = ABS(X)
- Z = FRAC(X)
- Z = INT(X)
- Z = X MOD F
- Z = X ↑ Y
- Z = SIN(X)
- Z = ARCTAN (X/Y)
- Spatial Maximum
- Spatial Minimum
- Spatial Average
- Scaling Array
- 5th Order Polynomial
- Saturation Vapor Pressure
- Wet/Dry Bulb Temp to Vapor Pressure
- Low Pass Filter
- Resistance from Bridge Output

OUTPUT PROCESSING INSTRUCTIONS process measured values, collected over time.

- Sample
- Average
- Totalize
- Maximize
- Minimize
- Histogram
- Windvector
- Real Time
- High/Low Resolution
- Sample on Max or Min
- Redirect Output to Input Storage
- Standard Deviation

PROGRAM CONTROL INSTRUCTIONS allow logic based on time or data. They also control serial data output and CR10-initiated telecommunications.

- Subroutine
- Loop
- If X Compared to Y
- If X Compared to F
- If Flag/Port
- If Time
- If Case/Begin Case
- Else
- End
- Control Serial Data Output
- Initiate Telecommunications
- Send Serial Character

Once an instruction is selected, a set of associated parameters is queued in the datalogger's program memory. Each parameter controls a specific aspect of the instruction's operation. Depending on the versatility of the instruction, from 1 to 12 parameters are required. For example, the parameters associated with Instruction 2 (DIFFerential voltage measurement) are:

1 - REPS - Defines the number of times an instruction executes (allows one instruction to measure several identical sensors).

2 - RANGE - Defines the full scale range of the voltage to be measured. Ranges are ± 2.5 , 7.5, 25, 250, and 2500 mV. Fast (272 μ s), slow (2.72 ms), 60 Hz rejection, and 50 Hz rejection integration times are also selected with this parameter.

3 - INPUT CHANNEL - Defines the analog input channel that will make the first measurement.

4 - LOCATION - Defines the first Input Storage location.

5 - MULTIPLIER - Allows multiplication of data; for example, 1.8 is entered to convert a temperature measurement from $^{\circ}$ C to $^{\circ}$ F.

6 - OFFSET - Allows addition or subtraction of an offset value; for example, 32 is entered to complete the above temperature conversion.

Once the parameters have been entered, the next instruction is selected. This procedure is followed until a specific program has been created. Following program entry, the datalogger checks for errors, then begins executing the program and acquiring data.


SCAN RATE, DATA STORAGE

The maximum rate at which the datalogger can execute its program is 64 times per second. (The maximum rate at which a single input can be measured is 750 samples per second.)

After measurement and analog-to-digital conversion, data are directed to Input Storage locations which hold the measurement value for viewing, subsequent processing, or until transfer to Final Storage. Data can be selectively stored based on user-defined events or intervals and need not be tied to scan rate. Data remains in Input Storage until written over by subsequent measurement or processing.

EDLOG

Datalogger program development is supported by PC208 software (EDLOG). Help screens are available to define all instructions and parameter options. Input locations can be annotated with alphanumeric labels so that computer-monitored data is labelled. Once the program has been created, it can be downloaded to the CR10 directly, through telecommunications, or to a storage module for later downloading.



EDLOG simplifies CR10 programming with annotated instructions, parameters and labels.

SAMPLE PROGRAM

Every five minutes, the following program measures air temperature ($^{\circ}$ C) at six locations within a greenhouse. Critical maximum temperature is 30° C (86° F); if any temperature exceeds that threshold, a control port trips a relay that activates an exhaust fan. The average temperature value measured by each thermistor is recorded hourly.

SENSOR CONNECTIONS

In this example, sensor signal leads are connected to CR10 single-ended input channels 1 through 6, excitation leads are connected to excitation channel 1, and sensor grounds are connected to any analog ground terminal. Port 1 controls the exhaust fan.

| | Program | Comments | |
|--------------------------|-------------------------|--------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|
| * 1 | Table 1 Programs | <i>Executes the following program every 5 minutes.</i> | |
| 01: 300 | Sec. Execution Interval | | |
| Measurement & Processing | 01: P11 | Temp 107 Probe | <i>Measures six Model 107 Thermistors and places the results in Input Locations 1-6.</i> |
| | 01: 6 | Reps | |
| | 02: 1 | IN Chan | |
| | 03: 1 | Excite all reps w/EXchan 1 | |
| | 04: 1 | Loc [:TEMP #1] | |
| | 05: 1 | Mult | |
| | 06: 0 | Offset | |
| Measurement & Processing | 02: P49 | Spatial Maximum | <i>Analyzes the incoming data and places the highest temperature in Input Location 7.</i> |
| | 01: 6 | Swath | |
| | 02: 1 | First Loc TEMP #1 | |
| | 03: 7 | Max Value Loc [:MAX TEMP] | |
| Exhaust Fan Control | 03: P89 | If X <=> F | <i>Compares that temp. against 30$^{\circ}$. If the measured temp. is higher, the exhaust fan is activated (or remains active), else, if lower</i> |
| | 01: 7 | X Loc MAX TEMP | |
| | 02: 3 | >= | |
| | 03: 30 | F | |
| | 04: 41 | Set high Port 1 | |
| | 04: P94 | Else | |
| Exhaust Fan Control | 05: P86 | Do | <i>the exhaust fan is turned off or remains off.</i> |
| | 01: 51 | Set low Port 1 | |
| | 06: P95 | End | |
| Data Output | 07: P92 | If time is | <i>The following data is output to Final Storage every hour:</i> |
| | 01: 0 | minutes into a | |
| | 02: 60 | minute interval | |
| | 03: 10 | Set high Flag 0 (output) | |
| Data Output | 08: P77 | Real Time | <i>date, hour, minute;</i> |
| | 01: 110 | Day,Hour-Minute | |
| Data Output | 09: P71 | Average | <i>average temp. measured by each sensor. (Each average is based on 12 measurements.)</i> |
| | 01: 6 | Reps | |
| | 02: 1 | Loc TEMP #1 | |
| | 10: P | End Table 1 | |

With PC208 software and an appropriate telecommunications link, a researcher can monitor real-time data or control the exhaust fan remotely. Data transfer to a computer can be selected as binary, comma-delineated or printable ASCII.

Enclosures, Power Supplies, and Towers

A CR10 housed in a weather-resistant enclosure is engineered for data collection under extremely harsh conditions. A low power design allows the CR10 to operate one year on 7.0 Ahr, unregulated 12 volt source, depending on scan rate, number of sensors scanned, and external temperature. For field installations, Campbell Scientific can provide towers and mounting accessories.

ENCLOSURES

A protective enclosure for the CR10 is required in indoor or outdoor areas where dust, water, sunlight, or environmental pollutants are present.


Our NEMA 4X enclosures are modified for cable entry and attach either to a flat surface or a vertical mast (1.00" to 1.25" IPS pipe). The white fiberglass-reinforced polyester enclosures are UV-stabilized and reflect solar radiation, reducing temperature gradients inside the housing. An internal mounting plate is prepunched for easy system configuration and exchange of equipment in the field. A lockable hasp provides additional security.

Two standard enclosures are available for the CR10, its power supply, and peripherals.

MODEL ENC 10/12 houses the CR10, a power supply, and one data retrieval peripheral such as a storage module. Inside dimensions are 12" x 10" x 4.5"; weight is 9 pounds.

MODEL ENC 12/14 houses the CR10, power supply, and one or more peripherals. Inside dimensions are 14" x 12" x 5.5"; weight is 12 pounds.

While these enclosures satisfy most application requirements, larger sizes can be specially ordered.




Model ENC 12/14 Enclosure with CR10, DC112 Telephone Modem, SM716 Storage Module, and PS12-ALK Power Supply

POWER SUPPLIES

The PS12 Power Supply with Charging Regulator accepts 16 to 26 VDC or AC input and provides a charging voltage to the 12 volt rechargeable battery option or to an external 12 volt battery. The battery options shown below are:

PS12-ALK contains eight non-rechargeable 'D'-cell alkaline batteries with a 7.5 Ahr rating at 20°C.

PS12-LA rechargeable battery option includes one 12 volt, 7 Ahr, rechargeable battery, and an AC transformer. It is float-charged with AC power or a solar panel.



SOLAR PANELS

MODEL MSX5 or **MSX10** unregulated solar panel is used to float-charge the PS12-LA rechargeable battery option. Based on an illumination of 1 kW/m² and ambient temperature of 20°C, a peak voltage of 17 volts is supplied. Call Campbell Scientific if regulated solar panels for recharging customer-supplied 12 volt batteries are required.

TOWERS & MOUNTS

For field installations, Campbell Scientific manufactures durable tripods and towers designed for easy installation and adjustable placement of sensor mounts.

CM6 and **CM10 TRIPODS** are portable, sturdy tripods, six and ten feet, respectively. They can be staked down or mounted to a concrete pad.

10-METER TOWER is an aluminum instrument tower designed for fixed applications. Its triangular sections are bolted together with zigzag bracing. Models are available for cementing into the ground or mounting onto a roof. They can be further stabilized by guy wires.

Specifications

The following electrical specifications are valid for an ambient temperature range of -25° to +50° C unless otherwise specified.

ANALOG INPUTS

NUMBER OF CHANNELS: 6 differential or up to 12 single-ended. Each differential channel can be configured as two single-ended channels.

CHANNEL EXPANSION: The Model AM416 Relay Multiplexer allows an additional 64 single-ended channels to multiplex into four CR10 single-ended channels. Up to three AM416's can be connected to one CR10.

ACCURACY OF VOLTAGE MEASUREMENTS AND ANALOG OUTPUT VOLTAGES:
0.2% of FSR, 0.1% of FSR (0 to 40°C)

RANGE AND RESOLUTION: Ranges are software selectable for any channel. Resolution for a single-ended measurement is twice the value shown.

| Full Scale Range | Resolution |
|-------------------|-----------------|
| ± 2500 millivolts | 333 microvolts |
| ± 250 millivolts | 33.3 microvolts |
| ± 25 millivolts | 3.33 microvolts |
| ± 7.5 millivolts | 1.00 microvolts |
| ± 2.5 millivolts | 0.33 microvolts |

INPUT SAMPLE RATES: The fast A/D conversion uses a 0.25 ms signal integration time and the slow conversion uses a 2.72 ms signal integration. Two integrations, separated in time by 1/2 of an AC line cycle, are used with the 60 Hz or 50 Hz noise rejection option. Differential measurements include a second sampling with reversed input polarity to reduce thermal offset and common mode errors. Input sample rates are the time required to measure and convert the result to engineering units.

| | |
|------------------------------------|---------|
| Fast single-ended voltage: | 2.6 ms |
| Fast differential voltage: | 4.2 ms |
| Slow single-ended voltage: | 5.1 ms |
| Slow differential voltage: | 9.2 ms |
| Differential with 60 Hz rejection: | 25.9 ms |
| Fast differential thermocouple: | 8.6 ms |

INPUT NOISE VOLTAGE:

| | | |
|-----------------------------------|-----|---------------------|
| Fast differential | --- | 0.82 microvolts RMS |
| Slow differential | --- | 0.25 microvolts RMS |
| Differential with 60 Hz rejection | --- | 0.18 microvolts RMS |

COMMON MODE RANGE: ± 2.5 volts.

DC COMMON MODE REJECTION: > 140 dB.

NORMAL MODE REJECTION: 70 dB
(60 Hz with slow differential measurement).

INPUT CURRENT: 3 nanoamps maximum.

INPUT RESISTANCE: 200 gigohms.

EXCITATION OUTPUTS

DESCRIPTION: The CR10 has 3 switched excitations, active only during measurement, with only one output active at any time. The off state is high impedance.

RANGE: ± 2.5 volts.

RESOLUTION: 0.67 millivolts.

ACCURACY: Same as voltage input.

OUTPUT CURRENT: 20 mA @ ± 2.5 V; 35 mA @ ± 2.0 V; 50 mA @ ± 1.5 V.

FREQUENCY SWEEP FUNCTION: A swept frequency, square wave output between 0 and 2.5 volts is provided for vibrating wire transducers. Timing and frequency range are specified by the instruction.

RESISTANCE AND CONDUCTIVITY MEASUREMENTS

ACCURACY: 0.015% of full scale bridge output, limited by the matching bridge resistors. The excitation voltage should be programmed so the bridge output matches the full scale input voltage range.

MEASUREMENT TYPES: 6-wire and 4-wire full bridge, 4-wire, 3-wire, and 2-wire half bridge. Bridge measurements are ratiometric and dual polarity to eliminate thermal emf's. AC resistance measurements use a dual polarity 0.75 ms excitation pulse for ionic depolarization, with the signal integration occurring over the last 0.25 ms.

PERIOD AVERAGING MEASUREMENTS

DEFINITION: The time period for a specified number of cycles of an input frequency is measured, then divided by the number of cycles to obtain the average period of a single cycle.

INPUTS: Any single-ended analog channel; signal dividing or AC coupling is normally required.

INPUT FREQUENCY RANGE:

| Range Code | Peak to Peak Volts Required @ Max. Freq.* | Maximum Frequency |
|------------|-------------------------------------------|-------------------|
| 1 | 2 mV | 8 kHz |
| 2 | 3 mV | 20 kHz |
| 3 | 12 mV | 50 kHz |
| 4 | 2000 mV | 200 kHz |

*AC voltage; must be centered around CR10 ground

REFERENCE ACCURACY: ± 40 ppm.

RESOLUTION: ± 100 nanoseconds divided by the number of cycles measured. Resolution is reduced by signal noise and for signals with a slow transition through the zero voltage threshold.

TIME REQUIRED FOR MEASUREMENT: Signal period times the number of cycles measured plus 1.5 cycles.

PULSE COUNTERS

NUMBER OF PULSE COUNTER CHANNELS: 2 eight bit or 1 sixteen bit; software selectable.

MAXIMUM COUNT RATE: 2000 Hz, eight bit counter; 250 kHz, sixteen bit counter. Pulse counter channels are scanned at 8 Hz.

MODES: Switch closure, high frequency pulse, and low level AC.

SWITCH CLOSURE MODE

Minimum Switch Closed Time: 5 milliseconds.
Minimum Switch Open Time: 6 milliseconds.
Maximum Bounce Time: 1 millisecond open without being counted.

HIGH FREQUENCY PULSE MODE

Minimum Pulse Width: 0.002 milliseconds.
Maximum Input Frequency: 250 kHz.
Voltage Thresholds: Count upon transition from below 1.5 V to above 3.5 V.
Maximum Input Voltage: ± 20 V.

LOW LEVEL AC MODE

(Typical of magnetic pulse flow transducers or other low voltage, sine wave outputs).
Minimum AC Input Voltage: 6 mV RMS.
Input Hysteresis: 11 mV.
Maximum AC Input Voltage: 20 V RMS.

| Frequency Range: | AC Input (RMS) | Range |
|------------------|----------------|-------------------|
| | 20 mV | 1 Hz to 100 Hz |
| | 50 mV | 0.5 Hz to 400 Hz |
| | 150 mV to 20 V | 0.3 Hz to 1000 Hz |

(Consult factory if higher frequencies are desired.)

DIGITAL I/O PORTS

8 ports, software selectable as binary inputs or control outputs.

OUTPUT VOLTAGES (no load): high 5.0 V ± 0.1V; low < 0.1 V.

OUTPUT RESISTANCE: 500 Ω.

INPUT STATE: high 3.0 V to 5.5 V; low -0.5 V to 0.8 V.

INPUT RESISTANCE: 100 kΩ.

SDI-12 INTERFACE STANDARD

This communication protocol, developed for microprocessor-based hydrologic and environmental sensors, is available as a software option in the CR10.

SENSOR CONNECTIONS: Digital I/O Port #8 (for asynchronous communication), 12V power, and ground. Up to ten SDI-12 sensors can be connected to a CR10.

TRANSIENT PROTECTION

All input and output connections to the CR10 module are protected using RC filters or transzorbis connected to a heavy copper bar between the circuit card and the case. The CR10WP Wiring Panel includes additional spark gap and transzorb protection.

CPU AND INTERFACE

PROCESSOR: Hitachi 6303.

MEMORY: 32K ROM, 64K RAM.

DISPLAY: 8 digit LCD (0.5" digits).

PERIPHERAL INTERFACE: 9 pin D-type connector for keyboard display, storage module, modem, printer, cassette, and RS-232 adapter. Baud rates selectable at 300, 1200, 9600 and 76,800. ASCII communication protocol is one start bit, one stop bit, eight data bits (no parity).

CLOCK ACCURACY: ± 1 minute per month.

MAXIMUM PROGRAM EXECUTION RATE: System tasks initiated in sync with real-time up to 64 Hz. One measurement with data transfer is possible at this rate without interruption.

SYSTEM POWER REQUIREMENTS

VOLTAGE: 9.6 to 16 volts.

TYPICAL CURRENT DRAIN: 0.5 mA quiescent, 13 mA during processing, and 35 mA during analog measurement.

BATTERIES: Any 12 volt battery can be connected as a primary power source. Enclosures with power supply options are available.

PHYSICAL SPECIFICATIONS

SIZE: 7.8" x 3.5" x 1.5" - Measurement & Control Module; 9" x 3.5" x 2.9" - with CR10WP Wiring Panel. Additional room required for connectors.

WEIGHT: 2 lbs.

WARRANTY

Three years against defects in materials and workmanship.

Additional Information

ASSURANCE OF QUALITY

Campbell Scientific has been producing portable research-grade dataloggers for over fifteen years. Our commitment to quality is evidenced in the design and workmanship of the CR10 Measurement and Control System. Tailored for demanding field use, the CR10 features durable components, compact size, low power consumption, wide temperature tolerance, and easy field replacement.



After bench testing, all CR10 Modules are cycled between -35° to 60°C in an environmental chamber.

Every CR10 is calibrated and thoroughly tested to ensure consistent, dependable performance. The CPU, system components, and all I/O connections are tested. The datalogger's results are calibrated against NIST-traceable standards (National Institute of Standards and Technology, formerly known as NBS). A test report and calibration certificate including NIST traceable numbers are shipped with each CR10.

WARRANTY AND REPAIR

The CR10 is backed with a three-year warranty covering parts and labor. Our Mean Time Between Failure (MTBF) is over 50 years.




If repair is required, our professional staff of technicians will repair and recalibrate the CR10 to original specifications.

FOR MORE INFORMATION

For more detailed information on the products mentioned in this brochure, please contact Campbell Scientific sales or application engineers. Their technical and scientific backgrounds cover a wide range of fields including meteorology, agriculture, hydrology, industry, and vehicle testing. Trained in data acquisition, they can help develop your system configuration and give post-sale support if needed.

Pricing and ordering information is available from our price list or from our order entry staff. Contact our marketing department for information on customized training sessions or authorized representatives in your area.



Campbell Scientific's U.S. factory is located in Logan, Utah.

Please call us today; we would like to discuss your application needs with you.



CAMPBELL SCIENTIFIC, INC.™

P.O. Box 551
Logan, UT 84321
USA
Phone (801) 753-2342
TLX 453058
FAX 801-752-3268

Campbell Scientific Canada Corp.
9525 41st Avenue
Edmonton, Alberta T6E 5X7
CANADA
Phone (403) 461-5158
TLX 037-2966 (EDM)
FAX 403-450-2531

Campbell Scientific Ltd.
14-20 Field Street
Shepshed, Leics. LE12 9AL
ENGLAND
Phone (44) 509 601141
FAX (44) 509 601091

CR10 Instruction Set Options

The customer selects one of two OS10 PROM options (at no charge); both options contain the standard set of instructions. Differences in the OS10-0.1 and OS10-1.1 options, are listed below:

| <u>Instructions</u> | <u>OS10-0.1</u> | <u>OS10-1.1</u> |
|----------------------|-----------------|-----------------|
| 23 Burst Measurement | X | |
| 105, 106 SDI-12 | | X |
| 64 Paroscientific | | X |
| 65 Bulk load | | X |

The selected option must be specified at the time of purchase, otherwise, the OS10-0.1 (default) PROM is supplied.

INSTRUCTION 23 - Burst Measurement

Burst Measurement increases the CR10 sample rate; one channel is sampled at a maximum rate of 750 Hz (once every 1.333 ms). The number of samples taken is limited by available memory. Instruction 23 makes voltage measurements on a series of single-ended or differential channels, with or without excitation.

INSTRUCTION 105 - SDI-12 Recorder

Communicates with up to ten sensors using the SDI-12 interface standard. The SDI-12 communication protocol was developed for microprocessor-based hydrologic and environmental sensors. Each SDI-12 sensor, set to a unique address between 0 and 9, responds with measurement data as commanded by the datalogger.

INSTRUCTION 106 - SDI-12 Sensor

The CR10 can act as an SDI-12 sensor by supplying measurement data to another device that issues the SDI-12 commands.

INSTRUCTION 64 - Paroscientific Processing

An instruction which simplifies the programming required to apply the calibration equation to the measurement of a Paroscientific pressure transducer with frequency outputs for both temperature and pressure.

INSTRUCTION 64 - Bulk Load

Loads eight fixed values into consecutive input locations.

New Features of OS10

- Instruction 66, Arctangent, is new.
- Instruction 69, Wind Vector, incorporates an EPA recommended algorithm for standard deviation of wind direction.
- On power-up, the CR10 can automatically load and run a program stored in an SM192 or SM716 Storage Module.
- RF communication protocol is set up for use with the RF95 modem.

Library Special PROMs

The above PROMs meet the needs of the majority of CR10 applications. Where some additional capability is required, library special PROMs are available at an additional charge. Some features of OS10 must be removed to make room for the special instructions. Library special modules include:

- The capability to save and load programs from cassette tape.
- Serial communications through control ports (300 or 1200 baud). May be used with some intelligent sensors.
- Fast Fourier Transform - The FFT is used to obtain the frequencies, relative magnitudes, and phases of various frequency components in a time varying signal. Instruction 60 performs a Fast Fourier Transform on a set of data contained in sequential Input Storage locations.
- Rainflow Histogram - An algorithm used in estimating cumulative fatigue damage. Strain measurements are processed to provide a two dimensional histogram. One dimension is the amplitude of the stress/strain cycles, the number of cycles within each user defined amplitude range are counted. The other dimension (optional) is mean value of the strain cycle.

Consult Campbell Scientific for further information regarding library special PROMs.



CAMPBELL SCIENTIFIC, INC.

Copyright © 1990, 1991
Campbell Scientific, Inc.

P.O. Box 551 • Logan, Utah 84321 • (801) 753-2342 • TLX 453058 • FAX 801-752-3268

Printed August 1991

APPENDIX L

CHARACTERISTICS OF EXISTING DATA SETS

Characteristics of Existing High Quality Data Sets to be Included in the Monitoring Program - Wind

| Project Site | Data Site | Time Period | Current Collection | Equipment Description | Recording Interval | Anemometer Height | Contact Organization |
|---------------------------|-----------------------------|------------------------------------|--------------------|--------------------------------------------------------------|--------------------------------------|------------------------------|---------------------------------|
| Oahu Wind | | | | | | | |
| Kahuku Upper | Opana | 3/76 to 2/83 | no | Sierra Inst. 3 cup anem., UH recorder | 6 min. averages | 37 feet | UHMET |
| Hawaii Wind | | | | | | | |
| Kahua Ranch Southpoint | Kahua Ranch Southpoint | 4/92 to present 6/87 to present | yes yes | Zond WIRE 2000 SecondWind datalogger | hourly averages hourly averages | 90, 140 feet unknown | Kahua Ranch Kamaoa Wind Farm |
| MauI Wind | | | | | | | |
| McGregor Point Puunene | Maalaea Puunene | 2/93 to present 5/92 to present | yes yes | waiting for information waiting for information | 15 min. averages 15 min. averages | 10, 37, 64 meter 10 meter | HECO HECO |
| Kauai Wind | | | | | | | |
| N. of Hanapepe Port Allen | Robinson Port Allen Airport | 7/85 to 4/88 2/92 to 1/93 | no yes | Windrunner Met One #104 3 cup anem., #024 air foil sensor | approx. monthly 6 min. & hr. avg. | approx. 20 feet 30 feet | Robinson Measurement Tech. |
| Molokai Wind | | | | | | | |
| Small Applications | West Molokai | 2/92 to present | yes | Zond datalogger, 2 channel | hourly averages | 90 feet | Zond |

Characteristics of Existing High Quality Data Sets to be Included in the Monitoring Program - Solar

| Oahu Solar | | Time Period | Current Collection | Equipment Description | Recording Interval | Data Type | Contact Organization |
|---------------|---------------------|-------------------|--------------------|--------------------------------------------------------------------------------------------|--------------------|-----------------|----------------------|
| Project Site | Data Site | | | | | | |
| N. Ewa Plain | Kunia | 1989 to 1990 | yes | LI-COR pyronometer, LI-COR quantum sensor | hourly averages | global | HSPA |
| Ewa Plain | Campbell Industrial | 4/91 to present | yes | waiting for information | 15 min. averages | global | HECO |
| Hawaii Solar | | Time Period | Current Collection | Equipment Description | Recording Interval | Data Type | Contact Organization |
| Project Site | Data Site | | | | | | |
| Waikoloa | Kawaihae | 12/90 to 8/92 | no | waiting for information | 15 min. averages | global | HECO |
| Waikoloa | Puuanahulu | 1/92 to present | yes | waiting for information | 15 min. averages | global | HECO |
| Waikoloa | Kiholo Bay | mid 91 to present | yes | Ascension Tech. RSR, CR10 datalogger | hourly averages | global; direct | Bakken |
| Waikoloa | Waimea | 4/93 to present | yes | Ascension Tech. RSR, CR10 datalogger | hourly averages | global; direct | Bakken |
| Waikoloa | Mauna Lani Resort | 4/93 to present | yes | Ascension Tech. RSR, CR10 datalogger | hourly averages | global; direct | Bakken |
| Keahole Point | Keahole | 3/93 to present | yes | waiting for information | 15 min. averages | global; diffuse | HECO |
| Keahole Point | Keahole | 1985 to present | yes | 2 Eppley 8-48 pyron., 1 wband, CSI 21X datalogger since 4/92 LICOR LI200S pyron. as backup | 6 min. totals | global; diffuse | NEL/Daniel |
| North Kohala | Kahua Ranch | 10/92 to present | yes | Eppley pyronometer, CS21X datalogger | hourly averages | global | Zond |
| Maul Solar | | Time Period | Current Collection | Equipment Description | Recording Interval | Data Type | Contact Organization |
| Project Site | Data Site | | | | | | |
| Puunene | Puunene | 5/92 to present | yes | waiting for information | 15 min. averages | global | HECO |
| Kihui | PVUSA | 1990 to present | yes | CSI 21X datalogger, 2 Eppley PSP (horiz. & 22° tilt) | 10 min. averages | global | PVUSA |
| Kahului | Mauli Quarry | 5/92 to present | yes | waiting for information | 15 min. averages | global | HECO |
| Kahului | Maulinet #107 | 1983 to 1991 | no | waiting for information | hourly averages | global | UH (Agronomy & Soil) |
| Kauai | | Time Period | Current Collection | Equipment Description | Recording Interval | Data Type | Contact Organization |
| Project Site | Data Site | | | | | | |
| Barking Sands | McBryde Property | 1/91 to present | yes | LICOR pyron., CR10 datalogger | hourly averages | global | McBryde |

DEVELOPMENT OF RENEWABLE ENERGY
RESOURCE SUPPLY CURVES

Phase 2: Renewable Energy Resource Assessment And Development Program

November 1995

prepared for:

State of Hawaii
Department of Business, Economic Development & Tourism
Energy Division
335 Merchant Street, Room 110
Honolulu, Hawaii 98613
(808) 587-3800

prepared by:

RLA Consulting
18223 102nd Avenue NE, Suite A
Bothell, Washington 98011
(206) 488-0848




TABLE OF CONTENTS

| Section | Page |
|----------------------------------------------------------|------|
| SECTION 1. INTRODUCTION..... | 1 |
| PURPOSE | 1 |
| APPROACH TO DEVELOPING RESOURCE SUPPLY CURVES | 1 |
| REPORT ORGANIZATION..... | 2 |
| SECTION 2. COST AND PERFORMANCE ESTIMATES | 3 |
| OVERALL APPROACH | 3 |
| TECHNOLOGY-SPECIFIC ASSUMPTIONS | 5 |
| Wind | 5 |
| Photovoltaics | 6 |
| Solar Thermal | 8 |
| Hydroelectric | 9 |
| Biomass..... | 9 |
| Wave..... | 11 |
| Ocean Thermal Energy Conversion (OTEC)..... | 12 |
| Geothermal..... | 12 |
| SECTION 3. RESOURCE SUPPLY CURVES..... | 14 |
| ECONOMIC ASSUMPTIONS | 14 |
| RENEWABLE ENERGY PROJECTS INCLUDED IN THE DATABASE | 14 |
| ILLUSTRATIVE RESOURCE SUPPLY CURVE RESULTS..... | 15 |
| BIBLIOGRAPHY | 21 |

LIST OF APPENDICES

- A Guidelines for Using the RSC Computer Model
- B Illustrative Results from the RSC Computer Model
- C Technology Data Sheets

LIST OF TABLES

| Table | Page |
|--------------------------------------------------------|------|
| Table 1. Resource Supply Curves Variable Summary | 16 |
| Table 2. Hawaii Projects | 17 |
| Table 3. Maui Projects..... | 18 |
| Table 4. Oahu Projects..... | 19 |
| Table 5. Kauai Projects | 20 |



SECTION 1. INTRODUCTION

RLA Consulting (RLA) has been retained by the State of Hawaii Department of Business, Economic Development, & Tourism (DBEDT) to conduct a Renewable Energy Resource Assessment and Development Program. This three-phase program is part of the Hawaii Energy Strategy (HES), which is a multi-faceted program intended to produce an integrated energy strategy for the State of Hawaii. This report summarizes the results of Phase 2 of the program, Development of Renewable Energy Resource Supply Curves.

PURPOSE

In Phase 1 of the program, suitable locations with development potential for renewable energy projects were identified and defined on each of the major Hawaiian islands. The emphasis for project identification was on utility-scale, grid-connected renewable energy projects. The purpose of Phase 2 is to develop resource supply curves based on the costs and performance of the potential projects identified in the first phase. The cost and performance estimates are based on current renewable energy conversion systems and realistic future projections with consideration of all the necessary components of a project, including financing, permitting, shipping, equipment integration, construction, operation, and maintenance. The results of Phase 2 include detailed cost and performance estimates for more than 230 potential renewable energy projects in the state as well as a user-friendly computer program that calculates the cost of energy for the projects and displays a graphical summary of the results of a specified query.

The information contained in this report is intended to summarize the baseline assumptions and present some illustrative results. The resource supply curve program was developed to provide the user with maximum flexibility to compare various options under differing conditions. As such, there is no single set of results. In addition, the objective of Phase 3 of the program is to concentrate on the integration and interpretation of the data. Therefore, limited conclusions have been drawn at this time. The final report for the project, completed in Phase 3, will include an integrated plan for incorporating renewables into the state's energy mix.

APPROACH TO DEVELOPING RESOURCE SUPPLY CURVES

In order to estimate costs and performance for renewable energy projects in Hawaii, RLA compiled the most current cost and performance data for each of the renewable energy conversion technologies to be evaluated in the project. Technologies included wind, solar thermal (trough and dishes), photovoltaics (fixed and tracking arrays), biomass electricity (including municipal solid waste), biomass fuel (both ethanol and methanol), hydroelectric, wave, and ocean thermal. For each potential project, costs and performance were estimated based on site-specific resource data and other information, then technology data worksheets were developed to summarize the detailed information for the project in an accurate and consistent manner.

A Resource Supply Curve (RSC) computer model was then developed to calculate the levelized cost of energy for each project based on the Electric Power Research Institute Technical Assessment Guide (EPRI TAG) methodology, a common set of economic parameters, and the data provided on the technology data worksheets. The results of the program are a graphical presentation of the cost of energy of each project versus the cumulative energy for all the projects meeting a specified criteria.

Resource supply curves provide a means for comparing costs of different projects within a specific technology and between technologies for each island or for the state as a whole. They can be used to determine which technologies can make the greatest energy contribution on a given island and to the state as a whole considering both the availability of the resource and the technology's economics. The primary value of resource supply curves is in comparing different generating options with each other given similar economic assumptions and evaluation methodologies. Because of changing economic conditions, financing assumptions, tax credit considerations, and costing methodologies, the values

generated by the RSC program should not be used as absolute values outside the context of the program (i.e., for contracting purposes or pricing justification). Similarly, the values should not be compared against other non-renewable generating options unless the cost of energy is calculated using a consistent approach and methodology.

REPORT ORGANIZATION

This report is organized into three main sections. Following the introduction, Section 2 summarizes the approach and assumptions used to estimate the costs and performance for each of the potential renewable energy projects evaluated. Section 3 discusses the economic basis for calculating the cost of energy and contains illustrative results and examples from the RSC program. The technology data worksheets, guidelines for using the RSC computer model, and illustrative results for each island and technology are included in appendices.

SECTION 2. COST AND PERFORMANCE ESTIMATES

In developing cost and performance estimates for each of the projects evaluated in this program, RLA combined state-of-the-art knowledge regarding the status of the technology and its future implementation with a practical perspective on the elements necessary to bring a project from its conception stage to successful operation in Hawaii. The results are realistic estimates bounded by optimistic and conservative ranges to represent the uncertainty associated with the technology development or the resource availability.

OVERALL APPROACH

For each potential project location identified in Phase 1 of the Renewable Energy Assessment and Development Program, a number of possible project sizes were evaluated. The size and number of projects evaluated at each location was based on several factors. The size and characteristics of the land parcel available for potential development was the primary consideration. In some cases, only one project size was evaluated because land constraints prohibited consideration of other sizes. In most cases, however, multiple project sizes were evaluated because sufficient land was available to support larger projects.

The capacity of the existing transmission lines was the next criteria used to define potential project sizes. For most locations, transmission upgrades were required for projects above a certain size. In these cases, the largest project that could be installed at a particular site without costly transmission upgrades was evaluated. Larger projects (which included the costs of transmission upgrades) were also evaluated as appropriate.

The size of the utility grid on each island was also a consideration. For islands other than Oahu, projects larger than 30 MW may be difficult to develop because of the size of the existing utility grid and the projected demand growth. As a result, 30 MW project sizes were evaluated for sites in which other constraints did not define the size. On Oahu and for a few cases on the other islands, projects of 50 MW or larger were evaluated. This is justified on Oahu because of the size of the utility grid. Large projects were evaluated on the other islands to provide additional data on the economies of scale, and to account for any future changes in demand due to factors such as island interconnection, large load growth, or load profile changes.

For most technologies, two conceptual plant designs were developed. One design was based on plant components that are commercially available for installation in 1995 projects (current technology). The other design was based on components that are realistically expected to be commercially deployed by the year 2005 (future technology). In the case of technologies that have not been commercially deployed, estimates were made for only the future scenario. For mature technologies in which no substantial technological advances are expected, estimates were developed for only the current scenario.

In order to account for the uncertainty in cost and resource projections, three estimates (representing optimistic, nominal, and conservative cases) were made for each potential project and for both stages of technology development (current or future). As a result, a total of six cost and energy estimates were made for each potential project location and size for the majority of the technologies evaluated.

The optimistic, nominal, and conservative cases differ from each other because of uncertainty in energy production, project costs, or a combination of both. Energy production estimates vary to reflect the uncertainty of the resource, as well as the potential variation in energy conversion efficiency of the technology. Cost estimates vary to reflect uncertainties in factors such as the development pace of the technology, changes in market conditions, variations between suppliers and developers, and other uncertainties inherent in estimating project costs in an environment where few projects of this

type have been completed. The nominal value represents the best estimate but is not necessarily the mean value of the range.

Project performance estimates are based on the conceptual plant designs, potential project sizes, and the best available resource data. For wind and solar projects, additional data collection is underway at a number of the sites. Performance estimates for these technologies will be updated when better resource data are available and the results will be included in the Phase 3 report. In all cases, gross energy estimates were calculated and energy losses were assumed to account for factors such as line losses and downtime. The net energy estimates are the amount of energy expected to be delivered to the utility grid.

Costs on the technology data worksheets are estimated in a manner that is consistent with the EPRI TAG method of evaluating utility generating alternatives and are stated in 1995 dollars. Only the total capital costs, the total annual expenses, and the net annual energy production are used in the resource supply curve model. The detailed itemization of costs is given on the worksheets to provide supporting documentation for the totals, allow comparison between different projects, and ensure consistency. A description of the cost components follows.

Capital Costs include Total Plant Costs and Initial Costs. Total Plant Costs are made up of five components: process capital, general facilities capital, engineering and overhead, project contingency, and process contingency. Each of the components of the Total Plant Costs and Initial Costs is discussed in more detail below:

Process Capital is the total constructed cost of all on-site processing and generating units, including all direct and indirect construction costs. The estimates have been made based on site layouts consistent with the geographic and topographic constraints at each project location. Storage facilities and equipment required for fuel delivery and waste removal (if any) are included. Major equipment costs are based on recent equipment purchases whenever possible, and other equipment costs have been scaled based on costs from similar facilities. Labor costs were estimated from comparison with similar projects and have been adjusted to account for site constraints and local labor rates.

General Facilities Capital includes the cost of such facilities as roads, office buildings, shops, etc., that are required for plant operations, but which do not necessarily directly contribute to the production of the energy end product.

Engineering and Overhead is assumed to be 10% of the process capital.

Project Contingency is assumed to be 10% of the sum of the above three categories. Project contingency is meant to cover the cost of additional equipment or unexpected costs that may be overlooked in a preliminary cost estimate.

Process Contingency is defined in the EPRI TAG as a capital cost contingency factor applied to a new technology in an effort to quantify the uncertainty in the technical performance and cost of the commercial-scale equipment. In this study, process contingency is accounted for by the variation between the conservative and optimistic estimates of cost and performance. As such, no additional amount for process contingency has been added to the cost estimates.

Initial Costs reflect the cost of supplies needed on hand to begin operating the power plant. Initial or start-up costs include the equivalent of one month's operating costs, 25% of one month's fuel cost (if applicable), 2% of the Total Plant Cost (a simplifying assumption from the EPRI TAG) to account for any last minute changes, and the capital required for inventory of spare parts, fuel on hand, or other miscellaneous expenses.

Annual Expenses include the annual costs associated with project operation which are divided into two basic categories: fixed and variable. Variable costs are directly associated with how much energy is produced, while fixed costs are unaffected by the energy production. The annual operating costs include an allotment for periodic component replacements leveled on an annual basis.

Due to the high value of land in Hawaii, it is most likely that land for any potential renewable energy project will be leased rather than purchased. Land lease costs are included as a fixed operating cost. Lease rates depend on the land's value for other uses and the land owner. For consistency purposes, land lease costs were estimated for different categories of land ownership including private, state, federal (military), and Hawaiian Homes land, and these values were applied consistently among projects.

In order to adjust U.S. mainland costs to Hawaii, cost indexes were applied based on the R.S. Means Building Construction Cost Data, 1993.¹ This document specifies indexes for materials and installation of various construction-related projects for use in adjusting costs between U.S. cities. Additional cost information on labor rates, equipment rental, and construction processes was obtained from construction companies involved with projects on each of the Hawaiian islands and this information was applied as appropriate.

Permitting costs were estimated based on discussions with county, state, and federal permitting offices in Hawaii and they vary based on the technology type and the zoning classification of the project site. Shipping costs are based on recent quotations and actual equipment weight and include delivery of the equipment to the project site.

Transmission costs were based on discussions with Hawaiian Electric Company, recent studies of transmission upgrades, and costs for other utilities adjusted to Hawaii conditions.

TECHNOLOGY-SPECIFIC ASSUMPTIONS

The following sections describe the assumptions that were made for each of the renewable energy technologies evaluated in this study. For each technology, the technology status, performance assumptions, and cost basis are outlined.

WIND

Technology Status: Wind energy is a technology that has been commercially deployed on a large-scale basis for more than ten years. However, technology advances continue to improve the performance and reliability as well as reduce the cost of the technology. Research through the U.S. Department of Energy (U.S. DOE), European Community, and others is aimed at numerous technological advances to further reduce the cost of energy from wind projects. For this study, current cost and performance estimates are meant to reflect wind technology that is currently being bid for projects that will be installed in the 1995 time frame.

Future cost and performance estimates were scaled from current estimates based on technology advances that are currently under development and expected to be achievable in the next ten years. These developments include: improved aerodynamic performance, increased rotor size, higher installed capacity per turbine, advances in variable-speed technology, improved controls, and the cost advantages associated with mass production. Some improvements are also incorporated to account for increased industry experience that will reflect the incremental lessons learned in project construction, management, and operations and maintenance.

Performance Assumptions: Estimates of the wind resource at specific sites were based on historical data in the vicinity of the site, new data being collected under the Renewable Energy Resource Assessment and Development Program, and RLA's judgment. The variations between optimistic,

¹ Means Building Construction Cost Data, 50th Edition, R.S. Means Company, Inc., 1991.

nominal, and conservative performance estimates account for uncertainty in the resource data. A power curve for a hypothetical wind turbine was used to estimate per-turbine production at each site. In addition, the following assumptions were made:

- Hourly wind resource data were used for each site where high-quality data were available. In the absence of actual hourly data, site wind speed distributions were determined based on a Weibull distribution ($k = 2.9$) and estimated average annual wind speeds. The shape of the Weibull distribution was matched to the shape of distributions from typical Hawaii sites for which high-quality data were available. The average annual wind speeds were estimated based on the nearest available data and results from the on-going monitoring program.
- Estimated energy losses were determined on a site-specific basis and range from 18%-28%, depending on the site conditions and potential project layouts (particularly the spacing between turbines). Energy losses account for blade soiling, array effects, control inefficiencies, turbulence, downtime, and line losses.
- A hypothetical wind turbine representative of commercially available technology was used for project layout purposes. It was assumed that the turbine had a 30 meter rotor diameter and was mounted on a 120 foot tower.

Cost Basis: Itemized costs were developed for each nominal current technology case using the best currently available information. Future costs were estimated based on projections by U.S. DOE, EPRI, and others. The following assumptions were made:

- Equipment costs are based on publicly available information from equipment manufacturers and recent bids for actual projects. Balance-of-station costs are based on installation information on operating projects in California, adjusted to account for costs in Hawaii and expressed in terms of 1995 dollars.
- Parametric costs were developed for construction based on three different soil types: lava, rocky, and dirt.
- Parametric costs were developed for balance-of-station costs and construction costs based on types of terrain to account for larger spacing between turbines and ease of construction.
- The size of the control buildings, monitoring systems, and support equipment varied by project size.
- Turbine and tower costs were varied to reflect larger production run discounts. A discount was applied to the equipment costs for projects larger than 50 MW and a surcharge was added to projects 5 MW or smaller.
- The majority of balance-of-station costs are assumed to be proportional to the number of wind turbines in the project. Costs for roads, grading, and electrical interconnection are scaled according to the ruggedness of the terrain and the soil type.
- Land and permitting costs vary according to land ownership and zoning.

PHOTOVOLTAICS

Technology Status: Although a large market exists for photovoltaics for remote power applications and consumer products, there is limited experience with large-scale photovoltaic installations for bulk electricity generation. However, there are multiple demonstration projects installed throughout the U.S., including a PVUSA (Photovoltaics for Utility Scale Applications) satellite project located near Kihei on the island of Maui. For this study, current cost and performance estimates are based on

experience with recent demonstration projects. Research is concentrated on increasing module efficiency and improving manufacturing processes. Future costs and performance estimates are scaled from current technology values based on industry estimates of improved efficiency and the cost advantages associated with mass production.

Performance Assumptions: Typical Meteorological Year (TMY) weather data from Barber's Point, Oahu, serves as the basis for the annual energy production estimates. TMY data are a compilation of "typical" climatic months selected from a 23 year database. The data are in hourly format and designed to provide an accurate portrayal of the long-term average climatic regime. The weather data consist of direct normal beam irradiance, global horizontal irradiance, ambient dry bulb temperature, and wind speed. Indices were used to extrapolate the results from Barber's Point to other project sites in Hawaii. The indices were based on historical climatic data in the vicinity of the site,² new data being collected under the Renewable Energy Resource Assessment and Development Program, and engineering judgment. The variations between optimistic, nominal, and conservative performance estimates account for uncertainty in the resource data. In addition, the following assumptions were made:

- Both fixed and tracking photovoltaic systems were evaluated. Fixed systems were assumed to face due south at a 15 degree tilt angle. For tracking systems, a north-south, single-axis tracking array structure was assumed.
- Current technology assumes a 13.5% efficient crystalline module at 1000 W/m² and 20°C.
- Future technology assumes a 17% efficient crystalline module at 1000 W/m² and 20°C.
- A ground cover ratio of 70% was assumed.
- Energy losses are assumed to be approximately 16%, which includes consideration of inter-array shading, cabling losses, and power conditioning efficiency.
- The array field layouts are designed to minimize wiring and associated power losses, and the array field layout is optimized on the basis of inter-array shading.

Cost Basis: The following cost assumptions were made:

- Equipment costs are based on recent information from equipment manufacturers and experience with demonstration projects.
- Parametric costs were developed for foundations and construction based on three different soil types: lava, rocky, and dirt.
- The array structure costs are based on designs used extensively in recent utility PV installations.
- Module costs vary to reflect production run discounts. In addition, future module costs are reduced to represent mass production cost advantages due to a larger market for PV systems.
- For future technology, infrastructure costs were reduced due to the increased efficiency of the modules (fewer modules are necessary for the same size project).
- Land and permitting costs vary according to land ownership and zoning.

² Kearney, D. *Solar Electric Generating System (SEGS) Assessment for Hawaii*, State of Hawaii Department of Business, Economic Development & Tourism, Honolulu, Hawaii, December 1992.

SOLAR THERMAL

Technology Status: Three main types of collectors have been used for solar thermal systems: parabolic troughs, parabolic dishes, and central receivers. Central receivers were not evaluated in this study because of land use constraints in Hawaii and the status of the technology. Parabolic trough systems are the most mature solar thermal technology and they have been extensively deployed in commercial projects in California. Prototype parabolic dish systems have been operated on a limited basis. However, extensive research and development has resulted in continuing component improvements and expected cost reductions. Current technology cost and performance information for solar trough systems is based on experience with recently installed commercial projects. Current technology cost and performance information for solar dish systems is based on projections for Dish-Sterling systems currently under development and expected to be commercially available in 1995-97. Future technology estimates are scaled from the current estimates based on knowledge of technological advances that are currently under development and expected to be achievable in the next ten years.

Performance Assumptions: Typical Meteorological Year (TMY) weather data from Barber's Point, Oahu, serves as the basis for the annual energy production estimates. TMY data are a compilation of "typical" climatic months selected from a 23 year database. The data are in hourly format and designed to provide an accurate portrayal of the long-term average climatic regime. The weather data consist of direct normal beam irradiance, global horizontal irradiance, ambient dry bulb temperature, and wind speed. Indices were used to extrapolate the results from Barber's Point to other project sites in Hawaii. The indices were based on historical climatic data in the vicinity of the site,³ new data being collected under the Renewable Energy Resource Assessment and Development Program, and engineering judgment. The variations between optimistic, nominal, and conservative performance estimates account for uncertainty in the resource data. In addition, the following assumptions were made:

- Performance of solar trough systems is based on the operation of the Solar Electric Generating Station (SEGS) plants in California. Future performance for trough systems is based on industry projections and engineering judgment of factors such as expected solar field improvements.
- Performance of the solar dishes is based on prototype testing results and performance models. Future performance is increased by approximately 5% to account for increased efficiency.
- For solar dishes, utility-scale units of 25 kW are assumed.
- For solar troughs, north-south, single-axis tracking is assumed.

Cost Basis: The following cost assumptions were made:

- Equipment costs for the solar trough systems are based on data from the SEGS plants in California and recent quotes on major equipment from vendors.
- Cost assumptions for the solar dish systems are based on research conducted for the U.S. DOE by SAIC. Future costs are estimated based on knowledge of research and development programs, both within the U.S. and abroad.
- Parametric costs were developed for foundations and construction based on three different soil types: lava, rocky, and dirt.

³ Kearney, D. *Solar Electric Generating System (SEGS) Assessment for Hawaii*, State of Hawaii Department of Business, Economic Development & Tourism, Honolulu, Hawaii, December 1992.

- For solar dishes, future cost estimates are reduced to represent cost advantages due to higher production rates because of an anticipated larger market.
- Land and permitting costs vary according to land ownership and zoning.

HYDROELECTRIC

Technology Status: Hydroelectric is a mature technology. There are few appreciable differences between the types of projects that would be installed in 1995 and those that would be installed in the year 2005. As a result, only current technology projects are evaluated in this study. New projects are expected to have lower operation and maintenance costs than existing projects resulting from semi-automatic operating strategies and improvements in designs.

Completing the permitting and environmental requirements of hydro projects in Hawaii has proven to be difficult due to the high value placed on natural resources and competing uses. For these reasons, and due to the porosity of the ground soil, hydroelectric projects developed in Hawaii are likely to be run-of-the-river rather than storage type projects.

Performance Assumptions: A computer simulation model was used to predict hydroelectric performance based on series resource data, head, pipe sizes, and turbine type. The model accounts for frictional losses in the penstock, operational restrictions, and turbine/generator efficiencies. Water resource data were based on either information from actual project proposals or hydrology reports completed for nearby hydroelectric facilities. Information on rainfall estimates and soil characteristics was also examined. Allowances were made for water bypass to maintain minimum streamflows to maintain river ecology. Energy losses account for power transformation and transmission to the utility grid.

Cost Basis: Cost estimates are based on recent experience with hydroelectric project development both within Hawaii and at other mainland locations.

BIOMASS

Technology Status: There are a number of methods for converting biomass to energy. In this study, both the conversion of biomass to electricity and the conversion of biomass to liquid fuel (both ethanol and methanol) were evaluated. Biomass fuel sources include energy crops of either trees, grass crops and organic waste (agricultural and/or municipal solid waste). The biomass conversion technologies selected for evaluation in this study are based on their applicability to Hawaii's feedstocks and conditions.

There is extensive experience in Hawaii converting biomass to electricity. Current biomass-to-electricity technology is relatively mature. Biomass-to-electricity projects utilizing bagasse and organic waste as a fuel source are currently in operation in Hawaii. These projects use a biomass-fired boiler to drive a steam turbine/generator with either tree crops, sugar, or organic waste as a fuel source. This conversion process was used as current technology for this study.

Future projects converting biomass to electricity are likely to use biomass fixed bed gassifiers integrated with open cycle gas turbines⁴ and this type of conversion technology was assumed for the future biomass-to-electricity projects evaluated in this study. Examples of gassification technology are currently being demonstrated.

For biomass-to-liquid-fuel projects, only future conversion technologies were evaluated. The process of converting some types of biomass to ethanol is commercially developed in parts of the world. The conversion of corn to ethanol is currently practiced on the U.S. mainland and sugar cane is converted to ethanol in Brazil; however, these technologies are not considered to currently be commercially

⁴ California Energy Commission. *1992 Energy Technology Status Report*, 1992.

viable in the Hawaiian environment. Future biomass-to-ethanol projects will incorporate advanced techniques such as acid pre-treatment, simultaneous saccharification and fermentation, distillation, and co-product utilization.

The production of methanol from biomass is another possible future technology. While this process is not yet commercially available, technology is being developed that will produce methanol from biomass through a process of biomass gasification coupled with conditioning and catalytic reactions.

Performance Assumptions: Biomass crop yields were estimated using the Hawaii Natural Resources Information System database and data from the Hawaiian Sugar Planters' Association. Estimates of the annual generation of organic waste material were obtained from a recent survey of Hawaii's organic waste potential that was completed for DBEDT by Unisyn.⁵ Additional assumptions include:

- Feedstock supplies were calculated for plant sizes at 25 MW or 25 MGPY (million gallons per year) and 50 MW or 50 MGPY.
- The production of tree and grass crops at the same site were mutually exclusive because the same land area would be required for either crop. Combinations of either tree or grass and organic waste, however, are possible and are used to achieve the minimal amount of feedstock for the two targeted plant capacities.
- A 7 year growth cycle is assumed for tree crops based on experience and research on short-rotation tree crops in Hawaiian conditions. The land parcels with the highest tree yields were utilized first to meet the feedstock requirements.

Cost Basis: Cost estimates for biomass installations were based on the results of recent studies. Assumptions include:

- Plantations are assumed to be located on existing agricultural lands planted in crops. Conversion facilities are assumed to be located at the site of existing conversion or processing facilities because the usable agricultural lands currently have existing facilities associated with them.
- Site preparation, planting, and harvesting are assumed to be conducted continuously.
- Existing main and access roads are usable for biomass purposes and therefore no additional costs were included. New feeder roads were assumed as required.
- Costs associated with seeding and planting, fertilizer applications, mowing, etc., are based on current practices and experience in Hawaii.
- Land and permitting costs vary according to land ownership and zoning. Land lease fees for agricultural land are based on existing practices.
- A revenue stream resulting from tipping fees for organic waste disposal is assumed for facilities using municipal solid waste. Actual tipping fees or those proposed in recent solid waste management plans are used for Maui, Kauai, and Hawaii (\$17.00, \$19.50, \$17.00 per fresh ton, respectively). On Oahu, a tipping fee of \$25.00 per fresh ton is assumed. Although higher tipping fees are currently in effect on Oahu (approximately \$54.00 per fresh ton), this level of payment is due largely to the costs associated with the operation and payment of debt on the incinerator/RDF system (H-POWER).

⁵ Unisyn Biowaste Technology. *Feasibility Study of Organic Waste Conversion Facilities in Hawaii, Draft Report*, prepared for the Department of Business, Economic Development & Tourism, 1993.

- The cost of energy for biomass fuel projects was converted into cents/kWh to allow for comparison to electricity generating biomass projects.

WAVE

Technology Status: There are a number of different wave energy conversion devices currently under development. For this study, a heaving buoy, hose pump system was assumed based on its economic benefits when compared with other wave energy conversion systems.⁶ Because this technology is currently in the demonstration stage, only future technology projects were evaluated.

The reference design consists of one or more star-shaped clusters of buoys, moored in an 80 m water depth. Each star contains 60 buoys and six collecting lines arranged symmetrically around an underwater habitat, which houses a 10 MW turbine generator.

Performance Assumptions: The resource data used to estimate the performance of potential wave energy projects are based on a review of the available statistical summaries of visual, hindcast, and measured wave data in Hawaii. The performance was based on the best fit of the projected absorption efficiency of buoy/pump modules in random waves to the results of different numerical model simulations. The variation between optimistic, nominal, and conservative estimates accounts for the variation in the model results. The following assumptions were made:

- The conversion of absorbed power to offshore electric power assumed 90% fluid power transfer efficiency from the buoys to the underwater habitat and 90% turbine generator efficiency.
- Line losses vary with assumed line sizes and sea-to-shore distance. Sea-to-shore distances vary from 1.5 km to 8 km, depending on location.

Cost Basis: Costs are based on conceptual designs developed for a 30 MW facility off the northern California coast, adjusted to account for costs in Hawaii. The following cost assumptions were made:

- Equipment costs are based on quotes from component suppliers and lease rates for an onshore fabrication yard and offshore deployment equipment.
- A 30% contingency for weather delays was applied to all offshore equipment mobilization and deployment activities.
- Operation and maintenance costs were based on experience with offshore tanker terminals.⁷

⁶ Hagerman, G. and F.P. Heller. "Wave Energy: A Survey of Twelve Near-Term Technologies," *Proceedings of the International Renewable Energy Conference*, Honolulu, Hawaii, September 1988, pp. 98-110.

Hagerman, G. "Wave Power," *Encyclopedia of Energy Technology and the Environment*, edited by A. Bisio and S.G. Boots, New York: John Wiley & Sons, Inc., 1994 (in press).

⁷ SEASUN Power Systems. *Wave Energy Resource and Economic Assessment for the State of Hawaii*. Energy Division of the State of Hawaii, Department of Business, Economic Development & Tourism, 1992.

OCEAN THERMAL ENERGY CONVERSION (OTEC)

Technology Status: Hawaii has been a leader in the research and development of ocean thermal energy conversion technology. For this study, the basic conceptual design was assumed to be a land-based, closed-cycle, ammonia power system plant. Because this technology is currently in the demonstration stage, only future technology projects were evaluated in this study. Cost and performance data are based on research conducted and published by PICHTR in cooperation with U.S. DOE and work conducted in the mid-80s on the DOE OTEC Pilot Plant Program.

Performance Assumptions: The ocean thermal resource is based on the bathymetry, which is a measurement of the depth of water in the ocean, and by the seasonal surface temperature variations. The following performance assumptions were made:

- The conversion efficiency, availability, and parasitic losses were based on research projections and were varied among the optimistic, nominal, and conservative cases to account for uncertainty in the technology.
- At Kahe Point, performance was assumed to be enhanced by the warm water discharged from HECO's onshore thermal power plant at that site.

Cost Basis: All cost estimates for the conservative cases were based on the detailed work breakdown structure and associated cost estimate prepared by Ocean Thermal Corporation and its subcontractors, adjusted to 1995 dollars.⁸ All costs estimates for the nominal and optimistic cases are derived from more recent work conducted by PICHTR.⁹ Adjustments to these costs were made as appropriate in order to ensure consistency in approach and costing methodology for this study.

GEOTHERMAL

Technology Status: Geothermal energy conversion from high-temperature (> 150°C) water dominated resource areas is a mature technology that has been commercially deployed since the 1960s. While research and development efforts are underway for advanced technology applications such as energy conversion from magma, these advances are not expected to be commercially viable by the year 2005. Such developing technologies are not considered in this study.

Cost and performance estimates in this study reflect conventional flash-plant technology. One such geothermal facility is currently operating on the Big Island in the Kilauea east rift zone. The potential geothermal projects included in this report represent additional 25 and 50 MW generation capacity installed near the existing facility. However, due to recent experience with public opposition to geothermal development in this area, it is expected that new geothermal development would require a lengthy permitting process before drilling and/or construction could be initiated. Therefore, the geothermal projects are presented as future technology (able to be installed by 2005).

Performance Assumptions: The Kilauea east rift zone is known to be a high-temperature hydrothermal resource area. This fact has been confirmed by recent assessment and project development activities. Performance estimate variations for conservative, nominal and optimistic cases accounts for the normal differences that are encountered between different production wells both in resource temperature and flow rate. Other factors that affect a plant's productivity are the efficiency losses associated with corrosivity, scaling, and equipment required to account for gas concentrations. The following basic assumptions were made:


⁸ Carmichael, A.D., E.E. Adams, and M.A. Glucksman. *Ocean Energy Technologies: The State of the Art*, Electric Power Research Institute, Palo Alto, California, EPRI AP-4921, 1986.

⁹ Vega, L.A. "Economics of Ocean Thermal Energy Conversion (OTEC), in *Ocean Energy Recovery: The State of the Art*, edited by R.J. Seymour, American Society of Mechanical Engineers, New York, New York, 1992, pp. 152-181.

- The resource is a high temperature water dominated area. A normal amount of site and well variation is assumed relative to the experience of the existing power plant location.
- The exact plant configuration would depend on the resource condition, but is almost certain to include flashing, condensation, and reinjection.
- Energy losses include transmission losses, parasitic losses such as pumping, downtime, and equipment fouling.

Cost Basis: The following cost assumptions were made:

- Construction costs were based on the typical costs associated with similarly sized geothermal projects adjusted to account for Hawaii specific cost factors. The estimates assume that project construction management is handled appropriately to avoid any unnecessary overruns.
- Drilling costs include the assumption that some of the wells drilled will be non-productive. Even with the exploration performed for the existing facility, non-productive wells can be expected for any future expansions.
- Variations in the power plant costs account for potential variations in resource temperature, gas concentrations, corrosivity, and scaling characteristics.
- Permitting cost assumptions are consistent with the experience for similar geothermal projects and have been tailored specifically to development in Hawaii.



SECTION 3. RESOURCE SUPPLY CURVES

The Resource Supply Curve (RSC) computer model is an evaluation tool for use in comparing different energy generation options on each island and within the state. The model's database currently includes cost and performance information for over 230 potential renewable energy projects. In order to account for the optimistic, nominal, and conservative estimates, the database contains over 700 entries. The information in the database is used by the RSC program to calculate levelized cost of energy estimates in 1995 dollars for potential projects based on a set of criteria and economic assumptions selected by the user. Guidelines for using the model are included in Appendix A.

The model searches the database based on the chosen set of parameters and provides a graphical and tabular summary of the results of the query. The user can choose particular islands (or all islands), specific technologies (or all technologies), technology stage (current, future, or both), transmission cost (include, exclude, or both), certainty level (optimistic, nominal, conservative, or all), and project size ranges. The model is extremely flexible in that projects can be added or edited, and the majority of the economic parameters can be changed to represent different circumstances.

ECONOMIC ASSUMPTIONS

As previously discussed, the RSC model calculates levelized cost of energy in 1995 dollars based on the EPRI TAG methodology. The user has a choice of evaluating projects based on two valuation methods and two basic financing options. The valuation methods include constant dollar analysis (no inflation) or current dollar analysis. Financing options include either utility or non-utility financing. Default values are provided for each choice. For the utility financing options, the default values are those reported by HECO and HELCO in their Integrated Resource Plan submittals to the Hawaii Public Utility Commission. For non-utility financing, the default values are based on experience in obtaining financing for recent renewable energy independent power projects. To maximize the flexibility of the program, the user has the further option of changing the debt/equity ratios, the tax life, the inflation rate, the debt cost, the equity cost, the property tax, and the state and federal income tax to values other than the default values.

The cost of energy analysis also considers both state and federal tax credits and incentives. For each technology, both investment tax credits and production tax credits are included. The program assumes that the full value of the tax credits can be utilized. The user has the option of changing the default values or turning off the tax credits completely. A summary of the default settings for the economic variables is shown in Table 1.

RENEWABLE ENERGY PROJECTS INCLUDED IN THE DATABASE

Tables 2 through 5 list the potential renewable energy projects that are included in the database for each island. Additional information on the screening process to identify project sites and the characteristics of each project site are included in the Phase 1 report, *Renewable Energy Resource Assessment Plan*. Although no project sites are included in the database for either Lanai or Molokai, renewable energy has potential on these islands for use in small-scale applications. On these islands, the size of the utility grid, the extent of the existing renewable energy projects, and the projections for demand growth limit consideration of any additional utility-scale renewable energy projects at this time.

It should be noted that the list of projects included in the database is slightly different than those included in the Phase 1 report. In developing cost and project size estimates, several projects no longer appeared viable compared to other alternatives. In particular, several of the biomass projects were combined into larger projects and only representative combinations of crop types and project sites were evaluated to limit the size of the database. Other combinations may be viable. In addition, a few of the smaller hydroelectric projects were eliminated. A number of specific wave energy projects on each island have also been added to the database.

ILLUSTRATIVE RESOURCE SUPPLY CURVE RESULTS

Illustrative results from the resource supply curve program based on one possible set of economic parameters are shown in Appendix B. In the examples, only the most cost-effective project size is shown for each project site. An example is provided by island for all technologies (showing the most cost-effective projects at each project site on that island) and by technology for all islands (showing the most cost-effective projects at each project site within the state).

The illustrative results show that biomass projects using organic waste as a fuel source and wind energy projects are the least expensive options on each island. The biomass results are strongly dependent on the revenue that can be obtained from the tipping fees collected for waste disposal. Wind energy projects on each island are one of the lowest cost renewable energy alternatives under both current and future technology scenarios. Although only two hydroelectric projects were identified with significant development potential, current hydroelectric technology also offers one of the least-cost renewable energy options. For the technologies under development, cost and performance improvements in the future result in significantly lower cost-of-energy estimates in the future scenarios.

Appendix C includes the technology data worksheets with the supporting documentation for the cost and performance estimates. A separate worksheet showing optimistic, nominal, and conservative estimates is included for each project size and technology stage for all identified potential renewable energy projects. Each technology data sheet contains itemized cost and performance estimates that show the cost and performance assumptions that were applied in this study.

Table 1. Resource Supply Curves Variable Summary

Program Settings and Options: 28-Sep-95

| | | | | |
|----------------------------|----------------|--------------------|----------------------------|------------------|
| Financing Option: | Utility | | Valuation Option: | Constant Dollars |
| Financing Variables | Utility | Non-Utility | Valuation Variables | |
| Debt Ratio | 45% | 70% | Current Dollar: | |
| Equity Ratio | 55% | 30% | Inflation | 4.10% |
| | | | Discount Rate | 10.14% |
| Debt Interest Rate | 7.5% | 9.0% | Constant Dollar: | |
| Equity Return Rate | 12.3% | 18.0% | Inflation | N/A |
| | | | Discount Rate | 5.80% |

| Tax Credits Technology | Investment | | | Production | | |
|---------------------------|------------|-------------|---------|----------------|------------------|----------------|
| | State (%) | Federal (%) | Net (%) | State (\$/kWh) | Federal (\$/kWh) | Total (\$/kWh) |
| Wind | 20.0% | 0.0% | 13.0% | \$0.000 | \$0.010 | \$0.010 |
| Solar Thermal | 35.0% | 10.0% | 35.8% | \$0.000 | \$0.000 | \$0.000 |
| Photovoltaic | 35.0% | 10.0% | 35.8% | \$0.000 | \$0.000 | \$0.000 |
| Biomass Fuel | 0.0% | 0.0% | 0.0% | \$0.000 | \$0.010 | \$0.010 |
| Biomass Electric | 0.0% | 0.0% | 0.0% | \$0.000 | \$0.010 | \$0.010 |
| Wave | 0.0% | 0.0% | 0.0% | \$0.000 | \$0.000 | \$0.000 |
| OTEC | 0.0% | 0.0% | 0.0% | \$0.000 | \$0.000 | \$0.000 |
| Hydro | 0.0% | 0.0% | 0.0% | \$0.000 | \$0.000 | \$0.000 |
| Geothermal | 0.0% | 0.0% | 0.0% | \$0.000 | \$0.000 | \$0.000 |

Other Assumptions

| | |
|--------------------------|--------------------------|
| Tax Life | 5 years |
| Property Tax & Insurance | 2.00% of annual expenses |
| State Income Tax | 4.58% of income |
| Federal Income Tax | 35.00% of income |

Table 2. Hawaii Projects

| Technology | Project Location | Size (MW) | |
|------------------------------|------------------------------------------------|------------------|---------|
| Wind | Kahua Ranch | 5, 15 | |
| | Lalamilo Wells | 3, 30, 50 | |
| | N. Kohala | 5, 15 | |
| Solar Thermal | Dishes | Keahole | 30 |
| | | N. Kohala | 5, 15 |
| | | Waikoloa | 30 |
| | Trough | Keahole | 30 |
| | | Waikoloa | 30 |
| | Photovoltaic | Fixed | Keahole |
| N. Kohala | | | 5, 15 |
| Waikoloa | | | 30, 50 |
| Tracking | | Keahole | 30, 50 |
| | | N. Kohala | 5, 15 |
| | | Waikoloa | 30, 50 |
| Geothermal | | Kilauea | 25, 50 |
| Biomass Electric | Grass Crops | Hamakua Coast | 25 |
| | | Hilo Coast | 25 |
| | | Ka'u | 25 |
| | Tree & Organic Waste Tree Crops | Hilo Coast | 50 |
| | | Hamakua Coast | 25 |
| | Hilo Coast | 25 | |
| Biomass Fuel-Methanol | Grass Crops | Kaunakakai | 25 MGPY |
| | Tree Crops | Hamakua Coast | 25 MGPY |
| | | Hilo Coast | 25 MGPY |
| Hydro | Umauma Stream | 13.8 | |
| Wave | Honokaa | 10 | |
| | N. Kohala | 10, 30 | |
| | Pepeekeo | 10 | |
| Ocean Thermal | Keahole Point | 60 | |

Note: Project size is given in MW of installed capacity except biomass-fuels, which are given in millions of gallons per year.

Table 3. Maui Projects

| Technology | Project Location | Size (MW) | |
|------------------------------|-------------------------|------------------|-------------|
| Wind | McGregor Point | 30 | |
| | N.W. Haleakala | 10, 30, 50 | |
| | Puunene | 10, 30 | |
| | West Maui | 10, 30, 50 | |
| Solar Thermal | Dishes | Kahului | 10, 30 |
| | | Kihei | 10, 30 |
| | | Puunene | 10, 30 |
| | Trough | Kahului | 30 |
| | | Kihei | 30 |
| | | Puunene | 30 |
| Photovoltaic | Fixed | Kahului | 10, 30 |
| | | Kihei | 10, 30 |
| | | Puunene | 10, 30 |
| | Tracking | Kahului | 10, 30 |
| | | Kihei | 10, 30 |
| | | Puunene | 10, 30 |
| Biomass Electric | Organic Waste | Paia-Puunene | 25 |
| | Grass Crops | Paia-Puunene | 25, 50 |
| | Tree Crops | Paia-Puunene | 50 |
| Biomass Fuel-Ethanol | Grass Crops | Paia-Puunene | 25, 50 MGPY |
| | Tree Crops | Paia-Puunene | 25 MGPY |
| Biomass Fuel-Methanol | Organic Waste | Paia-Puunene | 25 MGPY |
| | Grass Crops | Paia-Puunene | 50 MGPY |
| | Tree Crops | Paia-Puunene | 50 MGPY |
| Wave | Lower Paia | 10, 30, 60 | |
| | Opana Point | 10, 30, 60 | |
| | Waiehu Point | 10, 30 | |

Note: Project size is given in MW of installed capacity except biomass-fuels, which are given in millions of gallons per year.

Table 4. Oahu Projects


| Technology | Project Location | Size (MW) | |
|------------------|------------------------------|----------------|------------|
| Wind | Kaena Point | 2, 15 | |
| | Kahuku | 30, 50, 80 | |
| Solar Thermal | Dishes | Lualualei | 50 |
| | | N. Ewa Plain | 50 |
| | | Pearl Harbor | 50 |
| | Trough | Lualualei | 80 |
| | | N. Ewa Plain | 80 |
| | | Pearl Harbor | 80 |
| Photovoltaic | Fixed | Lualualei | 10, 20, 50 |
| | | N. Ewa Plain | 10, 50 |
| | | Pearl Harbor | 10, 50 |
| | Tracking | Lualualei | 10, 20, 50 |
| | | N. Ewa Plain | 10, 50 |
| | | Pearl Harbor | 10, 50 |
| Biomass Electric | Organic Waste Grass Crops | Barber's Point | 50 |
| | | Waialua | 25 |
| Biomass Fuel | Organic Waste-Ethanol | Barber's Point | 25 MGPY |
| | Organic Waste-Methanol | Barber's Point | 50 MGPY |
| Wave | Makapuu | 30, 60 | |
| | Mokapu Point | 30 | |
| | N.E. Coast (upper) | 30 | |
| | N.E. Coast (lower) | 30 | |
| | Waimanalo | 30 | |
| | Kahuku Point | 30, 60 | |
| Ocean Thermal | Kahe Point | 60 | |

Note: Project size is given in MW of installed capacity except biomass-fuels, which are given in millions of gallons per year.

Table 5. Kauai Projects

| Technology | Project Location | Size (MW) |
|--------------------------------------------|-------------------------|------------------|
| Wind | Anahola | 7 |
| | N. Hanapepe | 10 |
| | Port Allen | 5 |
| Solar Thermal Dishes | Barking Sands | 10 |
| Photovoltaic Fixed Tracking | Barking Sands | 10 |
| | Barking Sands | 10 |
| Biomass Electric Grass Crops | Kaunakani | 25 |
| | Lihue | 25 |
| Tree & Organic Waste Tree Crops | Kaunakani | 50 |
| | Kaunakani | 25 |
| | Lihue | 25 |
| Biomass Fuel-Methanol Tree Crops | Kaunakani | 25 MGPY |
| | Lihue | 25 MGPY |
| Hydro | Wailua River | 6.6 |
| Wave | Anahola | 10, 30 |
| | Barking Sands | 10, 30 |

Note: Project size is given in MW of installed capacity except biomass-fuels, which are given in millions of gallons per year.



BIBLIOGRAPHY

- Bain, R.L. *Electricity Costs for Hawaii*, National Renewable Energy Laboratory, 1993.
- Bain, R.L. *Methanol Costs for Hawaii*, National Renewable Energy Laboratory, 1993.
- California Energy Commission. *1992 Energy Technology Status Report*, 1992.
- Carmichael, A.D., E.E. Adams, and M.A. Glucksman. *Ocean Energy Technologies: The State of the Art*, Electric Power Research Institute, Palo Alto, California, EPRI AP-4921, 1986.
- Castellano, C.C., E.A. Midboe, and G.M. Hagerman, Jr. "The U.S. Department of Energy's 40 MWe Ocean Thermal energy Conversion Pilot Plant Program: A Status Report," in *Oceans '83 Proceedings*, Vol. 2, Marine Technology Society, Washington, DC, 1983, pp. 728-733.
- Electric Power Research Institute. *TAG - Technical Assessment Guide, Volume 1: Electricity Supply - 1986*, EPRI P-4463-SR, Volume 1, December 1986.
- Electric Power Research Institute. *TAG - Technical Assessment Guide, Volume 3: Fundamentals and Methods, Supply - 1986*, EPRI P-4463-SR, Volume 3, May 1987.
- Hagerman, G. "Wave Power," *Encyclopedia of Energy Technology and the Environment*, edited by A. Bisio and S.G. Boots, New York: John Wiley & Sons, Inc., 1994 (in press).
- Hagerman, G. and F.P. Heller. "Wave Energy: A Survey of Twelve Near-Term Technologies," *Proceedings of the International Renewable Energy Conference*, Honolulu, Hawaii, September 1988, pp. 98-110.
- Hawaii Natural Energy Institute. *Investigation of Biomass-for-Energy Production on Molokai*, 1993.
- Hawaiian Electric Company. *Integrated Resource Planning, 1994-2013, Summary Report*, July 1993.
- Hawaiian Electric Company. *Integrated Resource Planning, 1994-2013, Integration Report*, July 1993.
- Hawaiian Electric Company. *Integrated Resource Planning, 1994-2013, Supply-Side Report*, July 1993.
- Hawaiian Electric Light Company. *Integrated Resource Planning, 1994-2013, Summary Report*, October 1993.
- Horner, M., et al. *The Central Station Photovoltaics Project. Volume 2, Design Report*, Pacific Gas & Electric Company, San Ramon, California, 1986.
- Johansson, T.B., H. Kelly, A.K.N. Reddy, and R.H. Williams, ed. *Renewable Energy Sources for Fuels and Electricity*, Island Press, Washington, DC, 1993.
- Kearney, D. *Solar Electric Generating System (SEGS) Assessment for Hawaii*, State of Hawaii Department of Business, Economic Development & Tourism, Honolulu, Hawaii, December 1992.

Kearney, D., et al. *Comparison of Solar Thermal Troughs with Photovoltaics as a PG&E Central Station Resource in the 1990s*, Pacific Gas & Electric Company, San Ramon, California, October 1991.

LCG Consulting and Xenergy, Inc. *Citizens Utilities, Kauai Electric Division, Integrated Resource Plan*, October 1993.

Liu, W., R.A. Merriam, V.D. Phillips, and D. Singh. "Estimating Short-Rotation *Eucalyptus saligna* Production in Hawaii: An Integrated Yield and Economic Model," *Biosource Technology*, 45, 1993, pp. 167-176.

Liu, W., V.D. Phillips, and D. Singh. *A Spatial Model for the Economic Evaluation of Biomass Production Systems*, Biomass and Bioenergy, 1992, pp. 345-356.

Maui Electric Company. *Integrated Resource Planning, 1994-2013: Summary Report*, December 1993.

Maui Electric Company. *Integrated Resource Planning, 1994-2013: Integration Report*, December 1993.

Maui Electric Company. *Integrated Resource Planning, 1994-2013: Demand-Side Management Report*, December 1993.

Maui Electric Company. *Integrated Resource Planning, 1994-2013: Supply-Side Report*, December 1993.

Means Building Construction Cost Data, 50th Edition, R.S. Means Company, Inc., 1991.

Owens, W.L. and L.C. Trimble. "Mini-OTEC Operational Results," in *Proceedings of the Seventh Ocean Energy Conference*, (Vol. 2, Paper 14.1), U.S. Department of Energy, Washington, DC, Conf-800633, 1980.

R. Lynette & Associates. *Comprehensive Review and Evaluation of Hawaii's Renewable Energy Resource Assessments*, prepared for the State of Hawaii, Department of Business, Economic Development & Tourism, April 1992.

R. Lynette & Associates. *Renewable Energy Resource Assessment Plan (Draft)*, prepared for the State of Hawaii, Department of Business, Economic Development & Tourism, August 1993.

SEASUN Power Systems. *Ocean Energy Technology Information Module*, Pacific Gas & Electric Company, Department of Research and Development, San Ramon, California, 007.691.4, 1991.

SEASUN Power Systems. *Wave Energy Resource and Economic Assessment for the State of Hawaii*, Energy Division of the State of Hawaii, Department of Business, Economic Development & Tourism, 1992.

Shleser, R. *Ethanol Production in Hawaii*, a report to the Energy Division of the State of Hawaii, Department of Business, Economic Development & Tourism, 1993.

Stolte, W. *Engineering and Economic Evaluation of Central-Station Photovoltaic Power Plants*, Electric Power Research Institute, Palo Alto, California, TR-101255, December 1982.

Synergic Resources Corporation. *Hawaiian Electric Company, Inc., Demand-Side Management Resource Assessment*, SRC Report No. 7782-R17.

The Potential of Renewable Energy, An Interlaboratory White Paper, prepared for Office of Policy, Planning & Analysis, U.S. Department of Energy, March 1990.

Unisyn Biowaste Technology. *Feasibility Study of Organic Waste Conversion Facilities in Hawaii, Draft Report*, prepared for the Department of Business, Economic Development & Tourism, 1993.

Unisyn Biowaste Technology. *Feasibility Study of Organic Wastes Conversion Facilities in Hawaii (Draft)*, prepared for the State of Hawaii, Department of Business, Economic Development & Tourism, 1993.

Vega, L.A. "Economics of Ocean Thermal Energy Conversion (OTEC)," in *Ocean Energy Recovery: The State of the Art*, edited by R.J. Seymour, American Society of Mechanical Engineers, New York, New York, 1992, pp. 152-181.

Wenger, H.J. and J.M. Gordon. *PVGRID: A User-Friendly PC Software Package for Predicting Utility-Intertie Photovoltaic System Performance*, presented at the Solar World Congress, Denver, Colorado, 1991.

Whitesell, C.D., D.S. DeBell, T.H. Schubert, R.F. Strand, and T.B. Crabb. *Short-Rotation Management of Eucalyptus: Guidelines for Plantations in Hawaii*, Forest Service, Report PSW-GTR-137, 1992.


Workshop Team, James Holderness, ed. *Hydropyrolysis of Biomass to Produce Liquid Hydrocarbon Fuels*, Hawaii Natural Energy Institute, 1981.



APPENDIX A

GUIDELINES FOR USING THE RSC COMPUTER MODEL

RSC program assistance will be provided at no cost for a period of one year. For assistance please contact Rana Vilhauer at RLA Consulting. Assistance is available by calling 206/488-0848 Monday through Friday from 8 AM to 4 PM (PST) or by fax by 206/488-0977. For additional assistance call DBED&T, Energy Division at 808/587-3800.



Hawaiian Renewable Energy Resource Supply Curve (RSC) Computer Model

INTRODUCTION

The purpose of the Resource Supply Curve (RSC) model is to provide the Department of Business, Economic Development & Tourism (DBED&T) with an evaluation tool for incorporating renewable energy into Hawaii's energy mix.

The RSC model was developed by R. Lynette & Associates, Inc. (RLA) under the Renewable Energy Assessment portion of the Hawaii Energy Strategy Program. RLA and affiliated subcontractors developed the database of potential renewable energy projects which is the foundation of the RSC model.

The results of the program are a graphical presentation of the cost of energy of each project versus the cumulative energy for all the projects meeting a specified criteria. Figure 1 is a sample of the graphical presentation and tabular summary which shows the potential projects that match a set of criteria selected by the user.

Following is a description of the menu-driven RSC model, the basis of the model, and its intended use. The RSC model and the economic assumptions it incorporates are based on the EPRI TAG methodology for calculating the levelized cost of energy for potential projects.

REQUIREMENTS

The model is intended to be used by DBED&T in its analysis of potential renewable energy projects in the State of Hawaii. The model is to be operated in QPro for Windows Version 5.0. The model was written on a 486 DX with 16 MB of RAM. Although the RSC model will run on a 386 computer, a 486 with at least 8 MB of RAM is recommended. The computer operator will be more comfortable with the model if they have some experience with Windows-based programs. The program is intended to be operated to a large degree with the use of a mouse.

INSTALLATION AND OPERATION

The RSC Model is a Quattro Pro for Windows file that makes use of Quattro Pro's spreadsheet, database, macro, and custom application capabilities. The model is executed by opening the file RSC_Ver4.WB1. The model is operated by selecting menu choices and dialogue box options. The main menu headings are RSC, variables, add, edit/delete, print/view, and quit. The following sections describe the operations available under each menu heading.

RSC

Choose this option to develop curves from the database of potential projects.


The RSC menu choice brings up a three-item secondary menu. The RSC process is begun by choosing to perform a New Query or going back to the Previous Query settings. You also have the option to Quit the program at this secondary menu level.

New Query

New Query provides the user choices of island, technology, technology stage, transmission cost, certainty level, and project size boundaries. These are the parameters by which the program will search the database.

Island(s): Kauai
Technology: All Technologies
Stage: Current Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avolded Cost: N/A



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------|--------|---------------|---------|---------|--------------|-----|------|------|---------|--------|
| Wind | | Kauai | N. Hanapepe | Current | Incl | Optimistic | 10 | 1 | 30 | 21,296 | 0.0475 |
| Wind | | Kauai | Port Allen | Current | Incl | Optimistic | 5 | 1 | 30 | 9,111 | 0.1 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0617 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0622 |
| Hydro | | Kauai | Wailua River | Current | Incl | Optimistic | 6.6 | 2 | 50 | 16,770 | 0.0667 |
| Wind | | Kauai | Anahola | Current | Incl | Optimistic | 7 | 1 | 30 | 7,800 | 0.0963 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Optimistic | 10 | 2 | 30 | 25,483 | 0.1215 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Optimistic | 10 | 1.5 | 30 | 17,250 | 0.1262 |
| Wind | | Kauai | N. Hanapepe | Current | Incl | Nominal | 10 | 1 | 30 | 18,252 | 0.0598 |
| Wind | | Kauai | Port Allen | Current | Incl | Nominal | 5 | 1 | 30 | 7,763 | 0.0696 |
| Hydro | | Kauai | Wailua River | Current | Incl | Nominal | 6.6 | 2 | 50 | 16,435 | 0.0712 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0834 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0886 |
| Wind | | Kauai | Anahola | Current | Incl | Nominal | 7 | 1 | 30 | 6,651 | 0.1210 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 1.5 | 30 | 16,428 | 0.1427 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 2 | 30 | 22,159 | 0.1533 |
| Hydro | | Kauai | Wailua River | Current | Incl | Conservative | 6.6 | 2 | 50 | 16,267 | 0.0753 |
| Wind | | Kauai | N. Hanapepe | Current | Incl | Conservative | 10 | 1 | 30 | 15,430 | 0.0774 |
| Wind | | Kauai | Port Allen | Current | Incl | Conservative | 5 | 1 | 30 | 6,519 | 0.0909 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1094 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1215 |
| Wind | | Kauai | Anahola | Current | Incl | Conservative | 7 | 1 | 30 | 5,589 | 0.1552 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Conservative | 10 | 1.5 | 30 | 14,786 | 0.1691 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Conservative | 10 | 2 | 30 | 19,943 | 0.1777 |

Figure 1

Figure 2 shows the Project Study dialog box which is displayed on the screen when the user chooses "New Query." The user has the following options for defining the data query criteria.

- *Island* - one island, all islands, or combination of islands can be included.
- *Technology* - one, all, or any combination of the technologies may be included.
- *Technology Stage* - current, future, or a comparison of both (two lines are shown on the RSC graph).
- *Transmission Costs* - costs included in COE, excluded, or a comparison of both (two lines are shown on the RSC graph).
- *Certainty Level* - optimistic, nominal, conservative, or a comparison of all levels (three lines are shown on the RSC graph).
- *Installed Capacity* - any range of project size is allowed within the default setting of 0-999 MW.




Figure 2

Graphing multiple comparisons within a single graph produces results that tend to be unclear. Multiple comparisons have been avoided by incorporating exclusions within the Project Study dialog box. For criteria settings for Technology Stage, Transmission Costs, and Certainty Level, if a

multiple comparison has been chosen for one setting, multiple comparisons are excluded for the other two. For example, if the user chooses Both under Technology Stage, the options for Transmission Cost Comparison and All Levels of Certainty are “grayed” by the program and cannot be chosen.

when the user has defined the set of criteria and clicked on OK, the program will search the database to find records that meet the selected criteria.

The user is then prompted with a **Graphing Choice** to provide further search refinement. As shown in Figure 3, this prompt offers three possibilities.

- *Option 1* - Graph all projects found in the query.
- *Option 2* - Graph only the project with the lowest COE for each unique location (a single project is chosen for each location based on lowest COE). This option results in a short waiting period while the program sorts and eliminates extraneous data.
- *Option 3* - Allow for manually choosing the projects to graph from the data found in the query. This option allows the user to review the projects that met the criteria and manually eliminate unwanted projects.




Figure 3

After the graphing choice is made, there is a waiting period and then the **Benchmarks** prompt is given. This prompt provides the option to include a benchmark COE value as a graphical comparison to the projects selected by the user's criteria settings. The benchmark is shown on the RSC graph as a single vertical line. Figure 4 shows the currently available benchmark options.

After the benchmark choice has been made, there is a short wait as the program processes the data. The length of the waiting period depends on the computer speed and the number of database records that met the search criteria. For example, choosing All Islands will require a longer waiting period than choosing only one island. The program is still processing if a “wait” or “macro” indicator appears in the lower right corner of the screen. When the calculations have been performed, the graph

| EOE Benchmark | | \$/kWh |
|----------------------------------|--|--------|
| State Average Avoided Cost | | 0.0549 |
| Oahu Avoided Cost | | 0.0473 |
| Hawaii Avoided Cost | | 0.0556 |
| Maua Avoided Cost | | 0.0604 |
| Kauai Avoided Cost | | 0.0564 |
| Wind/Water Pumping | | 0.15 |
| Other Benchmark | | 0 |
| + No Benchmark for Current Graph | | |

Figure 4

has been setup, and the data table assembled, the user will be prompted to choose between printing or viewing the results. The default setting is View. If the user chooses to view, they can later choose to print the current RSC graph and related data table from the main menu.

Previous Query

Previous Query begins with the criteria settings from the last query performed. This is useful for refining your criteria choices or performing similar queries. In all other ways, Previous Query provides the same choices and produces the same results as New Query.

Quit

Quit provides the opportunity to save (or not save) your changes, return QPro to its default settings, and exit the program.

VARIABLES

Choose this option to view or change the economic assumptions used in developing curves.

The Variables menu choice brings a four-item secondary menu that allows for changing, viewing and printing and current economic parameters, settings used in the program.

Choosing Calculation Method

User chooses the Valuation Method, either Constant or Current Dollar analysis; the Financing Option, either Utility or Non-Utility; and Tax Credits, either Included or Excluded. The discount rate, inflation rate, and debt equity ratio associated with these choices are shown. The dialog box, which is presented as Figure 5, also provides the user with a view of the current Economic Assumptions and Tax Credit settings.

Valuation and Financing Options

| | | | |
|------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|------------------------------------------------------------------|---------------------------------------------------------------------------------------|
| Valuation Method + Constant Dollars Discount Rate 0.058 Current Dollars Inflation 0.041 Discount Rate 0.1014 | Financing Option Debt/Equity + Utility 0.45/0.55 Non-Utility 0.77/0.3 | Tax Credit Option + Include Credits Exclude Credits | <input checked="" type="button" value="OK"/> <input type="button" value="Cancel"/> |
|------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------|------------------------------------------------------------------|---------------------------------------------------------------------------------------|

| | | | | | | |
|------------------------------------------------|---------|---------------------------------------|-----------------------|---------|---------------------|---------|
| Economic Assumptions (current settings) | | Tax Credits (current settings) | | | | |
| Tax Life | 5 years | Technology Classification | Investment (fraction) | | Production (\$/KWh) | |
| | | | State | Federal | State | Federal |
| | | Wind | 0.2 | 0 | 0 | 0.01 |
| | | Solar Thermal | 0.35 | 0.1 | 0 | 0 |
| | | Photovoltaic | 0.35 | 0.1 | 0 | 0 |
| | | Biomass Fuel | 0 | 0 | 0 | 0.01 |
| | | Biomass Electric | 0 | 0 | 0 | 0.01 |
| | | Wave/OTEC | 0 | 0 | 0 | 0 |
| | | Hydro | 0 | 0 | 0 | 0 |
| | | Geothermal | 0 | 0 | 0 | 0 |

| | | |
|----------------------------|---------|-------------|
| | Utility | Non-Utility |
| Debt Cost | 0.075 | 0 |
| Equity Cost | 0.123 | 0 |
| Property Tax and Insurance | 0.02 | |
| State Income Tax | 0.04575 | |
| Federal Income Tax | 0.35 | |

Figure 5

Change Economic Assumptions

The Economic Assumptions may be updated periodically, including the Financing Ratios and Tax Credits values, in the dialog box which is represented as Figure 6. It is advisable to have one person who is responsible for making required changes. Therefore, this option is password protected (Password = DBED). When leaving this dialog box with an OK, a macro is initiated that recalculates the Fixed Charge Rate tables.

Change COE Benchmarks

This option allows for updating the list of benchmarks and their related values. The Benchmarks dialog box with its current settings was shown previously in Figure 4.

Print Variables Summary

This option will send a summary of the variable settings to the printer.

ADD

Choose this option to add records to the database.

This option brings up the data entry form, shown in Figure 7, for entering new projects into the existing database. Information in the database was entered based on the Technology Data Sheets provided in Appendix C as documentation for the program. The Add Record entry form provides

Change Economic Assumptions

Financing Ratios (enter as fraction)

| | Utility | Non-Utility |
|--------|---------|-------------|
| Debt | 0.45 | 0.7 |
| Equity | 0.55 | 0.3 |

Tax Credits

| Technology Classification | Investment (fraction) | | Production (\$/kWh) | |
|---------------------------|-----------------------|---------|---------------------|---------|
| | State | Federal | State | Federal |
| Wind | 0.2 | 0 | 0 | 0.01 |
| Solar Thermal | 0.35 | 0.1 | 0 | 0 |
| Photovoltaic | 0.35 | 0.1 | 0 | 0 |
| Biomass - Fuel | 0 | 0 | 0 | 0.01 |
| Biomass - Electric | 0 | 0 | 0 | 0.01 |
| Wave/OTEC | 0 | 0 | 0 | 0 |
| Hydro | 0 | 0 | 0 | 0 |
| Geothermal | 0 | 0 | 0 | 0 |

Economic Assumptions (enter as fraction)

Tax Life: 5 years

Inflation Rate: 0.041

| | Utility | Non-Utility |
|-------------|---------|-------------|
| Debt Cost | 0.075 | 0.09 |
| Equity Cost | 0.123 | 0.18 |

Property Tax and Insurance: 0.02

State Income Tax: 0.04575

Federal Income Tax: 0.35

Figure 6

Add a Record to RSC Database

Project #: 726 Project Valuation Certainty: Optimistic

Technology: Wind Type: Island: Oahu:

Location: Technology Stage: Current

Capacity (MW): Project Life: 30 Construction Years:

Net Annual Energy (MWh):

Capital Costs:

Transmission Upgrade Cost:

Annual Expenses:

Figure 7

“pick lists” for several entry fields, which ensures that only acceptable field entry choices can be made. For example, there is a pick list for Technology which provides a list of all technology options currently available in the program. The user must choose one from the list.

Users are informed that the program requires project data records in multiples of three; Optimistic, Nominal and Conservative certainty levels. In most cases the user will also be entering project data records for Current and Future technology stages. It is recommended that a Technology Data Sheet be completed prior to adding a new project to the database. The data sheet can then be used to facilitate the addition of the record to the database.

EDIT/DELETE

Choose this option to edit or delete existing records in the database.

Editing and deleting data is accomplished by the use of a QPro Data Form, shown in Figure 8. This form is very flexible. Specific records can be easily found by using the Search option. Unwanted records can be permanently deleted from the database. It is, however, also very easy to accidentally make changes to the database in this form. Therefore, this option is password protected (password = DBED).

PRINT/VIEW

Choosing Print/View allows the user to view or print the most recently generated RSC graph and related data table.

QUIT

Quit provides the opportunity to save (or not save) your changes, return QPro to its default settings, and exit the program.

| Field | Value |
|------------|--------------|
| Study | 1 |
| Technology | Photovoltaic |
| Type | fixed |
| Island | Maui |
| Location | Puunene |
| Stage | Current |
| Upgrade | Incl |
| Certainty | Optimistic |
| MW | 10 |
| Lead | 2 |
| Life | 30 |
| Capital\$ | 51,379,551 |
| Trans \$ | 0 |
| Annual\$ | 90,846 |
| MWh | 23,587 |

1 of 726

New
Delete
Revert
Go Next
Go Previous
Search
Close
Help


Figure 8

APPENDIX B

**ILLUSTRATIVE RESULTS FROM
THE RSC COMPUTER MODEL**

Island(s): All Islands
Technology: Wind
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|------------|------|--------|----------------|---------|---------|-----------|----|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Future | Incl | Nominal | 15 | 1 | 30 | 71,178 | 0.0188 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Nominal | 50 | 1 | 30 | 192,086 | 0.0204 |
| Wind | | Maui | McGregor Point | Future | Incl | Nominal | 10 | 1 | 30 | 24,611 | 0.0365 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Nominal | 5 | 1 | 30 | 12,628 | 0.0380 |
| Wind | | Kauai | N. Hanapepe | Future | Incl | Nominal | 10 | 1 | 30 | 22,602 | 0.0429 |
| Wind | | Maui | NW Haleakala | Future | Incl | Nominal | 10 | 1 | 30 | 21,205 | 0.0445 |
| Wind | | Oahu | Kaena Point | Future | Incl | Nominal | 15 | 1 | 30 | 31,558 | 0.0467 |
| Wind | | Oahu | Kahuku | Future | Incl | Nominal | 30 | 1 | 30 | 56,977 | 0.0497 |
| Wind | | Kauai | Port Allen | Future | Incl | Nominal | 5 | 1 | 30 | 9,321 | 0.0503 |
| Wind | | Maui | Puunene | Future | Incl | Nominal | 10 | 1 | 30 | 15,784 | 0.0577 |
| Wind | | Maui | West Maui | Future | Incl | Nominal | 50 | 1 | 30 | 77,546 | 0.0607 |
| Wind | | Kauai | Anahola | Future | Incl | Nominal | 7 | 1 | 30 | 8,200 | 0.0884 |
| Wind | | Hawaii | North Kohala | Current | Incl | Nominal | 15 | 1 | 30 | 56,905 | 0.0272 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Nominal | 50 | 1 | 30 | 154,183 | 0.0297 |
| Wind | | Maui | McGregor Point | Current | Incl | Nominal | 10 | 1 | 30 | 19,874 | 0.0515 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Nominal | 5 | 1 | 30 | 10,516 | 0.0527 |
| Wind | | Kauai | N. Hanapepe | Current | Incl | Nominal | 10 | 1 | 30 | 18,252 | 0.0598 |
| Wind | | Maui | NW Haleakala | Current | Incl | Nominal | 10 | 1 | 30 | 17,124 | 0.0620 |
| Wind | | Oahu | Kaena Point | Current | Incl | Nominal | 15 | 1 | 30 | 25,230 | 0.0652 |
| Wind | | Oahu | Kahuku | Current | Incl | Nominal | 30 | 1 | 30 | 45,551 | 0.0694 |
| Wind | | Kauai | Port Allen | Current | Incl | Nominal | 5 | 1 | 30 | 7,763 | 0.0696 |
| Wind | | Maui | Puunene | Current | Incl | Nominal | 10 | 1 | 30 | 12,746 | 0.0805 |
| Wind | | Maui | West Maui | Current | Incl | Nominal | 50 | 1 | 30 | 62,245 | 0.0843 |
| Wind | | Kauai | Anahola | Current | Incl | Nominal | 7 | 1 | 30 | 6,651 | 0.1210 |

Island(s): All Islands
Technology: Solar_Thermal
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|--------|--------|---------------|---------|---------|-----------|----|------|------|---------|--------|
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 29,416 | 0.0814 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 1.5 | 30 | 84,949 | 0.0829 |
| Solar Thermal | dish | Oahu | Lualualei | Future | Incl | Nominal | 50 | 1.5 | 30 | 80,912 | 0.0846 |
| Solar Thermal | dish | Hawaii | Keahole | Future | Incl | Nominal | 30 | 1.5 | 30 | 55,125 | 0.0852 |
| Solar Thermal | dish | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 1.5 | 30 | 17,250 | 0.0878 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Nominal | 10 | 1.5 | 30 | 16,430 | 0.0901 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Nominal | 10 | 1.5 | 30 | 16,922 | 0.0929 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 1.5 | 30 | 78,489 | 0.0933 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Nominal | 10 | 1.5 | 30 | 15,938 | 0.0984 |
| Solar Thermal | dish | Hawaii | Waikoloa | Future | Incl | Nominal | 30 | 1.5 | 30 | 53,674 | 0.1103 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Future | Incl | Nominal | 80 | 1.5 | 30 | 160,541 | 0.1307 |
| Solar Thermal | trough | Oahu | Lualualei | Future | Incl | Nominal | 80 | 1.5 | 30 | 152,911 | 0.1343 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Future | Incl | Nominal | 80 | 1.5 | 30 | 148,333 | 0.1443 |
| Solar Thermal | trough | Hawaii | Keahole | Future | Incl | Nominal | 30 | 1.5 | 30 | 64,499 | 0.1609 |
| Solar Thermal | trough | Hawaii | Waikoloa | Future | Incl | Nominal | 30 | 1.5 | 30 | 62,801 | 0.1694 |
| Solar Thermal | trough | Maui | Puunene | Future | Incl | Nominal | 30 | 1.5 | 30 | 57,092 | 0.1778 |
| Solar Thermal | trough | Maui | Kihei | Future | Incl | Nominal | 30 | 1.5 | 30 | 58,801 | 0.1781 |
| Solar Thermal | trough | Maui | Kahului | Future | Incl | Nominal | 30 | 1.5 | 30 | 55,382 | 0.1886 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 1.5 | 30 | 28,015 | 0.1294 |
| Solar Thermal | dish | Hawaii | Keahole | Current | Incl | Nominal | 30 | 1.5 | 30 | 52,500 | 0.1355 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 1.5 | 30 | 80,904 | 0.1360 |
| Solar Thermal | dish | Oahu | Lualualei | Current | Incl | Nominal | 50 | 1.5 | 30 | 77,059 | 0.1403 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 1.5 | 30 | 16,428 | 0.1427 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Nominal | 10 | 1.5 | 30 | 15,648 | 0.1474 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Nominal | 10 | 1.5 | 30 | 16,116 | 0.1489 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 1.5 | 30 | 74,752 | 0.1509 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Nominal | 10 | 1.5 | 30 | 15,179 | 0.1578 |
| Solar Thermal | dish | Hawaii | Waikoloa | Current | Incl | Nominal | 30 | 1.5 | 30 | 51,118 | 0.1629 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Current | Incl | Nominal | 80 | 1.5 | 30 | 139,601 | 0.1939 |
| Solar Thermal | trough | Oahu | Lualualei | Current | Incl | Nominal | 80 | 1.5 | 30 | 132,966 | 0.2001 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Current | Incl | Nominal | 80 | 1.5 | 30 | 128,985 | 0.2130 |
| Solar Thermal | trough | Hawaii | Keahole | Current | Incl | Nominal | 30 | 1.5 | 30 | 56,086 | 0.2402 |
| Solar Thermal | trough | Hawaii | Waikoloa | Current | Incl | Nominal | 30 | 1.5 | 30 | 54,610 | 0.2514 |
| Solar Thermal | trough | Maui | Kihei | Current | Incl | Nominal | 30 | 1.5 | 30 | 51,131 | 0.2646 |
| Solar Thermal | trough | Maui | Puunene | Current | Incl | Nominal | 30 | 1.5 | 30 | 49,645 | 0.2659 |
| Solar Thermal | trough | Maui | Kahului | Current | Incl | Nominal | 30 | 1.5 | 30 | 48,159 | 0.2803 |

Island(s): All Islands
Technology: Photovoltaic
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|--------------|----------|--------|---------------|---------|---------|-----------|----|------|------|---------|--------|
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Nominal | 30 | 2 | 30 | 82,893 | 0.0807 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Nominal | 30 | 2 | 30 | 77,792 | 0.0850 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Nominal | 30 | 2 | 30 | 78,159 | 0.0857 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Nominal | 50 | 3 | 30 | 124,319 | 0.0862 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0873 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Nominal | 50 | 3 | 30 | 124,319 | 0.0873 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0878 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0883 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Nominal | 50 | 3 | 30 | 110,999 | 0.0903 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Nominal | 50 | 3 | 30 | 110,999 | 0.0915 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0921 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0926 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0932 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Nominal | 30 | 2 | 30 | 63,764 | 0.0980 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Nominal | 30 | 2 | 30 | 63,764 | 0.0992 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Nominal | 30 | 2 | 30 | 63,544 | 0.0997 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 35,542 | 0.1035 |
| Photovoltaic | tracking | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 1 | 30 | 22,962 | 0.1037 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 31,734 | 0.1096 |
| Photovoltaic | fixed | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 1 | 30 | 20,502 | 0.1099 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Nominal | 30 | 3 | 30 | 79,992 | 0.1186 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Nominal | 10 | 2 | 30 | 28,158 | 0.1238 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Nominal | 50 | 4 | 30 | 119,968 | 0.1264 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Nominal | 30 | 3 | 30 | 75,069 | 0.1271 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Nominal | 50 | 4 | 30 | 119,968 | 0.1278 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1288 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1297 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1303 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Nominal | 50 | 4 | 30 | 107,114 | 0.1328 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Nominal | 50 | 4 | 30 | 107,114 | 0.1344 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1364 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1373 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1381 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Nominal | 30 | 3 | 30 | 61,532 | 0.1446 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Nominal | 30 | 3 | 30 | 61,532 | 0.1462 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Nominal | 30 | 3 | 30 | 61,320 | 0.1468 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 2.5 | 30 | 34,298 | 0.1519 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 2 | 30 | 22,159 | 0.1533 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 2.5 | 30 | 30,623 | 0.1614 |
| Photovoltaic | fixed | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 2 | 30 | 19,785 | 0.1629 |

Island(s): All Islands
Technology: Biomass_Fuel
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|--------------|----------------------|--------|----------------|---------|---------|-----------|-----|------|------|---------|--------|
| Biomass Fuel | org waste-methanol | Oahu | Barber's Point | Future | Incl | Nominal | 95 | 2 | 30 | 581,342 | 0.0195 |
| Biomass Fuel | org waste-methanol | Mau | Puunene | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0461 |
| Biomass Fuel | tree crops-methanol | Mau | Paia-Puunene | Future | Incl | Nominal | 95 | 2 | 30 | 581,342 | 0.0483 |
| Biomass Fuel | grass crops-methanol | Mau | Paia-Puunene | Future | Incl | Nominal | 95 | 2 | 30 | 581,342 | 0.0575 |
| Biomass Fuel | grass crops-ethanol | Mau | Paia-Puunene | Future | Incl | Nominal | 141 | 2 | 30 | 864,392 | 0.0688 |
| Biomass Fuel | tree crops-methanol | Hawaii | Hamakua Coast | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0705 |
| Biomass Fuel | tree crops-methanol | Kauai | Lihue | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0722 |
| Biomass Fuel | tree crops-methanol | Hawaii | Hilo Coast | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0731 |
| Biomass Fuel | tree crops-methanol | Kauai | Kaumakani | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0752 |
| Biomass Fuel | tree crops-ethanol | Mau | Paia-Puunene | Future | Incl | Nominal | 70 | 2 | 30 | 432,196 | 0.0835 |
| Biomass Fuel | grass crops-methanol | Hawaii | Kaumakai | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0850 |
| Biomass Fuel | grass crops-ethanol | Mau | Paia-Puunene | Current | Incl | Nominal | 70 | 2 | 30 | 432,196 | 0.1350 |

Island(s): All Islands
Technology: Biomass_Elec
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A


RESOURCE SUPPLY CURVES



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|--------------|------------------|--------|----------------|---------|---------|-----------|----|------|------|---------|--------|
| Biomass Elec | org waste | Oahu | Barber's Point | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0289 |
| Biomass Elec | org waste | Maui | Puunene | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0415 |
| Biomass Elec | tree & org waste | Hawaii | Hilo Coast | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0672 |
| Biomass Elec | tree & org waste | Kauai | Kaunakani | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0694 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0695 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0770 |
| Biomass Elec | tree crops | Kauai | Lihue | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0794 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0811 |
| Biomass Elec | grass crops | Kauai | Kaunakani | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0829 |
| Biomass Elec | tree crops | Kauai | Kaunakani | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0837 |
| Biomass Elec | grass crops | Hawaii | Ka'u | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0903 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0964 |
| Biomass Elec | grass crops | Oahu | Waialua | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1041 |
| Biomass Elec | grass crops | Hawaii | Hilo Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1083 |
| Biomass Elec | grass crops | Kauai | Lihue | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1236 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.1342 |
| Biomass Elec | org waste | Maui | Puunene | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0357 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Current | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0772 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0805 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0834 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0847 |
| Biomass Elec | tree crops | Kauai | Kaunakani | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0886 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Current | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0931 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1053 |
| Biomass Elec | grass crops | Oahu | Waialua | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1139 |

Island(s): All Islands
Technology: Wave
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|------------|------|--------|---------------|--------|---------|-----------|----|------|------|---------|--------|
| Wave | | Oahu | Makapuu | Future | Incl | Nominal | 60 | 2 | 30 | 224,378 | 0.0863 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Nominal | 60 | 2 | 30 | 211,197 | 0.0918 |
| Wave | | Maui | Opana Point | Future | Incl | Nominal | 60 | 2 | 30 | 211,984 | 0.0920 |
| Wave | | Maui | Lower Pala | Future | Incl | Nominal | 60 | 2 | 30 | 203,974 | 0.0956 |
| Wave | | Oahu | NE Coast 2A | Future | Incl | Nominal | 30 | 2 | 30 | 103,704 | 0.0966 |
| Wave | | Oahu | NE Coast 2C | Future | Incl | Nominal | 30 | 2 | 30 | 101,831 | 0.0982 |
| Wave | | Maui | Waiehu Point | Future | Incl | Nominal | 30 | 2 | 30 | 101,256 | 0.1023 |
| Wave | | Kauai | Anahola | Future | Incl | Nominal | 30 | 2 | 30 | 98,947 | 0.1030 |
| Wave | | Oahu | Mokapu Point | Future | Incl | Nominal | 30 | 2 | 30 | 97,966 | 0.1034 |
| Wave | | Hawaii | N. Kohala | Future | Incl | Nominal | 30 | 2 | 30 | 93,084 | 0.1112 |
| Wave | | Hawaii | Honokaa 2A | Future | Incl | Nominal | 10 | 2 | 30 | 33,612 | 0.1125 |
| Wave | | Oahu | Waimanalo Bay | Future | Incl | Nominal | 30 | 2 | 30 | 88,957 | 0.1128 |
| Wave | | Hawaii | Pepeekeo 2E | Future | Incl | Nominal | 10 | 2 | 30 | 32,389 | 0.1171 |
| Wave | | Kauai | Barking Sands | Future | Incl | Nominal | 30 | 2 | 30 | 51,793 | 0.2072 |

Island(s): All Islands
Technology: OTEC
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|------------|------|--------|---------------|--------|---------|-----------|----|------|------|---------|--------|
| OTEC | | Hawaii | Keahole Point | Future | Incl | Nominal | 60 | 2 | 30 | 296,438 | 0.1963 |
| OTEC | | Oahu | Kahe Point | Future | Incl | Nominal | 60 | 2 | 30 | 311,260 | 0.2041 |

Island(s): All Islands
Technology: Hydro
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|------------|------|--------|---------------|---------|---------|-----------|------|------|------|--------|--------|
| Hydro | | Hawaii | Umauma Stream | Future | Incl | Nominal | 13.8 | 2 | 50 | 40,199 | 0.0544 |
| Hydro | | Kauai | Wailua River | Future | Incl | Nominal | 6.6 | 2 | 50 | 16,435 | 0.0678 |
| Hydro | | Hawaii | Umauma Stream | Current | Incl | Nominal | 13.8 | 2 | 50 | 40,199 | 0.0558 |
| Hydro | | Kauai | Wailua River | Current | Incl | Nominal | 6.6 | 2 | 50 | 16,435 | 0.0712 |

Island(s): All Islands
Technology: Geothermal
Stage: Current and Future Technology
Certainty: Nominal
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|------------|------|--------|----------|--------|---------|-----------|----|------|------|---------|--------|
| Geothermal | | Hawaii | Kilauea | Future | Incl - | Nominal | 50 | 6 | 30 | 362,314 | 0.0425 |

Island(s): Hawaii
Technology: All Technologies
Stage: Current Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------|--------|----------------|---------|---------|--------------|------|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Current | Incl | Optimistic | 15 | 1 | 30 | 66,395 | 0.0215 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Optimistic | 50 | 1 | 30 | 181,386 | 0.0233 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Optimistic | 5 | 1 | 30 | 12,334 | 0.0414 |
| Hydro | | Hawaii | Umauma Stream | Current | Incl | Optimistic | 13.8 | 2 | 50 | 41,019 | 0.0522 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0558 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0632 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Optimistic | 50 | 4 | 30 | 137,963 | 0.1008 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Optimistic | 50 | 4 | 30 | 137,963 | 0.1019 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Optimistic | 50 | 4 | 30 | 123,181 | 0.1056 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Optimistic | 50 | 4 | 30 | 123,181 | 0.1069 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Optimistic | 15 | 1.5 | 30 | 29,416 | 0.1147 |
| Solar Thermal | dish | Hawaii | Keahole | Current | Incl | Optimistic | 30 | 1.5 | 30 | 55,125 | 0.1197 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Optimistic | 15 | 2.5 | 30 | 39,442 | 0.1207 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Optimistic | 15 | 2.5 | 30 | 35,216 | 0.1281 |
| Solar Thermal | dish | Hawaii | Waikoloa | Current | Incl | Optimistic | 30 | 1.5 | 30 | 53,674 | 0.1433 |
| Solar Thermal | trough | Hawaii | Keahole | Current | Incl | Optimistic | 30 | 1.5 | 30 | 58,890 | 0.2102 |
| Solar Thermal | trough | Hawaii | Waikoloa | Current | Incl | Optimistic | 30 | 1.5 | 30 | 57,340 | 0.2199 |
| Wind | | Hawaii | North Kohala | Current | Incl | Nominal | 15 | 1 | 30 | 56,905 | 0.0272 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Nominal | 50 | 1 | 30 | 154,183 | 0.0297 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Nominal | 5 | 1 | 30 | 10,516 | 0.0527 |
| Hydro | | Hawaii | Umauma Stream | Current | Incl | Nominal | 13.8 | 2 | 50 | 40,199 | 0.0558 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0805 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0847 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Nominal | 50 | 4 | 30 | 119,968 | 0.1264 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Nominal | 50 | 4 | 30 | 119,968 | 0.1278 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 1.5 | 30 | 28,015 | 0.1294 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Nominal | 50 | 4 | 30 | 107,114 | 0.1328 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Nominal | 50 | 4 | 30 | 107,114 | 0.1344 |
| Solar Thermal | dish | Hawaii | Keahole | Current | Incl | Nominal | 30 | 1.5 | 30 | 52,500 | 0.1355 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 2.5 | 30 | 34,298 | 0.1519 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 2.5 | 30 | 30,623 | 0.1614 |
| Solar Thermal | dish | Hawaii | Waikoloa | Current | Incl | Nominal | 30 | 1.5 | 30 | 51,118 | 0.1629 |
| Solar Thermal | trough | Hawaii | Keahole | Current | Incl | Nominal | 30 | 1.5 | 30 | 56,086 | 0.2402 |
| Solar Thermal | trough | Hawaii | Waikoloa | Current | Incl | Nominal | 30 | 1.5 | 30 | 54,610 | 0.2514 |
| Wind | | Hawaii | North Kohala | Current | Incl | Conservative | 15 | 1 | 30 | 48,105 | 0.0360 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Conservative | 50 | 1 | 30 | 129,123 | 0.0396 |
| Hydro | | Hawaii | Umauma Stream | Current | Incl | Conservative | 13.8 | 2 | 50 | 39,788 | 0.0591 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Conservative | 5 | 1 | 30 | 8,838 | 0.0691 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1107 |

| | | | | | | | | | | | |
|---------------|------------|--------|------------|---------|------|--------------|----|-----|----|---------|--------|
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1111 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Conservative | 50 | 4 | 30 | 107,971 | 0.1466 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Conservative | 50 | 4 | 30 | 107,971 | 0.1483 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Conservative | 15 | 1.5 | 30 | 25,213 | 0.1532 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Conservative | 50 | 4 | 30 | 96,402 | 0.1539 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Conservative | 50 | 4 | 30 | 96,402 | 0.1558 |
| Solar Thermal | dish | Hawaii | Keahole | Current | Incl | Conservative | 30 | 1.5 | 30 | 47,250 | 0.1612 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Conservative | 15 | 2.5 | 30 | 30,868 | 0.1760 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Conservative | 15 | 2.5 | 30 | 27,561 | 0.1869 |
| Solar Thermal | dish | Hawaii | Waikoloa | Current | Incl | Conservative | 30 | 1.5 | 30 | 46,006 | 0.1946 |
| Solar Thermal | trough | Hawaii | Keahole | Current | Incl | Conservative | 30 | 1.5 | 30 | 50,477 | 0.2878 |
| Solar Thermal | trough | Hawaii | Waikoloa | Current | Incl | Conservative | 30 | 1.5 | 30 | 49,149 | 0.3014 |

Island(s): Hawaii
Technology: All Technologies
Stage: Future Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|----------------------|--------|----------------|--------|---------|------------|------|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Future | Incl | Optimistic | 15 | 1 | 30 | 83,049 | 0.0247 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Optimistic | 50 | 1 | 30 | 225,977 | 0.0258 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Optimistic | 50 | 6 | 30 | 390,871 | 0.0328 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Optimistic | 5 | 1 | 30 | 14,811 | 0.0397 |
| Hydro | | Hawaii | Umauma Stream | Future | Incl | Optimistic | 13.8 | 2 | 50 | 41,019 | 0.0509 |
| Biomass Elec | tree & org waste | Hawaii | Hilo Coast | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0546 |
| Biomass Fuel | tree crops-methanol | Hawaii | Hamakua Coast | Future | Incl | Optimistic | 47 | 2 | 30 | 319,738 | 0.0586 |
| Wave | | Hawaii | Honokaa 2A | Future | Incl | Optimistic | 10 | 2 | 30 | 42,134 | 0.0591 |
| Wave | | Hawaii | N. Kohala | Future | Incl | Optimistic | 30 | 2 | 30 | 117,856 | 0.0592 |
| Biomass Fuel | tree crops-methanol | Hawaii | Hilo Coast | Future | Incl | Optimistic | 47 | 2 | 30 | 319,738 | 0.0605 |
| Wave | | Hawaii | Pepeekeo 2E | Future | Incl | Optimistic | 10 | 2 | 30 | 40,968 | 0.0610 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0633 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0663 |
| Biomass Fuel | grass crops-methanol | Hawaii | Kaunakakai | Future | Incl | Optimistic | 47 | 2 | 30 | 319,738 | 0.0691 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Optimistic | 50 | 3 | 30 | 142,967 | 0.0692 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Optimistic | 50 | 3 | 30 | 142,967 | 0.0701 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Optimistic | 15 | 1.5 | 30 | 30,886 | 0.0709 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Optimistic | 50 | 3 | 30 | 127,649 | 0.0723 |
| Biomass Elec | grass crops | Hawaii | Ka'u | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0729 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Optimistic | 50 | 3 | 30 | 127,649 | 0.0733 |
| Solar Thermal | dish | Hawaii | Keahole | Future | Incl | Optimistic | 30 | 1.5 | 30 | 57,882 | 0.0738 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0774 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Optimistic | 15 | 1.5 | 30 | 40,873 | 0.0828 |
| Biomass Elec | grass crops | Hawaii | Hilo Coast | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0861 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Optimistic | 15 | 1.5 | 30 | 36,494 | 0.0876 |
| Solar Thermal | dish | Hawaii | Waikoloa | Future | Incl | Optimistic | 30 | 1.5 | 30 | 56,358 | 0.0953 |
| OTEC | | Hawaii | Keahole Point | Future | Incl | Optimistic | 60 | 2 | 30 | 319,565 | 0.1249 |
| Solar Thermal | trough | Hawaii | Keahole | Future | Incl | Optimistic | 30 | 1.5 | 30 | 67,724 | 0.1411 |
| Solar Thermal | trough | Hawaii | Waikoloa | Future | Incl | Optimistic | 30 | 1.5 | 30 | 65,941 | 0.1483 |
| Wind | | Hawaii | North Kohala | Future | Incl | Nominal | 15 | 1 | 30 | 71,178 | 0.0288 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Nominal | 50 | 1 | 30 | 192,086 | 0.0304 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Nominal | 50 | 6 | 30 | 362,314 | 0.0425 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Nominal | 5 | 1 | 30 | 12,628 | 0.0480 |
| Hydro | | Hawaii | Umauma Stream | Future | Incl | Nominal | 13.8 | 2 | 50 | 40,199 | 0.0544 |
| Biomass Elec | tree & org waste | Hawaii | Hilo Coast | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0772 |
| Biomass Fuel | tree crops-methanol | Hawaii | Hamakua Coast | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0805 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 29,416 | 0.0814 |
| Biomass Fuel | tree crops-methanol | Hawaii | Hilo Coast | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0831 |
| Solar Thermal | dish | Hawaii | Keahole | Future | Incl | Nominal | 30 | 1.5 | 30 | 55,125 | 0.0852 |

| | | | | | | | | | | | |
|---------------|----------------------|--------|----------------|--------|------|--------------|------|-----|----|---------|--------|
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Nominal | 50 | 3 | 30 | 124,319 | 0.0862 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0870 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Nominal | 50 | 3 | 30 | 124,319 | 0.0873 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Nominal | 50 | 3 | 30 | 110,999 | 0.0903 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0911 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Nominal | 50 | 3 | 30 | 110,999 | 0.0915 |
| Biomass Fuel | grass crops-methanol | Hawaii | Kaunakakai | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0950 |
| Biomass Elec | grass crops | Hawaii | Ka'u | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1003 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 35,542 | 0.1035 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1064 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 31,734 | 0.1096 |
| Solar Thermal | dish | Hawaii | Waikoloa | Future | Incl | Nominal | 30 | 1.5 | 30 | 53,674 | 0.1103 |
| Wave | | Hawaii | N. Kohala | Future | Incl | Nominal | 30 | 2 | 30 | 93,084 | 0.1112 |
| Wave | | Hawaii | Honokaa 2A | Future | Incl | Nominal | 10 | 2 | 30 | 33,612 | 0.1125 |
| Wave | | Hawaii | Pepeekeo 2E | Future | Incl | Nominal | 10 | 2 | 30 | 32,389 | 0.1171 |
| Biomass Elec | grass crops | Hawaii | Hilo Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1183 |
| Solar Thermal | trough | Hawaii | Keahole | Future | Incl | Nominal | 30 | 1.5 | 30 | 64,499 | 0.1609 |
| Solar Thermal | trough | Hawaii | Waikoloa | Future | Incl | Nominal | 30 | 1.5 | 30 | 62,801 | 0.1694 |
| OTEC | | Hawaii | Keahole Point | Future | Incl | Nominal | 60 | 2 | 30 | 296,438 | 0.1963 |
| Wind | | Hawaii | North Kohala | Future | Incl | Conservative | 15 | 1 | 30 | 60,171 | 0.0360 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Conservative | 50 | 1 | 30 | 160,865 | 0.0385 |
| Hydro | | Hawaii | Umauma Stream | Future | Incl | Conservative | 13.8 | 2 | 50 | 39,788 | 0.0576 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Conservative | 5 | 1 | 30 | 10,612 | 0.0617 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Conservative | 50 | 6 | 30 | 308,352 | 0.0641 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Conservative | 15 | 1.5 | 30 | 26,474 | 0.0978 |
| Solar Thermal | dish | Hawaii | Keahole | Future | Incl | Conservative | 30 | 1.5 | 30 | 49,613 | 0.1031 |
| Biomass Elec | tree & org waste | Hawaii | Hilo Coast | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1049 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Conservative | 50 | 3 | 30 | 105,671 | 0.1060 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Conservative | 50 | 3 | 30 | 105,671 | 0.1073 |
| Biomass Fuel | tree crops-methanol | Hawaii | Hamakua Coast | Future | Incl | Conservative | 47 | 2 | 30 | 261,604 | 0.1073 |
| Biomass Fuel | tree crops-methanol | Hawaii | Hilo Coast | Future | Incl | Conservative | 47 | 2 | 30 | 261,604 | 0.1108 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Conservative | 50 | 3 | 30 | 94,349 | 0.1109 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Conservative | 50 | 3 | 30 | 94,349 | 0.1124 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1160 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1215 |
| Biomass Fuel | grass crops-methanol | Hawaii | Kaunakakai | Future | Incl | Conservative | 47 | 2 | 30 | 261,604 | 0.1267 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Conservative | 15 | 1.5 | 30 | 30,211 | 0.1270 |
| Solar Thermal | dish | Hawaii | Waikoloa | Future | Incl | Conservative | 30 | 1.5 | 30 | 48,307 | 0.1337 |
| Biomass Elec | grass crops | Hawaii | Ka'u | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1337 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Conservative | 15 | 1.5 | 30 | 26,974 | 0.1344 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1419 |
| Biomass Elec | grass crops | Hawaii | Hilo Coast | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1578 |
| Solar Thermal | trough | Hawaii | Keahole | Future | Incl | Conservative | 30 | 1.5 | 30 | 58,049 | 0.1922 |
| Solar Thermal | trough | Hawaii | Waikoloa | Future | Incl | Conservative | 30 | 1.5 | 30 | 56,521 | 0.2025 |
| OTEC | | Hawaii | Keahole Point | Future | Incl | Conservative | 60 | 2 | 30 | 257,894 | 0.2887 |
| Wave | | Hawaii | N. Kohala | Future | Incl | Conservative | 30 | 2 | 30 | 42,077 | 0.3596 |
| Wave | | Hawaii | Honokaa 2A | Future | Incl | Conservative | 10 | 2 | 30 | 15,435 | 0.3619 |
| Wave | | Hawaii | Pepeekeo 2E | Future | Incl | Conservative | 10 | 2 | 30 | 14,691 | 0.3811 |

Island(s): Maui
Technology: All Technologies
Stage: Current Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|---------------------|--------|----------------|---------|---------|------------|----|------|------|---------|--------|
| Biomass Elec | org waste | Maui | Puunene | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0160 |
| Wind | | Maui | McGregor Point | Current | Incl | Optimistic | 10 | 1 | 30 | 23,189 | 0.0408 |
| Wind | | Maui | NW Haleakala | Current | Incl | Optimistic | 10 | 1 | 30 | 19,980 | 0.0492 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Current | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0534 |
| Wind | | Maui | Puunene | Current | Incl | Optimistic | 10 | 1 | 30 | 14,940 | 0.0636 |
| Wind | | Maui | West Maui | Current | Incl | Optimistic | 50 | 1 | 30 | 72,957 | 0.0670 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Current | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0697 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Optimistic | 30 | 3 | 30 | 91,990 | 0.0944 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Optimistic | 30 | 3 | 30 | 86,737 | 0.1002 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Optimistic | 30 | 3 | 30 | 86,330 | 0.1012 |
| Biomass Fuel | grass crops-ethanol | Maui | Paia-Puunene | Current | Incl | Optimistic | 70 | 2 | 30 | 475,416 | 0.1020 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Optimistic | 30 | 3 | 30 | 70,762 | 0.1149 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Optimistic | 30 | 3 | 30 | 70,762 | 0.1162 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Optimistic | 30 | 3 | 30 | 70,518 | 0.1167 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Optimistic | 10 | 1.5 | 30 | 16,430 | 0.1305 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Optimistic | 10 | 1.5 | 30 | 16,922 | 0.1316 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Optimistic | 10 | 1.5 | 30 | 15,938 | 0.1395 |
| Solar Thermal | trough | Maui | Kihei | Current | Incl | Optimistic | 30 | 1.5 | 30 | 53,688 | 0.2318 |
| Solar Thermal | trough | Maui | Puunene | Current | Incl | Optimistic | 30 | 1.5 | 30 | 52,127 | 0.2330 |
| Solar Thermal | trough | Maui | Kahului | Current | Incl | Optimistic | 30 | 1.5 | 30 | 50,567 | 0.2454 |
| Biomass Elec | org waste | Maui | Puunene | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0357 |
| Wind | | Maui | McGregor Point | Current | Incl | Nominal | 10 | 1 | 30 | 19,874 | 0.0515 |
| Wind | | Maui | NW Haleakala | Current | Incl | Nominal | 10 | 1 | 30 | 17,124 | 0.0620 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Current | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0772 |
| Wind | | Maui | Puunene | Current | Incl | Nominal | 10 | 1 | 30 | 12,746 | 0.0805 |
| Wind | | Maui | West Maui | Current | Incl | Nominal | 50 | 1 | 30 | 62,245 | 0.0843 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Current | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0931 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Nominal | 30 | 3 | 30 | 79,992 | 0.1186 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Nominal | 10 | 2 | 30 | 28,158 | 0.1238 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Nominal | 30 | 3 | 30 | 75,069 | 0.1271 |
| Biomass Fuel | grass crops-ethanol | Maui | Paia-Puunene | Current | Incl | Nominal | 70 | 2 | 30 | 432,196 | 0.1350 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Nominal | 30 | 3 | 30 | 61,532 | 0.1446 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Nominal | 30 | 3 | 30 | 61,532 | 0.1462 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Nominal | 30 | 3 | 30 | 61,320 | 0.1468 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Nominal | 10 | 1.5 | 30 | 15,648 | 0.1474 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Nominal | 10 | 1.5 | 30 | 16,116 | 0.1489 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Nominal | 10 | 1.5 | 30 | 15,179 | 0.1578 |
| Solar Thermal | trough | Maui | Kihei | Current | Incl | Nominal | 30 | 1.5 | 30 | 51,131 | 0.2646 |
| Solar Thermal | trough | Maui | Puunene | Current | Incl | Nominal | 30 | 1.5 | 30 | 49,645 | 0.2659 |

| | | | | | | | | | | | |
|---------------|---------------------|------|----------------|---------|------|--------------|----|-----|----|---------|--------|
| Solar Thermal | trough | Maui | Kahului | Current | Incl | Nominal | 30 | 1.5 | 30 | 48,159 | 0.2803 |
| Biomass Elec | org waste | Maui | Puunene | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.0597 |
| Wind | | Maui | McGregor Point | Current | Incl | Conservative | 10 | 1 | 30 | 16,801 | 0.0669 |
| Wind | | Maui | NW Haleakala | Current | Incl | Conservative | 10 | 1 | 30 | 14,476 | 0.0803 |
| Wind | | Maui | Puunene | Current | Incl | Conservative | 10 | 1 | 30 | 10,720 | 0.1043 |
| Biomass Elec | tree crops | Maui | Pala-Puunene | Current | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1063 |
| Wind | | Maui | West Maui | Current | Incl | Conservative | 50 | 1 | 30 | 52,349 | 0.1085 |
| Biomass Elec | grass crops | Maui | Pala-Puunene | Current | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1218 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Conservative | 30 | 3 | 30 | 71,992 | 0.1372 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Conservative | 10 | 2 | 30 | 25,343 | 0.1424 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Conservative | 30 | 3 | 30 | 67,562 | 0.1471 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Conservative | 30 | 3 | 30 | 55,379 | 0.1672 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Conservative | 30 | 3 | 30 | 55,379 | 0.1692 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Conservative | 30 | 3 | 30 | 55,188 | 0.1698 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Conservative | 10 | 1.5 | 30 | 14,083 | 0.1748 |
| Biomass Fuel | grass crops-ethanol | Maui | Pala-Puunene | Current | Incl | Conservative | 70 | 2 | 30 | 388,977 | 0.1753 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Conservative | 10 | 1.5 | 30 | 14,505 | 0.1767 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Conservative | 10 | 1.5 | 30 | 13,661 | 0.1874 |
| Solar Thermal | trough | Maui | Kihei | Current | Incl | Conservative | 30 | 1.5 | 30 | 46,018 | 0.3169 |
| Solar Thermal | trough | Maui | Puunene | Current | Incl | Conservative | 30 | 1.5 | 30 | 44,681 | 0.3184 |
| Solar Thermal | trough | Maui | Kahului | Current | Incl | Conservative | 30 | 1.5 | 30 | 43,343 | 0.3358 |

Island(s): Maui
Technology: All Technologies
Stage: Future Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|----------------------|--------|----------------|--------|---------|------------|----|------|------|---------|--------|
| Biomass Elec | org waste | Maui | Puunene | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0299 |
| Biomass Fuel | org waste-methanol | Maui | Puunene | Future | Incl | Optimistic | 47 | 2 | 30 | 319,738 | 0.0352 |
| Wind | | Maui | McGregor Point | Future | Incl | Optimistic | 10 | 1 | 30 | 28,715 | 0.0388 |
| Biomass Fuel | tree crops-methanol | Maui | Paia-Puunene | Future | Incl | Optimistic | 95 | 2 | 30 | 639,477 | 0.0424 |
| Wind | | Maui | NW Haleakala | Future | Incl | Optimistic | 10 | 1 | 30 | 24,741 | 0.0452 |
| Wave | | Maui | Opana Point | Future | Incl | Optimistic | 60 | 2 | 30 | 265,780 | 0.0485 |
| Biomass Fuel | grass crops-methanol | Maui | Paia-Puunene | Future | Incl | Optimistic | 95 | 2 | 30 | 639,477 | 0.0491 |
| Wave | | Maui | Lower Paia | Future | Incl | Optimistic | 60 | 2 | 30 | 255,885 | 0.0504 |
| Wave | | Maui | Walehu Point | Future | Incl | Optimistic | 30 | 2 | 30 | 126,887 | 0.0542 |
| Wind | | Maui | Puunene | Future | Incl | Optimistic | 10 | 1 | 30 | 18,501 | 0.0555 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0578 |
| Wind | | Maui | West Maui | Future | Incl | Optimistic | 50 | 1 | 30 | 90,891 | 0.0581 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Optimistic | 30 | 2 | 30 | 95,327 | 0.0647 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Optimistic | 30 | 2 | 30 | 89,461 | 0.0682 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Optimistic | 30 | 2 | 30 | 89,883 | 0.0687 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Optimistic | 10 | 1.5 | 30 | 17,252 | 0.0781 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Optimistic | 30 | 2 | 30 | 73,329 | 0.0784 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Optimistic | 30 | 2 | 30 | 73,329 | 0.0795 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Optimistic | 30 | 2 | 30 | 73,076 | 0.0798 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Optimistic | 10 | 1.5 | 30 | 17,768 | 0.0805 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Optimistic | 10 | 1.5 | 30 | 16,735 | 0.0853 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.1049 |
| Solar Thermal | trough | Maui | Puunene | Future | Incl | Optimistic | 30 | 1.5 | 30 | 59,946 | 0.1562 |
| Solar Thermal | trough | Maui | Kihei | Future | Incl | Optimistic | 30 | 1.5 | 30 | 61,741 | 0.1564 |
| Solar Thermal | trough | Maui | Kahului | Future | Incl | Optimistic | 30 | 1.5 | 30 | 58,152 | 0.1656 |
| Wind | | Maui | McGregor Point | Future | Incl | Nominal | 10 | 1 | 30 | 24,611 | 0.0465 |
| Biomass Elec | org waste | Maui | Puunene | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0515 |
| Wind | | Maui | NW Haleakala | Future | Incl | Nominal | 10 | 1 | 30 | 21,205 | 0.0545 |
| Biomass Fuel | org waste-methanol | Maui | Puunene | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0561 |
| Biomass Fuel | tree crops-methanol | Maui | Paia-Puunene | Future | Incl | Nominal | 95 | 2 | 30 | 581,342 | 0.0583 |
| Biomass Fuel | grass crops-methanol | Maui | Paia-Puunene | Future | Incl | Nominal | 95 | 2 | 30 | 581,342 | 0.0675 |
| Wind | | Maui | Puunene | Future | Incl | Nominal | 10 | 1 | 30 | 15,784 | 0.0677 |
| Wind | | Maui | West Maui | Future | Incl | Nominal | 50 | 1 | 30 | 77,546 | 0.0707 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0795 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Nominal | 30 | 2 | 30 | 82,893 | 0.0807 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Nominal | 30 | 2 | 30 | 77,792 | 0.0850 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Nominal | 30 | 2 | 30 | 78,159 | 0.0857 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Nominal | 10 | 1.5 | 30 | 16,430 | 0.0901 |
| Wave | | Maui | Opana Point | Future | Incl | Nominal | 60 | 2 | 30 | 211,984 | 0.0920 |

| | | | | | | | | | | | |
|---------------|----------------------|------|----------------|--------|------|--------------|----|-----|----|---------|--------|
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Nominal | 10 | 1.5 | 30 | 16,922 | 0.0929 |
| Wave | | Maui | Lower Paia | Future | Incl | Nominal | 60 | 2 | 30 | 203,974 | 0.0956 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Nominal | 30 | 2 | 30 | 63,764 | 0.0980 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Nominal | 10 | 1.5 | 30 | 15,938 | 0.0984 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Nominal | 30 | 2 | 30 | 63,764 | 0.0992 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Nominal | 30 | 2 | 30 | 63,544 | 0.0997 |
| Wave | | Maui | Waiehu Point | Future | Incl | Nominal | 30 | 2 | 30 | 101,256 | 0.1023 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.1442 |
| Solar Thermal | trough | Maui | Puunene | Future | Incl | Nominal | 30 | 1.5 | 30 | 57,092 | 0.1778 |
| Solar Thermal | trough | Maui | Kihei | Future | Incl | Nominal | 30 | 1.5 | 30 | 58,801 | 0.1781 |
| Solar Thermal | trough | Maui | Kahului | Future | Incl | Nominal | 30 | 1.5 | 30 | 55,382 | 0.1886 |
| Wind | | Maui | McGregor Point | Future | Incl | Conservative | 10 | 1 | 30 | 20,805 | 0.0592 |
| Wind | | Maui | NW Haleakala | Future | Incl | Conservative | 10 | 1 | 30 | 17,926 | 0.0695 |
| Biomass Fuel | tree crops-methanol | Maui | Paia-Puunene | Future | Incl | Conservative | 95 | 2 | 30 | 523,208 | 0.0777 |
| Biomass Elec | org waste | Maui | Puunene | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.0779 |
| Biomass Fuel | org waste-methanol | Maui | Puunene | Future | Incl | Conservative | 47 | 2 | 30 | 261,604 | 0.0815 |
| Wind | | Maui | Puunene | Future | Incl | Conservative | 10 | 1 | 30 | 13,275 | 0.0872 |
| Biomass Fuel | grass crops-methanol | Maui | Paia-Puunene | Future | Incl | Conservative | 95 | 2 | 30 | 523,208 | 0.0900 |
| Wind | | Maui | West Maui | Future | Incl | Conservative | 50 | 1 | 30 | 65,218 | 0.0905 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Conservative | 30 | 2 | 30 | 70,459 | 0.0990 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Conservative | 30 | 2 | 30 | 66,123 | 0.1042 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Conservative | 30 | 2 | 30 | 66,435 | 0.1051 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1060 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Conservative | 10 | 1.5 | 30 | 14,787 | 0.1085 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Conservative | 10 | 1.5 | 30 | 15,230 | 0.1119 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Conservative | 10 | 1.5 | 30 | 14,344 | 0.1187 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Conservative | 30 | 2 | 30 | 54,199 | 0.1200 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Conservative | 30 | 2 | 30 | 54,199 | 0.1216 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Conservative | 30 | 2 | 30 | 54,012 | 0.1221 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1922 |
| Solar Thermal | trough | Maui | Puunene | Future | Incl | Conservative | 30 | 1.5 | 30 | 51,383 | 0.2122 |
| Solar Thermal | trough | Maui | Kihei | Future | Incl | Conservative | 30 | 1.5 | 30 | 52,921 | 0.2127 |
| Solar Thermal | trough | Maui | Kahului | Future | Incl | Conservative | 30 | 1.5 | 30 | 49,844 | 0.2254 |
| Wave | | Maui | Opana Point | Future | Incl | Conservative | 60 | 2 | 30 | 98,882 | 0.2913 |
| Wave | | Maui | Lower Paia | Future | Incl | Conservative | 60 | 2 | 30 | 94,151 | 0.3060 |
| Wave | | Maui | Waiehu Point | Future | Incl | Conservative | 30 | 2 | 30 | 46,754 | 0.3260 |

Island(s): Oahu
Technology: All Technologies
Stage: Current Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|--------------|---------|---------|--------------|----|------|------|---------|--------|
| Wind | | Oahu | Kaena Point | Current | Incl | Optimistic | 15 | 1 | 30 | 29,553 | 0.0518 |
| Wind | | Oahu | Kahuku | Current | Incl | Optimistic | 30 | 1 | 30 | 53,588 | 0.0548 |
| Biomass Elec | grass crops | Oahu | Waialua | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0857 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Optimistic | 50 | 4 | 30 | 123,931 | 0.1026 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Optimistic | 50 | 4 | 30 | 123,931 | 0.1032 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 50 | 4 | 30 | 123,931 | 0.1038 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Optimistic | 50 | 4 | 30 | 110,654 | 0.1084 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Optimistic | 50 | 4 | 30 | 110,654 | 0.1091 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 50 | 4 | 30 | 110,654 | 0.1097 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Current | Incl | Optimistic | 50 | 1.5 | 30 | 84,949 | 0.1205 |
| Solar Thermal | dish | Oahu | Lualualei | Current | Incl | Optimistic | 50 | 1.5 | 30 | 80,912 | 0.1243 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 50 | 1.5 | 30 | 78,489 | 0.1335 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Current | Incl | Optimistic | 80 | 1.5 | 30 | 146,581 | 0.1700 |
| Solar Thermal | trough | Oahu | Lualualei | Current | Incl | Optimistic | 80 | 1.5 | 30 | 139,614 | 0.1755 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 80 | 1.5 | 30 | 135,434 | 0.1866 |
| Wind | | Oahu | Kaena Point | Current | Incl | Nominal | 15 | 1 | 30 | 25,230 | 0.0652 |
| Wind | | Oahu | Kahuku | Current | Incl | Nominal | 30 | 1 | 30 | 45,551 | 0.0694 |
| Biomass Elec | grass crops | Oahu | Waialua | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1139 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1288 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1297 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1303 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 1.5 | 30 | 80,904 | 0.1360 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1364 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1373 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1381 |
| Solar Thermal | dish | Oahu | Lualualei | Current | Incl | Nominal | 50 | 1.5 | 30 | 77,059 | 0.1403 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 1.5 | 30 | 74,752 | 0.1509 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Current | Incl | Nominal | 80 | 1.5 | 30 | 139,601 | 0.1939 |
| Solar Thermal | trough | Oahu | Lualualei | Current | Incl | Nominal | 80 | 1.5 | 30 | 132,966 | 0.2001 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Current | Incl | Nominal | 80 | 1.5 | 30 | 128,985 | 0.2130 |
| Wind | | Oahu | Kaena Point | Current | Incl | Conservative | 15 | 1 | 30 | 21,234 | 0.0841 |
| Wind | | Oahu | Kahuku | Current | Incl | Conservative | 30 | 1 | 30 | 38,147 | 0.0901 |
| Biomass Elec | grass crops | Oahu | Waialua | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1483 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Conservative | 50 | 4 | 30 | 96,990 | 0.1491 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Conservative | 50 | 4 | 30 | 96,990 | 0.1501 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Conservative | 50 | 4 | 30 | 96,990 | 0.1509 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Conservative | 50 | 4 | 30 | 86,598 | 0.1577 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Conservative | 50 | 4 | 30 | 86,598 | 0.1588 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Conservative | 50 | 4 | 30 | 86,598 | 0.1597 |

| | | | | | | | | | | | |
|---------------|--------|------|--------------|---------|------|--------------|----|-----|----|---------|--------|
| Solar Thermal | dish | Oahu | Pearl Harbor | Current | Incl | Conservative | 50 | 1.5 | 30 | 72,814 | 0.1612 |
| Solar Thermal | dish | Oahu | Lualualei | Current | Incl | Conservative | 50 | 1.5 | 30 | 69,353 | 0.1661 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Current | Incl | Conservative | 50 | 1.5 | 30 | 67,276 | 0.1791 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Current | Incl | Conservative | 80 | 1.5 | 30 | 125,641 | 0.2317 |
| Solar Thermal | trough | Oahu | Lualualei | Current | Incl | Conservative | 80 | 1.5 | 30 | 119,669 | 0.2391 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Current | Incl | Conservative | 80 | 1.5 | 30 | 116,086 | 0.2548 |

Island(s): Oahu
Technology: All Technologies
Stage: Future Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|--------------------|--------|----------------|--------|---------|------------|----|------|------|---------|--------|
| Biomass Fuel | org waste-methanol | Oahu | Barber's Point | Future | Incl | Optimistic | 95 | 2 | 30 | 639,477 | 0.0149 |
| Biomass Elec | org waste | Oahu | Barber's Point | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0194 |
| Wave | | Oahu | Makapuu | Future | Incl | Optimistic | 60 | 2 | 30 | 279,377 | 0.0461 |
| Wind | | Oahu | Kaena Point | Future | Incl | Optimistic | 15 | 1 | 30 | 36,966 | 0.0470 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Optimistic | 60 | 2 | 30 | 265,253 | 0.0486 |
| Wind | | Oahu | Kahuku | Future | Incl | Optimistic | 30 | 1 | 30 | 67,029 | 0.0491 |
| Wave | | Oahu | NE Coast 2A | Future | Incl | Optimistic | 30 | 2 | 30 | 129,936 | 0.0511 |
| Wave | | Oahu | NE Coast 2C | Future | Incl | Optimistic | 30 | 2 | 30 | 126,276 | 0.0525 |
| Wave | | Oahu | Mokapu Point | Future | Incl | Optimistic | 30 | 2 | 30 | 122,913 | 0.0547 |
| Wave | | Oahu | Waimanalo Bay | Future | Incl | Optimistic | 30 | 2 | 30 | 111,677 | 0.0595 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Optimistic | 50 | 3 | 30 | 128,426 | 0.0700 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Optimistic | 50 | 3 | 30 | 128,426 | 0.0704 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 50 | 3 | 30 | 128,426 | 0.0708 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Future | Incl | Optimistic | 50 | 1.5 | 30 | 89,197 | 0.0719 |
| Solar Thermal | dish | Oahu | Lualualei | Future | Incl | Optimistic | 50 | 1.5 | 30 | 84,957 | 0.0735 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Optimistic | 50 | 3 | 30 | 114,667 | 0.0737 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Optimistic | 50 | 3 | 30 | 114,667 | 0.0741 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 50 | 3 | 30 | 114,667 | 0.0746 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 50 | 1.5 | 30 | 82,414 | 0.0808 |
| Biomass Elec | grass crops | Oahu | Waialua | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0830 |
| Solar Thermal | trough | Oahu | Lualualei | Future | Incl | Optimistic | 80 | 1.5 | 30 | 160,556 | 0.1180 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 80 | 1.5 | 30 | 155,749 | 0.1267 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Future | Incl | Optimistic | 80 | 1.5 | 30 | 168,568 | 0.1278 |
| OTEC | | Oahu | Kahe Point | Future | Incl | Optimistic | 60 | 2 | 30 | 335,543 | 0.1334 |
| Biomass Fuel | org waste-methanol | Oahu | Barber's Point | Future | Incl | Nominal | 95 | 2 | 30 | 581,342 | 0.0295 |
| Biomass Elec | org waste | Oahu | Barber's Point | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0389 |
| Wind | | Oahu | Kaena Point | Future | Incl | Nominal | 15 | 1 | 30 | 31,558 | 0.0567 |
| Wind | | Oahu | Kahuku | Future | Incl | Nominal | 30 | 1 | 30 | 56,977 | 0.0597 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 1.5 | 30 | 84,949 | 0.0829 |
| Solar Thermal | dish | Oahu | Lualualei | Future | Incl | Nominal | 50 | 1.5 | 30 | 80,912 | 0.0846 |
| Wave | | Oahu | Makapuu | Future | Incl | Nominal | 60 | 2 | 30 | 224,378 | 0.0863 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0873 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0878 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0883 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Nominal | 60 | 2 | 30 | 211,197 | 0.0918 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0921 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0926 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0932 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 1.5 | 30 | 78,489 | 0.0933 |

| | | | | | | | | | | | |
|---------------|--------------------|------|----------------|--------|------|--------------|----|-----|----|---------|--------|
| Wave | | Oahu | NE Coast 2A | Future | Incl | Nominal | 30 | 2 | 30 | 103,704 | 0.0966 |
| Wave | | Oahu | NE Coast 2C | Future | Incl | Nominal | 30 | 2 | 30 | 101,831 | 0.0982 |
| Wave | | Oahu | Mokapu Point | Future | Incl | Nominal | 30 | 2 | 30 | 97,966 | 0.1034 |
| Wave | | Oahu | Waimanalo Bay | Future | Incl | Nominal | 30 | 2 | 30 | 88,957 | 0.1128 |
| Biomass Elec | grass crops | Oahu | Waialua | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1141 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Future | Incl | Nominal | 80 | 1.5 | 30 | 160,541 | 0.1307 |
| Solar Thermal | trough | Oahu | Lualualei | Future | Incl | Nominal | 80 | 1.5 | 30 | 152,911 | 0.1343 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Future | Incl | Nominal | 80 | 1.5 | 30 | 148,333 | 0.1443 |
| OTEC | | Oahu | Kahe Point | Future | Incl | Nominal | 60 | 2 | 30 | 311,260 | 0.2041 |
| Biomass Fuel | org waste-methanol | Oahu | Barber's Point | Future | Incl | Conservative | 95 | 2 | 30 | 523,208 | 0.0473 |
| Biomass Elec | org waste | Oahu | Barber's Point | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.0627 |
| Wind | | Oahu | Kaena Point | Future | Incl | Conservative | 15 | 1 | 30 | 26,560 | 0.0721 |
| Wind | | Oahu | Kahuku | Future | Incl | Conservative | 30 | 1 | 30 | 47,716 | 0.0766 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Future | Incl | Conservative | 50 | 1.5 | 30 | 76,454 | 0.0999 |
| Solar Thermal | dish | Oahu | Lualualei | Future | Incl | Conservative | 50 | 1.5 | 30 | 72,820 | 0.1019 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Conservative | 50 | 3 | 30 | 94,924 | 0.1070 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Conservative | 50 | 3 | 30 | 94,924 | 0.1077 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Conservative | 50 | 3 | 30 | 94,924 | 0.1083 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Future | Incl | Conservative | 50 | 1.5 | 30 | 70,640 | 0.1126 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Conservative | 50 | 3 | 30 | 84,754 | 0.1128 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Conservative | 50 | 3 | 30 | 84,754 | 0.1135 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Conservative | 50 | 3 | 30 | 84,754 | 0.1142 |
| Biomass Elec | grass crops | Oahu | Waialua | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1521 |
| Solar Thermal | trough | Oahu | Lualualei | Future | Incl | Conservative | 80 | 1.5 | 30 | 137,620 | 0.1599 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Future | Incl | Conservative | 80 | 1.5 | 30 | 133,499 | 0.1721 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Future | Incl | Conservative | 80 | 1.5 | 30 | 144,487 | 0.1734 |
| Wave | | Oahu | Makapuu | Future | Incl | Conservative | 60 | 2 | 30 | 105,316 | 0.2716 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Conservative | 60 | 2 | 30 | 98,372 | 0.2907 |
| OTEC | | Oahu | Kahe Point | Future | Incl | Conservative | 60 | 2 | 30 | 270,789 | 0.2997 |
| Wave | | Oahu | NE Coast 2A | Future | Incl | Conservative | 30 | 2 | 30 | 48,075 | 0.3078 |
| Wave | | Oahu | NE Coast 2C | Future | Incl | Conservative | 30 | 2 | 30 | 45,998 | 0.3214 |
| Wave | | Oahu | Mokapu Point | Future | Incl | Conservative | 30 | 2 | 30 | 45,087 | 0.3311 |
| Wave | | Oahu | Waimanalo Bay | Future | Incl | Conservative | 30 | 2 | 30 | 39,939 | 0.3710 |

Island(s): Kauai
Technology: All Technologies
Stage: Current Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------|--------|---------------|---------|---------|--------------|-----|------|------|---------|--------|
| Wind | | Kauai | N. Hanapepe | Current | Incl | Optimistic | 10 | 1 | 30 | 21,296 | 0.0475 |
| Wind | | Kauai | Port Allen | Current | Incl | Optimistic | 5 | 1 | 30 | 9,111 | 0.0546 |
| Biomass Elec | tree crops | Kauai | Kaunakani | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0617 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0622 |
| Hydro | | Kauai | Wailua River | Current | Incl | Optimistic | 6.6 | 2 | 50 | 16,770 | 0.0667 |
| Wind | | Kauai | Anahola | Current | Incl | Optimistic | 7 | 1 | 30 | 7,800 | 0.0963 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Optimistic | 10 | 2 | 30 | 25,483 | 0.1215 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Optimistic | 10 | 1.5 | 30 | 17,250 | 0.1262 |
| Wind | | Kauai | N. Hanapepe | Current | Incl | Nominal | 10 | 1 | 30 | 18,252 | 0.0598 |
| Wind | | Kauai | Port Allen | Current | Incl | Nominal | 5 | 1 | 30 | 7,763 | 0.0696 |
| Hydro | | Kauai | Wailua River | Current | Incl | Nominal | 6.6 | 2 | 50 | 16,435 | 0.0712 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0834 |
| Biomass Elec | tree crops | Kauai | Kaunakani | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0886 |
| Wind | | Kauai | Anahola | Current | Incl | Nominal | 7 | 1 | 30 | 6,651 | 0.1210 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 1.5 | 30 | 16,428 | 0.1427 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 2 | 30 | 22,159 | 0.1533 |
| Hydro | | Kauai | Wailua River | Current | Incl | Conservative | 6.6 | 2 | 50 | 16,267 | 0.0753 |
| Wind | | Kauai | N. Hanapepe | Current | Incl | Conservative | 10 | 1 | 30 | 15,430 | 0.0774 |
| Wind | | Kauai | Port Allen | Current | Incl | Conservative | 5 | 1 | 30 | 6,519 | 0.0909 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1094 |
| Biomass Elec | tree crops | Kauai | Kaunakani | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1215 |
| Wind | | Kauai | Anahola | Current | Incl | Conservative | 7 | 1 | 30 | 5,589 | 0.1552 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Conservative | 10 | 1.5 | 30 | 14,786 | 0.1691 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Conservative | 10 | 2 | 30 | 19,943 | 0.1777 |

Island(s): Kauai
Technology: All Technologies
Stage: Future Technology
Certainty: Optimistic, Nominal, and Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: Unique Location Lowest COE
Avoided Cost: N/A

RESOURCE SUPPLY CURVES



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|---------------------|--------|---------------|--------|---------|--------------|-----|------|------|---------|--------|
| Wind | | Kauai | N. Hanapepe | Future | Incl | Optimistic | 10 | 1 | 30 | 26,372 | 0.0440 |
| Wind | | Kauai | Port Allen | Future | Incl | Optimistic | 5 | 1 | 30 | 10,940 | 0.0494 |
| Wave | | Kauai | Anahola | Future | Incl | Optimistic | 30 | 2 | 30 | 124,296 | 0.0548 |
| Biomass Elec | tree & org waste | Kauai | Kaumakani | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0561 |
| Biomass Fuel | tree crops-methanol | Kauai | Lihue | Future | Incl | Optimistic | 47 | 2 | 30 | 319,738 | 0.0598 |
| Biomass Fuel | tree crops-methanol | Kauai | Kaumakani | Future | Incl | Optimistic | 47 | 2 | 30 | 319,738 | 0.0619 |
| Hydro | | Kauai | Wailua River | Future | Incl | Optimistic | 6.6 | 2 | 50 | 16,770 | 0.0635 |
| Biomass Elec | tree crops | Kauai | Lihue | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0650 |
| Biomass Elec | grass crops | Kauai | Kaumakani | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0675 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0681 |
| Solar Thermal | dish | Kauai | Barking Sands | Future | Incl | Optimistic | 10 | 1.5 | 30 | 18,112 | 0.0762 |
| Wind | | Kauai | Anahola | Future | Incl | Optimistic | 7 | 1 | 30 | 9,618 | 0.0803 |
| Photovoltaic | tracking | Kauai | Barking Sands | Future | Incl | Optimistic | 10 | 1 | 30 | 26,407 | 0.0828 |
| Biomass Elec | grass crops | Kauai | Lihue | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0972 |
| Wave | | Kauai | Barking Sands | Future | Incl | Optimistic | 30 | 2 | 30 | 71,415 | 0.0996 |
| Wind | | Kauai | N. Hanapepe | Future | Incl | Nominal | 10 | 1 | 30 | 22,602 | 0.0529 |
| Wind | | Kauai | Port Allen | Future | Incl | Nominal | 5 | 1 | 30 | 9,321 | 0.0603 |
| Hydro | | Kauai | Wailua River | Future | Incl | Nominal | 6.6 | 2 | 50 | 16,435 | 0.0678 |
| Biomass Elec | tree & org waste | Kauai | Kaumakani | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0794 |
| Biomass Fuel | tree crops-methanol | Kauai | Lihue | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0822 |
| Biomass Fuel | tree crops-methanol | Kauai | Kaumakani | Future | Incl | Nominal | 47 | 2 | 30 | 290,671 | 0.0852 |
| Solar Thermal | dish | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 1.5 | 30 | 17,250 | 0.0878 |
| Biomass Elec | tree crops | Kauai | Lihue | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0894 |
| Biomass Elec | grass crops | Kauai | Kaumakani | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0929 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0937 |
| Wind | | Kauai | Anahola | Future | Incl | Nominal | 7 | 1 | 30 | 8,200 | 0.0984 |
| Wave | | Kauai | Anahola | Future | Incl | Nominal | 30 | 2 | 30 | 98,947 | 0.1030 |
| Photovoltaic | tracking | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 1 | 30 | 22,962 | 0.1037 |
| Biomass Elec | grass crops | Kauai | Lihue | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1336 |
| Wave | | Kauai | Barking Sands | Future | Incl | Nominal | 30 | 2 | 30 | 51,793 | 0.2072 |
| Wind | | Kauai | N. Hanapepe | Future | Incl | Conservative | 10 | 1 | 30 | 19,107 | 0.0673 |
| Hydro | | Kauai | Wailua River | Future | Incl | Conservative | 6.6 | 2 | 50 | 16,267 | 0.0717 |
| Wind | | Kauai | Port Allen | Future | Incl | Conservative | 5 | 1 | 30 | 7,828 | 0.0780 |
| Solar Thermal | dish | Kauai | Barking Sands | Future | Incl | Conservative | 10 | 1.5 | 30 | 15,525 | 0.1058 |
| Biomass Elec | tree & org waste | Kauai | Kaumakani | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1078 |
| Biomass Fuel | tree crops-methanol | Kauai | Lihue | Future | Incl | Conservative | 47 | 2 | 30 | 261,604 | 0.1096 |
| Biomass Fuel | tree crops-methanol | Kauai | Kaumakani | Future | Incl | Conservative | 47 | 2 | 30 | 261,604 | 0.1137 |
| Biomass Elec | tree crops | Kauai | Lihue | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1191 |
| Biomass Elec | grass crops | Kauai | Kaumakani | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1238 |

| | | | | | | | | | | | |
|--------------|-------------|-------|---------------|--------|------|--------------|----|---|----|---------|--------|
| Biomass Elec | tree crops | Kauai | Kaumakani | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1249 |
| Wind | | Kauai | Anahola | Future | Incl | Conservative | 7 | 1 | 30 | 6,891 | 0.1264 |
| Photovoltaic | tracking | Kauai | Barking Sands | Future | Incl | Conservative | 10 | 1 | 30 | 19,518 | 0.1275 |
| Biomass Elec | grass crops | Kauai | Lihue | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1781 |
| Wave | | Kauai | Anahola | Future | Incl | Conservative | 30 | 2 | 30 | 45,353 | 0.3301 |
| Wave | | Kauai | Barking Sands | Future | Incl | Conservative | 30 | 2 | 30 | 23,201 | 0.6812 |

APPENDIX C

TECHNOLOGY DATA SHEETS

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops - Methanol

Island: Hawaii

Location: Hamakua Coast

Project Code: 177,178,179

| | | | |
|---------------------------|---------|--------------------------------|--------|
| Capacity (MW): | 47 | Stage (current/future): | future |
| Resource (dry tons/year): | 134,509 | Extent (harvested acres/year): | 1,928 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|---------|--------------|
| Gross Energy (eq. MWh/yr) | 319,738 | 290,671 | 261,604 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 319,738 | 290,671 | 261,604 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Feed handling, preparation | 7,229,993 | 9,037,491 | 10,844,989 |
| Gasification | 2,822,740 | 3,528,425 | 4,234,110 |
| Gas conditioning | 4,554,161 | 5,692,701 | 6,831,241 |
| Compression | 9,097,828 | 11,372,285 | 13,646,742 |
| Acid gas removal/cooling | 4,134,422 | 5,168,028 | 6,201,634 |
| MeOH syn/purification | 11,469,350 | 14,336,687 | 17,204,024 |
| Utilities/auxiliary | 9,832,370 | 12,290,463 | 14,748,555 |
| Legal fees & permitting | 594,852 | 743,565 | 892,278 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,255,528 | 1,569,410 | 1,883,292 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|---------------------|-----------|-----------|-----------|
| Project contingency | 4,973,572 | 6,216,964 | 7,460,357 |
| Initial cost | 5,752,874 | 7,191,093 | 8,629,311 |
| | 2,361,846 | 2,952,307 | 3,542,768 |

| | | | |
|-----------|------------|------------|------------|
| SUB-TOTAL | 65,643,461 | 82,054,327 | 98,465,192 |
|-----------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 6,563,948 | 8,204,935 | 9,845,922 |
| Fixed O&M (\$) | 5,413,676 | 6,767,095 | 8,120,514 |
| Land Lease | 555,700 | 694,625 | 833,550 |

| | | | |
|----------------|------------|------------|------------|
| FIRST YEAR O&M | 12,533,324 | 15,666,655 | 18,799,986 |
|----------------|------------|------------|------------|

Note: 1 MW = 0.5274 MGPY MeOH
47 MW = 25 MGPY MeOH

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Grass Crops - Electricity

Island: Hawaii

Location: Hamakua Coast

Project Code: 47,48,149

| | | | |
|----------------------------|---------|--------------------------------|---------|
| Capacity (MW electricity): | 25 | Stage (current/future): | current |
| Resource (dry tons/year): | 127,750 | Extent (harvested acres/year): | 5,079 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 6,142,154 | 7,226,064 | 8,309,973 |
| Gasification & compressor/precooler | 843,041 | 991,813 | 1,140,585 |
| Physical cleanup | 17,235,500 | 20,277,059 | 23,318,618 |
| Ash handling | 321,158 | 377,833 | 434,508 |
| Gas turbine | 334,540 | 393,576 | 452,613 |
| Balance of plant | 6,490,076 | 7,635,383 | 8,780,691 |
| Legal fee & permitting | 579,916 | 682,254 | 784,592 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 3,194,639 | 3,758,398 | 4,322,158 |
| <i>Project contingency</i> | 3,514,102 | 4,134,238 | 4,754,374 |
| <i>Initial cost</i> | 1,869,387 | 2,199,279 | 2,529,171 |

| | | | |
|-----------|------------|------------|------------|
| SUB-TOTAL | 40,524,513 | 47,675,898 | 54,827,283 |
|-----------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|------------|
| Variable O&M (\$) | 7,995,515 | 9,406,488 | 10,817,461 |
| Fixed O&M (\$) | 2,984,000 | 3,510,588 | 4,037,176 |
| Land Lease | 226,058 | 265,950 | 305,843 |

| | | | |
|----------------|------------|------------|------------|
| FIRST YEAR O&M | 11,205,573 | 13,183,026 | 15,160,480 |
|----------------|------------|------------|------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Tree crops - Electricity

Island: Hawaii

Location: Hamakua Coast

Project Code: 153,154,155

| | | | |
|----------------------------|---------|--------------------------------|---------|
| Capacity (MW electricity): | 25 | Stage (current/future): | current |
| Resource (dry tons-year): | 125,003 | Extent (harvested acres/year): | 1,771 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 5,780,851 | 7,226,064 | 8,671,276 |
| Gasification & compressor/precooler | 793,450 | 991,813 | 1,190,175 |
| Physical cleanup | 16,221,647 | 20,277,059 | 24,332,471 |
| Ash handling | 302,267 | 377,833 | 453,400 |
| Gas turbine | 314,861 | 393,576 | 472,292 |
| Balance of plant | 6,108,307 | 7,635,383 | 9,162,460 |
| Legal fee & permitting | 545,803 | 682,254 | 818,705 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,153,679 | 1,442,098 | 1,730,518 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project contingency</i> | 3,006,719 | 3,758,398 | 4,510,078 |
| <i>Initial cost</i> | 3,579,151 | 4,473,939 | 5,368,726 |
| | 1,440,561 | 1,800,701 | 2,160,841 |

SUB-TOTAL

| | | | |
|--|------------|------------|------------|
| | 40,811,223 | 51,014,026 | 61,216,832 |
|--|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 4,382,632 | 5,478,290 | 6,573,948 |
| Fixed O&M (\$) | 2,361,376 | 2,951,720 | 3,542,064 |
| Land Lease | 511,400 | 639,250 | 767,100 |

FIRST YEAR O&M

| | | | |
|--|-----------|-----------|------------|
| | 7,255,408 | 9,069,260 | 10,883,112 |
|--|-----------|-----------|------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Grass Crops - Electricity

Island: Hawaii

Location: Hamakua Coast

Project Code: 150,151,152

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 106,500 | Extent (harvested acres/year): | 4,233 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Project contingency</i> | 3,360,521 | 4,200,651 | 5,040,781 |
| <i>Initial cost</i> | 1,650,863 | 2,063,578 | 2,476,294 |

| | | | |
|-----------|------------|------------|------------|
| SUB-TOTAL | 38,616,589 | 48,270,736 | 57,924,884 |
|-----------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 6,581,425 | 8,226,782 | 9,872,138 |
| Fixed O&M (\$) | 2,650,361 | 3,312,951 | 3,975,541 |
| Land Lease | 178,920 | 223,650 | 268,380 |

| | | | |
|----------------|-----------|------------|------------|
| FIRST YEAR O&M | 9,410,706 | 11,763,383 | 14,116,059 |
|----------------|-----------|------------|------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops - Electricity

Island: Hawaii Location: Hamakua Coast Project Code: 156/157, 158

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 104,011 | Extent (harvested acres/year): | 1,447 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 942,163 | 1,177,704 | 1,413,245 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project contingency</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Initial cost</i> | 3,611,130 | 4,513,912 | 5,416,694 |
| | 1,399,778 | 1,749,722 | 2,099,667 |

| | | | |
|------------------|------------|------------|------------|
| SUB-TOTAL | 41,122,203 | 51,402,753 | 61,683,304 |
|------------------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 3,925,696 | 4,907,120 | 5,888,544 |
| Fixed O&M (\$) | 2,450,369 | 3,062,961 | 3,675,553 |
| Land Lease | 419,400 | 524,250 | 629,100 |

| | | | |
|---------------------------|-----------|-----------|------------|
| FIRST YEAR O&M | 6,795,465 | 8,494,331 | 10,193,197 |
|---------------------------|-----------|-----------|------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops & Organic Wastes - Electricity

Island: Hawaii

Location: Hilo Coast

Project Code: 180,181,182

| | | | |
|---------------------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 50 | Stage (current/future): | future |
| Resource (tree crops)(dry tons/year): | 170,228 | Extent (harvested acres/year): | 3,007 |
| organic wastes (wet tons/yr): | 67,732 | | |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| MSW to RDF front-end processing | 6,747,266 | 8,434,082 | 10,120,898 |
| Feed handling and prep. | 8,370,725 | 10,463,407 | 12,556,088 |
| Gasification & compressor/precooler | 14,769,967 | 18,462,459 | 22,154,951 |
| Physical cleanup | 904,943 | 1,131,179 | 1,357,415 |
| Ash handling | 872,624 | 1,090,780 | 1,308,936 |
| Gas turbine | 19,617,878 | 24,522,347 | 29,426,816 |
| Balance of plant | 11,139,421 | 13,924,276 | 16,709,131 |
| Legal fees & permitting | 611,189 | 763,986 | 916,783 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,958,357 | 2,447,946 | 2,937,535 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|------------|
| <i>Project contingency</i> | 6,303,401 | 7,879,252 | 9,455,102 |
| <i>Initial cost</i> | 7,218,497 | 9,023,121 | 10,827,746 |
| | 2,635,698 | 3,294,622 | 3,953,546 |

| | | | |
|------------------|-------------------|--------------------|--------------------|
| SUB-TOTAL | 82,713,893 | 103,392,365 | 124,070,837 |
|------------------|-------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|------------|
| Variable O&M (\$) | 5,821,404 | 7,937,811 | 10,052,880 |
| Fixed O&M (\$) | 3,929,130 | 4,911,412 | 5,893,695 |
| Land Lease | 861,400 | 1,076,750 | 1,292,100 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 10,611,934 | 13,925,973 | 17,238,675 |
|---------------------------|-------------------|-------------------|-------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops - Methanol

Island: Hawaii

Location: Hilo Coast

Project Code: 174,175;176

| | | | |
|---------------------------|---------|-------------------------------|--------|
| Capacity (MW): | 47 | Stage (current/future): | future |
| Resource (dry tons/year): | 134,509 | Extent (harvested acres/year) | 2,335 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|---------|--------------|
| Gross Energy (eq. MWh/yr) | 319,738 | 290,671 | 261,604 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 319,738 | 290,671 | 261,604 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Feed handling, preparation | 7,229,993 | 9,037,491 | 10,844,989 |
| Gasification | 2,822,740 | 3,528,425 | 4,234,110 |
| Gas conditioning | 4,554,161 | 5,692,701 | 6,831,241 |
| Compression | 9,097,828 | 11,372,285 | 13,646,742 |
| Acid gas removal/cooling | 4,134,422 | 5,168,028 | 6,201,634 |
| MeOH syn/purification | 11,469,350 | 14,336,687 | 17,204,024 |
| Utilities/auxiliary | 9,832,370 | 12,290,463 | 14,748,555 |
| Legal fees & permitting | 594,852 | 743,565 | 892,278 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,521,072 | 1,901,340 | 2,281,608 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project contingency</i> | 4,973,572 | 6,216,964 | 7,460,357 |
| <i>Initial cost</i> | 5,779,429 | 7,224,286 | 8,669,143 |
| | 2,417,880 | 3,022,350 | 3,626,820 |

| | | | |
|-----------|------------|------------|------------|
| SUB-TOTAL | 65,991,594 | 82,489,492 | 98,987,391 |
|-----------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|------------|
| Variable O&M (\$) | 6,969,620 | 8,712,025 | 10,454,430 |
| Fixed O&M (\$) | 5,466,785 | 6,833,481 | 8,200,178 |
| Land Lease | 671,200 | 839,000 | 1,006,800 |

| | | | |
|----------------|------------|------------|------------|
| FIRST YEAR O&M | 13,107,605 | 16,384,506 | 19,661,408 |
|----------------|------------|------------|------------|

Note: 1 MW = 0.5274 MGPY MeOH
47 MW = 25 MGPY MeOH

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Tree crops - Electricity

Island: Hawaii

Location: Hilo Coast

Project Code: 159,160,161

| | | | |
|----------------------------|---------|--------------------------------|---------|
| Capacity (MW electricity): | 25 | Stage (current/future): | current |
| Resource (dry tons/year): | 125,003 | Extent (harvested acres/year): | 2,161 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 6,142,154 | 7,226,064 | 8,309,973 |
| Gasification & compressor/precooler | 843,041 | 991,813 | 1,140,585 |
| Physical cleanup | 17,235,500 | 20,277,059 | 23,318,618 |
| Ash handling | 321,158 | 377,833 | 434,508 |
| Gas turbine | 334,540 | 393,576 | 452,613 |
| Balance of plant | 6,490,076 | 7,635,383 | 8,780,691 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,495,466 | 1,759,371 | 2,023,277 |
| Plantation lab | 119,517 | 140,608 | 161,699 |
| Equip. repair shop | 1,542,155 | 1,814,300 | 2,086,445 |

Engineering & overhead

| | | | |
|---------------------|-----------|-----------|-----------|
| Project contingency | 3,136,647 | 3,690,173 | 4,243,699 |
| Initial cost | 3,766,025 | 4,430,618 | 5,095,211 |
| | 1,573,111 | 1,850,718 | 2,128,326 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 42,999,390 | 50,587,516 | 58,175,645 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 5,068,277 | 5,962,678 | 6,857,080 |
| Fixed O&M (\$) | 2,562,898 | 3,015,175 | 3,467,451 |
| Land Lease | 660,663 | 777,250 | 893,838 |

| | | | |
|---------------------------|------------------|------------------|-------------------|
| FIRST YEAR O&M | 8,291,838 | 9,755,103 | 11,218,369 |
|---------------------------|------------------|------------------|-------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Tree crops - Electricity

Island: Hawaii

Location: Hilo Coast

Project Code: 162-163/164

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 104,011 | Extent (harvested acres/year): | 1,779 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,158,737 | 1,448,421 | 1,738,105 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project contingency</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Initial cost</i> | 3,632,787 | 4,540,984 | 5,449,180 |
| | 1,445,459 | 1,806,824 | 2,168,188 |

| | | | |
|------------------|------------|------------|------------|
| SUB-TOTAL | 41,406,114 | 51,757,643 | 62,109,172 |
|------------------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 4,262,393 | 5,327,992 | 6,393,590 |
| Fixed O&M (\$) | 2,493,684 | 3,117,104 | 3,740,525 |
| Land Lease | 513,600 | 642,000 | 770,400 |

| | | | |
|---------------------------|-----------|-----------|------------|
| FIRST YEAR O&M | 7,269,677 | 9,087,096 | 10,904,515 |
|---------------------------|-----------|-----------|------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Grass Crops - Electricity

Island: Hawaii

Location: Hilo Coast

Project Code: 171, 172, 173

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 106,500 | Extent (harvested acres/year): | 5,108 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Project contingency</i> | 3,360,521 | 4,200,651 | 5,040,781 |
| <i>Initial cost</i> | 1,797,867 | 2,247,334 | 2,696,800 |

| | | | |
|-----------|------------|------------|------------|
| SUB-TOTAL | 38,763,593 | 48,454,491 | 58,145,390 |
|-----------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|------------|------------|------------|
| Variable O&M (\$) | 7,693,338 | 9,616,673 | 11,540,007 |
| Fixed O&M (\$) | 2,949,687 | 3,687,108 | 4,424,530 |
| Land Lease | 213,920 | 267,400 | 320,880 |
| FIRST YEAR O&M | 10,856,945 | 13,571,181 | 16,285,417 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Grass Crops - Electricity

Island: Hawaii

Location: Ka'u

Project Code: 168,169,170

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 106,500 | Extent (harvested acres/year): | 3,780 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Project contingency</i> | 3,360,521 | 4,200,651 | 5,040,781 |
| <i>Initial cost</i> | 1,574,757 | 1,968,446 | 2,362,135 |

| | | | |
|-----------|------------|------------|------------|
| SUB-TOTAL | 38,540,483 | 48,175,604 | 57,810,724 |
|-----------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 6,005,772 | 7,507,215 | 9,008,658 |
| Fixed O&M (\$) | 2,495,395 | 3,119,244 | 3,743,093 |
| Land Lease | 160,800 | 201,000 | 241,200 |

| | | | |
|----------------|-----------|------------|------------|
| FIRST YEAR O&M | 8,661,967 | 10,827,459 | 12,992,951 |
|----------------|-----------|------------|------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Grass Crops - Methanol

Island: Hawaii

Location: Kaunakakai

Project Code: 165, 166, 167

| | | | |
|---------------------------|---------|--------------------------------|--------|
| Capacity (MW): | 47 | Stage (current/future): | future |
| Resource (dry tons/year): | 138,122 | Extent (harvested acres/year): | 5,492 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| | | | |
|---------------------------|-------------------|----------------|---------------------|
| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
| Gross Energy (eq. MWh/yr) | 319,738 | 290,671 | 261,604 |
| Expected Losses (%) | 0 | 0 | 0 |

| | | | |
|-------------------------|---------|---------|---------|
| Net Energy (eq. MWh/yr) | 319,738 | 290,671 | 261,604 |
|-------------------------|---------|---------|---------|

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Feed handling, preparation | 7,229,993 | 9,037,491 | 10,844,989 |
| Gasification | 2,822,740 | 3,528,425 | 4,234,110 |
| Gas conditioning | 4,554,161 | 5,692,701 | 6,831,241 |
| Compression | 9,097,828 | 11,372,285 | 13,646,742 |
| Acid gas removal/cooling | 4,134,422 | 5,168,028 | 6,201,634 |
| MeOH syn/purification | 11,469,350 | 14,336,687 | 17,204,024 |
| Utilities/auxiliary | 9,832,370 | 12,290,463 | 14,748,555 |
| Legal fees & permitting | 594,852 | 743,565 | 892,278 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 4,973,572 | 6,216,964 | 7,460,357 |
| <i>Project contingency</i> | 5,470,929 | 6,838,661 | 8,206,393 |
| <i>Initial cost</i> | 2,716,543 | 3,395,678 | 4,074,814 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 62,896,759 | 78,620,948 | 94,345,138 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|------------|------------|
| Variable O&M (\$) | 9,959,144 | 12,448,930 | 14,938,715 |
| Fixed O&M (\$) | 5,981,682 | 7,477,103 | 8,972,524 |
| Land Lease | 229,280 | 286,600 | 343,920 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 16,170,106 | 20,212,633 | 24,255,159 |
|---------------------------|-------------------|-------------------|-------------------|

Note: 1 MW = 0.5274 MGPY MeOH
47 MW = 25 MGPY MeOH

HAWAII ENERGY STRATEGY
PROJECT #3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Geothermal

Island: Hawaii Location: Kilauea Project Code: 733, 734, 735

| | | | |
|----------------------|-------------------------|---------------------------|---------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>Future</u> |
| Resource | <u>High-Temperature</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>5</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|------------|---------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 402,960 | 385,440 | 350,400 |
| Expected Losses (%) | 3% | 6% | 12% |
| Net Energy (MWh/yr) | 390,871 | 362,314 | 308,352 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------------|------------|------------|------------|
| Exploration & Assessment | 175,000 | 1,750,000 | 3,500,000 |
| Production & Injection Wells | 19,600,000 | 30,000,000 | 54,400,000 |
| Gathering/Injection System | 3,850,000 | 4,550,000 | 5,250,000 |
| Power Plant | 49,500,000 | 56,100,000 | 62,700,000 |
| Substation Tie-In | 312,500 | 375,000 | 500,000 |
| Water Supply | 750,000 | 1,500,000 | 1,875,000 |
| Permitting, Legal, Environmental | 625,000 | 750,000 | 675,000 |

General Facilities

| | | | |
|------------------------------|---------|-----------|-----------|
| Roads & Site Work | 800,000 | 1,200,000 | 1,800,000 |
| Control and Office Buildings | 437,500 | 562,500 | 687,500 |
| Land Acquisition | 218,750 | 306,250 | 437,500 |

Engineering & Overhead

| | | | |
|--|-----------|-----------|------------|
| | 7,595,625 | 9,671,875 | 13,132,500 |
|--|-----------|-----------|------------|

Project Contingency

| | | | |
|--|-----------|------------|------------|
| | 8,355,188 | 10,639,063 | 14,445,750 |
|--|-----------|------------|------------|

Initial Costs

| | | | |
|--|-----------|-----------|-----------|
| | 2,839,712 | 3,610,578 | 4,883,973 |
|--|-----------|-----------|-----------|

| | | | |
|-----------------------------------|-------------------|--------------------|--------------------|
| SUB-TOTAL | <u>95,059,274</u> | <u>121,015,266</u> | <u>164,287,223</u> |
| Capital Cost per kW (excl. trans) | \$1,895 | \$2,413 | \$3,276 |

| | | | |
|------------------------------------|----------|----------|----------|
| TRANSMISSION | <u>0</u> | <u>0</u> | <u>0</u> |
| Capital Cost per kW (incl. trans.) | \$1,901 | \$2,420 | \$3,285 |

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | 280,000 | 428,571 | 1,066,667 |
| Fixed O&M | 990,000 | 1,196,250 | 1,402,500 |
| Land Lease | 2,286,597 | 1,978,232 | 1,282,744 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>3,556,597</u> | <u>3,603,054</u> | <u>3,751,911</u> |
| O&M per kWh (mills) | 9.1 | 9.9 | 12.2 |

HAWAII ENERGY STRATEGY
PROJECT #3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Geothermal

Island: Hawaii Location: Kilauea Project Code: 730, 731, 732

| | | | |
|----------------------|-------------------------|---------------------------|---------------|
| Capacity (MW) | <u>25</u> | Stage (current/future) | <u>Future</u> |
| Resource | <u>High-Temperature</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>5</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------|-------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 201,480 | 192,720 | 175,200 |
| Expected Losses (%) | 4% | 8% | 14% |
| Net Energy (MWh/yr) | 193,421 | 177,302 | 150,672 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------------|------------|------------|------------|
| Exploration & Assessment | 100,000 | 1,000,000 | 2,000,000 |
| Production & Injection Wells | 11,200,000 | 18,000,000 | 32,000,000 |
| Gathering/Injection System | 2,200,000 | 2,600,000 | 3,000,000 |
| Power Plant | 30,000,000 | 34,000,000 | 38,000,000 |
| Substation Tie-In | 250,000 | 300,000 | 400,000 |
| Water Supply | 500,000 | 1,000,000 | 1,250,000 |
| Permitting, Legal, Environmental | 500,000 | 600,000 | 700,000 |

General Facilities

| | | | |
|------------------------------|---------|---------|-----------|
| Roads & Site Work | 500,000 | 750,000 | 1,000,000 |
| Control and Office Buildings | 350,000 | 450,000 | 550,000 |
| Land Acquisition | 125,000 | 175,000 | 250,000 |

Engineering & Overhead

| | | | |
|--|-----------|-----------|-----------|
| | 4,547,500 | 5,857,500 | 7,875,000 |
|--|-----------|-----------|-----------|

Project Contingency

| | | | |
|--|-----------|-----------|-----------|
| | 5,002,250 | 6,443,250 | 8,662,500 |
|--|-----------|-----------|-----------|

| | | | |
|----------------------|-----------|-----------|-----------|
| <i>Initial Costs</i> | 1,700,743 | 2,186,689 | 2,929,458 |
|----------------------|-----------|-----------|-----------|

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | <u>56,975,493</u> | <u>73,362,439</u> | <u>98,616,958</u> |
|------------------|-------------------|-------------------|-------------------|

| | | | |
|-----------------------------------|---------|---------|---------|
| Capital Cost per kW (excl. trans) | \$2,269 | \$2,922 | \$3,945 |
|-----------------------------------|---------|---------|---------|

| | | | |
|---------------------|----------|----------|----------|
| TRANSMISSION | <u>0</u> | <u>0</u> | <u>0</u> |
|---------------------|----------|----------|----------|

| | | | |
|------------------------------------|---------|---------|---------|
| Capital Cost per kW (incl. trans.) | \$2,279 | \$2,934 | \$3,945 |
|------------------------------------|---------|---------|---------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|---------|---------|
| Variable O&M | 186,667 | 300,000 | 640,000 |
| Fixed O&M | 600,000 | 725,000 | 850,000 |
| Land Lease | 1,131,512 | 968,071 | 626,796 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>1,918,178</u> | <u>1,993,071</u> | <u>2,116,796</u> |
|---------------------------|------------------|------------------|------------------|

| | | | |
|---------------------|-----|------|------|
| O&M per kWh (mills) | 9.9 | 11.2 | 14.0 |
|---------------------|-----|------|------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: HYDRO

Island: Hawaii

Location: Umauma Stream

Project Code: 240,241,242

Capacity (MW) 13.8
Resource(cfs, max) 260
Project Life (years) 50

Stage (current/future) current
Extent (ft of head) 835
Construction Time (years) 2.0

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|---------------------|---------------------|---------------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 42952 | 42093 | 41663 |
| Expected Losses (%) | 4.5% | 4.5% | 4.5% |
| Net Energy (MWh/yr) | 41019 | 40199 | 39788 |
| CAPITAL COSTS | | | |
| Process Capital | | | |
| Intake Structure | \$210,910 | \$221,456 | \$232,528 |
| Penstock | \$6,082,365 | \$6,386,483 | \$6,705,807 |
| Tailrace | \$287,345 | \$301,712 | \$316,798 |
| Diversion Structure | \$1,530,378 | \$1,606,897 | \$1,687,242 |
| Powerhouse | \$1,056,829 | \$1,109,670 | \$1,165,154 |
| Turbine | \$1,957,186 | \$2,055,045 | \$2,157,798 |
| Generator | \$2,624,413 | \$2,755,634 | \$2,893,415 |
| Switchgear | \$549,370 | \$576,839 | \$605,680 |
| Equipment Installation | \$180,725 | \$189,761 | \$199,249 |
| Interconnection | \$880,643 | \$924,675 | \$970,909 |
| Legal Fees & Permitting | \$550,000 | \$577,500 | \$606,375 |
| Environmental Moinitoring | \$375,620 | \$394,401 | \$414,121 |
| General Capital Facilities | | | |
| Access Road | \$542,813 | \$569,954 | \$598,451 |
| Station Service | \$180,725 | \$189,761 | \$199,249 |
| Telecommunications | \$48,000 | \$50,400 | \$52,920 |
| Engineering Services | | | |
| Engineering | \$1,364,586 | \$1,432,815 | \$1,504,456 |
| Construction Management | \$1,364,586 | \$1,432,815 | \$1,504,456 |
| Post Construction Environmental | \$85,000 | \$89,250 | \$93,713 |
| Project Contingency | 10.0% | 10.0% | 10.0% |
| SUB-TOTAL | \$21,858,643 | \$22,951,575 | \$24,099,154 |
| TRANSMISSION | | | |
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
| ANNUAL EXPENSES | | | |
| Variable O&M | \$71,500 | \$75,075 | \$78,829 |
| Fixed O&M | \$105,722 | \$111,008 | \$116,559 |
| Rep. Spare Parts (Sinking Fund) | \$21,859 | \$22,952 | \$24,100 |
| Land Lease | \$21,000 | \$22,050 | \$23,153 |
| Federal Fees | \$9,100 | \$9,555 | \$10,033 |
| FIRST YEAR O&M | \$229,181 | \$240,640 | \$252,672 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: HYDRO

Island: Hawaii

Location: Umauma Stream

Project Code: 243, 244, 245

Capacity (MW) 13.8
Resource(cfs, max) 260
Project Life (years) 50

Stage (current/future) future
Extent (ft of head) 835
Construction Time (years) 2.0

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|---------------------|---------------------|---------------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 42952 | 42093 | 41663 |
| Expected Losses (%) | 4.5% | 4.5% | 4.5% |
| Net Energy (MWh/yr) | 41019 | 40199 | 39788 |
| CAPITAL COSTS | | | |
| Process Capital | | | |
| Intake Structure | \$210,910 | \$221,456 | \$232,528 |
| Penstock | \$6,082,365 | \$6,386,483 | \$6,705,807 |
| Tailrace | \$287,345 | \$301,712 | \$316,798 |
| Diversion Structure | \$1,530,378 | \$1,606,897 | \$1,687,242 |
| Powerhouse | \$1,056,829 | \$1,109,670 | \$1,165,154 |
| Turbine | \$1,957,186 | \$2,055,045 | \$2,157,798 |
| Generator | \$2,624,413 | \$2,755,634 | \$2,893,415 |
| Switchgear | \$549,370 | \$576,839 | \$605,680 |
| Equipment Installation | \$180,725 | \$189,761 | \$199,249 |
| Interconnection | \$880,643 | \$924,675 | \$970,909 |
| Legal Fees & Permitting | \$550,000 | \$577,500 | \$606,375 |
| Environmental Moinitoring | \$375,620 | \$394,401 | \$414,121 |
| General Capital Facilities | | | |
| Access Road | \$542,813 | \$569,954 | \$598,451 |
| Station Service | \$180,725 | \$189,761 | \$199,249 |
| Telecommunications | \$48,000 | \$50,400 | \$52,920 |
| Engineering Services | | | |
| Engineering | \$1,364,586 | \$1,432,815 | \$1,504,456 |
| Construction Management | \$1,364,586 | \$1,432,815 | \$1,504,456 |
| Post Construction Environmental | \$85,000 | \$89,250 | \$93,713 |
| Project Contingency | 10.0% | 10.0% | 10.0% |
| SUB-TOTAL | \$21,858,643 | \$22,951,575 | \$24,099,154 |
| TRANSMISSION | | | |
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
| ANNUAL EXPENSES | | | |
| Variable O&M | \$71,500 | \$75,075 | \$78,829 |
| Fixed O&M | \$52,900 | \$55,545 | \$58,322 |
| Rep. Spare Parts (Sinking Fund) | \$21,859 | \$22,952 | \$24,100 |
| Land Lease | \$21,000 | \$22,050 | \$23,153 |
| Federal Fees | \$9,100 | \$9,555 | \$10,033 |
| FIRST YEAR O&M | \$176,359 | \$185,177 | \$194,436 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: OTEC (closed cycle, ammonia)

Island Hawaii Location Keahole Point Project Code 246, 247, 248

| | | | |
|---------------------------------------------|---------------|---------------------------|---------------------|
| Project size (MWe _{gross summer}) | <u>60</u> | Stage (current/future) | <u>future</u> |
| Resource (ΔT, summer) | <u>23.1°C</u> | CWP length, intake depth | <u>3000m, 1000m</u> |
| Project life (years) | <u>30</u> | Construction time (years) | <u>2</u> |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------|----------------|----------------|----------------|
| ENERGY PRODUCTION | | | |
| Gross energy at constant summer ΔT (MWh/yr) | 525,600 | 525,600 | 525,600 |
| Seasonal ΔT variability factor | 80% | 80% | 80% |
| Annual gross energy (MWh/yr) | 420,480 | 420,480 | 420,480 |
| Parasitic power losses | 12 MWe | 13 MWe | 14 MWe |
| Net energy at 100% availability (MWh/yr) | 336,384 | 329,376 | 322,368 |
| Annual average availability | 95% | 90% | 80% |
| NET ENERGY (MWh/yr) | 319,565 | 296,438 | 257,894 |

CAPITAL COSTS (\$)

| | | | |
|-------------------------------------------|--------------------|--------------------|--------------------|
| Plant structure | 84,600,000 | 82,837,000 | 148,097,000 |
| Seawater systems (pipelines and SW pumps) | 57,528,000 | 92,778,000 | 186,797,000 |
| Heat exchangers | 67,680,000 | 138,062,000 | 92,966,000 |
| Turbine/generators | 56,400,000 | 66,270,000 | 11,891,000 |
| Balance of plant | 33,840,000 | 33,135,000 | 59,995,000 |
| Substation | 2,538,000 | 2,485,000 | 2,432,000 |
| Legal fees and permitting | 1,347,000 | 1,629,000 | 1,846,000 |
| <i>Process Capital Sub-Total</i> | 303,933,000 | 417,198,000 | 504,024,000 |
| <i>General Facilities</i> | 15,197,000 | 41,720,000 | 75,604,000 |
| <i>Engineering & Overhead</i> | 30,393,000 | 41,720,000 | 50,402,000 |
| <i>Project Contingency</i> | 34,952,000 | 50,064,000 | 63,003,000 |
| <i>Initial Costs</i> | 7,917,000 | 11,431,000 | 14,491,000 |
| TOTAL PLANT COST | 392,393,000 | 562,132,000 | 707,524,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 2,000,000 | 2,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 2,735,000 | 5,006,000 | 7,560,000 |
| Amortized periodic replacements | 0 | 0 | 0 |
| FIRST YEAR O&M COST | 2,735,000 | 5,006,000 | 7,560,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: Keahole Project Code: 55, 56, 57

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,225</u> | Extent (PV module area, m ²) | <u>229,920</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>4</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|----------------------------|----------------|----------------|---------------|
| Gross Energy (MWh/yr) | 124,400 | 108,196 | 97,406 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 123,181 | 107,114 | 96,403 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|---------------|---------------|---------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$27,979,875 | \$29,452,500 | \$30,925,125 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$816,176 | \$1,020,220 | \$1,275,275 |

General Facilities

| | | | |
|-----------------------|--------------|--------------|--------------|
| Roads and Grading | \$12,259,958 | \$13,622,175 | \$14,984,393 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |

Engineering & Overhead

| | | | |
|------------------------|--------------|--------------|--------------|
| Engineering & Overhead | \$15,448,655 | \$15,448,655 | \$15,448,655 |
|------------------------|--------------|--------------|--------------|

Project Contingency

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$18,914,020 | \$18,914,020 | \$18,914,020 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$3,894,839 | \$3,894,839 | \$3,894,839 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | | |
|------------------|----------------------|----------------------|----------------------|
| SUB-TOTAL | \$224,162,872 | \$245,326,739 | \$255,854,117 |
|------------------|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$156,458 | \$173,842 | \$191,226 |
|--------------|-----------|-----------|-----------|

| | | | |
|-----------|-----------|-----------|-----------|
| Fixed O&M | \$123,500 | \$130,000 | \$136,500 |
|-----------|-----------|-----------|-----------|

| | | | |
|------------|----------|----------|----------|
| Land Lease | \$83,842 | \$88,255 | \$92,668 |
|------------|----------|----------|----------|

FIRST YEAR O&M

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$363,800 | \$392,097 | \$420,394 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: Keahole Project Code: 598, 599, 600

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | current |
| Resource (kWh/m ²) | 2,225 | Extent (PV module area, m ²) | 229,920 |
| Project Life (years) | 30 | Construction Time (years) | 4 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|----------------|
| Gross Energy (MWh/yr) | 139,328 | 121,179 | 109,095 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 137,963 | 119,968 | 107,971 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|---------------|---------------|---------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$41,969,813 | \$44,178,750 | \$46,387,688 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$816,176 | \$1,020,220 | \$1,275,275 |

General Facilities

| | | | |
|-----------------------|--------------|--------------|--------------|
| Roads and Grading | \$12,259,958 | \$13,622,175 | \$14,984,393 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |

Engineering & Overhead

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$18,914,020 | \$18,914,020 | \$18,914,020 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$3,894,839 | \$3,894,839 | \$3,894,839 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$238,152,810 | \$260,052,989 | \$271,316,679 |
|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$2,000,000 | \$2,000,000 | \$2,000,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$234,687 | \$260,763 | \$286,839 |
| Fixed O&M | \$154,375 | \$162,500 | \$170,625 |
| Land Lease | \$83,842 | \$88,255 | \$92,668 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$472,904 | \$511,518 | \$550,132 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: Keahole Project Code: 58, 59, 60

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,225</u> | Extent (PV module area, m ²) | <u>383,200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|---------------|
| Gross Energy (MWh/yr) | 128,912 | 112,120 | 95,331 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 127,649 | 110,999 | 94,349 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$20,145,510 | \$21,205,800 | \$22,266,090 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$699,978 | \$874,973 | \$1,093,716 |

General Facilities

| | | | |
|-----------------------|-------------|--------------|--------------|
| Roads and Grading | \$9,807,966 | \$10,897,740 | \$11,987,514 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |

Engineering & Overhead

| | | | |
|------------------------|--------------|--------------|--------------|
| Engineering & Overhead | \$10,249,675 | \$10,249,675 | \$10,249,675 |
|------------------------|--------------|--------------|--------------|

Project Contingency

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$13,282,948 | \$13,282,948 | \$13,282,948 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$2,726,940 | \$2,726,940 | \$2,726,940 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | | |
|------------------|----------------------|----------------------|----------------------|
| SUB-TOTAL | \$158,479,588 | \$172,279,863 | \$179,739,510 |
|------------------|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-------------|-------------|-------------|
| \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-------------|-------------|-------------|

ANNUAL EXPENSES

Variable O&M

| | | |
|-----------|-----------|-----------|
| \$146,528 | \$162,809 | \$179,090 |
|-----------|-----------|-----------|

Fixed O&M

| | | |
|-----------|-----------|-----------|
| \$117,032 | \$123,191 | \$129,351 |
|-----------|-----------|-----------|

Land Lease

| | | |
|----------|----------|----------|
| \$66,391 | \$69,885 | \$73,379 |
|----------|----------|----------|

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$329,951 | \$355,885 | \$381,820 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: Keahole Project Code: 601, 602, 603

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,225</u> | Extent (PV module area, m ²) | <u>383,200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|----------------|
| Gross Energy (MWh/yr) | 144,382 | 125,575 | 106,771 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 142,967 | 124,319 | 105,671 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$30,218,265 | \$31,808,700 | \$33,399,135 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$699,978 | \$874,973 | \$1,093,716 |

General Facilities

| | | | |
|-----------------------|-------------|--------------|--------------|
| Roads and Grading | \$9,807,966 | \$10,897,740 | \$11,987,514 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |

Engineering & Overhead

| | | | |
|--|--------------|--------------|--------------|
| | \$10,249,675 | \$10,249,675 | \$10,249,675 |
|--|--------------|--------------|--------------|

Project Contingency

| | | | |
|--|--------------|--------------|--------------|
| | \$13,282,948 | \$13,282,948 | \$13,282,948 |
|--|--------------|--------------|--------------|

Initial Costs

| | | | |
|--|-------------|-------------|-------------|
| | \$2,726,940 | \$2,726,940 | \$2,726,940 |
|--|-------------|-------------|-------------|

SUB-TOTAL

| | | | |
|--|----------------------|----------------------|----------------------|
| | \$168,552,343 | \$182,882,763 | \$190,872,555 |
|--|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | | |
|--|--------------------|--------------------|--------------------|
| | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|--|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

Variable O&M

| | | | |
|--|-----------|-----------|-----------|
| | \$219,792 | \$244,214 | \$268,635 |
|--|-----------|-----------|-----------|

Fixed O&M

| | | | |
|--|-----------|-----------|-----------|
| | \$146,290 | \$153,989 | \$161,689 |
|--|-----------|-----------|-----------|

Land Lease

| | | | |
|--|----------|----------|----------|
| | \$66,391 | \$69,885 | \$73,379 |
|--|----------|----------|----------|

FIRST YEAR O&M

| | | | |
|--|------------------|------------------|------------------|
| | \$432,473 | \$468,088 | \$503,703 |
|--|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: Keahole Project Code: 49, 50, 51

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,167</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 74,640 | 64,917 | 58,443 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 73,908 | 64,268 | 57,841 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$17,775,450 | \$18,711,000 | \$19,646,550 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$689,987 | \$862,484 | \$1,078,105 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$7,514,168 | \$8,349,075 | \$9,183,983 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |

Engineering & Overhead

| | | | |
|------------------------|--------------|--------------|--------------|
| Engineering & Overhead | \$10,388,491 | \$10,388,491 | \$10,388,491 |
|------------------------|--------------|--------------|--------------|

Project Contingency

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$12,654,925 | \$12,654,925 | \$12,654,925 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$2,619,977 | \$2,619,977 | \$2,619,977 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$149,764,482 | \$164,156,375 | \$171,233,893 |
|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$93,875 | \$104,305 | \$114,736 |
| Fixed O&M | \$111,150 | \$117,000 | \$122,850 |
| Land Lease | \$50,305 | \$52,953 | \$55,601 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$255,330 | \$274,258 | \$293,186 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: Keahole Project Code: 592, 593, 594

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 30 | Stage (current/future) | current |
| Resource (kWh/m ²) | 2,167 | Extent (PV module area, m ²) | 290,400 |
| Project Life (years) | 30 | Construction Time (years) | 3 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 83,596 | 72,707 | 65,456 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 82,777 | 71,980 | 64,782 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$26,663,175 | \$28,066,500 | \$29,469,825 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$689,987 | \$862,484 | \$1,078,105 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$7,514,168 | \$8,349,075 | \$9,183,983 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |
| <i>Engineering & Overhead</i> | \$10,388,491 | \$10,388,491 | \$10,388,491 |
| <i>Project Contingency</i> | \$12,654,925 | \$12,654,925 | \$12,654,925 |
| <i>Initial Costs</i> | \$2,619,977 | \$2,619,977 | \$2,619,977 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$158,652,207 | \$173,511,875 | \$181,057,168 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$140,812 | \$156,458 | \$172,103 |
| Fixed O&M | \$138,938 | \$146,250 | \$153,563 |
| Land Lease | \$50,305 | \$52,953 | \$55,601 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$330,055 | \$355,661 | \$381,266 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: Keahole Project Code: 52, 53, 54

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 30 | Stage (current/future) | future |
| Resource (kWh/m ²) | 2,225 | Extent (PV module area, m ²) | 229,920 |
| Project Life (years) | 30 | Construction Time (years) | 2 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 77,347 | 67,272 | 57,198 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 76,589 | 66,599 | 56,609 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$12,798,324 | \$13,471,920 | \$14,145,516 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$611,563 | \$764,454 | \$955,568 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$6,011,334 | \$6,679,260 | \$7,347,186 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |

Engineering & Overhead

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$8,867,195 | \$8,867,195 | \$8,867,195 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$1,831,798 | \$1,831,798 | \$1,831,798 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$105,652,849 | \$115,018,940 | \$120,032,378 |
|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$87,917 | \$97,685 | \$107,454 |
| Fixed O&M | \$105,329 | \$110,872 | \$116,416 |
| Land Lease | \$39,834 | \$41,931 | \$44,028 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$233,079 | \$250,488 | \$267,897 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: Keahole Project Code: 595, 596, 597

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,225</u> | Extent (PV module area, m ²) | <u>229,920</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 86,628 | 75,344 | 64,062 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 85,780 | 74,591 | 63,402 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$19,197,486 | \$20,207,880 | \$21,218,274 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$611,563 | \$764,454 | \$955,568 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$6,011,334 | \$6,679,260 | \$7,347,186 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |
| <i>Engineering & Overhead</i> | \$6,881,513 | \$6,881,513 | \$6,881,513 |
| <i>Project Contingency</i> | \$8,867,195 | \$8,867,195 | \$8,867,195 |
| <i>Initial Costs</i> | \$1,831,798 | \$1,831,798 | \$1,831,798 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$112,052,011 | \$121,754,900 | \$127,105,136 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$131,875 | \$146,528 | \$161,180 |
| Fixed O&M | \$131,661 | \$138,590 | \$145,520 |
| Land Lease | \$39,834 | \$41,931 | \$44,028 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$303,370 | \$327,049 | \$350,727 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: North Kohala Project Code: 67, 68, 69

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>15</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,358</u> | Extent (PV module area, m ²) | <u>58,080</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2.5</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 35,565 | 30,932 | 27,848 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 35,216 | 30,623 | 27,561 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$43,740,000 | \$48,600,000 | \$51,030,000 |
| Array Structure & Foundations | \$7,648,146 | \$8,050,680 | \$8,453,214 |
| Power Conditioning Units | \$3,729,375 | \$5,737,500 | \$6,024,375 |
| Electrical & SCADA | \$5,767,179 | \$5,825,434 | \$5,883,688 |
| Substation | \$753,021 | \$792,653 | \$832,286 |
| Overseas Shipping | \$469,965 | \$494,700 | \$519,435 |
| Legal Fees & Permitting | \$571,002 | \$713,752 | \$892,190 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$921,233 | \$1,023,593 | \$1,125,952 |
| Buildings and Fencing | \$160,530 | \$178,367 | \$196,204 |
| <i>Engineering & Overhead</i> | \$5,617,178 | \$5,617,178 | \$5,617,178 |
| <i>Project Contingency</i> | \$6,547,878 | \$6,547,878 | \$6,547,878 |
| <i>Initial Costs</i> | \$1,070,274 | \$1,070,274 | \$1,070,274 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$76,995,781 | \$84,652,009 | \$88,192,673 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | |
|-----------------|-------------|-------------|
| Cost of Upgrade | \$1,500,000 | \$1,500,000 |
|-----------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$49,731 | \$55,257 | \$60,783 |
| Fixed O&M | \$69,469 | \$73,125 | \$76,781 |
| Land Lease | \$72,439 | \$76,252 | \$80,065 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$191,639 | \$204,634 | \$217,629 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: North Kohala Project Code: 610, 611, 612

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>15</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,358</u> | Extent (PV module area, m ²) | <u>58,080</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2.5</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 39,833 | 34,644 | 31,189 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 39,442 | 34,298 | 30,868 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$43,740,000 | \$48,600,000 | \$51,030,000 |
| Array Structure & Foundations | \$11,472,219 | \$12,076,020 | \$12,679,821 |
| Power Conditioning Units | \$3,729,375 | \$5,737,500 | \$6,024,375 |
| Electrical & SCADA | \$5,767,179 | \$5,825,434 | \$5,883,688 |
| Substation | \$753,021 | \$792,653 | \$832,286 |
| Overseas Shipping | \$469,965 | \$494,700 | \$519,435 |
| Legal Fees & Permitting | \$571,002 | \$713,752 | \$892,190 |

General Facilities

| | | | |
|-----------------------|-----------|-------------|-------------|
| Roads and Grading | \$921,233 | \$1,023,593 | \$1,125,952 |
| Buildings and Fencing | \$160,530 | \$178,367 | \$196,204 |

Engineering & Overhead

| | | | |
|--|-------------|-------------|-------------|
| | \$5,617,178 | \$5,617,178 | \$5,617,178 |
|--|-------------|-------------|-------------|

Project Contingency

| | | | |
|--|-------------|-------------|-------------|
| | \$6,547,878 | \$6,547,878 | \$6,547,878 |
|--|-------------|-------------|-------------|

Initial Costs

| | | | |
|--|-------------|-------------|-------------|
| | \$1,070,274 | \$1,070,274 | \$1,070,274 |
|--|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$80,819,854 | \$88,677,349 | \$92,419,280 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$1,500,000 | \$1,500,000 | \$1,500,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

Variable O&M

| | | |
|----------|----------|----------|
| \$74,597 | \$82,886 | \$91,174 |
|----------|----------|----------|

Fixed O&M

| | | |
|----------|----------|----------|
| \$86,836 | \$91,406 | \$95,977 |
|----------|----------|----------|

Land Lease

| | | |
|----------|----------|----------|
| \$72,439 | \$76,252 | \$80,065 |
|----------|----------|----------|

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$233,872 | \$250,544 | \$267,215 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: North Kohala Project Code: 70, 71, 72

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>15</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,358</u> | Extent (PV module area, m ²) | <u>45,984</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 36,855 | 32,055 | 27,255 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 36,494 | 31,734 | 26,974 |

CAPITAL COSTS

Process Capital

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$30,618,000 | \$34,020,000 | \$35,721,000 |
| Array Structure & Foundations | \$5,506,666 | \$5,796,490 | \$6,086,315 |
| Power Conditioning Units | \$1,678,219 | \$2,581,875 | \$2,710,969 |
| Electrical & SCADA | \$4,547,421 | \$4,593,354 | \$4,639,288 |
| Substation | \$753,021 | \$792,653 | \$832,286 |
| Overseas Shipping | \$422,969 | \$445,230 | \$467,492 |
| Legal Fees & Permitting | \$528,459 | \$660,574 | \$825,718 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$736,987 | \$818,874 | \$900,761 |
| Buildings and Fencing | \$148,475 | \$164,972 | \$181,469 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | \$3,715,653 | \$3,715,653 | \$3,715,653 |
| <i>Initial Costs</i> | | | |
| | \$748,471 | \$748,471 | \$748,471 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$53,959,461 | \$58,893,269 | \$61,384,543 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$1,500,000 | \$1,500,000 | \$1,500,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------|------------|----------|--------------|
| Variable O&M | \$46,575 | \$51,750 | \$56,925 |
| Fixed O&M | \$65,830 | \$69,295 | \$72,760 |
| Land Lease | \$57,362 | \$60,381 | \$63,400 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$169,767 | \$181,426 | \$193,085 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: North Kohala Project Code: 613, 614, 615

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>15</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,358</u> | Extent (PV module area, m ²) | <u>45,984</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 41,278 | 35,901 | 30,525 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 40,873 | 35,542 | 30,211 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$30,618,000 | \$34,020,000 | \$35,721,000 |
| Array Structure & Foundations | \$8,259,998 | \$8,694,735 | \$9,129,472 |
| Power Conditioning Units | \$1,678,219 | \$2,581,875 | \$2,710,969 |
| Electrical & SCADA | \$4,547,421 | \$4,593,354 | \$4,639,288 |
| Substation | \$753,021 | \$792,653 | \$832,286 |
| Overseas Shipping | \$422,969 | \$445,230 | \$467,492 |
| Legal Fees & Permitting | \$528,459 | \$660,574 | \$825,718 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$736,987 | \$818,874 | \$900,761 |
| Buildings and Fencing | \$148,475 | \$164,972 | \$181,469 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$3,715,653 | \$3,715,653 | \$3,715,653 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$4,555,122 | \$4,555,122 | \$4,555,122 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$748,471 | \$748,471 | \$748,471 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | | |
|--|---------------------|---------------------|---------------------|
| | \$56,712,794 | \$61,791,514 | \$64,427,700 |
|--|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | | |
|--|-------------|-------------|-------------|
| | \$1,500,000 | \$1,500,000 | \$1,500,000 |
|--|-------------|-------------|-------------|

ANNUAL EXPENSES

Variable O&M

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$69,863 | \$77,625 | \$85,388 |
|--------------|----------|----------|----------|

Fixed O&M

| | | | |
|-----------|----------|----------|----------|
| Fixed O&M | \$82,288 | \$86,619 | \$90,950 |
|-----------|----------|----------|----------|

Land Lease

| | | | |
|------------|----------|----------|----------|
| Land Lease | \$57,362 | \$60,381 | \$63,400 |
|------------|----------|----------|----------|

FIRST YEAR O&M

| | | | |
|--|------------------|------------------|------------------|
| | \$209,512 | \$224,625 | \$239,737 |
|--|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: North Kohala Project Code: 61, 62, 63

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,358</u> | Extent (PV module area, m ²) | <u>19,360</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|--------------|
| Gross Energy (MWh/yr) | 11,855 | 10,311 | 9,283 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 11,739 | 10,208 | 9,187 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$16,200,000 | \$18,000,000 | \$18,900,000 |
| Array Structure & Foundations | \$2,683,560 | \$2,824,800 | \$2,966,040 |
| Power Conditioning Units | \$1,462,500 | \$2,250,000 | \$2,362,500 |
| Electrical & SCADA | \$2,002,493 | \$2,022,720 | \$2,042,947 |
| Substation | \$264,218 | \$278,124 | \$292,030 |
| Overseas Shipping | \$161,500 | \$170,000 | \$178,500 |
| Legal Fees & Permitting | \$483,091 | \$603,864 | \$754,830 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$316,575 | \$351,750 | \$386,925 |
| Buildings and Fencing | \$98,183 | \$109,092 | \$120,001 |
| <i>Engineering & Overhead</i> | \$2,091,961 | \$2,091,961 | \$2,091,961 |
| <i>Project Contingency</i> | \$2,439,696 | \$2,439,696 | \$2,439,696 |
| <i>Initial Costs</i> | \$267,768 | \$267,768 | \$267,768 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$28,471,545 | \$31,409,775 | \$32,803,199 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | |
|-----------------|-----|-----|
| Cost of Upgrade | \$0 | \$0 |
|-----------------|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$16,577 | \$18,419 | \$20,261 |
| Fixed O&M | \$30,875 | \$32,500 | \$34,125 |
| Land Lease | \$23,140 | \$24,358 | \$25,576 |

FIRST YEAR O&M

| | | |
|-----------------|-----------------|-----------------|
| \$70,592 | \$75,277 | \$79,962 |
|-----------------|-----------------|-----------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: North Kohala Project Code: 604, 605, 606

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,358</u> | Extent (PV module area, m ²) | <u>19,360</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 13,278 | 11,548 | 10,397 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 13,148 | 11,433 | 10,290 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$16,200,000 | \$18,000,000 | \$18,900,000 |
| Array Structure & Foundations | \$4,025,340 | \$4,237,200 | \$4,449,060 |
| Power Conditioning Units | \$1,462,500 | \$2,250,000 | \$2,362,500 |
| Electrical & SCADA | \$2,002,493 | \$2,022,720 | \$2,042,947 |
| Substation | \$264,218 | \$278,124 | \$292,030 |
| Overseas Shipping | \$161,500 | \$170,000 | \$178,500 |
| Legal Fees & Permitting | \$483,091 | \$603,864 | \$754,830 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$316,575 | \$351,750 | \$386,925 |
| Buildings and Fencing | \$98,183 | \$109,092 | \$120,001 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$2,091,961 | \$2,091,961 | \$2,091,961 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$2,439,696 | \$2,439,696 | \$2,439,696 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$267,768 | \$267,768 | \$267,768 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | | |
|--|---------------------|---------------------|---------------------|
| | \$29,813,325 | \$32,822,175 | \$34,286,219 |
|--|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$24,866 | \$27,629 | \$30,391 |
| Fixed O&M | \$38,594 | \$40,625 | \$42,656 |
| Land Lease | \$23,140 | \$24,358 | \$25,576 |

FIRST YEAR O&M

| | | | |
|--|-----------------|-----------------|-----------------|
| | \$86,600 | \$92,612 | \$98,624 |
|--|-----------------|-----------------|-----------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: North Kohala Project Code: 64, 65, 66

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,358</u> | Extent (PV module area, m ²) | <u>15,328</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|--------------|
| Gross Energy (MWh/yr) | 12,285 | 10,685 | 9,085 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 12,165 | 10,578 | 8,991 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$11,340,000 | \$12,600,000 | \$13,230,000 |
| Array Structure & Foundations | \$1,932,163 | \$2,033,856 | \$2,135,549 |
| Power Conditioning Units | \$658,125 | \$1,012,500 | \$1,063,125 |
| Electrical & SCADA | \$1,578,966 | \$1,594,915 | \$1,610,864 |
| Substation | \$264,218 | \$278,124 | \$292,030 |
| Overseas Shipping | \$145,350 | \$153,000 | \$160,650 |
| Legal Fees & Permitting | \$467,345 | \$584,181 | \$730,226 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$253,260 | \$281,400 | \$309,540 |
| Buildings and Fencing | \$91,370 | \$101,522 | \$111,674 |
| <i>Engineering & Overhead</i> | \$1,387,500 | \$1,387,500 | \$1,387,500 |
| <i>Project Contingency</i> | \$1,702,295 | \$1,702,295 | \$1,702,295 |
| <i>Initial Costs</i> | \$188,177 | \$188,177 | \$188,177 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$20,008,768 | \$21,917,470 | \$22,921,630 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$15,525 | \$17,250 | \$18,975 |
| Fixed O&M | \$29,258 | \$30,798 | \$32,338 |
| Land Lease | \$18,324 | \$19,288 | \$20,252 |

FIRST YEAR O&M

| | | |
|-----------------|-----------------|-----------------|
| \$63,107 | \$67,336 | \$71,565 |
|-----------------|-----------------|-----------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: North Kohala Project Code: 607, 608, 609

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,358</u> | Extent (PV module area, m ²) | <u>15,328</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 13,759 | 11,967 | 10,175 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 13,624 | 11,847 | 10,070 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$11,340,000 | \$12,600,000 | \$13,230,000 |
| Array Structure & Foundations | \$2,898,245 | \$3,050,784 | \$3,203,323 |
| Power Conditioning Units | \$658,125 | \$1,012,500 | \$1,063,125 |
| Electrical & SCADA | \$1,578,966 | \$1,594,915 | \$1,610,864 |
| Substation | \$264,218 | \$278,124 | \$292,030 |
| Overseas Shipping | \$145,350 | \$153,000 | \$160,650 |
| Legal Fees & Permitting | \$467,345 | \$584,181 | \$730,226 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$253,260 | \$281,400 | \$309,540 |
| Buildings and Fencing | \$91,370 | \$101,522 | \$111,674 |
| <i>Engineering & Overhead</i> | \$1,387,500 | \$1,387,500 | \$1,387,500 |
| <i>Project Contingency</i> | \$1,702,295 | \$1,702,295 | \$1,702,295 |
| <i>Initial Costs</i> | \$188,177 | \$188,177 | \$188,177 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$20,974,850 | \$22,934,398 | \$23,989,405 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | |
|-----------------|-----|-----|
| Cost of Upgrade | \$0 | \$0 |
|-----------------|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$23,288 | \$25,875 | \$28,463 |
| Fixed O&M | \$36,573 | \$38,498 | \$40,422 |
| Land Lease | \$18,324 | \$19,288 | \$20,252 |

FIRST YEAR O&M

| | | |
|-----------------|-----------------|-----------------|
| \$78,184 | \$83,661 | \$89,137 |
|-----------------|-----------------|-----------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: Waikoloa Project Code: 43, 44, 45

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,167</u> | Extent (PV module area, m ²) | <u>484,000</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>4</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|---------------|
| Gross Energy (MWh/yr) | 124,400 | 108,196 | 97,406 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 123,181 | 107,114 | 96,403 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|----------------------|----------------------|----------------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$27,979,875 | \$29,452,500 | \$30,925,125 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$816,176 | \$1,020,220 | \$1,275,275 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$12,259,958 | \$13,622,175 | \$14,984,393 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |
| <i>Engineering & Overhead</i> | \$15,448,655 | \$15,448,655 | \$15,448,655 |
| <i>Project Contingency</i> | \$18,914,020 | \$18,914,020 | \$18,914,020 |
| <i>Initial Costs</i> | \$3,909,145 | \$3,909,145 | \$3,909,145 |
| SUB-TOTAL | \$224,177,178 | \$245,341,045 | \$255,868,423 |

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$152,112 | \$169,013 | \$185,914 |
| Fixed O&M | \$123,500 | \$130,000 | \$136,500 |
| Land Lease | \$251,526 | \$264,764 | \$278,002 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$527,138 | \$563,777 | \$600,417 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: Waikoloa Project Code: 586, 587, 588

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | current |
| Resource (kWh/m ²) | 2,167 | Extent (PV module area, m ²) | 484,000 |
| Project Life (years) | 30 | Construction Time (years) | 4 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------|---------|---------|
| Gross Energy (MWh/yr) | 139,328 | 121,179 | 109,095 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 137,963 | 119,968 | 107,971 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------|---------------|---------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$41,969,813 | \$44,178,750 | \$46,387,688 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$816,176 | \$1,020,220 | \$1,275,275 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$12,259,958 | \$13,622,175 | \$14,984,393 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |
| <i>Engineering & Overhead</i> | \$15,448,655 | \$15,448,655 | \$15,448,655 |
| <i>Project Contingency</i> | \$18,914,020 | \$18,914,020 | \$18,914,020 |
| <i>Initial Costs</i> | \$3,909,145 | \$3,909,145 | \$3,909,145 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$238,167,116 | \$260,067,295 | \$271,330,985 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$228,168 | \$253,520 | \$278,871 |
| Fixed O&M | \$154,375 | \$162,500 | \$170,625 |
| Land Lease | \$251,526 | \$264,764 | \$278,002 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$634,068 | \$680,784 | \$727,499 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: Waikoloa Project Code: 46, 47, 48

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,167</u> | Extent (PV module area, m ²) | <u>383,200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|---------------|
| Gross Energy (MWh/yr) | 128,912 | 112,120 | 95,331 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 127,649 | 110,999 | 94,349 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$20,145,510 | \$21,205,800 | \$22,266,090 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$699,978 | \$874,973 | \$1,093,716 |

General Facilities

| | | | |
|-----------------------|-------------|--------------|--------------|
| Roads and Grading | \$9,807,966 | \$10,897,740 | \$11,987,514 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |

Engineering & Overhead

| | | | |
|------------------------|--------------|--------------|--------------|
| Engineering & Overhead | \$10,249,675 | \$10,249,675 | \$10,249,675 |
|------------------------|--------------|--------------|--------------|

Project Contingency

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$13,282,948 | \$13,282,948 | \$13,282,948 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$2,738,211 | \$2,738,211 | \$2,738,211 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | | |
|------------------|----------------------|----------------------|----------------------|
| SUB-TOTAL | \$158,490,859 | \$172,291,134 | \$179,750,781 |
|------------------|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$142,458 | \$158,287 | \$174,116 |
| Fixed O&M | \$117,032 | \$123,191 | \$129,351 |
| Land Lease | \$199,172 | \$209,655 | \$220,138 |

FIRST YEAR O&M

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$458,662 | \$491,133 | \$523,604 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: Waikoloa Project Code: 589, 590, 591

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,167</u> | Extent (PV module area, m ²) | <u>383,200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|----------------|
| Gross Energy (MWh/yr) | 144,382 | 125,575 | 106,771 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 142,967 | 124,319 | 105,671 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$30,218,265 | \$31,808,700 | \$33,399,135 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$699,978 | \$874,973 | \$1,093,716 |

General Facilities

| | | | |
|-----------------------|-------------|--------------|--------------|
| Roads and Grading | \$9,807,966 | \$10,897,740 | \$11,987,514 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |

Engineering & Overhead

| | | | |
|------------------------|--------------|--------------|--------------|
| Engineering & Overhead | \$10,249,675 | \$10,249,675 | \$10,249,675 |
|------------------------|--------------|--------------|--------------|

Project Contingency

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$13,282,948 | \$13,282,948 | \$13,282,948 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$2,738,211 | \$2,738,211 | \$2,738,211 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | | |
|--|----------------------|----------------------|----------------------|
| | \$168,563,614 | \$182,894,034 | \$190,883,826 |
|--|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$213,687 | \$237,431 | \$261,174 |
| Fixed O&M | \$146,290 | \$153,989 | \$161,689 |
| Land Lease | \$199,172 | \$209,655 | \$220,138 |

FIRST YEAR O&M

| | | | |
|--|------------------|------------------|------------------|
| | \$559,149 | \$601,075 | \$643,000 |
|--|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: Waikoloa Project Code: 37, 38, 39

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,167</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 74,640 | 64,917 | 58,443 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 73,909 | 64,268 | 57,841 |

CAPITAL COSTS

Process Capital

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$17,775,450 | \$18,711,000 | \$19,646,550 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$689,987 | \$862,484 | \$1,078,105 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$7,514,167 | \$8,349,075 | \$9,183,982 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |

Engineering & Overhead

| | | | |
|------------------------|--------------|--------------|--------------|
| Engineering & Overhead | \$10,388,491 | \$10,388,491 | \$10,388,491 |
|------------------------|--------------|--------------|--------------|

Project Contingency

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$12,654,925 | \$12,654,925 | \$12,654,925 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$2,628,562 | \$2,628,562 | \$2,628,562 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | | |
|--|----------------------|----------------------|----------------------|
| | \$149,773,067 | \$164,164,960 | \$171,242,477 |
|--|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------|------------|-----------|--------------|
| Variable O&M | \$91,267 | \$101,408 | \$111,549 |
| Fixed O&M | \$111,150 | \$117,000 | \$122,850 |
| Land Lease | \$150,916 | \$158,859 | \$166,802 |

FIRST YEAR O&M

| | | |
|-----------|-----------|-----------|
| \$353,333 | \$377,267 | \$401,201 |
|-----------|-----------|-----------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: Waikoloa Project Code: 580, 581, 582

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,167</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 83,596 | 72,707 | 65,456 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 82,777 | 71,980 | 64,782 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$26,663,175 | \$28,066,500 | \$29,469,825 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$689,987 | \$862,484 | \$1,078,105 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$7,514,167 | \$8,349,075 | \$9,183,982 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |
| <i>Engineering & Overhead</i> | \$10,388,491 | \$10,388,491 | \$10,388,491 |
| <i>Project Contingency</i> | \$12,654,925 | \$12,654,925 | \$12,654,925 |
| <i>Initial Costs</i> | \$2,628,562 | \$2,628,562 | \$2,628,562 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$158,660,792 | \$173,520,460 | \$181,065,752 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | |
|-----------------|-----|-----|
| Cost of Upgrade | \$0 | \$0 |
|-----------------|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$136,901 | \$152,112 | \$167,323 |
| Fixed O&M | \$138,938 | \$146,250 | \$153,563 |
| Land Lease | \$150,916 | \$158,859 | \$166,802 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$426,754 | \$457,221 | \$487,688 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Hawaii Location: Waikoloa Project Code: 40, 41, 42

| | | | |
|--------------------------------|--------------|------------------------------------------|-----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>· future</u> |
| Resource (kWh/m ²) | <u>2,167</u> | Extent (PV module area, m ²) | <u>229,920</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 77,347 | 67,272 | 57,198 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 76,589 | 66,599 | 56,609 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$12,798,324 | \$13,471,920 | \$14,145,516 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$611,563 | \$764,454 | \$955,568 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$6,011,334 | \$6,679,260 | \$7,347,186 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$6,881,513 | \$6,881,513 | \$6,881,513 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$8,867,195 | \$8,867,195 | \$8,867,195 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$1,838,261 | \$1,838,261 | \$1,838,261 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$105,659,312 | \$115,025,403 | \$120,038,841 |
|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$85,475 | \$94,972 | \$104,469 |
| Fixed O&M | \$105,329 | \$110,872 | \$116,416 |
| Land Lease | \$119,503 | \$125,793 | \$132,083 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$310,307 | \$331,637 | \$352,968 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Hawaii Location: Waikoloa Project Code: 583, 584, 585

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 30 | Stage (current/future) | future |
| Resource (kWh/m ²) | 2,167 | Extent (PV module area, m ²) | 229,920 |
| Project Life (years) | 30 | Construction Time (years) | 2 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 86,628 | 75,344 | 64,062 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 85,780 | 74,591 | 63,402 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$19,197,486 | \$20,207,880 | \$21,218,274 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$611,563 | \$764,454 | \$955,568 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$6,011,334 | \$6,679,260 | \$7,347,186 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |
| <i>Engineering & Overhead</i> | \$6,881,513 | \$6,881,513 | \$6,881,513 |
| <i>Project Contingency</i> | \$8,867,195 | \$8,867,195 | \$8,867,195 |
| <i>Initial Costs</i> | \$1,838,261 | \$1,838,261 | \$1,838,261 |

SUB-TOTAL

| | | |
|---------------|---------------|---------------|
| \$112,058,474 | \$121,761,363 | \$127,111,599 |
|---------------|---------------|---------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$128,212 | \$142,458 | \$156,704 |
| Fixed O&M | \$131,661 | \$138,590 | \$145,520 |
| Land Lease | \$119,503 | \$125,793 | \$132,083 |

FIRST YEAR O&M

| | | |
|-----------|-----------|-----------|
| \$379,376 | \$406,841 | \$434,306 |
|-----------|-----------|-----------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Hawaii Location: Keahole Project Code: 270, 271, 272
 Ownrshp: State

Capacity (MW) 30 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 5.66 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type lava

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 57,101 | 54,382 | 48,944 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 21.3% | 20.3% | 18.3% |
| Net Energy (MWh/yr) | 55,125 | 52,500 | 47,250 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|--------------|--------------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 294 | 310 | 325 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 240 | 266 | 306 |
| Roads, buildings, fence | 34 | 38 | 42 |
| Engineering & Overhead | 101 | 106 | 111 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 14 | 14 | 15 |
| TOTAL CAPITAL COSTS | 3,138 | 3,368 | 3,611 |
| | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 92,645 | 99,429 | 106,606 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 23.21 | 25.79 | 28.37 |
| Variable O&M | cents/kWh | 0.90 | 1.00 | 1.10 |
| Land Lease | \$K | 352 | 391 | 430 |
| FIRST YEAR O&M | \$K | 1,543 | 1,688 | 1,799 |
| Total O&M, cents/kWh | | 2.20 | 2.45 | 2.69 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Hawaii Location: Keahole Project Code: 352, 353, 354
 Ownrshp: State

| | | | |
|---------------------------------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Current</u> |
| Resource (avg NIP, kWh/m ² -day) | <u>5.66</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>lava</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 64,715 | 61,633 | 55,470 |
| Expected Losses (%) | 8.6% | 9.0% | 9.9% |
| Net Energy (MWh/yr) | 58,890 | 56,086 | 50,477 |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------|--------------|--------------|
| <i>Process Capital</i> | | | |
| Power Block | 731 | 769 | 808 |
| Solar Field | 1775 | 1972 | 2169 |
| HTF System | 352 | 371 | 408 |
| BOP | 798 | 886 | 975 |
| Interconnect | 37 | 39 | 41 |
| Overseas Shipping | 432 | 455 | 478 |
| Legal Fees & Permitting | 13 | 15 | 16 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 296 | 329 | 361 |
| Buildings; fence | 97 | 103 | 108 |
| Water supply | 52 | 57 | 63 |
| <i>Engineering & Overhead</i> | 312 | 329 | 345 |
| <i>Project Contingency</i> | 391 | 411 | 432 |
| <i>Initial Costs</i> | 30 | 32 | 34 |
| TOTAL CAPITAL COSTS | 5,316 | 5,767 | 6,237 |
| | \$/kWe, ne | | |
| | \$K | \$K | \$K |
| | 159,479 | 173,018 | 187,113 |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>0</u> |

ANNUAL EXPENSES

| | 1995\$ | | |
|---------------------------|------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 85.81 | 95.34 |
| Variable O&M | cents/kWh | 1.74 | 1.93 |
| Land Lease | \$K | 82 | 92 |
| FIRST YEAR O&M | \$K | 3,679 | 4,034 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Dish Stirling

Island: Hawaii Location: Keahole Project Code: 273, 274, 275
 Ownrshp: State

Capacity (MW) 30 Stage (current/future) Future
 Resource (avg NIP, kWh/m²-day) 5.66 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type lava

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 59,956 | 57,101 | 51,391 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 22.4% | 21.3% | 19.2% |
| Net Energy (MWh/yr) | 57,882 | 55,125 | 49,613 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|-------------------------|---------------|---------------|
| <i>Process Capital</i> | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 279 | 310 | 341 |
| Overseas Shipping | 30 | 33 | 36 |
| Legal Fees & Permitting | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 216 | 240 | 276 |
| Roads, buildings, fence | 34 | 38 | 42 |
| <i>Engineering & Overhead</i> | 86 | 90 | 95 |
| <i>Project Contingency</i> | 189 | 199 | 209 |
| <i>Initial Costs</i> | 10 | 11 | 12 |
| TOTAL CAPITAL COSTS | \$/kWe,net <u>1,917</u> | <u>2,114</u> | <u>2,322</u> |
| | \$K <u>56,598</u> | <u>62,395</u> | <u>68,547</u> |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 13.93 | 15.47 | 17.02 |
| Variable O&M | cents/kWh | 0.72 | 0.80 | 0.88 |
| Land Lease | \$K | 352 | 391 | 430 |
| FIRST YEAR O&M | \$K | <u>1,185</u> | <u>1,295</u> | <u>1,376</u> |
| Total O&M, cents/kWh | | 1.46 | 1.63 | 1.79 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Hawaii Location: Keahole Project Code: 355, 356, 357
 Ownrshp: State

| | | | |
|---------------------------------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Future</u> |
| Resource (avg NIP, kWh/m ² -day) | <u>5.66</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>lava</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 74,422 | 70,878 | 63,790 |
| Expected Losses (%) | 7.7% | 8.1% | 8.9% |
| Net Energy (MWh/yr) | 67,724 | 64,499 | 58,049 |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------|--------------|--------------|
| <i>Process Capital</i> | | | |
| Power Block | 585 | 615 | 646 |
| Solar Field | 1242 | 1381 | 1519 |
| HTF System | 264 | 278 | 306 |
| BOP | 718 | 798 | 877 |
| Interconnect | 33 | 35 | 37 |
| Overseas Shipping | 432 | 455 | 478 |
| Legal Fees & Permitting | 11 | 12 | 13 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 266 | 296 | 325 |
| Buildings; fence | 88 | 92 | 97 |
| Water supply | 52 | 57 | 63 |
| <i>Engineering & Overhead</i> | 266 | 280 | 294 |
| <i>Project Contingency</i> | 293 | 308 | 324 |
| <i>Initial Costs</i> | 21 | 22 | 23 |
| TOTAL CAPITAL COSTS | 4,270 | 4,628 | 5,001 |
| \$/kWe, ne | 128,092 | 138,849 | 150,023 |
| \$K | | | |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>0</u> |

ANNUAL EXPENSES

| | 1995\$ | | | |
|---------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 51.49 | 57.21 | 62.93 |
| Variable O&M | cents/kWh | 1.39 | 1.54 | 1.70 |
| Land Lease | \$K | 82 | 92 | 101 |
| FIRST YEAR O&M | \$K | 2,567 | 2,803 | 2,974 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Dish Stirling

Island: Hawaii Location: N. Kohala Project Code: 282, 283, 284
 Ownrshp: Private

Capacity (MW) 15 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 6.01 Extent (# of units) 600
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type rock

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 30,470 | 29,019 | 26,117 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 22.8% | 21.7% | 19.5% |
| Net Energy (MWh/yr) | 29,416 | 28,015 | 25,213 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|-------------------|-------------------|-------------------|
| <i>Process Capital</i> | | | |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 311 | 327 | 343 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.4 | 0.5 | 0.5 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 115 | 128 | 147 |
| Roads, buildings, fence | 42 | 47 | 51 |
| Engineering & Overhead | 107 | 113 | 118 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 15 | 15 | 16 |
| TOTAL CAPITAL COSTS | 3,046 | 3,264 | 3,488 |
| | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 44,955 | 48,175 | 51,489 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 1.5 1.5 1.5

ANNUAL EXPENSES

1995\$

| | | | | |
|--------------|-----------|-------|-------|-------|
| Fixed O&M | \$/kW-yr | 26.66 | 29.63 | 32.59 |
| Variable O&M | cents/kWh | 1.03 | 1.14 | 1.26 |
| Land Lease | \$K | 135 | 150 | 165 |

FIRST YEAR O&M \$K 838 915 971

Total O&M, cents/kWh 2.44 2.71 2.98

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Hawaii Location: N. Kohala Project Code: 285, 286, 287
 Ownrshp: Private

Capacity (MW) 15 Stage (current/future) Future
 Resource (avg NIP, kWh/m²-day) 6.01 Extent (# of units) 600
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type rock

ENERGY PRODUCTION

Gross Energy (MWh/yr)
 Expected Losses (%)
 Capacity Factor (net)
 Net Energy (MWh/yr)

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------|------------------|------------|--------------|
| Gross Energy (MWh/yr) | 31,993 | 30,470 | 27,423 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 23.9% | 22.8% | 20.5% |
| Net Energy (MWh/yr) | 30,886 | 29,416 | 26,474 |
| CAPITAL COSTS 1995\$ | | | |
| <i>Process Capital</i> | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 294 | 327 | 360 |
| Overseas Shipping | 30 | 33 | 36 |
| Legal Fees & Permitting | 0.4 | 0.4 | 0.5 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 104 | 115 | 133 |
| Roads, buildings, fence | 42 | 47 | 51 |
| Engineering & Overhead | 91 | 96 | 100 |
| Project Contingency | 189 | 199 | 209 |
| <i>Initial Costs</i> | | | |
| TOTAL CAPITAL COSTS | \$/kWe,net 1,835 | 2,022 | 2,214 |
| | \$K 27,081 | 29,839 | 32,682 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 1.5 1.5 1.5

ANNUAL EXPENSES 1995\$

Fixed O&M \$/kW-yr 16.00 17.78 19.55
 Variable O&M cents/kWh 0.82 0.92 1.01
 Land Lease \$K 135 150 165
 FIRST YEAR O&M \$K 629 686 725
 Total O&M, cents/kWh 1.63 1.81 1.99

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Dish Stirling

Island: Hawaii Location: N. Kohala Project Code: 276, 277, 278
 Ownrshp: Private

| | | | |
|--------------------------------|-------------|---------------------------|------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | |
| Resource (avg NIP, kWh/m2-day) | <u>6.01</u> | Extent (# of units) | <u>200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>rock</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 10,259 | 9,771 | 8,794 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 23.0% | 21.9% | 19.7% |
| Net Energy (MWh/yr) | 9,904 | 9,433 | 8,489 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|--------------|--------------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 327 | 344 | 361 |
| Overseas Shipping | 41 | 43 | 45 |
| Legal Fees & Permitting | 0.9 | 0.9 | 1.0 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 136 | 151 | 174 |
| Roads, buildings, fence | 59 | 65 | 72 |
| Engineering & Overhead | 126 | 132 | 139 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 18 | 19 | 20 |
| TOTAL CAPITAL COSTS | 3,123 | 3,348 | 3,579 |
| | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | \$K | \$K | \$K |
| | 15,366 | 16,470 | 17,611 |

TRANSMISSION

| | | | |
|----------------------|----------|------------------|----------|
| Size (kV) | <u>—</u> | Distance (Miles) | <u>—</u> |
| Cost of Upgrade, \$M | | | <u>0</u> |

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------|----------------------|------------|------------|------------|
| Fixed O&M | \$/kW-yr | 33.22 | 36.91 | 40.60 |
| Variable O&M | cents/kWh | 1.28 | 1.43 | 1.57 |
| Land Lease | \$K | 45 | 50 | 55 |
| FIRST YEAR O&M | \$K | 338 | 369 | 391 |
| | | 3.02 | 3.35 | 3.69 |
| | Total O&M, cents/kWh | | | |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Hawaii Location: N. Kohala Project Code: 279, 280, 281
 Ownrshp: Private

Capacity (MW) 5 Stage (current/future) Future
 Resource (avg NIP, kWh/m2-day) 6.01 Extent (# of units) 200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type rock

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 10,772 | 10,259 | 9,233 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 24.1% | 23.0% | 20.7% |
| Net Energy (MWh/yr) | 10,399 | 9,904 | 8,914 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|------------|------------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 310 | 344 | 379 |
| Overseas Shipping | 31 | 35 | 38 |
| Legal Fees & Permitting | 0.7 | 0.8 | 0.9 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 122 | 136 | 156 |
| Roads, buildings, fence | 59 | 65 | 72 |
| Engineering & Overhead | 107 | 113 | 118 |
| Project Contingency | 189 | 199 | 209 |
| Initial Costs | 13 | 14 | 15 |
| TOTAL CAPITAL COSTS | | | |
| | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 1,905 | 2,099 | 2,299 |
| | \$K | \$K | \$K |
| | 9,373 | 10,326 | 11,312 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|-------------|-------------|-------------|
| Fixed O&M | \$/kW-yr | 19.93 | 22.14 | 24.36 |
| Variable O&M | cents/kWh | 1.03 | 1.14 | 1.26 |
| Land Lease | \$K | 45 | 50 | 55 |
| FIRST YEAR O&M | \$K | 251 | 274 | 289 |
| Total O&M, cents/kWh | | 2.02 | 2.24 | 2.47 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Hawaii Location: Waikoloa Project Code: 264, 265, 266
 Ownrshp: Private

Capacity (MW) 30 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 5.51 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type lava

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 55,598 | 52,950 | 47,655 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 20.8% | 19.8% | 17.8% |
| Net Energy (MWh/yr) | 53,674 | 51,118 | 46,006 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|--------------|--------------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 294 | 310 | 325 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 240 | 266 | 306 |
| Roads, buildings, fence | 34 | 38 | 42 |
| Engineering & Overhead | 101 | 106 | 111 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 23 | 24 | 26 |
| TOTAL CAPITAL COSTS | 3,148 | 3,378 | 3,622 |
| | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 92,930 | 99,729 | 106,922 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 23.21 | 25.79 | 28.37 |
| Variable O&M | cents/kWh | 0.90 | 1.00 | 1.10 |
| Land Lease | \$K | 1,445 | 1,605 | 1,766 |
| FIRST YEAR O&M | \$K | 2,622 | 2,888 | 3,121 |
| Total O&M, cents/kWh | | 2.24 | 2.49 | 2.73 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Solar Thermal

Island: Hawaii Location: Waikoloa Project Code: 346, 347, 348
 Ownrshp: Private

| | | | |
|--------------------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Current</u> |
| Resource (avg NIP, kWh/m2-day) | <u>5.51</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>lava</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 63,011 | 60,011 | 54,009 |
| Expected Losses (%) | 8.6% | 9.0% | 9.9% |
| Net Energy (MWh/yr) | 57,340 | 54,610 | 49,149 |

CAPITAL COSTS

1995\$ -- \$/kWnet

Process Capital

| | | | |
|-------------------------|------|------|------|
| Power Block | 731 | 769 | 808 |
| Solar Field | 1775 | 1972 | 2169 |
| HTF System | 352 | 371 | 408 |
| BOP | 798 | 886 | 975 |
| Interconnect | 37 | 39 | 41 |
| Overseas Shipping | 432 | 455 | 478 |
| Legal Fees & Permitting | 13 | 15 | 16 |

General Facilities

| | | | |
|-----------------------------------|-----|-----|-----|
| Roads & Grading | 296 | 329 | 361 |
| Buildings; fence | 97 | 103 | 108 |
| Water supply | 52 | 57 | 63 |
| <i>Engineering & Overhead</i> | 312 | 329 | 345 |
| <i>Project Contingency</i> | 391 | 411 | 432 |
| <i>Initial Costs</i> | 30 | 32 | 34 |

TOTAL CAPITAL COSTS

| | | | |
|-----------|---------|---------|---------|
| \$/kWe,ne | 5,316 | 5,767 | 6,237 |
| \$K | 159,479 | 173,018 | 187,113 |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>0</u> |

ANNUAL EXPENSES

| | | | | |
|---------------------------|--------------------|--------------|--------------|--------------|
| Fixed O&M | 1995\$ \$/kW-yr | 85.81 | 95.34 | 104.88 |
| Variable O&M | cents/kWh | 1.74 | 1.93 | 2.12 |
| Land Lease | \$K | 338 | 376 | 414 |
| FIRST YEAR O&M | \$K | <u>3,908</u> | <u>4,290</u> | <u>4,603</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Hawaii Location: Waikoloa Project Code: 267, 268, 269
 Ownrshp: Private

Capacity (MW) 30 Stage (current/future) Future
 Resource (avg NIP, kWh/m2-day) 5.51 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type lava

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 58,378 | 55,598 | 50,038 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 21.8% | 20.8% | 18.7% |
| Net Energy (MWh/yr) | 56,358 | 53,674 | 48,307 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|------------------|----------------|----------------|
| <i>Process Capital</i> | | | |
| Support Structure | \$/kWe,net 391 | \$/kWe,Oet 435 | \$/kWe,net 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 279 | 310 | 341 |
| Overseas Shipping | 30 | 33 | 36 |
| Legal Fees & Permitting | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 216 | 240 | 276 |
| Roads, buildings, fence | 34 | 38 | 42 |
| Engineering & Overhead | 86 | 90 | 95 |
| Project Contingency | 189 | 199 | 209 |
| Initial Costs | 20 | 21 | 22 |
| TOTAL CAPITAL COSTS | \$/kWe,net 1,927 | 2,124 | 2,333 |
| | \$K 56,884 | 62,696 | 68,862 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|-----------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 13.93 | 15.47 | 17.02 |
| Variable O&M | cents/kWh | 0.72 | 0.80 | 0.88 |
| Land Lease | \$K | 1,445 | 1,605 | 1,766 |
| FIRST YEAR O&M | \$K | <u>2,267</u> | <u>2,497</u> | <u>2,700</u> |
| Total O&M, cents/kWh | | 1.48 | 1.65 | 1.81 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Hawaii Location: Waikoloa Project Code: 349, 350, 351
 Ownrshp: Private

| | | | |
|--------------------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Future</u> |
| Resource (avg NIP, kWh/m2-day) | <u>5.51</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>lava</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 72,463 | 69,012 | 62,111 |
| Expected Losses (%) | 7.7% | 8.1% | 8.9% |
| Net Energy (MWh/yr) | 65,941 | 62,801 | 56,521 |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------|--------------|--------------|
| <i>Process Capital</i> | | | |
| Power Block | 585 | 615 | 646 |
| Solar Field | 1242 | 1381 | 1519 |
| HTF System | 264 | 278 | 306 |
| BOP | 718 | 798 | 877 |
| Interconnect | 33 | 35 | 37 |
| Overseas Shipping | 432 | 455 | 478 |
| Legal Fees & Permitting | 11 | 12 | 13 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 266 | 296 | 325 |
| Buildings; fence | 88 | 92 | 97 |
| Water supply | 52 | 57 | 63 |
| <i>Engineering & Overhead</i> | 266 | 280 | 294 |
| <i>Project Contingency</i> | 293 | 308 | 324 |
| <i>Initial Costs</i> | 21 | 22 | 23 |
| TOTAL CAPITAL COSTS | 4,270 | 4,628 | 5,001 |
| \$/kWe, ne | 128,092 | 138,849 | 150,023 |
| \$K | | | |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>0</u> |

ANNUAL EXPENSES

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 51.49 | 57.21 | 62.93 |
| Variable O&M | cents/kWh | 1.39 | 1.54 | 1.70 |
| Land Lease | \$K | 338 | 376 | 414 |
| FIRST YEAR O&M | \$K | 2,799 | 3,061 | 3,261 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Hawaii Location Honokaa 2A Project Code 697,698,699

| | | | |
|-----------------------|------|---------------------------|----------|
| Project size (MWe) | 10 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 12.9 | Extent (no. x dia. buoys) | 60 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 108,467 | 108,467 | 108,467 |
| Wave energy absorption efficiency | 54% | 44% | 22% |
| Absorbed energy (MWh/yr) | 58,451 | 47,726 | 23,863 |
| Conversion & sea-to-shore transmission efficiency | 76% | 78% | 81% |
| Landed energy at 100% availability (MWh/yr) | 44,352 | 37,347 | 19,294 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 42,134 | 33,612 | 15,435 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 7,080,000 | 10,620,000 | 14,160,000 |
| Pelton turbine/generator | 2,937,000 | 2,937,000 | 2,937,000 |
| Balance of mechanical & electrical plant | 1,119,000 | 1,119,000 | 1,119,000 |
| Mooring hardware | 1,493,000 | 1,493,000 | 1,493,000 |
| Deployment | 1,161,000 | 1,741,000 | 2,322,000 |
| Sea-to-shore transmission | 1,378,000 | 1,378,000 | 1,378,000 |
| Onshore substation | 529,000 | 529,000 | 529,000 |
| Legal fees and permitting | 630,000 | 640,000 | 650,000 |
| <i>Process Capital Sub-Total</i> | 16,327,000 | 20,457,000 | 24,588,000 |
| <i>General Facilities</i> | 816,000 | 2,046,000 | 3,688,000 |
| <i>Engineering & Overhead</i> | 1,633,000 | 2,046,000 | 2,459,000 |
| <i>Project Contingency</i> | 1,878,000 | 2,455,000 | 3,074,000 |
| <i>Initial Costs</i> | 455,000 | 638,000 | 869,000 |
| TOTAL PLANT COST | 21,108,000 | 27,642,000 | 34,678,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|----------------|------------------|------------------|
| Ongoing fixed O&M costs | 327,000 | 818,000 | 1,475,000 |
| Amortized periodic replacements | 175,000 | 356,000 | 842,000 |
| FIRST YEAR O&M COST | 501,000 | 1,174,000 | 2,317,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Hawaii Location North Kohala Project Code 694,695,696

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 11.0 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 276,814 | 276,814 | 276,814 |
| Wave energy absorption efficiency | 57% | 47% | 24% |
| Absorbed energy (MWh/yr) | 158,555 | 130,194 | 65,097 |
| Conversion & sea-to-shore transmission efficiency | 78% | 79% | 81% |
| Landed energy at 100% availability (MWh/yr) | 124,059 | 103,426 | 52,596 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 117,856 | 93,084 | 42,077 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 2,973,000 | 2,973,000 | 2,973,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 696,000 | 723,000 | 749,000 |
| <i>Process Capital Sub-Total</i> | 42,984,000 | 53,551,000 | 64,117,000 |
| <i>General Facilities</i> | 2,149,000 | 5,355,000 | 9,618,000 |
| <i>Engineering & Overhead</i> | 4,298,000 | 5,355,000 | 6,412,000 |
| <i>Project Contingency</i> | 4,943,000 | 6,426,000 | 8,015,000 |
| <i>Initial Costs</i> | 1,201,000 | 1,677,000 | 2,282,000 |
| TOTAL PLANT COST | 55,576,000 | 72,363,000 | 90,443,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 4,000,000 | 4,000,000 | 4,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 860,000 | 2,142,000 | 3,847,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,362,000 | 3,156,000 | 6,226,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Hawaii Location North Kohala Project Code 691,692,693

| | | | |
|-----------------------|------|---------------------------|----------|
| Project size (MWe) | 10 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 11.0 | Extent (no. x dia. buoys) | 60 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 92,271 | 92,271 | 92,271 |
| Wave energy absorption efficiency | 57% | 47% | 24% |
| Absorbed energy (MWh/yr) | 52,852 | 43,398 | 21,699 |
| Conversion & sea-to-shore transmission efficiency | 78% | 79% | 81% |
| Landed energy at 100% availability (MWh/yr) | 41,343 | 34,468 | 17,530 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 39,276 | 31,021 | 14,024 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 7,080,000 | 10,620,000 | 14,160,000 |
| Pelton turbine/generator | 2,937,000 | 2,937,000 | 2,937,000 |
| Balance of mechanical & electrical plant | 1,119,000 | 1,119,000 | 1,119,000 |
| Mooring hardware | 1,493,000 | 1,493,000 | 1,493,000 |
| Deployment | 1,161,000 | 1,741,000 | 2,322,000 |
| Sea-to-shore transmission | 1,513,000 | 1,513,000 | 1,513,000 |
| Onshore substation | 529,000 | 529,000 | 529,000 |
| Legal fees and permitting | 630,000 | 640,000 | 651,000 |
| <i>Process Capital Sub-Total</i> | 16,462,000 | 20,593,000 | 24,724,000 |
| <i>General Facilities</i> | 823,000 | 2,059,000 | 3,709,000 |
| <i>Engineering & Overhead</i> | 1,646,000 | 2,059,000 | 2,472,000 |
| <i>Project Contingency</i> | 1,893,000 | 2,471,000 | 3,090,000 |
| <i>Initial Costs</i> | 458,000 | 642,000 | 874,000 |
| TOTAL PLANT COST | 21,283,000 | 27,824,000 | 34,869,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 1,500,000 | 1,500,000 | 1,500,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|----------------|------------------|------------------|
| Ongoing fixed O&M costs | 329,000 | 824,000 | 1,483,000 |
| Amortized periodic replacements | 175,000 | 356,000 | 842,000 |
| FIRST YEAR O&M COST | 504,000 | 1,180,000 | 2,325,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Hawaii Location Pepeekeo 2E Project Code 700,701,702

| | | | |
|-----------------------|------|---------------------------|----------|
| Project size (MWe) | 10 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 11.3 | Extent (no. x dia. buoys) | 60 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 95,445 | 95,445 | 95,445 |
| Wave energy absorption efficiency | 58% | 48% | 24% |
| Absorbed energy (MWh/yr) | 55,279 | 45,441 | 22,720 |
| Conversion & sea-to-shore transmission efficiency | 78% | 79% | 81% |
| Landed energy at 100% availability (MWh/yr) | 43,124 | 35,988 | 18,363 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 40,968 | 32,389 | 14,691 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 7,080,000 | 10,620,000 | 14,160,000 |
| Pelton turbine/generator | 2,937,000 | 2,937,000 | 2,937,000 |
| Balance of mechanical & electrical plant | 1,119,000 | 1,119,000 | 1,119,000 |
| Mooring hardware | 1,493,000 | 1,493,000 | 1,493,000 |
| Deployment | 1,161,000 | 1,741,000 | 2,322,000 |
| Sea-to-shore transmission | 1,445,000 | 1,445,000 | 1,445,000 |
| Onshore substation | 529,000 | 529,000 | 529,000 |
| Legal fees and permitting | 630,000 | 640,000 | 651,000 |
| <i>Process Capital Sub-Total</i> | 16,394,000 | 20,525,000 | 24,656,000 |
| <i>General Facilities</i> | 820,000 | 2,053,000 | 3,698,000 |
| <i>Engineering & Overhead</i> | 1,639,000 | 2,053,000 | 2,466,000 |
| <i>Project Contingency</i> | 1,885,000 | 2,463,000 | 3,082,000 |
| <i>Initial Costs</i> | 457,000 | 640,000 | 871,000 |
| TOTAL PLANT COST | 21,196,000 | 27,733,000 | 34,773,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|----------------|------------------|------------------|
| Ongoing fixed O&M costs | 328,000 | 821,000 | 1,479,000 |
| Amortized periodic replacements | 175,000 | 356,000 | 842,000 |
| FIRST YEAR O&M COST | 503,000 | 1,177,000 | 2,321,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Kahua Ranch Project Code: 406,407,408
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>15</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>60</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 45,988 | 41,807 | 37,626 |
| Expected Losses (%) | 22% | 27% | 32% |
| Net Energy (MWh/yr) | <u>35,735</u> | <u>30,396</u> | <u>25,475</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|------------|
| Turbines & Towers | 8,394,435 | 9,327,150 | 10,259,865 |
| Foundations | 586,278 | 592,200 | 598,122 |
| Assembly & Checkout | 387,630 | 391,545 | 395,460 |
| Electrical Infrastructure | 1,287,853 | 1,300,862 | 1,313,870 |
| Sub-Station | 826,028 | 834,372 | 842,716 |
| Overseas Shipping | 290,021 | 292,950 | 295,880 |
| Legal Fees & Permitting | 258,677 | 323,347 | 404,183 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 114,345 | 115,500 | 116,655 |
| Control System | 132,100 | 133,434 | 134,768 |
| Control Buildings | 55,484 | 56,045 | 56,605 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 1,241,797 | 1,346,198 | 1,453,635 |
| <i>Project Contingency</i> | 1,365,977 | 1,480,818 | 1,598,998 |
| <i>Initial Costs</i> | 674,838 | 699,925 | 734,331 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$15,700,583</u> | <u>\$16,988,925</u> | <u>\$18,323,312</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$1,500,000</u> | <u>\$1,500,000</u> | <u>\$1,500,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|----------------|------------------|------------------|------------------|
| Variable O&M | 206,371 | 159,580 | 147,120 |
| Fixed O&M | 206,211 | 208,294 | 210,377 |
| Land Lease | 127,121 | 133,812 | 140,503 |
| FIRST YEAR O&M | <u>\$539,703</u> | <u>\$501,686</u> | <u>\$497,999</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Kahua Ranch Project Code: 409,410,411
(leave blank)
 Capacity (MW) 15 Stage (current/future) Future
 Resource (mph, avg.) 15.7 Extent (# of units) 50
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 57,523 | 52,293 | 47,064 |
| Expected Losses (%) | 22% | 27% | 32% |
| Net Energy (MWh/yr) | <u>44,699</u> | <u>38,021</u> | <u>31,865</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 7,422,080 | 8,246,755 | 9,483,768 |
| Foundations | 478,794 | 483,630 | 488,466 |
| Assembly & Checkout | 319,794 | 323,025 | 326,255 |
| Electrical Infrastructure | 1,268,405 | 1,281,217 | 1,294,030 |
| Sub-Station | 826,028 | 834,372 | 842,716 |
| Overseas Shipping | 241,684 | 244,125 | 246,566 |
| Legal Fees & Permitting | 255,921 | 319,902 | 399,877 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 95,634 | 96,600 | 97,566 |
| Control System | 108,982 | 110,083 | 111,184 |
| Control Buildings | 45,775 | 46,237 | 46,699 |
| Central Building | 85,121 | 94,579 | 118,223 |

Engineering & Overhead 1,114,822 1,208,052 1,345,535

Project Contingency 1,226,304 1,328,858 1,480,089

Initial Costs 655,625 674,337 718,403

SUB-TOTAL \$14,144,969 \$15,291,772 \$16,999,377

TRANSMISSION

Cost of Upgrade \$1,500,000 \$1,500,000 \$1,500,000

ANNUAL EXPENSES

Variable O&M 252,973 195,616 180,342

Fixed O&M 202,087 204,128 206,169

Land Lease 131,670 138,600 145,530

FIRST YEAR O&M \$586,729 \$538,344 \$532,041

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Kahua Ranch Project Code: 400,401,402
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>20</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 15,329 | 13,936 | 12,542 |
| Expected Losses (%) | 20% | 25% | 30% |
| Net Energy (MWh/yr) | <u>12,334</u> | <u>10,516</u> | <u>8,838</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 2,938,052 | 3,264,503 | 3,590,953 |
| Foundations | 195,426 | 197,400 | 199,374 |
| Assembly & Checkout | 129,210 | 130,515 | 131,820 |
| Electrical Infrastructure | 429,284 | 433,621 | 437,957 |
| Sub-Station | 275,343 | 278,124 | 280,905 |
| Overseas Shipping | 96,674 | 97,650 | 98,627 |
| Legal Fees & Permitting | 241,435 | 301,794 | 377,242 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 39,501 | 39,900 | 40,299 |
| Control System | 44,033 | 44,478 | 44,923 |
| Control Buildings | 18,495 | 18,682 | 18,868 |
| Central Building | 11,349 | 12,611 | 15,763 |

Engineering & Overhead

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 441,880 | 481,928 | 523,673 |
| <i>Project Contingency</i> | 486,068 | 530,120 | 576,040 |
| <i>Initial Costs</i> | 337,353 | 347,035 | 360,090 |

| | | | |
|------------------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$5,684,104</u> | <u>\$6,178,359</u> | <u>\$6,696,534</u> |
|------------------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|--------|--------|--------|
| Variable O&M | 71,231 | 55,210 | 51,037 |
| Fixed O&M | 68,737 | 69,431 | 70,126 |
| Land Lease | 42,374 | 44,604 | 46,834 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$182,342</u> | <u>\$169,246</u> | <u>\$167,997</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Kahua Ranch Project Code: 403404,405
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>16</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 18,407 | 16,734 | 15,061 |
| Expected Losses (%) | 20% | 25% | 30% |
| Net Energy (MWh/yr) | <u>14,811</u> | <u>12,628</u> | <u>10,612</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 2,493,819 | 2,770,910 | 3,186,546 |
| Foundations | 153,214 | 154,762 | 156,309 |
| Assembly & Checkout | 102,334 | 103,368 | 104,402 |
| Electrical Infrastructure | 405,890 | 409,990 | 414,089 |
| Sub-Station | 275,343 | 278,124 | 280,905 |
| Overseas Shipping | 77,339 | 78,120 | 78,901 |
| Legal Fees & Permitting | 240,180 | 300,226 | 375,282 |

General Facilities

| | | | |
|-----------------------------------|---------|---------|---------|
| Roads & Grading | 32,017 | 32,340 | 32,663 |
| Control System | 34,874 | 35,227 | 35,579 |
| Control Buildings | 14,648 | 14,796 | 14,944 |
| Central Building | 11,349 | 12,611 | 15,763 |
| <i>Engineering & Overhead</i> | 384,101 | 419,047 | 469,538 |
| <i>Project Contingency</i> | 422,511 | 460,952 | 516,492 |
| <i>Initial Costs</i> | 331,156 | 338,395 | 354,267 |

| | | | |
|-----------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$4,978,774</u> | <u>\$5,408,865</u> | <u>\$6,035,682</u> |
|-----------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|----------------|------------------|------------------|------------------|
| Variable O&M | 83,823 | 64,971 | 60,059 |
| Fixed O&M | 67,362 | 68,043 | 68,723 |
| Land Lease | 42,134 | 44,352 | 46,570 |
| FIRST YEAR O&M | <u>\$193,320</u> | <u>\$177,365</u> | <u>\$175,352</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Lalamilo Wells Project Code: 424, 425, 426
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>21.1</u> | Extent (# of units) | <u>200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|----------------|----------------|----------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 235,700 | 214,272 | 192,845 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>181,386</u> | <u>154,183</u> | <u>129,123</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 27,421,821 | 30,468,690 | 33,515,559 |
| Foundations | 1,954,260 | 1,974,000 | 1,993,740 |
| Assembly & Checkout | 1,292,099 | 1,305,150 | 1,318,202 |
| Electrical Infrastructure | 4,292,844 | 4,336,206 | 4,379,568 |
| Sub-Station | 2,753,428 | 2,781,240 | 2,809,052 |
| Overseas Shipping | 966,735 | 976,500 | 986,265 |
| Legal Fees & Permitting | 318,296 | 397,870 | 497,338 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 376,299 | 380,100 | 383,901 |
| Control System | 440,332 | 444,780 | 449,228 |
| Control Buildings | 184,948 | 186,816 | 188,684 |
| Central Building | 85,121 | 94,579 | 118,223 |

Engineering & Overhead 4,008,618 4,334,593 4,663,976

Project Contingency 4,409,480 4,768,052 5,130,374

Initial Costs 1,868,787 1,922,224 2,020,053

SUB-TOTAL \$50,373,067 \$54,370,801 \$58,454,163

TRANSMISSION

Cost of Upgrade \$2,000,000 \$2,000,000 \$2,000,000

ANNUAL EXPENSES

Variable O&M 1,047,507 809,462 745,683

Fixed O&M 687,369 694,313 701,256

Land Lease 141,246 148,680 156,114

FIRST YEAR O&M \$1,876,122 \$1,652,454 \$1,603,053

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Lalamilo Wells Project Code: 427,428,429
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>21.1</u> | Extent (# of units) | <u>166</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|----------------|----------------|----------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 293,642 | 266,947 | 240,252 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>225,977</u> | <u>192,086</u> | <u>160,865</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 24,148,478 | 26,831,642 | 30,856,389 |
| Foundations | 1,589,595 | 1,605,652 | 1,621,708 |
| Assembly & Checkout | 1,061,717 | 1,072,442 | 1,083,166 |
| Electrical Infrastructure | 4,211,105 | 4,253,642 | 4,296,178 |
| Sub-Station | 2,753,428 | 2,781,240 | 2,809,052 |
| Overseas Shipping | 802,390 | 810,495 | 818,600 |
| Legal Fees & Permitting | 308,969 | 386,211 | 482,764 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 312,682 | 315,840 | 318,998 |
| Control System | 361,821 | 365,476 | 369,130 |
| Control Buildings | 151,972 | 153,507 | 155,042 |
| Central Building | 85,121 | 94,579 | 118,223 |

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & Overhead</i> | 3,578,728 | 3,867,072 | 4,292,925 |
|-----------------------------------|-----------|-----------|-----------|

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project Contingency</i> | 3,936,601 | 4,253,780 | 4,722,218 |
|----------------------------|-----------|-----------|-----------|

| | | | |
|----------------------|-----------|-----------|-----------|
| <i>Initial Costs</i> | 1,797,035 | 1,824,606 | 1,952,061 |
|----------------------|-----------|-----------|-----------|

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$45,099,641</u> | <u>\$48,616,184</u> | <u>\$53,896,456</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$2,000,000</u> | <u>\$2,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|---------|---------|
| Variable O&M | 1,278,915 | 988,283 | 910,414 |
|--------------|-----------|---------|---------|

| | | | |
|-----------|---------|---------|---------|
| Fixed O&M | 673,622 | 680,426 | 687,231 |
|-----------|---------|---------|---------|

| | | | |
|------------|---------|---------|---------|
| Land Lease | 145,715 | 153,384 | 161,053 |
|------------|---------|---------|---------|

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| FIRST YEAR O&M | <u>\$2,098,252</u> | <u>\$1,822,093</u> | <u>\$1,758,698</u> |
|---------------------------|--------------------|--------------------|--------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Lalamilo Wells Project Code: 418,419,420
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>21.1</u> | Extent (# of units) | <u>120</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|----------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 141,420 | 128,563 | 115,707 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>108,832</u> | <u>92,510</u> | <u>77,474</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 16,788,870 | 18,654,300 | 20,519,730 |
| Foundations | 1,172,556 | 1,184,400 | 1,196,244 |
| Assembly & Checkout | 775,259 | 783,090 | 790,921 |
| Electrical Infrastructure | 2,575,706 | 2,601,724 | 2,627,741 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 580,041 | 585,900 | 591,759 |
| Legal Fees & Permitting | 284,761 | 355,951 | 444,939 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 226,611 | 228,900 | 231,189 |
| Control System | 264,199 | 266,868 | 269,537 |
| Control Buildings | 110,969 | 112,090 | 113,210 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 2,451,615 | 2,653,655 | 2,858,893 |
| <i>Project Contingency</i> | 2,696,777 | 2,919,020 | 3,144,782 |
| <i>Initial Costs</i> | 1,198,050 | 1,232,048 | 1,292,960 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$30,862,592</u> | <u>\$33,341,268</u> | <u>\$35,885,559</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$2,000,000</u> | <u>\$2,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 628,504 | 485,677 | 447,410 |
| Fixed O&M | 412,422 | 416,588 | 420,753 |
| Land Lease | 84,748 | 89,208 | 93,668 |

| | | | |
|----------------|--------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$1,125,673</u> | <u>\$991,472</u> | <u>\$961,832</u> |
|----------------|--------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Lalamilo Wells Project Code: 421,422,423
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>21.1</u> | Extent (# of units) | <u>100</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 176,893 | 160,811 | 144,730 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>136,131</u> | <u>115,714</u> | <u>96,907</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 14,844,159 | 16,493,510 | 18,967,537 |
| Foundations | 957,587 | 967,260 | 976,933 |
| Assembly & Checkout | 639,589 | 646,049 | 652,510 |
| Electrical Infrastructure | 2,536,810 | 2,562,435 | 2,588,059 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 483,368 | 488,250 | 493,133 |
| Legal Fees & Permitting | 279,249 | 349,061 | 436,327 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 189,189 | 191,100 | 193,011 |
| Control System | 217,964 | 220,166 | 222,368 |
| Control Buildings | 91,549 | 92,474 | 93,399 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 2,197,664 | 2,377,363 | 2,642,693 |
| <i>Project Contingency</i> | 2,417,431 | 2,615,099 | 2,906,962 |
| <i>Initial Costs</i> | 1,160,807 | 1,179,194 | 1,258,592 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$27,752,545</u> | <u>\$29,945,284</u> | <u>\$33,235,177</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$2,000,000</u> | <u>\$2,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 770,431 | 595,351 | 548,442 |
| Fixed O&M | 404,173 | 408,256 | 412,338 |
| Land Lease | 87,780 | 92,400 | 97,020 |

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| FIRST YEAR O&M | <u>\$1,262,384</u> | <u>\$1,096,007</u> | <u>\$1,057,801</u> |
|---------------------------|--------------------|--------------------|--------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Lalamilo Wells Project Code: 412,413,414
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>3</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>21.1</u> | Extent (# of units) | <u>12</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 14,142 | 12,856 | 11,571 |
| Expected Losses (%) | 14% | 19% | 24% |
| Net Energy (MWh/yr) | <u>12,109</u> | <u>10,366</u> | <u>8,750</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 1,762,831 | 1,958,702 | 2,154,572 |
| Foundations | 117,256 | 118,440 | 119,624 |
| Assembly & Checkout | 77,526 | 78,309 | 79,092 |
| Electrical Infrastructure | 257,571 | 260,172 | 262,774 |
| Sub-Station | 165,206 | 166,874 | 168,543 |
| Overseas Shipping | 58,004 | 58,590 | 59,176 |
| Legal Fees & Permitting | 237,833 | 297,291 | 371,614 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 24,532 | 24,780 | 25,028 |
| Control System | 26,420 | 26,687 | 26,954 |
| Control Buildings | 11,097 | 11,209 | 11,321 |
| Central Building | 11,349 | 12,611 | 15,763 |

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 274,962 | 301,366 | 329,446 |
| <i>Project Contingency</i> | 302,459 | 331,503 | 362,391 |
| <i>Initial Costs</i> | 269,534 | 274,220 | 282,218 |

| | | | |
|------------------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$3,596,579</u> | <u>\$3,920,754</u> | <u>\$4,268,516</u> |
|------------------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|--------|--------|--------|
| Variable O&M | 69,931 | 54,419 | 50,534 |
| Fixed O&M | 41,242 | 41,659 | 42,075 |
| Land Lease | 8,475 | 8,921 | 9,367 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$119,648</u> | <u>\$104,999</u> | <u>\$101,976</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT . . .
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location Lalamilo Wells Project Code: 415,416,417
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>3</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>21.1</u> | Extent (# of units) | <u>10</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 17,689 | 16,081 | 14,473 |
| Expected Losses (%) | 14% | 19% | 24% |
| Net Energy (MWh/yr) | <u>15,147</u> | <u>12,966</u> | <u>10,945</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 1,558,637 | 1,731,819 | 1,991,591 |
| Foundations | 95,759 | 96,726 | 97,693 |
| Assembly & Checkout | 63,959 | 64,605 | 65,251 |
| Electrical Infrastructure | 253,681 | 256,243 | 258,806 |
| Sub-Station | 165,206 | 166,874 | 168,543 |
| Overseas Shipping | 48,337 | 48,825 | 49,313 |
| Legal Fees & Permitting | 237,260 | 296,575 | 370,719 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 20,790 | 21,000 | 21,210 |
| Control System | 21,796 | 22,017 | 22,237 |
| Control Buildings | 9,155 | 9,247 | 9,340 |
| Central Building | 11,349 | 12,611 | 15,763 |

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 248,593 | 272,654 | 307,047 |
|-----------------------------------|---------|---------|---------|

| | | | |
|----------------------------|---------|---------|---------|
| <i>Project Contingency</i> | 273,452 | 299,920 | 337,751 |
|----------------------------|---------|---------|---------|

| | | | |
|----------------------|---------|---------|---------|
| <i>Initial Costs</i> | 274,410 | 277,429 | 287,377 |
|----------------------|---------|---------|---------|

| | | | |
|------------------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$3,282,384</u> | <u>\$3,576,545</u> | <u>\$4,002,641</u> |
|------------------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|--------|--------|--------|
| Variable O&M | 85,722 | 66,708 | 61,945 |
|--------------|--------|--------|--------|

| | | | |
|-----------|--------|--------|--------|
| Fixed O&M | 40,417 | 40,826 | 41,234 |
|-----------|--------|--------|--------|

| | | | |
|------------|-------|-------|-------|
| Land Lease | 8,778 | 9,240 | 9,702 |
|------------|-------|-------|-------|

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$134,918</u> | <u>\$116,774</u> | <u>\$112,881</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location North Kohala Project Code: 436,437,438
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>15</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>21.9</u> | Extent (# of units) | <u>60</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 76,002 | 69,093 | 62,183 |
| Expected Losses (%) | 13% | 18% | 23% |
| Net Energy (MWh/yr) | <u>66,395</u> | <u>56,905</u> | <u>48,105</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|------------|
| Turbines & Towers | 8,394,435 | 9,327,150 | 10,259,865 |
| Foundations | 654,885 | 661,500 | 668,115 |
| Assembly & Checkout | 387,630 | 391,545 | 395,460 |
| Electrical Infrastructure | 1,287,853 | 1,300,862 | 1,313,870 |
| Sub-Station | 826,028 | 834,372 | 842,716 |
| Overseas Shipping | 290,021 | 292,950 | 295,880 |
| Legal Fees & Permitting | 258,816 | 323,520 | 404,400 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 114,345 | 115,500 | 116,655 |
| Control System | 132,100 | 133,434 | 134,768 |
| Control Buildings | 55,484 | 56,045 | 56,605 |
| Central Building | 85,121 | 94,579 | 118,223 |

Engineering & Overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| Engineering & Overhead | 1,248,672 | 1,353,146 | 1,460,656 |
| <i>Project Contingency</i> | 1,373,539 | 1,488,460 | 1,606,721 |
| <i>Initial Costs</i> | 720,767 | 736,399 | 768,701 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$15,829,695</u> | <u>\$17,109,461</u> | <u>\$18,442,636</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$1,500,000</u> | <u>\$1,500,000</u> | <u>\$1,500,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 383,433 | 298,750 | 277,807 |
| Fixed O&M | 206,211 | 208,294 | 210,377 |
| Land Lease | 127,121 | 133,812 | 140,503 |

| | | | |
|----------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$716,765</u> | <u>\$640,856</u> | <u>\$628,686</u> |
|----------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location North Kohala Project Code: 439,440,441
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>15</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>21.9</u> | Extent (# of units) | <u>50</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 95,066 | 86,423 | 77,781 |
| Expected Losses (%) | 13% | 18% | 23% |
| Net Energy (MWh/yr) | <u>83,049</u> | <u>71,178</u> | <u>60,171</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 7,422,080 | 8,246,755 | 9,483,768 |
| Foundations | 534,823 | 540,225 | 545,627 |
| Assembly & Checkout | 319,794 | 323,025 | 326,255 |
| Electrical Infrastructure | 1,268,405 | 1,281,217 | 1,294,030 |
| Sub-Station | 826,028 | 834,372 | 842,716 |
| Overseas Shipping | 241,684 | 244,125 | 246,566 |
| Legal Fees & Permitting | 256,034 | 320,043 | 400,054 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 95,634 | 96,600 | 97,566 |
| Control System | 108,982 | 110,083 | 111,184 |
| Control Buildings | 45,775 | 46,237 | 46,699 |
| Central Building | 85,121 | 94,579 | 118,223 |

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & Overhead</i> | 1,120,436 | 1,213,726 | 1,351,269 |
|-----------------------------------|-----------|-----------|-----------|

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project Contingency</i> | 1,232,480 | 1,335,099 | 1,486,396 |
|----------------------------|-----------|-----------|-----------|

| | | | |
|----------------------|---------|---------|---------|
| <i>Initial Costs</i> | 711,245 | 718,359 | 759,840 |
|----------------------|---------|---------|---------|

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$14,268,521</u> | <u>\$15,404,445</u> | <u>\$17,110,193</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$1,500,000</u> | <u>\$1,500,000</u> | <u>\$1,500,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 470,018 | 366,213 | 340,540 |
|--------------|---------|---------|---------|

| | | | |
|-----------|---------|---------|---------|
| Fixed O&M | 202,087 | 204,128 | 206,169 |
|-----------|---------|---------|---------|

| | | | |
|------------|---------|---------|---------|
| Land Lease | 131,670 | 138,600 | 145,530 |
|------------|---------|---------|---------|

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$803,775</u> | <u>\$708,940</u> | <u>\$692,239</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location North Kohala Project Code: 430,431,432
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>21.9</u> | Extent (# of units) | <u>20</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 25,334 | 23,031 | 20,728 |
| Expected Losses (%) | 14% | 19% | 24% |
| Net Energy (MWh/yr) | <u>21,693</u> | <u>18,569</u> | <u>15,676</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 2,938,052 | 3,264,503 | 3,590,953 |
| Foundations | 218,295 | 220,500 | 222,705 |
| Assembly & Checkout | 129,210 | 130,515 | 131,820 |
| Electrical Infrastructure | 429,284 | 433,621 | 437,957 |
| Sub-Station | 275,343 | 278,124 | 280,905 |
| Overseas Shipping | 96,674 | 97,650 | 98,627 |
| Legal Fees & Permitting | 241,544 | 301,930 | 377,413 |

General Facilities

| | | | |
|-----------------------------------|---------|---------|---------|
| Roads & Grading | 39,501 | 39,900 | 40,299 |
| Control System | 44,033 | 44,478 | 44,923 |
| Control Buildings | 18,495 | 18,682 | 18,868 |
| Central Building | 39,723 | 44,137 | 55,171 |
| <i>Engineering & Overhead</i> | 447,015 | 487,404 | 529,964 |
| <i>Project Contingency</i> | 491,717 | 536,144 | 582,960 |
| <i>Initial Costs</i> | 352,107 | 358,930 | 371,485 |

| | | | |
|-----------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$5,760,993</u> | <u>\$6,256,517</u> | <u>\$6,784,050</u> |
|-----------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|--------|--------|
| Variable O&M | 125,274 | 97,487 | 90,527 |
| Fixed O&M | 68,737 | 69,431 | 70,126 |
| Land Lease | 42,374 | 44,604 | 46,834 |

| | | | |
|----------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$236,385</u> | <u>\$211,522</u> | <u>\$207,487</u> |
|----------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Hawaii Location North Kohala Project Code: 433,434,435
(leave blank)
 Capacity (MW) 5 Stage (current/future) Future
 Resource (mph, avg.) 21.9 Extent (# of units) 16
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 30,421 | 27,656 | 24,890 |
| Expected Losses (%) | 14% | 19% | 24% |
| Net Energy (MWh/yr) | <u>26,048</u> | <u>22,298</u> | <u>18,823</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 2,493,819 | 2,770,910 | 3,186,546 |
| Foundations | 171,143 | 172,872 | 174,601 |
| Assembly & Checkout | 102,334 | 103,368 | 104,402 |
| Electrical Infrastructure | 405,890 | 409,990 | 414,089 |
| Sub-Station | 275,343 | 278,124 | 280,905 |
| Overseas Shipping | 77,339 | 78,120 | 78,901 |
| Legal Fees & Permitting | 240,280 | 300,350 | 375,437 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 32,017 | 32,340 | 32,663 |
| Control System | 34,874 | 35,227 | 35,579 |
| Control Buildings | 14,648 | 14,796 | 14,944 |
| Central Building | 39,723 | 44,137 | 55,171 |

Engineering & Overhead

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 388,741 | 424,023 | 475,324 |
| <i>Project Contingency</i> | 427,615 | 466,426 | 522,856 |
| <i>Initial Costs</i> | 348,178 | 352,037 | 367,285 |

| | | | |
|------------------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$5,051,943</u> | <u>\$5,482,717</u> | <u>\$6,118,703</u> |
|------------------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 147,421 | 114,721 | 106,530 |
| Fixed O&M | 67,362 | 68,043 | 68,723 |
| Land Lease | 42,134 | 44,352 | 46,570 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$256,917</u> | <u>\$227,116</u> | <u>\$221,823</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Grass Crops - Ethanol

Island: Maui

Location: Paia-Puunene

Project Code: 228,229,230

| | | | |
|---------------------------|---------|--------------------------------|--------|
| Capacity (MW) | 141 | Stage (current/future): | future |
| Resource (dry tons/year): | 454,600 | Extent (harvested acres/year): | 15,186 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|---------|--------------|
| Gross Energy (eq. MWh/yr) | 950,832 | 864,392 | 777,953 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 950,832 | 864,392 | 777,953 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Biomass preparation | 5,990,731 | 7,488,414 | 8,986,097 |
| Pretreatment | 19,023,199 | 23,778,999 | 28,534,799 |
| Hexose fermentation | 18,655,347 | 23,319,184 | 27,983,021 |
| Pentose fermentation | 5,202,477 | 6,503,096 | 7,803,716 |
| Distillation & dehydration | 3,258,117 | 4,072,646 | 4,887,175 |
| Product storage & denature | 2,378,591 | 2,973,239 | 3,567,887 |
| Boiler | 16,613,262 | 20,766,578 | 24,919,893 |
| Non-boiler utilities | 27,851,645 | 34,814,557 | 41,777,468 |
| Environmental | 3,442,504 | 4,303,130 | 5,163,756 |
| Miscellaneous & control | 5,334,314 | 6,667,892 | 8,001,471 |
| Enzyme production | 2,259,662 | 2,824,577 | 3,389,493 |
| Legal fee & permitting | 747,025 | 933,781 | 1,120,537 |

General Facilities

| | | | |
|------------------------------------------|------------|------------|------------|
| <i>Engineering & overhead</i> | 11,075,687 | 13,844,609 | 16,613,531 |
| <i>Project contingency</i> | 12,183,256 | 15,229,070 | 18,274,884 |
| <i>Initial cost</i> | 6,880,824 | 8,601,030 | 10,321,236 |

| | | | |
|------------------|-------------|-------------|-------------|
| SUB-TOTAL | 140,896,642 | 176,120,803 | 211,344,963 |
|------------------|-------------|-------------|-------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|------------|------------|------------|
| Variable O&M (\$) | 25,684,826 | 32,106,032 | 38,527,239 |
| Fixed O&M (\$) | 14,921,772 | 18,652,214 | 22,382,657 |
| Land Lease | 617,040 | 771,300 | 925,560 |

| | | | |
|---------------------------|------------|------------|------------|
| FIRST YEAR O&M | 41,223,638 | 51,529,546 | 61,835,456 |
|---------------------------|------------|------------|------------|

Note: 1 MW = 0.355 MGPY ethanol
141 MW = 50 MGPY ethanol

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Grass Crops - Ethanol

Island: Maui

Location: Paia-Puunene

Project Code: 225, 226, 227

| | | | |
|---------------------------|---------|--------------------------------|---------|
| Capacity (MW) | 70 | Stage (current/future): | current |
| Resource (dry tons/year): | 454,600 | Extent (harvested acres/year): | 15,186 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------|-------------------|----------------|---------------------|
| Gross Energy (eq. MWh/yr) | 475,416 | 432,196 | 388,977 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 475,416 | 432,196 | 388,977 |

CAPITAL COSTS

| | | | |
|------------------|------------|-------------|-------------|
| SUB-TOTAL | 98,125,199 | 115,441,410 | 132,757,622 |
|------------------|------------|-------------|-------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|------------|------------|------------|
| Variable O&M (\$) | 29,891,164 | 35,166,075 | 40,440,986 |
| Fixed O&M (\$) | 13,409,110 | 15,775,424 | 18,141,738 |
| Land Lease | 720,120 | 847,200 | 974,280 |

| | | | |
|---------------------------|------------|------------|------------|
| FIRST YEAR O&M | 44,020,394 | 51,788,699 | 59,557,004 |
|---------------------------|------------|------------|------------|

Note: 1 MW = 0.355 MGPY ethanol
70 MW = 25 MGPY ethanol

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Tree crops - Ethanol

Island: Maui

Location: Paia/Puunene

Project Code: 138,139,140

| | | | |
|---------------------------|---------|--------------------------------|--------|
| Capacity (MW) | 70 | Stage (current/future): | future |
| Resource (dry tons/year): | 303,036 | Extent (harvested acres/year): | 5,029 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|---------|--------------|
| Gross Energy (eq. MWh/yr) | 475,416 | 432,196 | 388,977 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 475,416 | 432,196 | 388,977 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Biomass preparation | 3,888,024 | 4,860,030 | 5,832,036 |
| Pretreatment | 12,347,089 | 15,433,862 | 18,520,634 |
| Hexose fermentation | 12,107,926 | 15,134,907 | 18,161,889 |
| Pentose fermentation | 3,376,300 | 4,220,375 | 5,064,450 |
| Distillation & dehydration | 2,114,766 | 2,643,458 | 3,172,149 |
| Product storage & denature | 1,705,387 | 2,131,734 | 2,558,081 |
| Boiler | 10,782,830 | 13,478,538 | 16,174,245 |
| Non-boiler utilities | 18,077,319 | 22,596,649 | 27,115,979 |
| Environmental | 2,234,348 | 2,792,935 | 3,351,522 |
| Miscellaneous & control | 3,461,408 | 4,326,760 | 5,192,112 |
| Enzyme production | 1,466,224 | 1,832,779 | 2,199,335 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 3,275,270 | 4,094,088 | 4,912,905 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|------------|------------|
| <i>Project contingency</i> | 7,221,253 | 9,026,566 | 10,831,879 |
| <i>Initial cost</i> | 8,427,298 | 10,534,122 | 12,640,946 |
| | 3,923,894 | 4,904,867 | 5,885,841 |

| | | | |
|------------------|-------------------|--------------------|--------------------|
| SUB-TOTAL | 95,973,263 | 119,966,579 | 143,959,894 |
|------------------|-------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|------------|------------|------------|
| Variable O&M (\$) | 12,367,659 | 15,459,574 | 18,551,489 |
| Fixed O&M (\$) | 9,496,118 | 11,870,147 | 14,244,176 |
| Land Lease | 1,434,200 | 1,792,750 | 2,151,300 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 23,297,977 | 29,122,471 | 34,946,965 |
|---------------------------|-------------------|-------------------|-------------------|

Note: 1 MW = 0.355 MGPY ethanol
70 MW = 25 MGPY ethanol

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Tree crops - Methanol

Island: Maui

Location: Paia-Puunene

Project Code: 141,142,143

| | | | |
|---------------------------|---------|--------------------------------|--------|
| Capacity (MW): | 95 | Stage (current/future): | future |
| Resource (dry tons/year): | 268,910 | Extent (harvested acres/year): | 4,333 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|---------|--------------|
| Gross Energy (eq. MWh/yr) | 639,477 | 581,342 | 523,208 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 639,477 | 581,342 | 523,208 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Feed handling, preparation | 8,971,907 | 11,214,883 | 13,457,860 |
| Gasification | 3,494,321 | 4,367,902 | 5,241,482 |
| Gas conditioning | 5,645,480 | 7,056,850 | 8,468,221 |
| Compression | 11,269,974 | 14,087,467 | 16,904,961 |
| Acid gas removal/cooling | 5,131,301 | 6,414,126 | 7,696,951 |
| MeOH syn/purification | 14,208,142 | 17,760,178 | 21,312,213 |
| Utilities/auxiliary | 12,172,411 | 15,215,514 | 18,258,617 |
| Legal fees & permitting | 624,234 | 780,292 | 936,351 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 2,822,351 | 3,527,939 | 4,233,527 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|---------------------|-----------|-----------|------------|
| Project contingency | 6,151,777 | 7,689,721 | 9,227,666 |
| Initial cost | 7,205,583 | 9,006,978 | 10,808,374 |
| | 3,307,609 | 4,134,511 | 4,961,413 |

| | | | |
|------------------|-------------------|--------------------|--------------------|
| SUB-TOTAL | 82,569,016 | 103,211,270 | 123,853,524 |
|------------------|-------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|------------|------------|------------|
| Variable O&M (\$) | 11,383,149 | 14,228,937 | 17,074,724 |
| Fixed O&M (\$) | 6,702,933 | 8,378,666 | 10,054,399 |
| Land Lease | 1,237,200 | 1,546,500 | 1,855,800 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 19,323,282 | 24,154,103 | 28,984,923 |
|---------------------------|-------------------|-------------------|-------------------|

Note: 1 MW = 0.5274 MGPY MeOH
95 MW = 50 MGPY MeOH

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Grass Crops - Methanol

Island: Maui

Location: Paia-Puunene

Project Code: 394, 395, 396

| | | | |
|---------------------------|---------|--------------------------------|--------|
| Capacity (MW): | 95 | Stage (current/future): | future |
| Resource (dry tons/year): | 276,300 | Extent (harvested acres/year): | 9,229 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|---------|--------------|
| Gross Energy (eq. MWh/yr) | 639,477 | 581,342 | 523,208 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 639,477 | 581,342 | 523,208 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Feed handling, preparation | 8,971,907 | 11,214,883 | 13,457,860 |
| Gasification | 3,494,321 | 4,367,902 | 5,241,482 |
| Gas conditioning | 5,645,480 | 7,056,850 | 8,468,221 |
| Compression | 11,269,974 | 14,087,467 | 16,904,961 |
| Acid gas removal/cooling | 5,131,301 | 6,414,126 | 7,696,951 |
| MeOH syn/purification | 14,208,142 | 17,760,178 | 21,312,213 |
| Utilities/auxiliary | 12,172,411 | 15,215,514 | 18,258,617 |
| Legal fees & permitting | 624,234 | 780,292 | 936,351 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|------------|
| <i>Engineering & overhead</i> | 6,151,777 | 7,689,721 | 9,227,666 |
| <i>Project contingency</i> | 6,766,955 | 8,458,693 | 10,150,432 |
| <i>Initial cost</i> | 3,768,540 | 4,710,675 | 5,652,810 |

| | | | |
|------------------|-------------------|-------------------|--------------------|
| SUB-TOTAL | 78,205,042 | 97,756,303 | 117,307,563 |
|------------------|-------------------|-------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|------------|------------|------------|
| Variable O&M (\$) | 15,400,534 | 19,250,667 | 23,100,800 |
| Fixed O&M (\$) | 8,235,952 | 10,294,940 | 12,353,928 |
| Land Lease | 378,760 | 473,450 | 568,140 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 24,015,246 | 30,019,057 | 36,022,868 |
|---------------------------|-------------------|-------------------|-------------------|

Note: 1 MW = 0.5274 MGPY MeOH
95 MW = 50 MGPY MeOH

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Grass Crops - Electricity

Island: Maui

Location: Paia-Puunene :

Project Code: 121,122,123

| | | | |
|---------------------------|---------|--------------------------------|---------|
| Capacity (MW): | 50 | Stage (current/future): | current |
| Resource (dry tons/year): | 255,500 | Extent (harvested acres/year): | 8,536 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 10,221,685 | 12,025,511 | 13,829,338 |
| Gasification & compressor/precooler | 15,178,000 | 17,856,470 | 20,534,941 |
| Physical cleanup | 24,186,360 | 28,454,541 | 32,722,722 |
| Ash handling | 526,537 | 619,455 | 712,374 |
| Gas turbine | 503,644 | 592,522 | 681,401 |
| Balance of plant | 10,118,666 | 11,904,313 | 13,689,960 |
| Legal fee & permitting | 653,337 | 768,632 | 883,927 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 6,138,823 | 7,222,145 | 8,305,466 |
| <i>Project contingency</i> | 6,752,705 | 7,944,359 | 9,136,013 |
| <i>Initial cost</i> | 3,388,630 | 3,986,623 | 4,584,617 |

| | | | |
|-----------|------------|------------|-------------|
| SUB-TOTAL | 77,668,386 | 91,374,572 | 105,080,758 |
|-----------|------------|------------|-------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|------------|------------|------------|
| Variable O&M (\$) | 13,801,037 | 16,236,514 | 18,671,992 |
| Fixed O&M (\$) | 5,378,455 | 6,327,595 | 7,276,734 |
| Land Lease | 372,980 | 438,800 | 504,620 |

| | | | |
|----------------|------------|------------|------------|
| FIRST YEAR O&M | 19,552,472 | 23,002,909 | 26,453,346 |
|----------------|------------|------------|------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Tree crops - Electricity

Island: Maui

Location: Paia-Puunene

Project Code: 133,134,135

| | | | |
|---------------------------|---------|--------------------------------|---------|
| Capacity (MW): | 50 | Stage (current/future): | current |
| Resource (dry tons/year): | 250,006 | Extent (harvested acres/year): | 3,982 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 9,620,409 | 12,025,511 | 14,430,613 |
| Gasification & compressor/precooler | 14,285,176 | 17,856,470 | 21,427,764 |
| Physical cleanup | 22,763,633 | 28,454,541 | 34,145,449 |
| Ash handling | 495,564 | 619,455 | 743,346 |
| Gas turbine | 474,018 | 592,522 | 711,027 |
| Balance of plant | 9,523,451 | 11,904,313 | 14,285,176 |
| Legal fee & permitting | 614,906 | 768,632 | 922,358 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 2,593,363 | 3,241,704 | 3,890,044 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|---------------------|-----------|-----------|------------|
| Project contingency | 5,777,716 | 7,222,145 | 8,666,573 |
| Initial cost | 6,771,216 | 8,464,020 | 10,156,824 |
| | 2,766,838 | 3,458,548 | 4,150,257 |

| | | | |
|------------------|-------------------|-------------------|--------------------|
| SUB-TOTAL | 77,250,215 | 96,562,769 | 115,875,323 |
|------------------|-------------------|-------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|------------|------------|
| Variable O&M (\$) | 9,258,133 | 11,572,666 | 13,887,199 |
| Fixed O&M (\$) | 3,720,325 | 4,650,406 | 5,580,487 |
| Land Lease | 1,137,600 | 1,422,000 | 1,706,400 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 14,116,058 | 17,645,072 | 21,174,086 |
|---------------------------|-------------------|-------------------|-------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Grass Crops - Electricity

Island: Maui

Location: Paia-Puunene

Project Code: 124,125,126

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 50 | Stage (current/future): | future |
| Resource (dry tons-year): | 212,917 | Extent (harvested acres/year): | 7,114 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 8,370,725 | 10,463,407 | 12,556,088 |
| Gasification & compressor/precooler | 14,769,967 | 18,462,459 | 22,154,951 |
| Physical cleanup | 904,943 | 1,131,179 | 1,357,415 |
| Ash handling | 872,624 | 1,090,780 | 1,308,936 |
| Gas turbine | 19,617,878 | 24,522,347 | 29,426,816 |
| Balance of plant | 11,139,421 | 13,924,276 | 16,709,131 |
| Legal fee & permitting | 611,189 | 763,986 | 916,783 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 5,628,675 | 7,035,843 | 8,443,012 |
| <i>Project contingency</i> | 6,191,542 | 7,739,428 | 9,287,313 |
| <i>Initial cost</i> | 4,185,526 | 5,231,907 | 6,278,289 |

| | | | |
|------------------|-------------------|-------------------|--------------------|
| SUB-TOTAL | 72,292,490 | 90,365,612 | 108,438,734 |
|------------------|-------------------|-------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|------------|------------|------------|
| Variable O&M (\$) | 20,805,077 | 26,006,346 | 31,207,615 |
| Fixed O&M (\$) | 7,144,326 | 8,930,407 | 10,716,489 |
| Land Lease | 598,000 | 747,500 | 897,000 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 28,547,403 | 35,684,253 | 42,821,104 |
|---------------------------|-------------------|-------------------|-------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree Crops - Electricity

Island: Maui

Location: Puunene

Project Code: 213,214,215

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 50 | Stage (current/future): | future |
| Resource (dry tons/year): | 208,008 | Extent (harvested acres/year): | 3,245 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 8,370,725 | 10,463,407 | 12,556,088 |
| Gasification & compressor/precooler | 14,769,967 | 18,462,459 | 22,154,951 |
| Physical cleanup | 904,943 | 1,131,179 | 1,357,415 |
| Ash handling | 872,624 | 1,090,780 | 1,308,936 |
| Gas turbine | 19,617,878 | 24,522,347 | 29,426,816 |
| Balance of plant | 11,139,421 | 13,924,276 | 16,709,131 |
| Legal fees & permitting | 611,189 | 763,986 | 916,783 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 2,113,775 | 2,642,218 | 3,170,662 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|---------------------|-----------|-----------|-----------|
| Project contingency | 5,628,675 | 7,035,843 | 8,443,012 |
| Initial cost | 6,559,312 | 8,199,140 | 9,838,968 |
| | 2,563,155 | 3,203,944 | 3,844,733 |

| | | | |
|------------------|-------------------|-------------------|--------------------|
| SUB-TOTAL | 74,715,591 | 93,394,487 | 112,073,385 |
|------------------|-------------------|-------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|------------|
| Variable O&M (\$) | 7,937,833 | 9,922,291 | 11,906,750 |
| Fixed O&M (\$) | 3,594,613 | 4,493,267 | 5,391,920 |
| Land Lease | 929,000 | 1,161,250 | 1,393,500 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 12,461,446 | 15,576,808 | 18,692,170 |
|---------------------------|-------------------|-------------------|-------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Organic Wastes - Methanol

Island: Maui

Location: Puunene

Project Code: 144,145,146

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 47 | Stage (current/future): | future |
| Resource (tons/year): | 260,417 | Extent (harvested acres/year): | N/A |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------|-------------------|----------------|---------------------|
| Gross Energy (eq. MWh/yr) | 319,738 | 290,671 | 261,604 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 319,738 | 290,671 | 261,604 |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------------|------------|------------|------------|
| MSW.to RDF front-end processing | 17,237,015 | 21,546,269 | 25,855,522 |
| Feed handling, preparation | 7,229,993 | 9,037,491 | 10,844,989 |
| Gasification | 2,822,740 | 3,528,425 | 4,234,110 |
| Gas conditioning | 4,554,161 | 5,692,701 | 6,831,241 |
| Compression | 9,097,828 | 11,372,285 | 13,646,742 |
| Acid gas removal/cooling | 4,134,422 | 5,168,028 | 6,201,634 |
| MeOH syn-purification | 11,469,350 | 14,336,687 | 17,204,024 |
| Utilities/auxiliary | 9,832,370 | 12,290,463 | 14,748,555 |
| Legal fees & permitting | 594,852 | 743,565 | 892,278 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|------------|
| <i>Engineering & overhead</i> | 6,697,273 | 8,371,591 | 10,045,910 |
| <i>Project contingency</i> | 7,367,000 | 9,208,750 | 11,050,501 |
| <i>Initial cost</i> | 1,980,705 | 2,475,882 | 2,971,058 |

| | | | |
|------------------|-------------------|--------------------|--------------------|
| SUB-TOTAL | 83,017,709 | 103,772,137 | 124,526,564 |
|------------------|-------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-------------|-----------|-----------|
| Variable O&M (\$) | (1,604,364) | 208,089 | 2,020,542 |
| Fixed O&M (\$) | 5,038,530 | 6,298,163 | 7,557,795 |
| Land Lease | 9,600 | 12,000 | 14,400 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | 3,443,766 | 6,518,252 | 9,592,737 |
|---------------------------|------------------|------------------|------------------|

Note: 1MW = 0.5274 MGPY MeOH
 47 MW = 25 MGPY MeOH

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Organic Waste - Electricity

Island: Maui

Location: Puunene

Project Code: 127,128,129

| | | | |
|----------------------------|---------|--------------------------------|---------|
| Capacity (MW electricity): | 25 | Stage (current/future): | current |
| Resource (dry tons/year): | 224,123 | Extent (harvested acres/year): | N/A |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| MSW to RDF front-end processing | 16,578,219 | 19,503,787 | 22,429,355 |
| Feed handling and prep. | 6,142,154 | 7,226,064 | 8,309,973 |
| Gasification & compressor/precooler | 843,041 | 991,813 | 1,140,585 |
| Physical cleanup | 17,235,500 | 20,277,059 | 23,318,618 |
| Ash handling | 321,158 | 377,833 | 434,508 |
| Gas turbine | 334,540 | 393,576 | 452,613 |
| Balance of plant | 6,490,076 | 7,635,383 | 8,780,691 |
| Legal fees & permitting | 579,916 | 682,254 | 784,592 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 3,194,639 | 3,758,398 | 4,322,158 |
| <i>Project contingency</i> | 3,514,102 | 4,134,238 | 4,754,374 |
| <i>Initial cost</i> | 1,430,278 | 1,682,680 | 1,935,082 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 56,663,623 | 66,663,085 | 76,662,549 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|---------------------------|------------------|----------------|------------------|
| Variable O&M (\$) | (2,873,897) | (1,687,326) | (500,755) |
| Fixed O&M (\$) | 1,913,914 | 2,392,392 | 2,870,870 |
| Land Lease | 9,600 | 12,000 | 14,400 |
| FIRST YEAR O&M | (950,383) | 717,066 | 2,384,515 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Organic Wastes - Electricity

Island: Maui

Location: Puunene

Project Code: 130,131,132

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 186,951 | Extent (harvested acres/year): | N/A |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 168,630 | 306,600 | 275,940 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 306,600 | 275,940 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| MSW to RDF front-end processing | 13,753,341 | 17,191,677 | 20,630,012 |
| Feed handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fees & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 4,430,353 | 5,537,941 | 6,645,529 |
| <i>Project contingency</i> | 4,873,388 | 6,091,735 | 7,310,082 |
| <i>Initial cost</i> | 1,378,066 | 1,722,583 | 2,067,099 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 54,985,335 | 68,731,671 | 82,478,002 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-------------|-------------|-----------|
| Variable O&M (\$) | (2,087,892) | (1,020,782) | 46,328 |
| Fixed O&M (\$) | 1,945,143 | 2,431,429 | 2,917,714 |
| Land Lease | 9,600 | 12,000 | 14,400 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | (133,149) | 1,422,647 | 2,978,442 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Kahului Project Code: 31, 32, 33

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 71,462 | 62,154 | 55,955 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 70,762 | 61,532 | 55,379 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$14,107,500 | \$14,850,000 | \$15,592,500 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$682,265 | \$852,832 | \$1,066,040 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$1,804,478 | \$2,004,975 | \$2,205,473 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |
| <i>Engineering & Overhead</i> | \$10,078,838 | \$10,078,838 | \$10,078,838 |
| <i>Project Contingency</i> | \$11,760,351 | \$11,760,351 | \$11,760,351 |
| <i>Initial Costs</i> | \$2,550,148 | \$2,550,148 | \$2,550,148 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$139,105,064 | \$152,667,567 | \$158,915,211 |
|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$3,000,000 | \$3,000,000 | \$3,000,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$80,465 | \$89,405 | \$98,346 |
| Fixed O&M | \$111,150 | \$117,000 | \$122,850 |
| Land Lease | \$150,916 | \$158,859 | \$166,802 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$342,531 | \$365,264 | \$387,997 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Kahului Project Code: 574, 575, 576

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 92,901 | 80,800 | 72,742 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 91,990 | 79,992 | 71,992 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$21,161,250 | \$22,275,000 | \$23,388,750 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$682,265 | \$852,832 | \$1,066,040 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,804,478 | \$2,004,975 | \$2,205,473 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |

Engineering & Overhead

| | | | |
|------------------------|--------------|--------------|--------------|
| Engineering & Overhead | \$10,078,838 | \$10,078,838 | \$10,078,838 |
|------------------------|--------------|--------------|--------------|

Project Contingency

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$11,760,351 | \$11,760,351 | \$11,760,351 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$2,550,148 | \$2,550,148 | \$2,550,148 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$146,158,814 | \$160,092,567 | \$166,711,461 |
|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$3,000,000 | \$3,000,000 | \$3,000,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$120,697 | \$134,108 | \$147,518 |
| Fixed O&M | \$138,938 | \$146,250 | \$153,563 |
| Land Lease | \$150,916 | \$158,859 | \$166,802 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$410,550 | \$439,217 | \$467,883 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Kahului Project Code: 34, 35, 36

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>229,920</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 74,054 | 64,408 | 54,763 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 73,329 | 63,764 | 54,199 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$10,157,400 | \$10,692,000 | \$11,226,600 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$606,004 | \$757,505 | \$946,881 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,443,582 | \$1,603,980 | \$1,764,378 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$6,669,710 | \$6,669,710 | \$6,669,710 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$8,180,910 | \$8,180,910 | \$8,180,910 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$1,781,887 | \$1,781,887 | \$1,781,887 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|---------------------|----------------------|----------------------|
| \$97,490,615 | \$106,208,792 | \$110,573,969 |
|---------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$3,000,000 | \$3,000,000 | \$3,000,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$75,357 | \$83,730 | \$92,103 |
| Fixed O&M | \$105,329 | \$110,872 | \$116,416 |
| Land Lease | \$119,503 | \$125,793 | \$132,083 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$300,189 | \$320,395 | \$340,601 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Kahului Project Code: 577, 578, 579

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>229,920</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 96,271 | 83,731 | 71,193 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 95,327 | 82,893 | 70,459 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$15,236,100 | \$16,038,000 | \$16,839,900 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$606,004 | \$757,505 | \$946,881 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,443,582 | \$1,603,980 | \$1,764,378 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |

Engineering & Overhead

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$8,180,910 | \$8,180,910 | \$8,180,910 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|------------------|----------------------|----------------------|----------------------|
| Initial Costs | \$1,781,887 | \$1,781,887 | \$1,781,887 |
| SUB-TOTAL | \$102,569,315 | \$111,554,792 | \$116,187,269 |

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | \$3,000,000 | \$3,000,000 | \$3,000,000 |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$113,036 | \$125,595 | \$138,155 |
| Fixed O&M | \$131,661 | \$138,590 | \$145,520 |
| Land Lease | \$119,503 | \$125,793 | \$132,083 |

FIRST YEAR O&M

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$364,199 | \$389,978 | \$415,757 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Kahului Project Code: 25, 26, 27

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 10 | Stage (current/future) | current |
| Resource (kWh/m ²) | 1,909 | Extent (PV module area, m ²) | 96,800 |
| Project Life (years) | 30 | Construction Time (years) | 2 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 23,821 | 20,718 | 18,652 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 23,588 | 20,511 | 18,460 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$4,963,750 | \$5,225,000 | \$5,486,250 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |
| <i>Engineering & Overhead</i> | \$3,747,787 | \$3,747,787 | \$3,747,787 |
| <i>Project Contingency</i> | \$4,371,853 | \$4,371,853 | \$4,371,853 |
| <i>Initial Costs</i> | \$713,492 | \$713,492 | \$713,492 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$51,382,226 | \$56,518,914 | \$58,920,877 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$26,822 | \$29,802 | \$32,782 |
| Fixed O&M | \$46,313 | \$48,750 | \$51,188 |
| Land Lease | \$48,293 | \$50,835 | \$53,377 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$121,428 | \$129,387 | \$137,346 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Kahului Project Code: 568, 569, 570

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>96,800</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 30,967 | 26,934 | 24,248 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 30,664 | 26,664 | 23,998 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$7,445,625 | \$7,837,500 | \$8,229,375 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$3,747,787 | \$3,747,787 | \$3,747,787 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$4,371,853 | \$4,371,853 | \$4,371,853 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$713,492 | \$713,492 | \$713,492 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | | |
|--|---------------------|---------------------|---------------------|
| | \$53,864,101 | \$59,131,414 | \$61,664,002 |
|--|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$40,233 | \$44,703 | \$49,173 |
| Fixed O&M | \$57,891 | \$60,938 | \$63,984 |
| Land Lease | \$48,293 | \$50,835 | \$53,377 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$146,417 | \$156,476 | \$166,534 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Kahului Project Code: 28, 29, 30

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>76,640</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 24,685 | 21,470 | 18,255 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 24,443 | 21,255 | 18,067 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$3,573,900 | \$3,762,000 | \$3,950,100 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$2,482,986 | \$2,482,986 | \$2,482,986 |
|------------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$499,593 | \$499,593 | \$499,593 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$36,067,740 | \$39,391,291 | \$41,095,473 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$25,119 | \$27,910 | \$30,701 |
| Fixed O&M | \$43,887 | \$46,197 | \$48,507 |
| Land Lease | \$38,241 | \$40,254 | \$42,267 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$107,247 | \$114,361 | \$121,474 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Kahului Project Code: 571, 572, 573

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>76,640</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 32,091 | 27,911 | 23,731 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 31,776 | 27,632 | 23,487 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$5,360,850 | \$5,643,000 | \$5,925,150 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$2,482,986 | \$2,482,986 | \$2,482,986 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$3,046,815 | \$3,046,815 | \$3,046,815 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$499,593 | \$499,593 | \$499,593 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$37,854,690 | \$41,272,291 | \$43,070,523 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$37,679 | \$41,865 | \$46,052 |
| Fixed O&M | \$54,859 | \$57,746 | \$60,633 |
| Land Lease | \$38,241 | \$40,254 | \$42,267 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$130,778 | \$139,865 | \$148,951 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Kihei Project Code: 13, 14, 15

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>96,800</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 23,739 | 20,646 | 18,587 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 23,506 | 20,440 | 18,396 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$4,963,750 | \$5,225,000 | \$5,486,250 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$3,747,787 | \$3,747,787 | \$3,747,787 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$4,371,853 | \$4,371,853 | \$4,371,853 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$713,642 | \$713,642 | \$713,642 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | | |
|--|--------------|--------------|--------------|
| | \$51,382,376 | \$56,519,064 | \$58,921,027 |
|--|--------------|--------------|--------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$28,436 | \$31,595 | \$34,755 |
| Fixed O&M | \$46,313 | \$48,750 | \$51,188 |
| Land Lease | \$48,293 | \$50,835 | \$53,377 |

FIRST YEAR O&M

| | | | |
|--|-----------|-----------|-----------|
| | \$123,041 | \$131,180 | \$139,319 |
|--|-----------|-----------|-----------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Kihei Project Code: 556, 557, 558

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>96,800</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 29,198 | 28,442 | 25,607 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 28,912 | 28,158 | 25,343 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------------|---------------------|---------------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$8,507,495 | \$8,955,258 | \$9,403,021 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |
| <i>Engineering & Overhead</i> | \$3,747,787 | \$3,747,787 | \$3,747,787 |
| <i>Project Contingency</i> | \$4,371,853 | \$4,371,853 | \$4,371,853 |
| <i>Initial Costs</i> | \$713,642 | \$713,642 | \$713,642 |
| SUB-TOTAL | \$54,926,121 | \$60,249,322 | \$62,837,797 |

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$53,622 | \$59,580 | \$65,538 |
| Fixed O&M | \$59,606 | \$62,743 | \$65,880 |
| Land Lease | \$48,293 | \$50,835 | \$53,377 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$161,521 | \$173,158 | \$184,795 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Kihei Project Code: 16, 17, 18

| | | | |
|--------------------------------|-------|------------------------------------------|--------|
| Capacity (MW) | 10 | Stage (current/future) | future |
| Resource (kWh/m ²) | 2,027 | Extent (PV module area, m ²) | 76,640 |
| Project Life (years) | 30 | Construction Time (years) | 1 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 24,600 | 21,395 | 18,191 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 24,359 | 21,181 | 18,004 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$3,573,900 | \$3,762,000 | \$3,950,100 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$2,482,986 | \$2,482,986 | \$2,482,986 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$3,046,815 | \$3,046,815 | \$3,046,815 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$499,733 | \$499,733 | \$499,733 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | | |
|--|--------------|--------------|--------------|
| | \$36,067,880 | \$39,391,431 | \$41,095,613 |
|--|--------------|--------------|--------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$26,631 | \$29,590 | \$32,549 |
| Fixed O&M | \$43,887 | \$46,197 | \$48,507 |
| Land Lease | \$38,241 | \$40,254 | \$42,267 |

FIRST YEAR O&M

| | | | |
|--|-----------|-----------|-----------|
| | \$108,759 | \$116,041 | \$123,322 |
|--|-----------|-----------|-----------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Kihei Project Code: 559, 560, 561

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>76,640</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 30,257 | 26,316 | 22,375 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 29,961 | 26,053 | 22,145 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$5,360,850 | \$5,643,000 | \$5,925,150 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | \$2,482,986 | \$2,482,986 | \$2,482,986 |
| <i>Project Contingency</i> | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | \$499,733 | \$499,733 | \$499,733 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$37,854,830 | \$41,272,431 | \$43,070,663 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$39,947 | \$44,385 | \$48,824 |
| Fixed O&M | \$54,859 | \$57,746 | \$60,633 |
| Land Lease | \$38,241 | \$40,254 | \$42,267 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$133,046 | \$142,385 | \$151,723 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Kihei Project Code: 19, 20, 21

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 71,216 | 61,939 | 55,762 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 70,518 | 61,320 | 55,188 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$14,107,500 | \$14,850,000 | \$15,592,500 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$682,265 | \$852,832 | \$1,066,040 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,804,478 | \$2,004,975 | \$2,205,473 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |

Engineering & Overhead

| | | | |
|--|--------------|--------------|--------------|
| | \$10,078,838 | \$10,078,838 | \$10,078,838 |
|--|--------------|--------------|--------------|

Project Contingency

| | | | |
|--|--------------|--------------|--------------|
| | \$11,760,351 | \$11,760,351 | \$11,760,351 |
|--|--------------|--------------|--------------|

Initial Costs

| | | | |
|--|-------------|-------------|-------------|
| | \$2,550,597 | \$2,550,597 | \$2,550,597 |
|--|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$139,105,513 | \$152,668,016 | \$158,915,660 |
|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$3,000,000 | \$3,000,000 | \$3,000,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$85,307 | \$94,785 | \$104,264 |
| Fixed O&M | \$111,150 | \$117,000 | \$122,850 |
| Land Lease | \$150,916 | \$158,859 | \$166,802 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$347,373 | \$370,644 | \$393,915 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Kihei Project Code: 562, 563, 564

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 87,596 | 76,185 | 68,588 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 86,737 | 75,424 | 67,881 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$21,161,250 | \$22,275,000 | \$23,388,750 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$682,265 | \$852,832 | \$1,066,040 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,804,478 | \$2,004,975 | \$2,205,473 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |

Engineering & Overhead

| | | | |
|--|--------------|--------------|--------------|
| | \$10,078,838 | \$10,078,838 | \$10,078,838 |
|--|--------------|--------------|--------------|

Project Contingency

| | | | |
|--|--------------|--------------|--------------|
| | \$11,760,351 | \$11,760,351 | \$11,760,351 |
|--|--------------|--------------|--------------|

Initial Costs

| | | | |
|--|-------------|-------------|-------------|
| | \$2,550,597 | \$2,550,597 | \$2,550,597 |
|--|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$146,159,263 | \$160,093,016 | \$166,711,910 |
|----------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$3,000,000 | \$3,000,000 | \$3,000,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$127,960 | \$142,178 | \$156,395 |
| Fixed O&M | \$138,938 | \$146,250 | \$153,563 |
| Land Lease | \$150,916 | \$158,859 | \$166,802 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$417,813 | \$447,287 | \$476,760 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Kihei Project Code: 22, 23, 24

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>229,920</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 73,799 | 64,186 | 54,575 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 73,076 | 63,544 | 54,012 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$10,157,400 | \$10,692,000 | \$11,226,600 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$606,004 | \$757,505 | \$946,881 |

General Facilities

| | | | |
|-------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,443,582 | \$1,603,980 | \$1,764,378 |
|-------------------|-------------|-------------|-------------|

| | | | |
|-----------------------|-----------|-----------|-----------|
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |
|-----------------------|-----------|-----------|-----------|

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$6,669,710 | \$6,669,710 | \$6,669,710 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$8,180,910 | \$8,180,910 | \$8,180,910 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$1,782,307 | \$1,782,307 | \$1,782,307 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|---------------------|----------------------|----------------------|
| \$97,491,035 | \$106,209,212 | \$110,574,389 |
|---------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-------------|-------------|-------------|
| \$3,000,000 | \$3,000,000 | \$3,000,000 |
|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$79,893 | \$88,770 | \$97,647 |
|--------------|----------|----------|----------|

| | | | |
|-----------|-----------|-----------|-----------|
| Fixed O&M | \$105,329 | \$110,872 | \$116,416 |
|-----------|-----------|-----------|-----------|

| | | | |
|------------|-----------|-----------|-----------|
| Land Lease | \$119,503 | \$125,793 | \$132,083 |
|------------|-----------|-----------|-----------|

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$304,725 | \$325,435 | \$346,145 |
|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Kihei Project Code: 565, 566, 567

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 30 | Stage (current/future) | future |
| Resource (kWh/m ²) | 1,909 | Extent (PV module area, m ²) | 229,920 |
| Project Life (years) | 30 | Construction Time (years) | 2 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 90,773 | 78,949 | 67,127 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 89,883 | 78,159 | 66,435 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$15,236,100 | \$16,038,000 | \$16,839,900 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$606,004 | \$757,505 | \$946,881 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$1,443,582 | \$1,603,980 | \$1,764,378 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |
| <i>Engineering & Overhead</i> | \$6,669,710 | \$6,669,710 | \$6,669,710 |
| <i>Project Contingency</i> | \$8,180,910 | \$8,180,910 | \$8,180,910 |
| <i>Initial Costs</i> | \$1,782,307 | \$1,782,307 | \$1,782,307 |

| | | | |
|------------------|----------------------|----------------------|----------------------|
| SUB-TOTAL | \$102,569,735 | \$111,555,212 | \$116,187,689 |
|------------------|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$3,000,000 | \$3,000,000 | \$3,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$119,840 | \$133,155 | \$146,471 |
| Fixed O&M | \$131,661 | \$138,590 | \$145,520 |
| Land Lease | \$119,503 | \$125,793 | \$132,083 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$371,003 | \$397,538 | \$424,073 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Puunene Project Code: 7, 8, 9

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 71,462 | 62,154 | 55,955 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 70,762 | 61,532 | 55,379 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$14,107,500 | \$14,850,000 | \$15,592,500 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$682,265 | \$852,832 | \$1,066,040 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,804,478 | \$2,004,975 | \$2,205,473 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |

Engineering & Overhead

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$11,760,351 | \$11,760,351 | \$11,760,351 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|------------------|----------------------|----------------------|----------------------|
| Initial Costs | \$2,541,771 | \$2,541,771 | \$2,541,771 |
| SUB-TOTAL | \$139,096,687 | \$152,659,190 | \$158,906,834 |

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$3,000,000 | \$3,000,000 | \$3,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$85,307 | \$94,785 | \$104,264 |
| Fixed O&M | \$111,150 | \$117,000 | \$122,850 |
| Land Lease | \$50,305 | \$52,953 | \$55,601 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$246,762 | \$264,738 | \$282,714 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Puunene Project Code: 550, 551, 552

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>290,400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>3</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 87,184 | 75,827 | 68,265 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 86,330 | 75,069 | 67,562 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$77,760,000 | \$86,400,000 | \$90,720,000 |
| Array Structure & Foundations | \$23,679,232 | \$24,925,507 | \$26,171,782 |
| Power Conditioning Units | \$6,581,250 | \$10,125,000 | \$10,631,250 |
| Electrical & SCADA | \$11,173,910 | \$11,286,778 | \$11,399,645 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$920,550 | \$969,000 | \$1,017,450 |
| Legal Fees & Permitting | \$682,265 | \$852,832 | \$1,066,040 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,804,478 | \$2,004,975 | \$2,205,473 |
| Buildings and Fencing | \$258,999 | \$287,776 | \$316,554 |

Engineering & Overhead

| | | | |
|---------------------|--------------|--------------|--------------|
| Project Contingency | \$10,078,838 | \$10,078,838 | \$10,078,838 |
|---------------------|--------------|--------------|--------------|

Initial Costs

| | | | |
|------------------|----------------------|----------------------|----------------------|
| Initial Costs | \$11,760,351 | \$11,760,351 | \$11,760,351 |
| SUB-TOTAL | \$2,541,771 | \$2,541,771 | \$2,541,771 |
| | \$148,668,419 | \$162,734,697 | \$169,486,117 |

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$3,000,000 | \$3,000,000 | \$3,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$136,136 | \$151,262 | \$166,388 |
| Fixed O&M | \$137,977 | \$145,239 | \$152,501 |
| Land Lease | \$50,305 | \$52,953 | \$55,601 |

FIRST YEAR O&M

| | | | |
|--|-----------|-----------|-----------|
| | \$324,418 | \$349,454 | \$374,490 |
|--|-----------|-----------|-----------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Puunene Project Code: 10, 11, 12

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>229,920</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 74,055 | 64,408 | 54,763 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 73,329 | 63,764 | 54,199 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$10,157,400 | \$10,692,000 | \$11,226,600 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$606,004 | \$757,505 | \$946,881 |

General Facilities

| | | | |
|-----------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,443,582 | \$1,603,980 | \$1,764,378 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |

Engineering & Overhead

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$6,669,710 | \$6,669,710 | \$6,669,710 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-------------|-------------|-------------|
| Initial Costs | \$8,180,910 | \$8,180,910 | \$8,180,910 |
|---------------|-------------|-------------|-------------|

SUB-TOTAL

| | | |
|---------------------|----------------------|----------------------|
| \$97,484,046 | \$106,202,223 | \$110,567,400 |
|---------------------|----------------------|----------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-------------|-------------|-------------|
| \$3,000,000 | \$3,000,000 | \$3,000,000 |
|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$79,893 | \$88,770 | \$97,647 |
| Fixed O&M | \$105,329 | \$110,872 | \$116,416 |
| Land Lease | \$39,834 | \$41,931 | \$44,028 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$225,056 | \$241,573 | \$258,090 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Puunene Project Code: 553, 554, 555

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>229,920</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 90,346 | 78,578 | 66,811 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 89,461 | 77,792 | 66,123 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$54,432,000 | \$60,480,000 | \$63,504,000 |
| Array Structure & Foundations | \$15,236,100 | \$16,038,000 | \$16,839,900 |
| Power Conditioning Units | \$2,961,563 | \$4,556,250 | \$4,784,063 |
| Electrical & SCADA | \$8,810,628 | \$8,899,624 | \$8,988,620 |
| Substation | \$1,426,776 | \$1,501,870 | \$1,576,963 |
| Overseas Shipping | \$828,495 | \$872,100 | \$915,705 |
| Legal Fees & Permitting | \$606,004 | \$757,505 | \$946,881 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$1,443,582 | \$1,603,980 | \$1,764,378 |
| Buildings and Fencing | \$191,661 | \$212,956 | \$234,252 |
| <i>Engineering & Overhead</i> | \$6,669,710 | \$6,669,710 | \$6,669,710 |
| <i>Project Contingency</i> | \$8,180,910 | \$8,180,910 | \$8,180,910 |
| <i>Initial Costs</i> | \$1,775,318 | \$1,775,318 | \$1,775,318 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$102,562,746 | \$111,548,223 | \$116,180,700 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | |
|-----------------|-------------|-------------|
| Cost of Upgrade | \$3,000,000 | \$3,000,000 |
|-----------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$119,840 | \$133,155 | \$146,471 |
| Fixed O&M | \$131,661 | \$138,590 | \$145,520 |
| Land Lease | \$39,834 | \$41,931 | \$44,028 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$291,335 | \$313,676 | \$336,018 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Puunene Project Code: 1, 2, 3

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>96,800</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 23,820 | 20,718 | 18,652 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 23,587 | 20,511 | 18,460 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$4,963,750 | \$5,225,000 | \$5,486,250 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |

Engineering & Overhead

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$3,747,787 | \$3,747,787 | \$3,747,787 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|------------------|---------------------|---------------------|---------------------|
| Initial Costs | \$710,818 | \$710,818 | \$710,818 |
| SUB-TOTAL | \$51,379,552 | \$56,516,240 | \$58,918,203 |

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$28,436 | \$31,595 | \$34,755 |
| Fixed O&M | \$46,313 | \$48,750 | \$51,188 |
| Land Lease | \$16,098 | \$16,945 | \$17,792 |

FIRST YEAR O&M

| | | |
|----------|----------|-----------|
| \$90,846 | \$97,290 | \$103,734 |
|----------|----------|-----------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Puunene Project Code: 544, 545, 546

| | | | |
|--------------------------------|--------------|------------------------------------------|----------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>current</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>96,800</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>2</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 29,061 | 25,276 | 22,755 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 28,776 | 25,023 | 22,521 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$8,507,318 | \$8,955,072 | \$9,402,826 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |
| <i>Engineering & Overhead</i> | \$3,747,787 | \$3,747,787 | \$3,747,787 |
| <i>Project Contingency</i> | \$4,371,853 | \$4,371,853 | \$4,371,853 |
| <i>Initial Costs</i> | \$710,818 | \$710,818 | \$710,818 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$54,923,120 | \$60,246,312 | \$62,834,778 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$47,115 | \$52,350 | \$57,585 |
| Fixed O&M | \$56,172 | \$59,128 | \$62,084 |
| Land Lease | \$16,098 | \$16,945 | \$17,792 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$119,384 | \$128,423 | \$137,462 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Maui Location: Puunene Project Code: 4, 5, 6

| | |
|---------------------------------------------|--------------------------------------------------------|
| Capacity (MW) <u>10</u> | Stage (current/future) <u>future</u> |
| Resource (kWh/m ²) <u>2,027</u> | Extent (PV module area, m ²) <u>76,640</u> |
| Project Life (years) <u>30</u> | Construction Time (years) <u>1</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 24,685 | 21,470 | 18,255 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 24,443 | 21,255 | 18,067 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$3,573,900 | \$3,762,000 | \$3,950,100 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | | | |
| | \$497,497 | \$497,497 | \$497,497 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | \$36,065,644 | \$39,389,195 | \$41,093,377 |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$26,631 | \$29,590 | \$32,549 |
| Fixed O&M | \$43,887 | \$46,197 | \$48,507 |
| Land Lease | \$12,747 | \$13,418 | \$14,089 |

| | | | |
|---------------------------|-----------------|-----------------|-----------------|
| FIRST YEAR O&M | \$83,265 | \$89,205 | \$95,144 |
|---------------------------|-----------------|-----------------|-----------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Maui Location: Puunene Project Code: 547, 548, 549

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>2,027</u> | Extent (PV module area, m ²) | <u>76,640</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 30,116 | 26,193 | 22,271 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 29,821 | 25,931 | 22,041 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$5,360,850 | \$5,643,000 | \$5,925,150 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | \$2,482,986 | \$2,482,986 | \$2,482,986 |
| <i>Project Contingency</i> | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | \$497,497 | \$497,497 | \$497,497 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$37,852,594 | \$41,270,195 | \$43,068,427 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$39,947 | \$44,385 | \$48,824 |
| Fixed O&M | \$54,859 | \$57,746 | \$60,633 |
| Land Lease | \$12,747 | \$13,418 | \$14,089 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$107,552 | \$115,549 | \$123,546 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Maui Location: Kahului Project Code: 370, 371, 372
 Ownrshp: Private

Capacity (MW) 30 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 4.86 Extent (# of units) 1
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 55,568 | 52,922 | 47,629 |
| Expected Losses (%) | 8.6% | 9.0% | 9.9% |
| Net Energy (MWh/yr) | 50,567 | 48,159 | 43,343 |

CAPITAL COSTS

1995\$ -- \$/kWnet

Process Capital

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|-----------------|---------|--------------|
| Power Block | 731 | 769 | 808 |
| Solar Field | 1775 | 1972 | 2169 |
| HTF System | 352 | 371 | 408 |
| BOP | 798 | 886 | 975 |
| Interconnect | 37 | 39 | 41 |
| Overseas Shipping | 432 | 455 | 478 |
| Legal Fees & Permitting | 13 | 15 | 16 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 118 | 131 | 145 |
| Buildings; fence | 97 | 103 | 108 |
| Water supply | 52 | 57 | 63 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 312 | 329 | 345 |
| Initial Costs | 391 | 411 | 432 |
| | 30 | 32 | 34 |
| TOTAL CAPITAL COSTS | | | |
| | \$/kWe,ne 5,138 | 5,570 | 6,020 |
| | \$K 154,155 | 167,103 | 180,607 |

TRANSMISSION

Size (kV) -- Distance (Miles) --
 Cost of Upgrade, \$M 3 3 3

ANNUAL EXPENSES

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|-----------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 85.81 | 95.34 | 104.88 |
| Variable O&M | cents/kWh | 1.74 | 1.93 | 2.12 |
| Land Lease | \$/K | 384 | 426 | 469 |
| FIRST YEAR O&M | \$/K | <u>3,836</u> | <u>4,216</u> | <u>4,535</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Dish Stirling

Island: Maui Location: Kahului Project Code: 318, 319, 320
 Ownrshp: Private

Capacity (MW) 30 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 4.86 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 49,030 | 46,695 | 42,026 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 18.3% | 17.4% | 15.7% |
| Net Energy (MWh/yr) | 47,334 | 45,080 | 40,572 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|---------------------|-------------------|--------------------|
| <i>Process Capital</i> | | | |
| Support Structure | \$/kWe,net 910 | \$/kWe,net 958 | \$/kWe,net 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 294 | 310 | 325 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 96 | 107 | 123 |
| Roads, buildings, fence | 34 | 38 | 42 |
| Engineering & Overhead | 101 | 106 | 111 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 24 | 26 | 27 |
| TOTAL CAPITAL COSTS | \$/kWe,net 3,005 | 3,220 | 3,440 |
| | \$K 88,720 | 95,049 | 101,536 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 3 3 3

ANNUAL EXPENSES

1995\$

| | | | | |
|--------------|-----------|-------|-------|-------|
| Fixed O&M | \$/kW-yr | 23.21 | 25.79 | 28.37 |
| Variable O&M | cents/kWh | 0.90 | 1.00 | 1.10 |
| Land Lease | \$K | 1,638 | 1,820 | 2,002 |

FIRST YEAR O&M \$K 2,759 3,043 3,298

Total O&M, cents/kWh 2.42 2.69 2.95

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Kahului Project Code: 321, 322, 323
 Ownrshp: Private

Capacity (MW) 30 Stage (current/future) Future
 Resource (avg NIP, kWh/m²-day) 4.86 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 51,482 | 49,030 | 44,127 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 19.2% | 18.3% | 16.5% |
| Net Energy (MWh/yr) | 49,700 | 47,334 | 42,600 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|---------------------|-------------------|-------------------|
| <i>Process Capital</i> | | | |
| Support Structure | \$/kWe,net 391 | \$/kWe,net 435 | \$/kWe,net 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 279 | 310 | 341 |
| Overseas Shipping | 30 | 33 | 36 |
| Legal Fees & Permitting | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 86 | 96 | 110 |
| Roads, buildings, fence | 34 | 38 | 42 |
| Engineering & Overhead | 86 | 90 | 95 |
| Project Contingency | 189 | 199 | 209 |
| Initial Costs | 21 | 23 | 24 |
| TOTAL CAPITAL COSTS | \$/kWe,net 1,799 | 1,981 | 2,169 |
| | \$K 53,101 | 58,491 | 64,022 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 3 3 3

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 13.93 | 15.47 | 17.02 |
| Variable O&M | cents/kWh | 0.72 | 0.80 | 0.88 |
| Land Lease | \$K | 1,638 | 1,820 | 2,002 |
| FIRST YEAR O&M | \$K | 2,413 | 2,662 | 2,886 |
| Total O&M, cents/kWh | | 1.59 | 1.76 | 1.94 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Maui Location: Kahului Project Code: 373, 374, 375
 Ownrshp: Private

Capacity (MW) 30 Stage (current/future) Future
 Resource (avg NIP, kWh/m2-day) 4.86 Extent (# of units) 1
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 63,903 | 60,860 | 54,774 |
| Expected Losses (%) | 7.7% | 8.1% | 8.9% |
| Net Energy (MWh/yr) | 58,152 | 55,382 | 49,844 |

CAPITAL COSTS

1995\$ -- \$/kWnet

Process Capital

| | | | |
|-----------------------------------|------|------|------|
| Power Block | 585 | 615 | 646 |
| Solar Field | 1242 | 1381 | 1519 |
| HTF System | 264 | 278 | 306 |
| BOP | 718 | 798 | 877 |
| Interconnect | 33 | 35 | 37 |
| Overseas Shipping | 432 | 455 | 478 |
| Legal Fees & Permitting | 11 | 12 | 13 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 106 | 118 | 130 |
| Buildings; fence | 88 | 92 | 97 |
| Water supply | 52 | 57 | 63 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 266 | 280 | 294 |
| Initial Costs | 293 | 308 | 324 |
| | 21 | 22 | 23 |

TOTAL CAPITAL COSTS

| | | | |
|-----------|---------|---------|---------|
| \$/kWe,ne | 4,110 | 4,451 | 4,806 |
| \$K | 123,301 | 133,525 | 144,167 |

TRANSMISSION

| | | | |
|----------------------|----------------------------|----------|----------|
| Size (kV) <u>--</u> | Distance (Miles) <u>--</u> | | |
| Cost of Upgrade, \$M | <u>3</u> | <u>3</u> | <u>3</u> |

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 51.49 | 57.21 | 62.93 |
| Variable O&M | cents/kWh | 1.39 | 1.54 | 1.70 |
| Land Lease | \$K | 384 | 426 | 469 |
| FIRST YEAR O&M | \$K | <u>2,736</u> | <u>2,997</u> | <u>3,203</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Kahului Project Code: 312, 313, 314
 Ownrshp: Private

Capacity (MW) 10 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 4.86 Extent (# of units) 400
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 16,509 | 15,723 | 14,151 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 18.5% | 17.6% | 15.8% |
| Net Energy (MWh/yr) | 15,938 | 15,179 | 13,661 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|------------|------------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 317 | 334 | 351 |
| Overseas Shipping | 40 | 42 | 44 |
| Legal Fees & Permitting | 0.6 | 0.6 | 0.6 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 113 | 126 | 145 |
| Roads, buildings, fence | 48 | 53 | 58 |
| Engineering & Overhead | 113 | 119 | 125 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 15 | 16 | 17 |
| TOTAL CAPITAL COSTS | | | |
| | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 3,063 | 3,283 | 3,508 |
| | \$K | \$K | \$K |
| | 30,143 | 32,300 | 34,520 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|-------------|-------------|-------------|
| Fixed O&M | \$/kW-yr | 28.92 | 32.13 | 35.34 |
| Variable O&M | cents/kWh | 1.12 | 1.24 | 1.37 |
| Land Lease | \$K | 111 | 123 | 136 |
| FIRST YEAR O&M | \$K | 578 | 633 | 676 |
| Total O&M, cents/kWh | | 2.99 | 3.32 | 3.66 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Kahului Project Code: 315, 316, 317
 Ownrshp: Private

Capacity (MW) 10 Stage (current/future) Future
 Resource (avg NIP, kWh/m2-day) 4.86 Extent (# of units) 400
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 17,335 | 16,509 | 14,858 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 19.4% | 18.5% | 16.6% |
| Net Energy (MWh/yr) | 16,735 | 15,938 | 14,344 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|------------------|----------------|----------------|
| <i>Process Capital</i> | | | |
| Support Structure | \$/kWe,net 391 | \$/kWe,net 435 | \$/kWe,net 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 301 | 334 | 367 |
| Overseas Shipping | 30 | 34 | 37 |
| Legal Fees & Permitting | 0.5 | 0.5 | 0.6 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 102 | 113 | 130 |
| Roads, buildings, fence | 48 | 53 | 58 |
| Engineering & Overhead | 96 | 101 | 106 |
| Project Contingency | 189 | 199 | 209 |
| Initial Costs | 11 | 12 | 13 |
| TOTAL CAPITAL COSTS | | | |
| | \$/kWe,net 1,851 | 2,039 | 2,233 |
| | \$K 18,213 | 20,066 | 21,975 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|-------------|-------------|-------------|
| Fixed O&M | \$/kW-yr | 17.35 | 19.28 | 21.21 |
| Variable O&M | cents/kWh | 0.89 | 0.99 | 1.09 |
| Land Lease | \$K | 111 | 123 | 136 |
| FIRST YEAR O&M | \$K | 434 | 474 | 504 |
| Total O&M, cents/kWh | | 1.97 | 2.18 | 2.40 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Solar Thermal

Island: Maui Location: Kihei Project Code: 364, 365, 366
Ownrshp: Private

| | | | |
|-------------------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Current</u> |
| Resource (avg NIP,kWh/m2-day) | <u>5.16</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | <u>58,998</u> | <u>56,188</u> | <u>50,570</u> |
| Expected Losses (%) | <u>8.6%</u> | <u>9.0%</u> | <u>9.9%</u> |
| Net Energy (MWh/yr) | <u>53,688</u> | <u>51,131</u> | <u>46,018</u> |

CAPITAL COSTS

1995\$ -- \$/kWnet

Process Capital

| | | | |
|-------------------------|-------------|-------------|-------------|
| Power Block | <u>731</u> | <u>769</u> | <u>808</u> |
| Solar Field | <u>1775</u> | <u>1972</u> | <u>2169</u> |
| HTF System | <u>352</u> | <u>371</u> | <u>408</u> |
| BOP | <u>798</u> | <u>886</u> | <u>975</u> |
| Interconnect | <u>37</u> | <u>39</u> | <u>41</u> |
| Overseas Shipping | <u>432</u> | <u>455</u> | <u>478</u> |
| Legal Fees & Permitting | <u>13</u> | <u>15</u> | <u>16</u> |

General Facilities

| | | | |
|-----------------------------------|------------|------------|------------|
| Roads & Grading | <u>118</u> | <u>131</u> | <u>145</u> |
| Buildings; fence | <u>97</u> | <u>103</u> | <u>108</u> |
| Water supply | <u>52</u> | <u>57</u> | <u>63</u> |
| <i>Engineering & Overhead</i> | <u>312</u> | <u>329</u> | <u>345</u> |
| <i>Project Contingency</i> | <u>391</u> | <u>411</u> | <u>432</u> |
| <i>Initial Costs</i> | <u>30</u> | <u>32</u> | <u>34</u> |

TOTAL CAPITAL COSTS

| | | | |
|-------------|----------------|----------------|----------------|
| | <u>5,138</u> | <u>5,570</u> | <u>6,020</u> |
| \$/kWe, net | | | |
| \$K | <u>154,155</u> | <u>167,103</u> | <u>180,607</u> |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>3</u> |

ANNUAL EXPENSES

| | | | | |
|---------------------------|--------------------|---------------------|---------------------|---------------------|
| Fixed O&M | 1995\$ \$/kW-yr | <u>85.81</u> | <u>95.34</u> | <u>104.88</u> |
| Variable O&M | cents/kWh | <u>1.74</u> | <u>1.93</u> | <u>2.12</u> |
| Land Lease | \$K | <u>362</u> | <u>402</u> | <u>442</u> |
| FIRST YEAR O&M | \$K | <u>3,868</u> | <u>4,248</u> | <u>4,565</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Dish Stirling

Island: Maui Location: Kihei Project Code: 306, 307, 308
 Ownrshp: Private

Capacity (MW) 30 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 5.16 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 52,057 | 49,578 | 44,620 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 19.4% | 18.5% | 16.7% |
| Net Energy (MWh/yr) | 50,256 | 47,862 | 43,076 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|-----------------|-----------------|------------------|
| <i>Process Capital</i> | | | |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 294 | 310 | 325 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 96 | 107 | 123 |
| Roads, buildings, fence | 34 | 38 | 42 |
| Engineering & Overhead | 101 | 106 | 111 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 24 | 25 | 26 |
| TOTAL CAPITAL COSTS | 3,005 | 3,219 | 3,439 |
| | \$88,702 | \$95,030 | \$101,515 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 3 3 3

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 23.21 | 25.79 | 28.37 |
| Variable O&M | cents/kWh | 0.90 | 1.00 | 1.10 |
| Land Lease | \$K | 1,543 | 1,714 | 1,886 |
| FIRST YEAR O&M | \$K | 2,690 | 2,965 | 3,209 |
| Total O&M, cents/kWh | | 2.33 | 2.59 | 2.85 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Kihei Project Code: 309, 310, 311
 Ownrshp: Private

Capacity (MW) 30 Stage (current/future) Future
 Resource (avg NIP, kWh/m2-day) 5.16 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 54,660 | 52,057 | 46,851 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 20.4% | 19.4% | 17.5% |
| Net Energy (MWh/yr) | 52,768 | 50,256 | 45,230 |

CAPITAL COSTS

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|--------|------------------|----------------|----------------|
| <i>Process Capital</i> | | | | |
| Support Structure | | \$/kWe,net 391 | \$/kWe,net 435 | \$/kWe,net 478 |
| Aximuth/Elevation Drives | | 115 | 128 | 140 |
| Facets | | 151 | 168 | 184 |
| Dish Control System | | 5 | 5 | 6 |
| Stirling Engine/Generator | | 412 | 458 | 503 |
| Installation | | 279 | 310 | 341 |
| Overseas Shipping | | 30 | 33 | 36 |
| Legal Fees & Permitting | | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | | |
| Grubbing & Grading | | 86 | 96 | 110 |
| Roads, buildings, fence | | 34 | 38 | 42 |
| Engineering & Overhead | | 86 | 90 | 95 |
| Project Contingency | | 189 | 199 | 209 |
| Initial Costs | | 21 | 22 | 23 |
| TOTAL CAPITAL COSTS | | \$/kWe,net 1,798 | 1,981 | 2,168 |
| | | \$K 53,081 | 58,470 | 64,000 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 3 3 3

ANNUAL EXPENSES

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------|-----------|------------|---------|--------------|
| Fixed O&M | \$/kW-yr | 13.93 | 15.47 | 17.02 |
| Variable O&M | cents/kWh | 0.72 | 0.80 | 0.88 |
| Land Lease | \$K | 1,543 | 1,714 | 1,886 |

FIRST YEAR O&M \$K 2,339 2,579 2,793

Total O&M, cents/kWh 1.54 1.71 1.88

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Solar Thermal

Island: Maui Location: Kihei Project Code: 367, 368, 369
Ownrshp: Private

| | | | |
|---------------------------------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Future</u> |
| Resource (avg NIP, kWh/m ² -day) | <u>5.16</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 67,847 | 64,617 | 58,155 |
| Expected Losses (%) | 7.7% | 8.1% | 8.9% |
| Net Energy (MWh/yr) | 61,741 | 58,801 | 52,921 |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|------------|---------|--------------|
| <i>Process Capital</i> | | | |
| Power Block | 585 | 615 | 646 |
| Solar Field | 1242 | 1381 | 1519 |
| HTF System | 264 | 278 | 306 |
| BOP | 718 | 798 | 877 |
| Interconnect | 33 | 35 | 37 |
| Overseas Shipping | 432 | 455 | 478 |
| Legal Fees & Permitting | 11 | 12 | 13 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 106 | 118 | 130 |
| Buildings; fence | 88 | 92 | 97 |
| Water supply | 52 | 57 | 63 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 266 | 280 | 294 |
| <i>Initial Costs</i> | | | |
| TOTAL CAPITAL COSTS | 293 | 308 | 324 |
| | 21 | 22 | 23 |
| | 4,110 | 4,451 | 4,806 |
| | 123,301 | 133,525 | 144,167 |

TRANSMISSION

| | | | | |
|----------------------|-----------|------------------|-----------|----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> | |
| Cost of Upgrade, \$M | | | <u>3</u> | <u>3</u> |

ANNUAL EXPENSES

| | 1995\$ | | | |
|----------------|-----------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 51.49 | 57.21 | 62.93 |
| Variable O&M | cents/kWh | 1.39 | 1.54 | 1.70 |
| Land Lease | \$K | 362 | 402 | 442 |
| FIRST YEAR O&M | \$K | <u>2,764</u> | <u>3,025</u> | <u>3,228</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Kihei Project Code: 300, 301, 302
 Ownrshp: Private

Capacity (MW) 10 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 5.16 Extent (# of units) 400
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 17,528 | 16,694 | 15,024 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 19.6% | 18.7% | 16.8% |
| Net Energy (MWh/yr) | 16,922 | 16,116 | 14,505 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|------------|------------|--------------|
| <i>Process Capital</i> | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 317 | 334 | 351 |
| Overseas Shipping | 40 | 42 | 44 |
| Legal Fees & Permitting | 0.6 | 0.6 | 0.6 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 113 | 126 | 145 |
| Roads, buildings, fence | 48 | 53 | 58 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 252 | 265 | 278 |
| <i>Initial Costs</i> | | | |
| | 15 | 16 | 17 |
| TOTAL CAPITAL COSTS | \$/kWe,net | | |
| | 3,063 | 3,283 | 3,508 |
| | \$K | | |
| | 30,144 | 32,302 | 34,521 |

TRANSMISSION

Size (kV) -- Distance (Miles) --
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|-----------|-------------|-------------|-------------|
| Fixed O&M | \$/kW-yr | 28.92 | 32.13 | 35.34 |
| Variable O&M | cents/kWh | 1.12 | 1.24 | 1.37 |
| Land Lease | \$K | 105 | 116 | 128 |
| FIRST YEAR O&M | \$K | <u>583</u> | <u>638</u> | <u>679</u> |
| Total O&M, cents/kWh | | 2.88 | 3.20 | 3.52 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Kihei Project Code: 303, 304, 305
 Ownrshp: Private

Capacity (MW) 10 Stage (current/future) Future
 Resource (avg NIP, kWh/m2-day) 5.16 Extent (# of units) 400
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 18,405 | 17,528 | 15,776 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 20.6% | 19.6% | 17.7% |
| Net Energy (MWh/yr) | 17,768 | 16,922 | 15,230 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|------------------|---------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 301 | 334 | 367 |
| Overseas Shipping | 30 | 34 | 37 |
| Legal Fees & Permitting | 0.5 | 0.5 | 0.6 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 102 | 113 | 130 |
| Roads, buildings, fence | 48 | 53 | 58 |
| Engineering & Overhead | 96 | 101 | 106 |
| Project Contingency | 189 | 199 | 209 |
| <i>Initial Costs</i> | | | |
| | 12 | 12 | 13 |
| TOTAL CAPITAL COSTS | | | |
| | \$/kWe,net 1,851 | 2,039 | 2,233 |
| | \$K 18,213 | 20,067 | 21,975 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|-------------|-------------|-------------|
| Fixed O&M | \$/kW-yr | 17.35 | 19.28 | 21.21 |
| Variable O&M | cents/kWh | 0.89 | 0.99 | 1.09 |
| Land Lease | \$K | 105 | 116 | 128 |
| FIRST YEAR O&M | \$K | 437 | 477 | 506 |
| Total O&M, cents/kWh | | 1.90 | 2.11 | 2.33 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Solar Thermal

Island: Maui Location: Puunene Project Code: 358, 359, 360
Ownrshp: State

Capacity (MW) 30 Stage (current/future) Current
Resource (avg NIP, kWh/m2-day) 5.01 Extent (# of units) 1
Project Life (years) 30 Construction Time (years) 1.5
Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 57,283 | 54,555 | 49,100 |
| Expected Losses (%) | 8.6% | 9.0% | 9.9% |
| Net Energy (MWh/yr) | 52,127 | 49,645 | 44,681 |

CAPITAL COSTS

1995\$ -- \$/kWnet

Process Capital

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|------------------|---------|--------------|
| Power Block | 731 | 769 | 808 |
| Solar Field | 1775 | 1972 | 2169 |
| HTF System | 352 | 371 | 408 |
| BOP | 798 | 886 | 975 |
| Interconnect | 37 | 39 | 41 |
| Overseas Shipping | 432 | 455 | 478 |
| Legal Fees & Permitting | 13 | 15 | 16 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 118 | 131 | 145 |
| Buildings; fence | 97 | 103 | 108 |
| Water supply | 52 | 57 | 63 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 312 | 329 | 345 |
| <i>Initial Costs</i> | | | |
| | 30 | 32 | 34 |
| TOTAL CAPITAL COSTS | | | |
| | \$/kWe, ne 5,138 | 5,570 | 6,020 |
| | \$K 154,155 | 167,103 | 180,607 |

TRANSMISSION

Size (kV) -- Distance (Miles) --
Cost of Upgrade, \$M 3 3 3

ANNUAL EXPENSES

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|-----------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 85.81 | 95.34 | 104.88 |
| Variable O&M | cents/kWh | 1.74 | 1.93 | 2.12 |
| Land Lease | \$K | 93 | 103 | 114 |
| FIRST YEAR O&M | \$K | <u>3,572</u> | <u>3,921</u> | <u>4,208</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Puunene Project Code: 294, 295, 296
 Ownrshp: State

Capacity (MW) 30 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 5.01 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 50,544 | 48,137 | 43,323 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 18.9% | 18.0% | 16.2% |
| Net Energy (MWh/yr) | 48,795 | 46,471 | 41,824 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|------------|------------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 294 | 310 | 325 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 96 | 107 | 123 |
| Roads, buildings, fence | 34 | 38 | 42 |
| Engineering & Overhead | 101 | 106 | 111 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 14 | 14 | 15 |
| TOTAL CAPITAL COSTS | | | |
| | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 2,994 | 3,208 | 3,427 |
| | \$K | \$K | \$K |
| | 88,396 | 94,708 | 101,178 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 3 3 3

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 23.21 | 25.79 | 28.37 |
| Variable O&M | cents/kWh | 0.90 | 1.00 | 1.10 |
| Land Lease | \$K | 397 | 441 | 486 |
| FIRST YEAR O&M | \$K | 1,531 | 1,678 | 1,795 |
| Total O&M, cents/kWh | | 2.37 | 2.64 | 2.90 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Puunene Project Code: 297, 298, 299
 Ownrshp: State

Capacity (MW) 30 Stage (current/future) Future
 Resource (avg NIP, kWh/m2-day) 5.01 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 53,071 | 50,544 | 45,489 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 19.8% | 18.9% | 17.0% |
| Net Energy (MWh/yr) | 51,234 | 48,795 | 43,915 |

CAPITAL COSTS

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|--------|--------------------------|---------------|---------------|
| <i>Process Capital</i> | | \$/kWe, net | \$/kWe, net | \$/kWe, net |
| Support Structure | | 391 | 435 | 478 |
| Aximuth/Elevation Drives | | 115 | 128 | 140 |
| Facets | | 151 | 168 | 184 |
| Dish Control System | | 5 | 5 | 6 |
| Stirling Engine/Generator | | 412 | 458 | 503 |
| Installation | | 279 | 310 | 341 |
| Overseas Shipping | | 30 | 33 | 36 |
| Legal Fees & Permitting | | 0.3 | 0.3 | 0.3 |
| <i>General Facilities</i> | | | | |
| Grubbing & Grading | | 86 | 96 | 110 |
| Roads, buildings, fence | | 34 | 38 | 42 |
| Engineering & Overhead | | 86 | 90 | 95 |
| Project Contingency | | 189 | 199 | 209 |
| Initial Costs | | 10 | 11 | 12 |
| TOTAL CAPITAL COSTS | | \$/kWe, net 1,788 | 1,970 | 2,157 |
| | | \$K 52,776 | 58,149 | 63,663 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 3 3 3

ANNUAL EXPENSES

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 13.93 | 15.47 | 17.02 |
| Variable O&M | cents/kWh | 0.72 | 0.80 | 0.88 |
| Land Lease | \$K | 397 | 441 | 486 |
| FIRST YEAR O&M | \$K | 1,183 | 1,295 | 1,381 |
| Total O&M, cents/kWh | | 1.56 | 1.73 | 1.91 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Maui Location: Puunene Project Code: 361, 362, 363
 Ownrshp: State

| | | | |
|--------------------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Future</u> |
| Resource (avg NIP, kWh/m2-day) | <u>5.01</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 65,875 | 62,738 | 56,464 |
| Expected Losses (%) | 7.7% | 8.1% | 8.9% |
| Net Energy (MWh/yr) | 59,946 | 57,092 | 51,383 |

CAPITAL COSTS

1995\$ -- \$/kWnet

Process Capital

| | | | | |
|-----------------------------------|-------------|---------|---------|---------|
| Power Block | 585 | 615 | 646 | |
| Solar Field | 1242 | 1381 | 1519 | |
| HTF System | 264 | 278 | 306 | |
| BOP | 718 | 798 | 877 | |
| Interconnect | 33 | 35 | 37 | |
| Overseas Shipping | 432 | 455 | 478 | |
| Legal Fees & Permitting | 11 | 12 | 13 | |
| <i>General Facilities</i> | | | | |
| Roads & Grading | 106 | 118 | 130 | |
| Buildings; fence | 88 | 92 | 97 | |
| Water supply | 52 | 57 | 63 | |
| <i>Engineering & Overhead</i> | | | | |
| Project Contingency | 266 | 280 | 294 | |
| Initial Costs | 293 | 308 | 324 | |
| TOTAL CAPITAL COSTS | 21 | 22 | 23 | |
| | \$ /kWe, ne | 4,110 | 4,451 | 4,806 |
| | \$K | 123,301 | 133,525 | 144,167 |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>3</u> |

ANNUAL EXPENSES

| | 1995\$ | | | |
|----------------|-----------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 51.49 | 57.21 | 62.93 |
| Variable O&M | cents/kWh | 1.39 | 1.54 | 1.70 |
| Land Lease | \$K | 93 | 103 | 114 |
| FIRST YEAR O&M | \$K | <u>2,470</u> | <u>2,701</u> | <u>2,874</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Puunene Project Code: 288, 289, 290
 Ownrshp: State

Capacity (MW) 10 Stage (current/future) Current
 Resource (avg NIP, kWh/m²-day) 5.01 Extent (# of units) 400
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 17,019 | 16,208 | 14,588 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 19.1% | 18.2% | 16.3% |
| Net Energy (MWh/yr) | 16,430 | 15,648 | 14,083 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE | |
|----------------------------|------------|---------|--------------|--------|
| <i>Process Capital</i> | | | | |
| Support Structure | 910 | 958 | 1006 | |
| Aximuth/Elevation Drives | 222 | 234 | 246 | |
| Facets | 194 | 204 | 214 | |
| Dish Control System | 8 | 8 | 8 | |
| Stirling Engine/Generator | 831 | 924 | 1016 | |
| Installation | 317 | 334 | 351 | |
| Overseas Shipping | 40 | 42 | 44 | |
| Legal Fees & Permitting | 0.6 | 0.6 | 0.6 | |
| <i>General Facilities</i> | | | | |
| Grubbing & Grading | 113 | 126 | 145 | |
| Roads, buildings, fence | 48 | 53 | 58 | |
| Engineering & Overhead | 113 | 119 | 125 | |
| Project Contingency | 252 | 265 | 278 | |
| Initial Costs | 13 | 14 | 15 | |
| TOTAL CAPITAL COSTS | | | | |
| | \$/kWe,net | 3,061 | 3,280 | 3,506 |
| | \$K | 30,122 | 32,279 | 34,497 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|-------------|-------------|-------------|
| Fixed O&M | \$/kW-yr | 28.92 | 32.13 | 35.34 |
| Variable O&M | cents/kWh | 1.12 | 1.24 | 1.37 |
| Land Lease | \$K | 27 | 30 | 33 |
| FIRST YEAR O&M | \$K | 500 | 545 | 579 |
| Total O&M, cents/kWh | | 2.94 | 3.26 | 3.59 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Maui Location: Puunene Project Code: 291, 292, 293
 Ownrshp: State

Capacity (MW) 10 Stage (current/future) Future
 Resource (avg NIP, kWh/m2-day) 5.01 Extent (# of units) 400
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 17,870 | 17,019 | 15,317 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 20.0% | 19.1% | 17.2% |
| Net Energy (MWh/yr) | 17,252 | 16,430 | 14,787 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|------------|------------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 301 | 334 | 367 |
| Overseas Shipping | 30 | 34 | 37 |
| Legal Fees & Permitting | 0.5 | 0.5 | 0.6 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 102 | 113 | 130 |
| Roads, buildings, fence | 48 | 53 | 58 |
| Engineering & Overhead | 96 | 101 | 106 |
| Project Contingency | 189 | 199 | 209 |
| Initial Costs | 9 | 10 | 10 |
| TOTAL CAPITAL COSTS | | | |
| | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 1,849 | 2,037 | 2,231 |
| | \$K | \$K | \$K |
| | 18,192 | 20,044 | 21,951 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 0 0 0

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|-------------|-------------|-------------|
| Fixed O&M | \$/kW-yr | 17.35 | 19.28 | 21.21 |
| Variable O&M | cents/kWh | 0.89 | 0.99 | 1.09 |
| Land Lease | \$K | 27 | 30 | 33 |
| FIRST YEAR O&M | \$K | 355 | 386 | 407 |
| Total O&M, cents/kWh | | 1.93 | 2.15 | 2.36 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Maui Location Lower Paia Project Code 679,680,681

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 60 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 13.7 | Extent (no. x dia. buoys) | 360 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 692,688 | 692,688 | 692,688 |
| Wave energy absorption efficiency | 52% | 42% | 21% |
| Absorbed energy (MWh/yr) | 359,023 | 291,993 | 145,996 |
| Conversion & sea-to-shore transmission efficiency | 75% | 78% | 81% |
| Landed energy at 100% availability (MWh/yr) | 269,353 | 226,638 | 117,689 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 255,885 | 203,974 | 94,151 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|--------------------|--------------------|--------------------|
| Buoy and damper plate fabrication | 35,430,000 | 53,145,000 | 70,860,000 |
| Pelton turbine/generator | 17,625,000 | 17,625,000 | 17,625,000 |
| Balance of mechanical & electrical plant | 6,712,000 | 6,712,000 | 6,712,000 |
| Mooring hardware | 8,961,000 | 8,961,000 | 8,961,000 |
| Deployment | 4,909,000 | 7,364,000 | 9,818,000 |
| Sea-to-shore transmission | 4,994,000 | 4,994,000 | 4,994,000 |
| Onshore substation | 3,172,000 | 3,172,000 | 3,172,000 |
| Legal fees and permitting | 795,000 | 845,000 | 896,000 |
| <i>Process Capital Sub-Total</i> | 82,598,000 | 102,818,000 | 123,038,000 |
| <i>General Facilities</i> | 4,130,000 | 10,282,000 | 18,456,000 |
| <i>Engineering & Overhead</i> | 8,260,000 | 10,282,000 | 12,304,000 |
| <i>Project Contingency</i> | 9,499,000 | 12,338,000 | 15,380,000 |
| <i>Initial Costs</i> | 2,310,000 | 3,224,000 | 4,389,000 |
| TOTAL PLANT COST | 106,797,000 | 138,943,000 | 173,566,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 3,000,000 | 4,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|-------------------|
| Ongoing fixed O&M costs | 1,652,000 | 4,113,000 | 7,382,000 |
| Amortized periodic replacements | 994,000 | 2,000,000 | 4,685,000 |
| FIRST YEAR O&M COST | 2,646,000 | 6,112,000 | 12,067,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Maui Location Lower Paia Project Code 676,677,678

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 13.7 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 346,344 | 346,344 | 346,344 |
| Wave energy absorption efficiency | 52% | 42% | 21% |
| Absorbed energy (MWh/yr) | 179,512 | 145,996 | 72,998 |
| Conversion & sea-to-shore transmission efficiency | 75% | 78% | 81% |
| Landed energy at 100% availability (MWh/yr) | 134,692 | 113,331 | 58,848 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 127,957 | 101,998 | 47,078 |

| CAPITAL COSTS (\$) | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,220,000 | 3,220,000 | 3,220,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 697,000 | 723,000 | 750,000 |
| <i>Process Capital Sub-Total</i> | 43,231,000 | 53,798,000 | 64,364,000 |
| <i>General Facilities</i> | 2,162,000 | 5,380,000 | 9,655,000 |
| <i>Engineering & Overhead</i> | 4,323,000 | 5,380,000 | 6,436,000 |
| <i>Project Contingency</i> | 4,972,000 | 6,456,000 | 8,046,000 |
| <i>Initial Costs</i> | 1,208,000 | 1,684,000 | 2,290,000 |
| TOTAL PLANT COST | 55,896,000 | 72,697,000 | 90,791,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 3,000,000 | 4,000,000 |
|-------------------------------------|------------------|------------------|------------------|

| ANNUAL EXPENSES (\$) | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 865,000 | 2,152,000 | 3,862,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,367,000 | 3,166,000 | 6,241,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Maui Location Lower Paia Project Code 073.674.675

| | | | |
|-----------------------|------|---------------------------|----------|
| Project size (MWe) | 10 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 13.7 | Extent (no. x dia. buoys) | 60 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 115,448 | 115,448 | 115,448 |
| Wave energy absorption efficiency | 52% | 42% | 21% |
| Absorbed energy (MWh/yr) | 59,837 | 48,665 | 24,333 |
| Conversion & sea-to-shore transmission efficiency | 75% | 78% | 81% |
| Landed energy at 100% availability (MWh/yr) | 44,879 | 37,763 | 19,612 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 42,635 | 33,987 | 15,690 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 7,080,000 | 10,620,000 | 14,160,000 |
| Pelton turbine/generator | 2,937,000 | 2,937,000 | 2,937,000 |
| Balance of mechanical & electrical plant | 1,119,000 | 1,119,000 | 1,119,000 |
| Mooring hardware | 1,493,000 | 1,493,000 | 1,493,000 |
| Deployment | 1,161,000 | 1,741,000 | 2,322,000 |
| Sea-to-shore transmission | 1,715,000 | 1,715,000 | 1,715,000 |
| Onshore substation | 529,000 | 529,000 | 529,000 |
| Legal fees and permitting | 631,000 | 641,000 | 651,000 |
| <i>Process Capital Sub-Total</i> | 16,665,000 | 20,796,000 | 24,927,000 |
| <i>General Facilities</i> | 833,000 | 2,080,000 | 3,739,000 |
| <i>Engineering & Overhead</i> | 1,667,000 | 2,080,000 | 2,493,000 |
| <i>Project Contingency</i> | 1,917,000 | 2,496,000 | 3,116,000 |
| <i>Initial Costs</i> | 464,000 | 648,000 | 880,000 |
| TOTAL PLANT COST | 21,546,000 | 28,099,000 | 35,155,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|----------------|------------------|------------------|
| Ongoing fixed O&M costs | 333,000 | 832,000 | 1,496,000 |
| Amortized periodic replacements | 175,000 | 356,000 | 842,000 |
| FIRST YEAR O&M COST | 508,000 | 1,188,000 | 2,337,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Maui Location Opana Point Project Code 688,689,690

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 60 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 14.4 | Extent (no. x dia. buoys) | 360 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 727,264 | 727,264 | 727,264 |
| Wave energy absorption efficiency | 52% | 42% | 21% |
| Absorbed energy (MWh/yr) | 376,834 | 306,735 | 153,368 |
| Conversion & sea-to-shore transmission efficiency | 74% | 77% | 81% |
| Landed energy at 100% availability (MWh/yr) | 279,768 | 235,538 | 123,603 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 265,780 | 211,984 | 98,882 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|--------------------|--------------------|--------------------|
| Buoy and damper plate fabrication | 35,430,000 | 53,145,000 | 70,860,000 |
| Pelton turbine/generator | 17,625,000 | 17,625,000 | 17,625,000 |
| Balance of mechanical & electrical plant | 6,712,000 | 6,712,000 | 6,712,000 |
| Mooring hardware | 8,961,000 | 8,961,000 | 8,961,000 |
| Deployment | 4,909,000 | 7,364,000 | 9,818,000 |
| Sea-to-shore transmission | 4,994,000 | 4,994,000 | 4,994,000 |
| Onshore substation | 3,172,000 | 3,172,000 | 3,172,000 |
| Legal fees and permitting | 795,000 | 845,000 | 896,000 |
| <i>Process Capital Sub-Total</i> | 82,598,000 | 102,818,000 | 123,038,000 |
| <i>General Facilities</i> | 4,130,000 | 10,282,000 | 18,456,000 |
| <i>Engineering & Overhead</i> | 8,260,000 | 10,282,000 | 12,304,000 |
| <i>Project Contingency</i> | 9,499,000 | 12,338,000 | 15,380,000 |
| <i>Initial Costs</i> | 2,310,000 | 3,224,000 | 4,389,000 |
| TOTAL PLANT COST | 106,797,000 | 138,943,000 | 173,566,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 3,000,000 | 4,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|-------------------|
| Ongoing fixed O&M costs | 1,652,000 | 4,113,000 | 7,382,000 |
| Amortized periodic replacements | 994,000 | 2,000,000 | 4,685,000 |
| FIRST YEAR O&M COST | 2,646,000 | 6,112,000 | 12,067,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Maui Location Opana Point Project Code 685, 686, 687

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 14.4 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 363,632 | 363,632 | 363,632 |
| Wave energy absorption efficiency | 52% | 42% | 21% |
| Absorbed energy (MWh/yr) | 188,417 | 153,368 | 76,684 |
| Conversion & sea-to-shore transmission efficiency | 74% | 77% | 81% |
| Landed energy at 100% availability (MWh/yr) | 139,901 | 117,782 | 61,805 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 132,906 | 106,004 | 49,444 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,220,000 | 3,220,000 | 3,220,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 697,000 | 723,000 | 750,000 |
| <i>Process Capital Sub-Total</i> | 43,231,000 | 53,798,000 | 64,364,000 |
| <i>General Facilities</i> | 2,162,000 | 5,380,000 | 9,655,000 |
| <i>Engineering & Overhead</i> | 4,323,000 | 5,380,000 | 6,436,000 |
| <i>Project Contingency</i> | 4,972,000 | 6,456,000 | 8,046,000 |
| <i>Initial Costs</i> | 1,208,000 | 1,684,000 | 2,290,000 |
| TOTAL PLANT COST | 55,896,000 | 72,697,000 | 90,791,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 3,000,000 | 4,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 865,000 | 2,152,000 | 3,862,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,367,000 | 3,166,000 | 6,241,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Maui Location Opana Point Project Code 682.683.684

| | | | |
|-----------------------|------|---------------------------|----------|
| Project size (MWe) | 10 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 14.4 | Extent (no. x dia. buoys) | 60 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 121,211 | 121,211 | 121,211 |
| Wave energy absorption efficiency | 52% | 42% | 21% |
| Absorbed energy (MWh/yr) | 62,806 | 51,123 | 25,561 |
| Conversion & sea-to-shore transmission efficiency | 74% | 77% | 81% |
| Landed energy at 100% availability (MWh/yr) | 46,614 | 39,246 | 20,597 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 44,283 | 35,321 | 16,478 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 7,080,000 | 10,620,000 | 14,160,000 |
| Pelton turbine/generator | 2,937,000 | 2,937,000 | 2,937,000 |
| Balance of mechanical & electrical plant | 1,119,000 | 1,119,000 | 1,119,000 |
| Mooring hardware | 1,493,000 | 1,493,000 | 1,493,000 |
| Deployment | 1,161,000 | 1,741,000 | 2,322,000 |
| Sea-to-shore transmission | 1,715,000 | 1,715,000 | 1,715,000 |
| Onshore substation | 529,000 | 529,000 | 529,000 |
| Legal fees and permitting | 631,000 | 641,000 | 651,000 |
| <i>Process Capital Sub-Total</i> | 16,665,000 | 20,796,000 | 24,927,000 |
| <i>General Facilities</i> | 833,000 | 2,080,000 | 3,739,000 |
| <i>Engineering & Overhead</i> | 1,667,000 | 2,080,000 | 2,493,000 |
| <i>Project Contingency</i> | 1,917,000 | 2,496,000 | 3,116,000 |
| <i>Initial Costs</i> | 464,000 | 648,000 | 880,000 |
| TOTAL PLANT COST | 21,546,000 | 28,099,000 | 35,155,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|----------------|------------------|------------------|
| Ongoing fixed O&M costs | 333,000 | 832,000 | 1,496,000 |
| Amortized periodic replacements | 175,000 | 356,000 | 842,000 |
| FIRST YEAR O&M COST | 508,000 | 1,188,000 | 2,337,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Maui Location Waichu Point Project Code 670,671,672

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 12.5 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 340,455 | 340,455 | 340,455 |
| Wave energy absorption efficiency | 52% | 43% | 21% |
| Absorbed energy (MWh/yr) | 178,477 | 145,330 | 72,665 |
| Conversion & sea-to-shore transmission efficiency | 75% | 77% | 80% |
| Landed energy at 100% availability (MWh/yr) | 133,565 | 112,507 | 58,443 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 126,887 | 101,256 | 46,754 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,549,000 | 3,549,000 | 3,549,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 698,000 | 724,000 | 750,000 |
| <i>Process Capital Sub-Total</i> | 43,561,000 | 54,128,000 | 64,694,000 |
| <i>General Facilities</i> | 2,178,000 | 5,413,000 | 9,704,000 |
| <i>Engineering & Overhead</i> | 4,356,000 | 5,413,000 | 6,469,000 |
| <i>Project Contingency</i> | 5,010,000 | 6,495,000 | 8,087,000 |
| <i>Initial Costs</i> | 1,217,000 | 1,694,000 | 2,301,000 |
| TOTAL PLANT COST | 56,322,000 | 73,142,000 | 91,255,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 3,000,000 | 4,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 871,000 | 2,165,000 | 3,882,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,374,000 | 3,179,000 | 6,261,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Maui Location Waiehu Point Project Code 667,668,669

| | | | |
|-----------------------|------|---------------------------|----------|
| Project size (MWe) | 10 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 13.5 | Extent (no. x dia. buoys) | 60 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 113,485 | 113,485 | 113,485 |
| Wave energy absorption efficiency | 52% | 43% | 21% |
| Absorbed energy (MWh/yr) | 59,492 | 48,443 | 24,222 |
| Conversion & sea-to-shore transmission efficiency | 75% | 77% | 80% |
| Landed energy at 100% availability (MWh/yr) | 44,494 | 37,481 | 19,475 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 42,269 | 33,733 | 15,580 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 7,080,000 | 10,620,000 | 14,160,000 |
| Pelton turbine/generator | 2,937,000 | 2,937,000 | 2,937,000 |
| Balance of mechanical & electrical plant | 1,119,000 | 1,119,000 | 1,119,000 |
| Mooring hardware | 1,493,000 | 1,493,000 | 1,493,000 |
| Deployment | 1,161,000 | 1,741,000 | 2,322,000 |
| Sea-to-shore transmission | 1,986,000 | 1,986,000 | 1,986,000 |
| Onshore substation | 529,000 | 529,000 | 529,000 |
| Legal fees and permitting | 631,000 | 642,000 | 652,000 |
| <i>Process Capital Sub-Total</i> | 16,936,000 | 21,067,000 | 25,198,000 |
| <i>General Facilities</i> | 847,000 | 2,107,000 | 3,780,000 |
| <i>Engineering & Overhead</i> | 1,694,000 | 2,107,000 | 2,520,000 |
| <i>Project Contingency</i> | 1,948,000 | 2,528,000 | 3,150,000 |
| <i>Initial Costs</i> | 471,000 | 656,000 | 889,000 |
| TOTAL PLANT COST | 21,896,000 | 28,464,000 | 35,536,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|----------------|------------------|------------------|
| Ongoing fixed O&M costs | 339,000 | 843,000 | 1,512,000 |
| Amortized periodic replacements | 175,000 | 356,000 | 842,000 |
| FIRST YEAR O&M COST | 514,000 | 1,199,000 | 2,354,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wind

Island Maui Location McGregor Point Project Code: 460,461,462
(leave blank)
Capacity (MW) 10 Stage (current/future) Current
Resource (mph, avg.) 15.7 Extent (# of units) 40
Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 26,544 | 24,131 | 21,718 |
| Expected Losses (%) | 13% | 18% | 23% |
| Net Energy (MWh/yr) | <u>23,189</u> | <u>19,874</u> | <u>16,801</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 5,596,290 | 6,218,100 | 6,839,910 |
| Foundations | 436,590 | 441,000 | 445,410 |
| Assembly & Checkout | 258,420 | 261,030 | 263,640 |
| Electrical Infrastructure | 1,144,758 | 1,156,322 | 1,167,885 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 193,347 | 195,300 | 197,253 |
| Legal Fees & Permitting | 250,704 | 313,379 | 391,724 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 101,871 | 102,900 | 103,929 |
| Control System | 88,066 | 88,956 | 89,846 |
| Control Buildings | 36,990 | 37,363 | 37,737 |
| Central Building | 85,121 | 94,579 | 118,223 |

Engineering & Overhead

| | | | |
|-----------------------------------|---------|-----------|-----------|
| <i>Engineering & Overhead</i> | 874,284 | 946,518 | 1,021,737 |
| <i>Project Contingency</i> | 961,713 | 1,041,169 | 1,123,910 |
| <i>Initial Costs</i> | 497,902 | 514,925 | 538,237 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$11,076,741</u> | <u>\$11,967,789</u> | <u>\$12,901,252</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|----------------|------------------|------------------|------------------|
| Variable O&M | 133,915 | 104,339 | 97,025 |
| Fixed O&M | 137,474 | 138,863 | 140,251 |
| Land Lease | 28,249 | 29,736 | 31,223 |
| FIRST YEAR O&M | <u>\$299,638</u> | <u>\$272,938</u> | <u>\$268,499</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location McGregor Point Project Code: 463,464,465
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>33</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 32,870 | 29,882 | 26,894 |
| Expected Losses (%) | 13% | 18% | 23% |
| Net Energy (MWh/yr) | <u>28,715</u> | <u>24,611</u> | <u>20,805</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 4,898,573 | 5,442,858 | 6,259,287 |
| Foundations | 352,983 | 356,549 | 360,114 |
| Assembly & Checkout | 211,064 | 213,196 | 215,328 |
| Electrical Infrastructure | 1,116,197 | 1,127,471 | 1,138,746 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 159,511 | 161,123 | 162,734 |
| Legal Fees & Permitting | 248,681 | 310,851 | 388,564 |

General Facilities

| | | | |
|------------------------|---------|---------|-----------|
| Roads & Grading | 84,407 | 85,260 | 86,113 |
| Control System | 71,928 | 72,655 | 73,381 |
| Control Buildings | 30,211 | 30,516 | 30,822 |
| Central Building | 85,121 | 94,579 | 118,223 |
| Engineering & Overhead | 780,936 | 845,131 | 939,512 |
| Project Contingency | 859,030 | 929,644 | 1,033,463 |
| Initial Costs | 484,459 | 497,185 | 526,692 |

| | | | |
|-----------|--------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$9,933,787</u> | <u>\$10,723,265</u> | <u>\$11,894,790</u> |
|-----------|--------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 162,514 | 126,622 | 117,745 |
| Fixed O&M | 134,724 | 136,085 | 137,446 |
| Land Lease | 28,967 | 30,492 | 32,017 |

| | | | |
|----------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$326,205</u> | <u>\$293,199</u> | <u>\$287,208</u> |
|----------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location NW Haleakala Project Code: 478,479,480
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 114,352 | 103,956 | 93,561 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>88,001</u> | <u>74,804</u> | <u>62,645</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 27,421,821 | 30,468,690 | 33,515,559 |
| Foundations | 1,954,260 | 1,974,000 | 1,993,740 |
| Assembly & Checkout | 1,292,099 | 1,305,150 | 1,318,202 |
| Electrical Infrastructure | 4,292,844 | 4,336,206 | 4,379,568 |
| Sub-Station | 2,753,428 | 2,781,240 | 2,809,052 |
| Overseas Shipping | 966,735 | 976,500 | 986,265 |
| Legal Fees & Permitting | 318,296 | 397,870 | 497,338 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 376,299 | 380,100 | 383,901 |
| Control System | 440,332 | 444,780 | 449,228 |
| Control Buildings | 184,948 | 186,816 | 188,684 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 4,008,618 | 4,334,593 | 4,663,976 |
| <i>Project Contingency</i> | 4,409,480 | 4,768,052 | 5,130,374 |
| <i>Initial Costs</i> | 1,804,585 | 1,892,379 | 2,002,134 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$50,308,866</u> | <u>\$54,340,955</u> | <u>\$58,436,243</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$3,000,000</u> | <u>\$4,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 508,208 | 392,718 | 361,776 |
| Fixed O&M | 687,369 | 694,313 | 701,256 |
| Land Lease | 423,738 | 446,040 | 468,342 |

| | | | |
|----------------|--------------------|--------------------|--------------------|
| FIRST YEAR O&M | <u>\$1,619,316</u> | <u>\$1,533,071</u> | <u>\$1,531,373</u> |
|----------------|--------------------|--------------------|--------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location NW Haleakala Project Code: 481,482,483
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>166</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|----------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 142,463 | 129,512 | 116,561 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>109,635</u> | <u>93,192</u> | <u>78,045</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 24,148,478 | 26,831,642 | 30,856,389 |
| Foundations | 1,589,595 | 1,605,652 | 1,621,708 |
| Assembly & Checkout | 1,061,717 | 1,072,442 | 1,083,166 |
| Electrical Infrastructure | 4,211,105 | 4,253,642 | 4,296,178 |
| Sub-Station | 2,753,428 | 2,781,240 | 2,809,052 |
| Overseas Shipping | 802,390 | 810,495 | 818,600 |
| Legal Fees & Permitting | 308,969 | 386,211 | 482,764 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 312,682 | 315,840 | 318,998 |
| Control System | 361,821 | 365,476 | 369,130 |
| Control Buildings | 151,972 | 153,507 | 155,042 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 3,578,728 | 3,867,072 | 4,292,925 |
| <i>Project Contingency</i> | 3,936,601 | 4,253,780 | 4,722,218 |
| <i>Initial Costs</i> | 1,705,283 | 1,774,096 | 1,915,409 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$45,007,889</u> | <u>\$48,565,674</u> | <u>\$53,859,803</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$3,000,000</u> | <u>\$4,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 620,478 | 479,475 | 441,697 |
| Fixed O&M | 673,622 | 680,426 | 687,231 |
| Land Lease | 437,144 | 460,152 | 483,160 |

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| FIRST YEAR O&M | <u>\$1,731,245</u> | <u>\$1,620,053</u> | <u>\$1,612,087</u> |
|---------------------------|--------------------|--------------------|--------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location NW Haleakala Project Code: 472 14731474
(leave blank)
 Capacity (MW) 30 Stage (current/future) Current
 Resource (mph, avg.) 15.7 Extent (# of units) 120
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 68,611 | 62,374 | 56,136 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>52,801</u> | <u>44,882</u> | <u>37,587</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 16,788,870 | 18,654,300 | 20,519,730 |
| Foundations | 1,172,556 | 1,184,400 | 1,196,244 |
| Assembly & Checkout | 775,259 | 783,090 | 790,921 |
| Electrical Infrastructure | 2,575,706 | 2,601,724 | 2,627,741 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 580,041 | 585,900 | 591,759 |
| Legal Fees & Permitting | 284,761 | 355,951 | 444,939 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 226,611 | 228,900 | 231,189 |
| Control System | 264,199 | 266,868 | 269,537 |
| Control Buildings | 110,969 | 112,090 | 113,210 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 2,451,615 | 2,653,655 | 2,858,893 |
| <i>Project Contingency</i> | 2,696,777 | 2,919,020 | 3,144,782 |
| <i>Initial Costs</i> | 1,159,529 | 1,214,141 | 1,282,208 |

SUB-TOTAL \$30,824,071 \$33,323,361 \$35,874,807

TRANSMISSION

Cost of Upgrade \$2,000,000 \$3,000,000 \$4,000,000

ANNUAL EXPENSES

| | | | |
|---------------------------|------------------|------------------|------------------|
| Variable O&M | 304,925 | 235,631 | 217,065 |
| Fixed O&M | 412,422 | 416,588 | 420,753 |
| Land Lease | 254,243 | 267,624 | 281,005 |
| FIRST YEAR O&M | <u>\$971,589</u> | <u>\$919,843</u> | <u>\$918,824</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location NW Haleakala Project Code: 475,476,477
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>100</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 85,821 | 78,019 | 70,217 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>66,045</u> | <u>56,140</u> | <u>47,015</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 14,844,159 | 16,493,510 | 18,967,537 |
| Foundations | 957,587 | 967,260 | 976,933 |
| Assembly & Checkout | 639,589 | 646,049 | 652,510 |
| Electrical Infrastructure | 2,536,810 | 2,562,435 | 2,588,059 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 483,368 | 488,250 | 493,133 |
| Legal Fees & Permitting | 279,249 | 349,061 | 436,327 |

General Facilities

| | | | |
|------------------------|-----------|-----------|-----------|
| Roads & Grading | 189,189 | 191,100 | 193,011 |
| Control System | 217,964 | 220,166 | 222,368 |
| Control Buildings | 91,549 | 92,474 | 93,399 |
| Central Building | 85,121 | 94,579 | 118,223 |
| Engineering & Overhead | 2,197,664 | 2,377,363 | 2,642,693 |
| Project Contingency | 2,417,431 | 2,615,099 | 2,906,962 |
| Initial Costs | 1,105,535 | 1,148,766 | 1,236,512 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$27,697,273</u> | <u>\$29,914,856</u> | <u>\$33,213,097</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$3,000,000</u> | <u>\$4,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|---------------------------|--------------------|------------------|------------------|
| Variable O&M | 373,782 | 288,840 | 266,082 |
| Fixed O&M | 404,173 | 408,256 | 412,338 |
| Land Lease | 263,340 | 277,200 | 291,060 |
| FIRST YEAR O&M | <u>\$1,041,295</u> | <u>\$974,296</u> | <u>\$969,481</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location NW Haleakala Project Code: 4466, 467, 468
(leave blank)
 Capacity (MW) 10 Stage (current/future) Current
 Resource (mph, avg.) 15.7 Extent (# of units) 40
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 22,870 | 20,791 | 18,712 |
| Expected Losses (%) | 13% | 18% | 23% |
| Net Energy (MWh/yr) | <u>19,980</u> | <u>17,124</u> | <u>14,476</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 5,596,290 | 6,218,100 | 6,839,910 |
| Foundations | 390,852 | 394,800 | 398,748 |
| Assembly & Checkout | 258,420 | 261,030 | 263,640 |
| Electrical Infrastructure | 858,569 | 867,241 | 875,914 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 193,347 | 195,300 | 197,253 |
| Legal Fees & Permitting | 249,983 | 312,478 | 390,598 |

General Facilities

| | | | |
|-------------------|--------|--------|---------|
| Roads & Grading | 76,923 | 77,700 | 78,477 |
| Control System | 88,066 | 88,956 | 89,846 |
| Control Buildings | 36,990 | 37,363 | 37,737 |
| Central Building | 85,121 | 94,579 | 118,223 |

Engineering & Overhead 838,525 910,380 985,216

Project Contingency 922,377 1,001,417 1,083,737

Initial Costs 498,739 517,438 541,653

SUB-TOTAL \$10,644,886 \$11,533,030 \$12,462,762

TRANSMISSION

Cost of Upgrade \$0 \$0 \$0

ANNUAL EXPENSES

Variable O&M 115,382 89,899 83,597

Fixed O&M 137,474 138,863 140,251

Land Lease 84,748 89,208 93,668

FIRST YEAR O&M \$337,604 \$317,970 \$317,517

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location NW Haleakala Project Code: 469,470,471
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>33</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 28,321 | 25,746 | 23,172 |
| Expected Losses (%) | 13% | 18% | 23% |
| Net Energy (MWh/yr) | <u>24,741</u> | <u>21,205</u> | <u>17,926</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 4,898,573 | 5,442,858 | 6,259,287 |
| Foundations | 316,004 | 319,196 | 322,388 |
| Assembly & Checkout | 211,064 | 213,196 | 215,328 |
| Electrical Infrastructure | 837,147 | 845,603 | 854,060 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 159,511 | 161,123 | 162,734 |
| Legal Fees & Permitting | 248,001 | 310,001 | 387,501 |

General Facilities

| | | | |
|-----------------------------------|---------|---------|---------|
| Roads & Grading | 63,825 | 64,470 | 65,115 |
| Control System | 71,928 | 72,655 | 73,381 |
| Control Buildings | 30,211 | 30,516 | 30,822 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 747,207 | 811,045 | 905,065 |
| <i>Project Contingency</i> | 821,928 | 892,149 | 995,571 |
| <i>Initial Costs</i> | 485,157 | 499,801 | 530,290 |

| | | | |
|------------------|--------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$9,526,364</u> | <u>\$10,313,440</u> | <u>\$11,481,576</u> |
|------------------|--------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|---------------------------|------------------|------------------|------------------|
| Variable O&M | 140,023 | 109,098 | 101,450 |
| Fixed O&M | 134,724 | 136,085 | 137,446 |
| Land Lease | 86,902 | 91,476 | 96,050 |
| FIRST YEAR O&M | <u>\$361,650</u> | <u>\$336,659</u> | <u>\$334,946</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location Puunene Project Code: 490,491,492
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>13.6</u> | Extent (# of units) | <u>120</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 55,135 | 50,123 | 45,110 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>42,430</u> | <u>36,067</u> | <u>30,204</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 16,788,870 | 18,654,300 | 20,519,730 |
| Foundations | 1,309,770 | 1,323,000 | 1,336,230 |
| Assembly & Checkout | 775,259 | 783,090 | 790,921 |
| Electrical Infrastructure | 2,575,706 | 2,601,724 | 2,627,741 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 580,041 | 585,900 | 591,759 |
| Legal Fees & Permitting | 285,038 | 356,298 | 445,372 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 226,611 | 228,900 | 231,189 |
| Control System | 264,199 | 266,868 | 269,537 |
| Control Buildings | 110,969 | 112,090 | 113,210 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 2,465,364 | 2,667,549 | 2,872,934 |
| <i>Project Contingency</i> | 2,711,901 | 2,934,304 | 3,160,228 |
| <i>Initial Costs</i> | 1,105,510 | 1,161,329 | 1,228,113 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$30,936,416</u> | <u>\$33,438,674</u> | <u>\$35,990,620</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$3,000,000</u> | <u>\$4,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|----------------|------------------|------------------|------------------|
| Variable O&M | 245,033 | 189,350 | 174,430 |
| Fixed O&M | 412,422 | 416,588 | 420,753 |
| Land Lease | 84,748 | 89,208 | 93,668 |
| FIRST YEAR O&M | <u>\$742,202</u> | <u>\$695,145</u> | <u>\$688,852</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location Puunene Project Code: 493,494,495
(leave blank)
 Capacity (MW) 30 Stage (current/future) Future
 Resource (mph, avg.) 13.6 Extent (# of units) 100
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 68,965 | 62,695 | 56,426 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>53,073</u> | <u>45,113</u> | <u>37,781</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 14,844,159 | 16,493,510 | 18,967,537 |
| Foundations | 1,069,646 | 1,080,450 | 1,091,255 |
| Assembly & Checkout | 639,589 | 646,049 | 652,510 |
| Electrical Infrastructure | 2,536,810 | 2,562,435 | 2,588,059 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 483,368 | 488,250 | 493,133 |
| Legal Fees & Permitting | 279,476 | 349,344 | 436,680 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 189,189 | 191,100 | 193,011 |
| Control System | 217,964 | 220,166 | 222,368 |
| Control Buildings | 91,549 | 92,474 | 93,399 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 2,208,893 | 2,388,710 | 2,654,161 |
| <i>Project Contingency</i> | 2,429,782 | 2,627,581 | 2,919,577 |
| <i>Initial Costs</i> | 1,046,008 | 1,091,129 | 1,177,712 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$27,773,610</u> | <u>\$29,994,522</u> | <u>\$33,293,054</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$3,000,000</u> | <u>\$3,000,000</u> | <u>\$3,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|---------------------------|------------------|------------------|------------------|
| Variable O&M | 300,366 | 232,108 | 213,820 |
| Fixed O&M | 404,173 | 408,256 | 412,338 |
| Land Lease | 87,780 | 92,400 | 97,020 |
| FIRST YEAR O&M | <u>\$792,319</u> | <u>\$732,764</u> | <u>\$723,178</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location Puunene Project Code: 484, 485, 486
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>13.6</u> | Extent (# of units) | <u>40</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 18,378 | 16,708 | 15,037 |
| Expected Losses (%) | 19% | 24% | 29% |
| Net Energy (MWh/yr) | <u>14,940</u> | <u>12,746</u> | <u>10,720</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 5,596,290 | 6,218,100 | 6,839,910 |
| Foundations | 436,590 | 441,000 | 445,410 |
| Assembly & Checkout | 258,420 | 261,030 | 263,640 |
| Electrical Infrastructure | 858,569 | 867,241 | 875,914 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 193,347 | 195,300 | 197,253 |
| Legal Fees & Permitting | 250,075 | 312,594 | 390,742 |

General Facilities

| | | | |
|-------------------|--------|--------|---------|
| Roads & Grading | 76,923 | 77,700 | 78,477 |
| Control System | 88,066 | 88,956 | 89,846 |
| Control Buildings | 36,990 | 37,363 | 37,737 |
| Central Building | 85,121 | 94,579 | 118,223 |

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 843,108 | 915,011 | 989,896 |
|-----------------------------------|---------|---------|---------|

| | | | |
|----------------------------|---------|-----------|-----------|
| <i>Project Contingency</i> | 927,418 | 1,006,512 | 1,088,886 |
|----------------------------|---------|-----------|-----------|

| | | | |
|----------------------|---------|---------|---------|
| <i>Initial Costs</i> | 478,448 | 497,945 | 521,752 |
|----------------------|---------|---------|---------|

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$10,680,050</u> | <u>\$11,569,580</u> | <u>\$12,499,496</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|--------|--------|--------|
| Variable O&M | 86,278 | 66,919 | 61,908 |
|--------------|--------|--------|--------|

| | | | |
|-----------|---------|---------|---------|
| Fixed O&M | 137,474 | 138,863 | 140,251 |
|-----------|---------|---------|---------|

| | | | |
|------------|--------|--------|--------|
| Land Lease | 28,249 | 29,736 | 31,223 |
|------------|--------|--------|--------|

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$252,001</u> | <u>\$235,517</u> | <u>\$233,382</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location Puunene Project Code: 487,488,489
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>13.6</u> | Extent (# of units) | <u>33</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 22,758 | 20,689 | 18,620 |
| Expected Losses (%) | 19% | 24% | 29% |
| Net Energy (MWh/yr) | <u>18,501</u> | <u>15,784</u> | <u>13,275</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 4,898,573 | 5,442,858 | 6,259,287 |
| Foundations | 352,983 | 356,549 | 360,114 |
| Assembly & Checkout | 211,064 | 213,196 | 215,328 |
| Electrical Infrastructure | 837,147 | 845,603 | 854,060 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 159,511 | 161,123 | 162,734 |
| Legal Fees & Permitting | 248,076 | 310,094 | 387,618 |

General Facilities

| | | | |
|-------------------|--------|--------|---------|
| Roads & Grading | 63,825 | 64,470 | 65,115 |
| Control System | 71,928 | 72,655 | 73,381 |
| Control Buildings | 30,211 | 30,516 | 30,822 |
| Central Building | 85,121 | 94,579 | 118,223 |

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 750,913 | 814,789 | 908,849 |
|-----------------------------------|---------|---------|---------|

| | | | |
|----------------------------|---------|---------|---------|
| <i>Project Contingency</i> | 826,004 | 896,268 | 999,734 |
|----------------------------|---------|---------|---------|

| | | | |
|----------------------|---------|---------|---------|
| <i>Initial Costs</i> | 462,741 | 478,489 | 508,617 |
|----------------------|---------|---------|---------|

| | | | |
|------------------|--------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$9,548,782</u> | <u>\$10,337,438</u> | <u>\$11,505,693</u> |
|------------------|--------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|--------|--------|
| Variable O&M | 104,704 | 81,210 | 75,129 |
|--------------|---------|--------|--------|

| | | | |
|-----------|---------|---------|---------|
| Fixed O&M | 134,724 | 136,085 | 137,446 |
|-----------|---------|---------|---------|

| | | | |
|------------|--------|--------|--------|
| Land Lease | 28,967 | 30,492 | 32,017 |
|------------|--------|--------|--------|

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$268,396</u> | <u>\$247,787</u> | <u>\$244,591</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location West Maui Project Code: SOB, SOA, SIO
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>14.4</u> | Extent (# of units) | <u>200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

OPTIMISTIC NOMINAL CONSERVATIVE

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | <u>89,747</u> | <u>81,588</u> | <u>73,429</u> |
| Expected Losses (%) | <u>19%</u> | <u>24%</u> | <u>29%</u> |
| Net Energy (MWh/yr) | <u>72,957</u> | <u>62,245</u> | <u>52,349</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 27,421,821 | 30,468,690 | 33,515,559 |
| Foundations | 1,954,260 | 1,974,000 | 1,993,740 |
| Assembly & Checkout | 1,292,099 | 1,305,150 | 1,318,202 |
| Electrical Infrastructure | 5,151,413 | 5,203,447 | 5,255,482 |
| Sub-Station | 2,753,428 | 2,781,240 | 2,809,052 |
| Overseas Shipping | 966,735 | 976,500 | 986,265 |
| Legal Fees & Permitting | 320,182 | 400,227 | 500,284 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 451,143 | 455,700 | 460,257 |
| Control System | 440,332 | 444,780 | 449,228 |
| Control Buildings | 184,948 | 186,816 | 188,684 |
| Central Building | 85,121 | 94,579 | 118,223 |

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & Overhead</i> | 4,102,148 | 4,429,113 | 4,759,498 |
|-----------------------------------|-----------|-----------|-----------|

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project Contingency</i> | 4,512,363 | 4,872,024 | 5,235,447 |
|----------------------------|-----------|-----------|-----------|

| | | | |
|----------------------|-----------|-----------|-----------|
| <i>Initial Costs</i> | 1,805,498 | 1,898,769 | 2,010,384 |
|----------------------|-----------|-----------|-----------|

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$51,441,490</u> | <u>\$55,491,035</u> | <u>\$59,600,306</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 421,324 | 326,785 | 302,314 |
|--------------|---------|---------|---------|

| | | | |
|-----------|---------|---------|---------|
| Fixed O&M | 687,369 | 694,313 | 701,256 |
|-----------|---------|---------|---------|

| | | | |
|------------|---------|---------|---------|
| Land Lease | 423,738 | 446,040 | 468,342 |
|------------|---------|---------|---------|

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| FIRST YEAR O&M | <u>\$1,532,432</u> | <u>\$1,467,137</u> | <u>\$1,471,912</u> |
|---------------------------|--------------------|--------------------|--------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location West Maui Project Code: 511,512,513
(leave blank)
 Capacity (MW) 50 Stage (current/future) Future
 Resource (mph, avg.) 14.4 Extent (# of units) 166
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 111,810 | 101,645 | 91,481 |
| Expected Losses (%) | 19% | 24% | 29% |
| Net Energy (MWh/yr) | <u>90,891</u> | <u>77,546</u> | <u>65,218</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 24,148,478 | 26,831,642 | 30,856,389 |
| Foundations | 1,589,595 | 1,605,652 | 1,621,708 |
| Assembly & Checkout | 1,061,717 | 1,072,442 | 1,083,166 |
| Electrical Infrastructure | 5,053,326 | 5,104,370 | 5,155,414 |
| Sub-Station | 2,753,428 | 2,781,240 | 2,809,052 |
| Overseas Shipping | 802,390 | 810,495 | 818,600 |
| Legal Fees & Permitting | 310,796 | 388,495 | 485,619 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 374,802 | 378,588 | 382,374 |
| Control System | 361,821 | 365,476 | 369,130 |
| Control Buildings | 151,972 | 153,507 | 155,042 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 3,669,345 | 3,958,649 | 4,385,472 |
| <i>Project Contingency</i> | 4,036,279 | 4,354,513 | 4,824,019 |
| <i>Initial Costs</i> | 1,700,693 | 1,776,133 | 1,919,656 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$46,099,763</u> | <u>\$49,675,780</u> | <u>\$54,983,864</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| Variable O&M | 514,400 | 398,976 | 369,100 |
| Fixed O&M | 673,622 | 680,426 | 687,231 |
| Land Lease | 437,144 | 460,152 | 483,160 |
| FIRST YEAR O&M | <u>\$1,625,167</u> | <u>\$1,539,554</u> | <u>\$1,539,490</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location West Maui Project Code: SD2,SD3,SD4
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>14.4</u> | Extent (# of units) | <u>120</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 53,848 | 48,953 | 44,058 |
| Expected Losses (%) | 19% | 24% | 29% |
| Net Energy (MWh/yr) | <u>43,774</u> | <u>37,347</u> | <u>31,409</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 16,788,870 | 18,654,300 | 20,519,730 |
| Foundations | 1,172,556 | 1,184,400 | 1,196,244 |
| Assembly & Checkout | 775,259 | 783,090 | 790,921 |
| Electrical Infrastructure | 3,090,848 | 3,122,068 | 3,153,289 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 580,041 | 585,900 | 591,759 |
| Legal Fees & Permitting | 285,893 | 357,366 | 446,707 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 271,517 | 274,260 | 277,003 |
| Control System | 264,199 | 266,868 | 269,537 |
| Control Buildings | 110,969 | 112,090 | 113,210 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 2,507,733 | 2,710,366 | 2,916,205 |
| <i>Project Contingency</i> | 2,758,506 | 2,981,403 | 3,207,826 |
| <i>Initial Costs</i> | 1,160,077 | 1,217,975 | 1,287,158 |

| | | | |
|------------------|----------------------------|----------------------------|----------------------------|
| SUB-TOTAL | <u>\$31,503,646</u> | <u>\$34,013,409</u> | <u>\$36,573,245</u> |
|------------------|----------------------------|----------------------------|----------------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|---------------------------|-------------------------|-------------------------|-------------------------|
| Variable O&M | 252,795 | 196,071 | 181,389 |
| Fixed O&M | 412,422 | 416,588 | 420,753 |
| Land Lease | 254,243 | 267,624 | 281,005 |
| FIRST YEAR O&M | <u>\$919,459</u> | <u>\$880,282</u> | <u>\$883,147</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location West Maui Project Code: 505, 506, 507
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>14.4</u> | Extent (# of units) | <u>100</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

OPTIMISTIC NOMINAL CONSERVATIVE

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 67,355 | 61,232 | 55,109 |
| Expected Losses (%) | 19% | 24% | 29% |
| Net Energy (MWh/yr) | <u>54,754</u> | <u>46,715</u> | <u>39,288</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 14,844,159 | 16,493,510 | 18,967,537 |
| Foundations | 957,587 | 967,260 | 976,933 |
| Assembly & Checkout | 639,589 | 646,049 | 652,510 |
| Electrical Infrastructure | 3,044,172 | 3,074,922 | 3,105,671 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 483,368 | 488,250 | 493,133 |
| Legal Fees & Permitting | 280,350 | 350,437 | 438,046 |

General Facilities

| | | | |
|------------------------|-----------|-----------|-----------|
| Roads & Grading | 226,611 | 228,900 | 231,189 |
| Control System | 217,964 | 220,166 | 222,368 |
| Control Buildings | 91,549 | 92,474 | 93,399 |
| Central Building | 85,121 | 94,579 | 118,223 |
| Engineering & Overhead | 2,252,253 | 2,432,529 | 2,698,444 |
| Project Contingency | 2,477,478 | 2,675,782 | 2,968,288 |
| Initial Costs | 1,102,770 | 1,149,993 | 1,239,071 |

| | | | |
|------------------|----------------------------|----------------------------|----------------------------|
| SUB-TOTAL | <u>\$28,355,028</u> | <u>\$30,583,595</u> | <u>\$33,890,242</u> |
|------------------|----------------------------|----------------------------|----------------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|---------------------------|-------------------------|-------------------------|-------------------------|
| Variable O&M | 309,880 | 240,347 | 222,349 |
| Fixed O&M | 404,173 | 408,256 | 412,338 |
| Land Lease | 263,340 | 277,200 | 291,060 |
| FIRST YEAR O&M | <u>\$977,393</u> | <u>\$925,803</u> | <u>\$925,747</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wind

Island Maui Location West Maui Project Code: 496,497,498
(leave blank)
Capacity (MW) 10 Stage (current/future) Current
Resource (mph, avg.) 14.4 Extent (# of units) 40
Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 17,949 | 16,318 | 14,686 |
| Expected Losses (%) | 19% | 24% | 29% |
| Net Energy (MWh/yr) | <u>14,591</u> | <u>12,449</u> | <u>10,470</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 5,596,290 | 6,218,100 | 6,839,910 |
| Foundations | 390,852 | 394,800 | 398,748 |
| Assembly & Checkout | 258,420 | 261,030 | 263,640 |
| Electrical Infrastructure | 1,030,283 | 1,040,689 | 1,051,096 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 193,347 | 195,300 | 197,253 |
| Legal Fees & Permitting | 250,360 | 312,950 | 391,187 |

General Facilities

| | | | |
|-----------------------------------|---------|-----------|-----------|
| Roads & Grading | 91,892 | 92,820 | 93,748 |
| Control System | 88,066 | 88,956 | 89,846 |
| Control Buildings | 36,990 | 37,363 | 37,737 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 857,231 | 929,284 | 1,004,320 |
| <i>Project Contingency</i> | 942,954 | 1,022,212 | 1,104,752 |
| <i>Initial Costs</i> | 495,487 | 515,877 | 540,493 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$10,867,976</u> | <u>\$11,760,207</u> | <u>\$12,692,764</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|----------------|------------------|------------------|------------------|
| Variable O&M | 84,265 | 65,357 | 60,463 |
| Fixed O&M | 137,474 | 138,863 | 140,251 |
| Land Lease | 84,748 | 89,208 | 93,668 |
| FIRST YEAR O&M | <u>\$306,486</u> | <u>\$293,427</u> | <u>\$294,382</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Maui Location West Maui Project Code: 499,500,SD1
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>14.4</u> | Extent (# of units) | <u>33</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 22,227 | 20,207 | 18,186 |
| Expected Losses (%) | 19% | 24% | 29% |
| Net Energy (MWh/yr) | <u>18,069</u> | <u>15,416</u> | <u>12,965</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 4,898,573 | 5,442,858 | 6,259,287 |
| Foundations | 316,004 | 319,196 | 322,388 |
| Assembly & Checkout | 211,064 | 213,196 | 215,328 |
| Electrical Infrastructure | 1,004,577 | 1,014,724 | 1,024,871 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 159,511 | 161,123 | 162,734 |
| Legal Fees & Permitting | 248,364 | 310,455 | 388,069 |

General Facilities

| | | | |
|-----------------------------------|---------|---------|-----------|
| Roads & Grading | 76,175 | 76,944 | 77,713 |
| Control System | 71,928 | 72,655 | 73,381 |
| Control Buildings | 30,211 | 30,516 | 30,822 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 765,221 | 829,249 | 923,463 |
| <i>Project Contingency</i> | 841,743 | 912,174 | 1,015,809 |
| <i>Initial Costs</i> | 480,076 | 496,761 | 527,724 |

| | | | |
|-----------|--------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$9,739,254</u> | <u>\$10,530,679</u> | <u>\$11,701,623</u> |
|-----------|--------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|----------------|------------------|------------------|------------------|
| Variable O&M | 102,260 | 79,315 | 73,375 |
| Fixed O&M | 134,724 | 136,085 | 137,446 |
| Land Lease | 86,902 | 91,476 | 96,050 |
| FIRST YEAR O&M | <u>\$323,887</u> | <u>\$306,876</u> | <u>\$306,871</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Organic Wastes - Ethanol

Island: Oahu

Location: Barber's Point

Project Code: 186,187,188

| | | | |
|-----------------------------|---------|----------------------------|--------|
| Capacity (MW) | 70 | Stage (current/future): | future |
| Resource (fresh tons/year): | 418,060 | Extent: | N/A |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------|-------------|-------------|--------------|
| Gross Energy (eq. MWh/yr) | 475,416 | 432,196 | 388,977 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 475,416 | 432,196 | 388,977 |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------------|------------|------------|------------|
| MSW to RDF front-end processing | 2,414,592 | 3,018,240 | 3,621,888 |
| Biomass preparation | 3,888,024 | 4,860,030 | 5,832,036 |
| Pretreatment | 12,347,089 | 15,433,862 | 18,520,634 |
| Hexose fermentation | 12,107,926 | 15,134,907 | 18,161,889 |
| Pentose fermentation | 3,376,300 | 4,220,375 | 5,064,450 |
| Distillation & dehydration | 2,114,766 | 2,643,458 | 3,172,149 |
| Product storage & denature | 1,705,387 | 2,131,734 | 2,558,081 |
| Boiler | 10,782,830 | 13,478,538 | 16,174,245 |
| Non-boiler utilities | 18,077,319 | 22,596,649 | 27,115,979 |
| Environmental | 2,234,348 | 2,792,935 | 3,351,522 |
| Miscellaneous & control | 3,461,408 | 4,326,760 | 5,192,112 |
| Enzyme production | 1,466,224 | 1,832,779 | 2,199,335 |
| Legal fee & Permitting | 650,904 | 813,630 | 976,356 |

General Facilities

| | | | |
|------------------------------------------|-----------|------------|------------|
| <i>Engineering & overhead</i> | 7,462,712 | 9,328,390 | 11,194,068 |
| <i>Project contingency</i> | 8,208,983 | 10,261,229 | 12,313,474 |
| <i>Initial cost</i> | 1,277,505 | 1,596,881 | 1,916,257 |

| | | | |
|------------------|------------|-------------|-------------|
| SUB-TOTAL | 91,576,318 | 114,470,398 | 137,364,476 |
|------------------|------------|-------------|-------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV): | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-------------|-------------|------------|
| Variable O&M (\$) | (5,346,689) | (2,502,761) | 341,167 |
| Fixed O&M (\$) | 11,546,833 | 14,433,541 | 17,320,250 |
| Land Lease | 9,600 | 12,000 | 14,400 |

| | | | |
|---------------------------|-----------|------------|------------|
| FIRST YEAR O&M | 6,209,744 | 11,942,780 | 17,675,817 |
|---------------------------|-----------|------------|------------|

Note: 1 MW = 0.355 MGPY ethanol
70 MW = 25 MGPY ethanol

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Organic Wastes - Methanol

Island: Oahu

Location: Barber's Point

Project Code: 216, 217, 218

| | | | |
|---------------------------|---------|--------------------------------|--------|
| Capacity (MW): | 95 | Stage (current/future): | future |
| Resource (dry tons/year): | 520,833 | Extent (harvested acres/year): | N/A |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------|-------------------|----------------|---------------------|
| Gross Energy (eq. MWh/yr) | 639,477 | 581,342 | 523,208 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (eq. MWh/yr) | 639,477 | 581,342 | 523,208 |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------------|------------|------------|------------|
| MSW to RDF front-end processing | 28,117,881 | 35,147,351 | 42,176,821 |
| Feed handling, preparation | 8,971,907 | 11,214,883 | 13,457,860 |
| Gasification | 3,494,321 | 4,367,902 | 5,241,482 |
| Gas conditioning | 5,645,480 | 7,056,850 | 8,468,221 |
| Compression | 11,269,974 | 14,087,467 | 16,904,961 |
| Acid gas removal/cooling | 5,131,301 | 6,414,126 | 7,696,951 |
| MeOH syn/purification | 14,208,142 | 17,760,178 | 21,312,213 |
| Utilities/auxiliary | 12,172,411 | 15,215,514 | 18,258,617 |
| Legal fees & permitting | 624,234 | 780,292 | 936,351 |

General Facilities

| | | | |
|-----------------------------------|-----------|------------|------------|
| <i>Engineering & overhead</i> | 8,963,565 | 11,204,456 | 13,445,348 |
| <i>Project contingency</i> | 9,859,922 | 12,324,902 | 14,789,882 |
| <i>Initial cost</i> | 802,719 | 1,003,398 | 1,204,078 |

| | | | |
|------------------|--------------------|--------------------|--------------------|
| SUB-TOTAL | 109,261,857 | 136,577,319 | 163,892,785 |
|------------------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-------------|-------------|-----------|
| Variable O&M (\$) | (7,371,282) | (4,005,772) | (640,262) |
| Fixed O&M (\$) | 6,598,701 | 8,248,377 | 9,898,052 |
| Land Lease | 9,600 | 12,000 | 14,400 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | (762,981) | 4,254,605 | 9,272,190 |
|---------------------------|------------------|------------------|------------------|

Note: IMW = 0.5274 MGPY MeOH
95 MW = 50 MGPY MeOH

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Organic Wastes - Electricity

Island: Oahu

Location: Barber's Point

Project Code: 219,220,221

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 50 | Stage (current/future): | future |
| Resource (dry tons/year): | 373,902 | Extent (harvested acres/year): | N/A |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| MSW to RDF front-end processing | 22,328,576 | 27,910,719 | 33,492,863 |
| Feed handling and prep. | 8,370,725 | 10,463,407 | 12,556,088 |
| Gasification & compressor/precooler | 14,769,967 | 18,462,459 | 22,154,951 |
| Physical cleanup | 904,943 | 1,131,179 | 1,357,415 |
| Ash handling | 872,624 | 1,090,780 | 1,308,936 |
| Gas turbine | 19,617,878 | 24,522,347 | 29,426,816 |
| Balance of plant | 11,139,421 | 13,924,276 | 16,709,131 |
| Legal fees & permitting | 611,189 | 763,986 | 916,783 |

General Facilities

| | | | |
|-----------------------------------|-----------|------------|------------|
| <i>Engineering & overhead</i> | 7,861,532 | 9,826,915 | 11,792,298 |
| <i>Project contingency</i> | 8,647,685 | 10,809,607 | 12,971,528 |
| <i>Initial cost</i> | 759,798 | 949,748 | 1,139,698 |

| | | | |
|------------------|-------------------|--------------------|--------------------|
| SUB-TOTAL | 95,884,338 | 119,855,423 | 143,826,507 |
|------------------|-------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|---------------------------|--------------------|----------------|------------------|
| Variable O&M (\$) | (5,814,218) | (3,528,753) | (1,243,268) |
| Fixed O&M (\$) | 3,318,969 | 4,148,712 | 4,978,454 |
| Land Lease | 9,600 | 12,000 | 14,400 |
| FIRST YEAR O&M | (2,485,649) | 631,959 | 3,749,586 |

PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Grass Crops - Electricity

Island: Oahu

Location: Waialua

Project Code: 724,725,726

| | | | |
|----------------------------|---------|--------------------------------|---------|
| Capacity (MW electricity): | 25 | Stage (current/future): | current |
| Resource (dry tons/year): | 127,750 | Extent (harvested acres/year): | 5,800 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 6,142,154 | 7,226,064 | 8,309,973 |
| Gasification & compressor/precooler | 843,041 | 991,813 | 1,140,585 |
| Physical cleanup | 17,235,500 | 20,277,059 | 23,318,618 |
| Ash handling | 321,158 | 377,833 | 434,508 |
| Gas turbine | 334,540 | 393,576 | 452,613 |
| Balance of plant | 6,490,076 | 7,635,383 | 8,780,691 |
| Legal fee & permitting | 579,916 | 682,254 | 784,592 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 3,194,639 | 3,758,398 | 4,322,158 |
| <i>Project contingency</i> | 3,514,102 | 4,134,238 | 4,754,374 |
| <i>Initial cost</i> | 1,869,387 | 2,199,279 | 2,529,171 |

| | | | |
|-----------|------------|------------|------------|
| SUB-TOTAL | 40,524,513 | 47,675,897 | 54,827,283 |
|-----------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|------------|------------|
| Variable O&M (\$) | 8,795,067 | 10,347,137 | 11,899,207 |
| Fixed O&M (\$) | 3,282,400 | 3,861,647 | 4,440,894 |
| Land Lease | 248,664 | 292,545 | 336,427 |

| | | | |
|----------------|------------|------------|------------|
| FIRST YEAR O&M | 12,326,131 | 14,501,329 | 16,676,528 |
|----------------|------------|------------|------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Grass Crops - Electricity

Island: Oahu

Location: Waialua

Project Code: 727,728,729

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 106,500 | Extent (harvested acres/year): | 5,000 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Project contingency</i> | 3,360,521 | 4,200,651 | 5,040,781 |
| <i>Initial cost</i> | 1,650,863 | 2,063,578 | 2,476,294 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 38,616,590 | 48,270,737 | 57,924,883 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|------------|
| Variable O&M (\$) | 7,239,568 | 9,049,460 | 10,859,352 |
| Fixed O&M (\$) | 2,915,397 | 3,644,246 | 4,373,095 |
| Land Lease | 196,812 | 246,015 | 295,218 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 10,351,777 | 12,939,721 | 15,527,665 |
|---------------------------|-------------------|-------------------|-------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: OTEC (closed cycle, ammonia)

Island Oahu Location Kahe Point Project Code 249,250,251

| | | | |
|---------------------------------------------|--------|---------------------------|-------------|
| Project size (MWe _{gross summer}) | 60 | Stage (current/future) | future |
| Resource (ΔT , summer) | 23.1°C | CWP length, intake depth | 3670m, 670m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|-----------------------------------------------------|----------------|----------------|----------------|
| ENERGY PRODUCTION | | | |
| Gross energy at constant summer ΔT (MWh/yr) | 525,600 | 525,600 | 525,600 |
| Seasonal ΔT variability factor | 84% | 84% | 84% |
| Annual gross energy (MWh/yr) | 441,504 | 441,504 | 441,504 |
| Parasitic power losses | 12 MWe | 13 MWe | 14 MWe |
| Net energy at 100% availability (MWh/yr) | 353,203 | 345,845 | 338,486 |
| Annual average availability | 95% | 90% | 80% |
| NET ENERGY (MWh/yr) | 335,543 | 311,260 | 270,789 |

CAPITAL COSTS (\$)

| | | | |
|-------------------------------------------|--------------------|--------------------|--------------------|
| Plant structure | 84,600,000 | 82,837,000 | 148,097,000 |
| Seawater systems (pipelines and SW pumps) | 95,880,000 | 132,540,000 | 233,496,000 |
| Heat exchangers | 67,680,000 | 138,062,000 | 92,966,000 |
| Turbine/generators | 56,400,000 | 66,270,000 | 11,891,000 |
| Balance of plant | 33,840,000 | 33,135,000 | 59,995,000 |
| Substation | 2,538,000 | 2,485,000 | 2,432,000 |
| Legal fees and permitting | 1,443,000 | 1,729,000 | 1,963,000 |
| <i>Process Capital Sub-Total</i> | 432,381,000 | 457,059,000 | 550,840,000 |
| <i>General Facilities</i> | 17,119,000 | 45,706,000 | 82,626,000 |
| <i>Engineering & Overhead</i> | 34,238,000 | 45,706,000 | 55,084,000 |
| <i>Project Contingency</i> | 39,374,000 | 54,847,000 | 68,855,000 |
| <i>Initial Costs</i> | 8,919,000 | 12,523,000 | 15,837,000 |
| TOTAL PLANT COST | 442,031,000 | 615,841,000 | 773,242,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 3,081,000 | 5,485,000 | 8,263,000 |
| Amortized periodic replacements | 0 | 0 | 0 |
| FIRST YEAR O&M COST | 3,081,000 | 5,485,000 | 8,263,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Lualualei Project Code: 97, 98, 99

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 50 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 1,965 </u> | Extent (PV module area, m ²) | <u> 484,000 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 4 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|---------------|---------------|
| Gross Energy (MWh/yr) | 111,749 | 97,192 | 87,499 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 110,654 | 96,220 | 86,598 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|----------------------|----------------------|----------------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$22,206,250 | \$23,375,000 | \$24,543,750 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$804,021 | \$1,005,026 | \$1,256,283 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,944,148 | \$3,271,275 | \$3,598,403 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |
| <i>Engineering & Overhead</i> | \$14,961,240 | \$14,961,240 | \$14,961,240 |
| <i>Project Contingency</i> | \$17,474,884 | \$17,474,884 | \$17,474,884 |
| <i>Initial Costs</i> | \$3,767,583 | \$3,767,583 | \$3,767,583 |
| SUB-TOTAL | \$207,007,475 | \$226,829,338 | \$236,013,952 |

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$137,832 | \$153,147 | \$168,462 |
| Fixed O&M | \$123,500 | \$130,000 | \$136,500 |
| Land Lease | \$41,921 | \$44,127 | \$46,333 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$303,253 | \$327,274 | \$351,295 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Lualualei Project Code: 640, 641, 642

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | current |
| Resource (kWh/m ²) | 1,965 | Extent (PV module area, m ²) | 484,000 |
| Project Life (years) | 30 | Construction Time (years) | 4 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|---------------|
| Gross Energy (MWh/yr) | 125,158 | 108,855 | 97,999 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 123,931 | 107,766 | 96,990 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|----------------------|----------------------|----------------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$33,309,375 | \$35,062,500 | \$36,815,625 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$804,021 | \$1,005,026 | \$1,256,283 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,944,148 | \$3,271,275 | \$3,598,403 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |
| <i>Engineering & Overhead</i> | \$14,961,240 | \$14,961,240 | \$14,961,240 |
| <i>Project Contingency</i> | \$17,474,884 | \$17,474,884 | \$17,474,884 |
| <i>Initial Costs</i> | \$3,767,583 | \$3,767,583 | \$3,767,583 |
| SUB-TOTAL | \$218,110,600 | \$238,516,838 | \$248,285,827 |

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$206,748 | \$229,721 | \$252,693 |
| Fixed O&M | \$154,375 | \$162,500 | \$170,625 |
| Land Lease | \$41,921 | \$44,127 | \$46,333 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$403,044 | \$436,348 | \$469,651 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Lualualei Project Code: 100, 101, 102

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 50 </u> | Stage (current/future) | <u> future </u> |
| Resource (kWh/m ²) | <u> 1,965 </u> | Extent (PV module area, m ²) | <u> 383,200 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 3 </u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|---------------|---------------|
| Gross Energy (MWh/yr) | 115,801 | 100,717 | 85,636 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 114,666 | 99,710 | 84,754 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$15,988,500 | \$16,830,000 | \$17,671,500 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$691,226 | \$864,033 | \$1,080,041 |

General Facilities

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| Roads and Grading | \$2,355,318 | \$2,617,020 | \$2,878,722 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |
| <i>Engineering & Overhead</i> | \$9,916,283 | \$9,916,283 | \$9,916,283 |
| <i>Project Contingency</i> | \$12,177,875 | \$12,177,875 | \$12,177,875 |
| <i>Initial Costs</i> | \$2,634,678 | \$2,634,678 | \$2,634,678 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$145,330,451 | \$158,081,675 | \$164,491,726 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | |
|-----------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$129,084 | \$143,427 | \$157,770 |
| Fixed O&M | \$117,031 | \$123,191 | \$129,351 |
| Land Lease | \$33,196 | \$34,943 | \$36,690 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$279,312 | \$301,561 | \$323,810 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Lualualei Project Code: 643, 644, 645

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | future |
| Resource (kWh/m ²) | 1,965 | Extent (PV module area, m ²) | 383,200 |
| Project Life (years) | 30 | Construction Time (years) | 3 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|---------------|
| Gross Energy (MWh/yr) | 129,698 | 112,803 | 95,912 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 128,426 | 111,675 | 94,924 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|----------------------|----------------------|----------------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$23,982,750 | \$25,245,000 | \$26,507,250 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$691,226 | \$864,033 | \$1,080,041 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,355,318 | \$2,617,020 | \$2,878,722 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |
| <i>Engineering & Overhead</i> | \$9,916,283 | \$9,916,283 | \$9,916,283 |
| <i>Project Contingency</i> | \$12,177,875 | \$12,177,875 | \$12,177,875 |
| <i>Initial Costs</i> | \$2,634,678 | \$2,634,678 | \$2,634,678 |
| SUB-TOTAL | \$153,324,701 | \$166,496,675 | \$173,327,476 |

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$2,000,000 | \$2,000,000 | \$2,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$193,626 | \$215,141 | \$236,655 |
| Fixed O&M | \$146,289 | \$153,989 | \$161,688 |
| Land Lease | \$33,196 | \$34,943 | \$36,690 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$373,112 | \$404,072 | \$435,033 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Lualualei Project Code: 91, 92, 93

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 20 | Stage (current/future) | current |
| Resource (kWh/m ²) | 1,965 | Extent (PV module area, m ²) | 193,600 |
| Project Life (years) | 30 | Construction Time (years) | 3 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 44,699 | 38,877 | 35,000 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 44,261 | 38,488 | 34,639 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------------|----------------------|----------------------|
| PV Modules | \$51,840,000 | \$57,600,000 | \$60,480,000 |
| Array Structure & Foundations | \$9,405,000 | \$9,900,000 | \$10,395,000 |
| Power Conditioning Units | \$4,387,500 | \$6,750,000 | \$7,087,500 |
| Electrical & SCADA | \$7,449,273 | \$7,524,518 | \$7,599,763 |
| Substation | \$951,184 | \$1,001,246 | \$1,051,308 |
| Overseas Shipping | \$613,700 | \$646,000 | \$678,300 |
| Legal Fees & Permitting | \$598,843 | \$748,554 | \$935,693 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$1,202,985 | \$1,336,650 | \$1,470,315 |
| Buildings and Fencing | \$230,007 | \$255,563 | \$281,119 |
| <i>Engineering & Overhead</i> | \$6,733,626 | \$6,733,626 | \$6,733,626 |
| <i>Project Contingency</i> | \$7,862,173 | \$7,862,173 | \$7,862,173 |
| <i>Initial Costs</i> | \$1,696,482 | \$1,696,482 | \$1,696,482 |
| SUB-TOTAL | \$92,970,772 | \$102,054,812 | \$106,271,279 |

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$55,133 | \$61,259 | \$67,385 |
| Fixed O&M | \$74,100 | \$78,000 | \$81,900 |
| Land Lease | \$16,768 | \$17,651 | \$18,534 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$146,002 | \$156,910 | \$167,818 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Lualualei Project Code: 634, 635, 636

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 20 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 1,965 </u> | Extent (PV module area, m ²) | <u> 193,600 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 3 </u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 50,063 | 43,542 | 39,200 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 49,573 | 43,107 | 38,796 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$51,840,000 | \$57,600,000 | \$60,480,000 |
| Array Structure & Foundations | \$14,107,500 | \$14,850,000 | \$15,592,500 |
| Power Conditioning Units | \$4,387,500 | \$6,750,000 | \$7,087,500 |
| Electrical & SCADA | \$7,449,273 | \$7,524,518 | \$7,599,763 |
| Substation | \$951,184 | \$1,001,246 | \$1,051,308 |
| Overseas Shipping | \$613,700 | \$646,000 | \$678,300 |
| Legal Fees & Permitting | \$598,843 | \$748,554 | \$935,693 |

General Facilities

| | | | |
|-----------------------------------|-------------|-------------|-------------|
| Roads and Grading | \$1,202,985 | \$1,336,650 | \$1,470,315 |
| Buildings and Fencing | \$230,007 | \$255,563 | \$281,119 |
| <i>Engineering & Overhead</i> | \$6,733,626 | \$6,733,626 | \$6,733,626 |
| <i>Project Contingency</i> | \$7,862,173 | \$7,862,173 | \$7,862,173 |
| <i>Initial Costs</i> | \$1,696,482 | \$1,696,482 | \$1,696,482 |

SUB-TOTAL

| | | |
|---------------------|----------------------|----------------------|
| \$97,673,272 | \$107,004,812 | \$111,468,779 |
|---------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|-----------|
| Variable O&M | \$82,700 | \$91,889 | \$101,077 |
| Fixed O&M | \$92,625 | \$97,500 | \$102,375 |
| Land Lease | \$16,768 | \$17,651 | \$18,534 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$192,093 | \$207,040 | \$221,986 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Lualualei Project Code: 94, 95, 96

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 20 </u> | Stage (current/future) | <u> future </u> |
| Resource (kWh/m ²) | <u> 1,965 </u> | Extent (PV module area, m ²) | <u> 153,280 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 2 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 46,321 | 40,287 | 34,254 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 45,867 | 39,884 | 33,901 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$36,288,000 | \$40,320,000 | \$42,336,000 |
| Array Structure & Foundations | \$6,771,600 | \$7,128,000 | \$7,484,400 |
| Power Conditioning Units | \$1,974,375 | \$3,037,500 | \$3,189,375 |
| Electrical & SCADA | \$5,873,752 | \$5,933,083 | \$5,992,414 |
| Substation | \$951,184 | \$1,001,246 | \$1,051,308 |
| Overseas Shipping | \$552,330 | \$581,400 | \$610,470 |
| Legal Fees & Permitting | \$548,002 | \$685,003 | \$856,254 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$962,388 | \$1,069,320 | \$1,176,252 |
| Buildings and Fencing | \$165,862 | \$184,291 | \$202,720 |
| <i>Engineering & Overhead</i> | \$4,460,154 | \$4,460,154 | \$4,460,154 |
| <i>Project Contingency</i> | \$5,474,000 | \$5,474,000 | \$5,474,000 |
| <i>Initial Costs</i> | \$1,185,830 | \$1,185,830 | \$1,185,830 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | \$65,207,477 | \$71,059,827 | \$74,019,177 |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$51,634 | \$57,371 | \$63,108 |
| Fixed O&M | \$70,219 | \$73,915 | \$77,611 |
| Land Lease | \$13,278 | \$13,977 | \$14,676 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$135,131 | \$145,263 | \$155,395 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Lualualei Project Code: 637, 638, 639

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 20 | Stage (current/future) | future |
| Resource (kWh/m ²) | 1,965 | Extent (PV module area, m ²) | 153,280 |
| Project Life (years) | 30 | Construction Time (years) | 2 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 51,879 | 45,121 | 38,365 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 51,371 | 44,670 | 37,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$36,288,000 | \$40,320,000 | \$42,336,000 |
| Array Structure & Foundations | \$10,157,400 | \$10,692,000 | \$11,226,600 |
| Power Conditioning Units | \$1,974,375 | \$3,037,500 | \$3,189,375 |
| Electrical & SCADA | \$5,873,752 | \$5,933,083 | \$5,992,414 |
| Substation | \$951,184 | \$1,001,246 | \$1,051,308 |
| Overseas Shipping | \$552,330 | \$581,400 | \$610,470 |
| Legal Fees & Permitting | \$548,002 | \$685,003 | \$856,254 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$962,388 | \$1,069,320 | \$1,176,252 |
| Buildings and Fencing | \$165,862 | \$184,291 | \$202,720 |
| <i>Engineering & Overhead</i> | \$4,460,154 | \$4,460,154 | \$4,460,154 |
| <i>Project Contingency</i> | \$5,474,000 | \$5,474,000 | \$5,474,000 |
| <i>Initial Costs</i> | \$1,185,830 | \$1,185,830 | \$1,185,830 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$68,593,277 | \$74,623,827 | \$77,761,377 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$77,451 | \$86,057 | \$94,662 |
| Fixed O&M | \$87,774 | \$92,394 | \$97,013 |
| Land Lease | \$13,278 | \$13,977 | \$14,676 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$178,503 | \$192,427 | \$206,351 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Lualualei Project Code: 85, 86, 87

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 1,965 </u> | Extent (PV module area, m ²) | <u> 96,800 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 2 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 22,350 | 19,438 | 17,500 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 22,131 | 19,244 | 17,320 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$4,963,750 | \$5,225,000 | \$5,486,250 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$3,747,787 | \$3,747,787 | \$3,747,787 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$4,371,853 | \$4,371,853 | \$4,371,853 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$710,031 | \$710,031 | \$710,031 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | | |
|--|---------------------|---------------------|---------------------|
| | \$51,378,765 | \$56,515,453 | \$58,917,416 |
|--|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$27,566 | \$30,629 | \$33,692 |
| Fixed O&M | \$46,313 | \$48,750 | \$51,188 |
| Land Lease | \$8,048 | \$8,472 | \$8,896 |

FIRST YEAR O&M

| | | |
|-----------------|-----------------|-----------------|
| \$81,927 | \$87,851 | \$93,775 |
|-----------------|-----------------|-----------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Lualualei Project Code: 628, 629, 630

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 10 | Stage (current/future) | current |
| Resource (kWh/m ²) | 1,965 | Extent (PV module area, m ²) | 96,800 |
| Project Life (years) | 30 | Construction Time (years) | 2 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 25,032 | 21,771 | 19,600 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 24,786 | 21,553 | 19,398 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$7,445,625 | \$7,837,500 | \$8,229,375 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$3,747,787 | \$3,747,787 | \$3,747,787 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$4,371,853 | \$4,371,853 | \$4,371,853 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$710,031 | \$710,031 | \$710,031 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | | |
|--|--------------|--------------|--------------|
| | \$53,860,640 | \$59,127,953 | \$61,660,541 |
|--|--------------|--------------|--------------|

TRANSMISSION

Cost of Upgrade

| | | | |
|--|-----|-----|-----|
| | \$0 | \$0 | \$0 |
|--|-----|-----|-----|

ANNUAL EXPENSES

Variable O&M

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$41,349 | \$45,944 | \$50,538 |
|--------------|----------|----------|----------|

Fixed O&M

| | | | |
|-----------|----------|----------|----------|
| Fixed O&M | \$57,891 | \$60,938 | \$63,984 |
|-----------|----------|----------|----------|

Land Lease

| | | | |
|------------|---------|---------|---------|
| Land Lease | \$8,048 | \$8,472 | \$8,896 |
|------------|---------|---------|---------|

FIRST YEAR O&M

| | | | |
|--|-----------|-----------|-----------|
| | \$107,288 | \$115,353 | \$123,418 |
|--|-----------|-----------|-----------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Lualualei Project Code: 88, 89, 90

| | | | |
|--------------------------------|-------|------------------------------------------|--------|
| Capacity (MW) | 10 | Stage (current/future) | future |
| Resource (kWh/m ²) | 1,965 | Extent (PV module area, m ²) | 76,640 |
| Project Life (years) | 30 | Construction Time (years) | 1 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 23,160 | 20,143 | 17,127 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 22,933 | 19,942 | 16,951 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$3,573,900 | \$3,762,000 | \$3,950,100 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | \$2,482,986 | \$2,482,986 | \$2,482,986 |
| <i>Project Contingency</i> | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | \$499,658 | \$499,658 | \$499,658 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$36,067,805 | \$39,391,356 | \$41,095,538 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|-----|-----|-----|
| Cost of Upgrade | \$0 | \$0 | \$0 |
|-----------------|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$25,817 | \$28,685 | \$31,554 |
| Fixed O&M | \$43,887 | \$46,197 | \$48,507 |
| Land Lease | \$6,374 | \$6,709 | \$7,044 |

FIRST YEAR O&M

| | | |
|-----------------|-----------------|-----------------|
| \$76,077 | \$81,591 | \$87,105 |
|-----------------|-----------------|-----------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Lualualei Project Code: 631, 632, 633

| | | | |
|--------------------------------|----------------------|------------------------------------------|-----------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> future </u> |
| Resource (kWh/m ²) | <u> 1,965 </u> | Extent (PV module area, m ²) | <u> 76,640 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 1 </u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 25,940 | 22,561 | 19,182 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 25,685 | 22,335 | 18,985 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$5,360,850 | \$5,643,000 | \$5,925,150 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | \$2,482,986 | \$2,482,986 | \$2,482,986 |
| <i>Project Contingency</i> | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | \$499,658 | \$499,658 | \$499,658 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$37,854,755 | \$41,272,356 | \$43,070,588 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | |
|-----------------|-----|-----|
| Cost of Upgrade | \$0 | \$0 |
|-----------------|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$38,725 | \$43,028 | \$47,330 |
| Fixed O&M | \$54,859 | \$57,746 | \$60,634 |
| Land Lease | \$6,374 | \$6,709 | \$7,044 |

FIRST YEAR O&M

| | | |
|-----------------|------------------|------------------|
| \$99,957 | \$107,483 | \$115,008 |
|-----------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: North Ewa Plain Project Code: 109, 110, 111

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | current |
| Resource (kWh/m ²) | 1,909 | Extent (PV module area, m ²) | 484,000 |
| Project Life (years) | 30 | Construction Time (years) | 4 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------|--------|--------|
| Gross Energy (MWh/yr) | 111,749 | 97,192 | 87,499 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 110,654 | 96,220 | 86,598 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------|---------------|---------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$22,206,250 | \$23,375,000 | \$24,543,750 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$804,021 | \$1,005,026 | \$1,256,283 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,944,148 | \$3,271,275 | \$3,598,403 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |
| <i>Engineering & Overhead</i> | \$14,961,240 | \$14,961,240 | \$14,961,240 |
| <i>Project Contingency</i> | \$17,474,884 | \$17,474,884 | \$17,474,884 |
| <i>Initial Costs</i> | \$3,785,624 | \$3,785,624 | \$3,785,624 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$207,025,516 | \$226,847,379 | \$236,031,993 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$134,107 | \$149,008 | \$163,909 |
| Fixed O&M | \$123,500 | \$130,000 | \$136,500 |
| Land Lease | \$251,526 | \$264,764 | \$278,002 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$509,133 | \$543,772 | \$578,411 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: North Ewa Plain Project Code: 652, 653, 654

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | current |
| Resource (kWh/m ²) | 1,909 | Extent (PV module area, m ²) | 484,000 |
| Project Life (years) | 30 | Construction Time (years) | 4 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|---------------|
| Gross Energy (MWh/yr) | 125,158 | 108,855 | 97,999 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 123,931 | 107,766 | 96,990 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------|---------------|---------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$33,309,375 | \$35,062,500 | \$36,815,625 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$804,021 | \$1,005,026 | \$1,256,283 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,944,148 | \$3,271,275 | \$3,598,403 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |
| <i>Engineering & Overhead</i> | \$14,961,240 | \$14,961,240 | \$14,961,240 |
| <i>Project Contingency</i> | \$17,474,884 | \$17,474,884 | \$17,474,884 |
| <i>Initial Costs</i> | \$3,785,624 | \$3,785,624 | \$3,785,624 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$218,128,641 | \$238,534,879 | \$248,303,868 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$201,161 | \$223,512 | \$245,863 |
| Fixed O&M | \$154,375 | \$162,500 | \$170,625 |
| Land Lease | \$251,526 | \$264,764 | \$278,002 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$607,062 | \$650,776 | \$694,490 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: North Ewa Plain Project Code: 112, 113, 114

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | future |
| Resource (kWh/m ²) | 1,909 | Extent (PV module area, m ²) | 383,200 |
| Project Life (years) | 30 | Construction Time (years) | 3 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|---------------|---------------|
| Gross Energy (MWh/yr) | 115,802 | 100,717 | 85,636 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 114,667 | 99,710 | 84,754 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|----------------------|----------------------|----------------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$15,988,500 | \$16,830,000 | \$17,671,500 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$691,227 | \$864,033 | \$1,080,042 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,355,318 | \$2,617,020 | \$2,878,722 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |
| <i>Engineering & Overhead</i> | \$9,916,283 | \$9,916,283 | \$9,916,283 |
| <i>Project Contingency</i> | \$12,177,875 | \$12,177,875 | \$12,177,875 |
| <i>Initial Costs</i> | \$2,648,915 | \$2,648,915 | \$2,648,915 |
| SUB-TOTAL | \$145,344,689 | \$158,095,913 | \$164,505,964 |

TRANSMISSION

| | | |
|-----------------|-------------|-------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 |
|-----------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$125,596 | \$139,551 | \$153,506 |
| Fixed O&M | \$117,031 | \$123,191 | \$129,351 |
| Land Lease | \$199,172 | \$209,655 | \$220,138 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$441,800 | \$472,397 | \$502,994 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: North Ewa Plain Project Code: 655, 656, 657

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | future |
| Resource (kWh/m ²) | 1,909 | Extent (PV module area, m ²) | 383,200 |
| Project Life (years) | 30 | Construction Time (years) | 3 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------|---------|--------|
| Gross Energy (MWh/yr) | 129,698 | 112,803 | 95,912 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 128,426 | 111,675 | 94,924 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$23,982,750 | \$25,245,000 | \$26,507,250 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$691,227 | \$864,033 | \$1,080,042 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,355,318 | \$2,617,020 | \$2,878,722 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | \$9,916,283 | \$9,916,283 | \$9,916,283 |
| <i>Initial Costs</i> | | | |
| | \$12,177,875 | \$12,177,875 | \$12,177,875 |
| | \$2,648,915 | \$2,648,915 | \$2,648,915 |

SUB-TOTAL

| | | |
|---------------|---------------|---------------|
| \$153,338,939 | \$166,510,913 | \$173,341,714 |
|---------------|---------------|---------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-------------|-------------|-------------|
| \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$188,394 | \$209,327 | \$230,259 |
| Fixed O&M | \$146,290 | \$153,989 | \$161,689 |
| Land Lease | \$199,172 | \$209,655 | \$220,138 |

FIRST YEAR O&M

| | | |
|-----------|-----------|-----------|
| \$533,856 | \$572,971 | \$612,085 |
|-----------|-----------|-----------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: North Ewa Plain Project Code: 103, 104, 105

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 1,909 </u> | Extent (PV module area, m ²) | <u> 96,800 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 2 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 22,350 | 19,438 | 17,500 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 22,131 | 19,244 | 17,320 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------------|---------------------|---------------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$4,963,750 | \$5,225,000 | \$5,486,250 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |
| <i>Engineering & Overhead</i> | \$3,747,787 | \$3,747,787 | \$3,747,787 |
| <i>Project Contingency</i> | \$4,371,853 | \$4,371,853 | \$4,371,853 |
| <i>Initial Costs</i> | \$713,492 | \$713,492 | \$713,492 |
| SUB-TOTAL | \$51,382,226 | \$56,518,914 | \$58,920,877 |

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$26,822 | \$29,802 | \$32,782 |
| Fixed O&M | \$46,313 | \$48,750 | \$51,188 |
| Land Lease | \$48,293 | \$50,835 | \$53,377 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$121,428 | \$129,387 | \$137,346 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: North Ewa Plain Project Code: 646, 647, 648

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 1,909 </u> | Extent (PV module area, m ²) | <u> 96,800 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 2 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 25,032 | 21,771 | 19,600 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 24,786 | 21,553 | 19,398 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------------|---------------------|---------------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$7,445,625 | \$7,837,500 | \$8,229,375 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |
| <i>Engineering & Overhead</i> | \$3,747,787 | \$3,747,787 | \$3,747,787 |
| <i>Project Contingency</i> | \$4,371,853 | \$4,371,853 | \$4,371,853 |
| <i>Initial Costs</i> | \$713,492 | \$713,492 | \$713,492 |
| SUB-TOTAL | \$53,864,101 | \$59,131,414 | \$61,664,002 |

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$40,233 | \$44,703 | \$49,173 |
| Fixed O&M | \$57,891 | \$60,938 | \$63,984 |
| Land Lease | \$48,293 | \$50,835 | \$53,377 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$146,417 | \$156,476 | \$166,534 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oāhu Location: North Ewa Plain Project Code: 106, 107, 108

| | | | |
|--------------------------------|-------|------------------------------------------|--------|
| Capacity (MW) | 10 | Stage (current/future) | future |
| Resource (kWh/m ²) | 1,909 | Extent (PV module area, m ²) | 76,640 |
| Project Life (years) | 30 | Construction Time (years) | 1 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 23,160 | 20,143 | 17,127 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 22,933 | 19,942 | 16,951 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------------|---------------------|---------------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$3,573,900 | \$3,762,000 | \$3,950,100 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | \$2,482,986 | \$2,482,986 | \$2,482,986 |
| <i>Project Contingency</i> | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | \$499,593 | \$499,593 | \$499,593 |
| SUB-TOTAL | \$36,067,740 | \$39,391,291 | \$41,095,473 |

TRANSMISSION

| | | |
|-----------------|-------------|-------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 |
|-----------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$25,119 | \$27,910 | \$30,701 |
| Fixed O&M | \$43,887 | \$46,197 | \$48,507 |
| Land Lease | \$38,241 | \$40,254 | \$42,267 |

| | | |
|---------------------------|------------------|------------------|
| FIRST YEAR O&M | \$107,247 | \$114,361 |
|---------------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: North Ewa Plain Project Code: 649, 650, 651

| | | | |
|--------------------------------|--------------|------------------------------------------|---------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>future</u> |
| Resource (kWh/m ²) | <u>1,909</u> | Extent (PV module area, m ²) | <u>76,640</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 25,940 | 22,561 | 19,182 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 25,685 | 22,335 | 18,985 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$5,360,850 | \$5,643,000 | \$5,925,150 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | \$2,482,986 | \$2,482,986 | \$2,482,986 |
| <i>Project Contingency</i> | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | \$499,593 | \$499,593 | \$499,593 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$37,854,690 | \$41,272,291 | \$43,070,523 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|--------------------|--------------------|--------------------|
| \$1,000,000 | \$1,000,000 | \$1,000,000 |
|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$37,679 | \$41,865 | \$46,052 |
| Fixed O&M | \$54,859 | \$57,746 | \$60,633 |
| Land Lease | \$38,241 | \$40,254 | \$42,267 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$130,778 | \$139,865 | \$148,951 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Pearl Harbor Project Code: 79, 80, 81

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | current |
| Resource (kWh/m ²) | 2,068 | Extent (PV module area, m ²) | 484,000 |
| Project Life (years) | 30 | Construction Time (years) | 4 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|---------------|---------------|
| Gross Energy (MWh/yr) | 111,749 | 97,192 | 87,499 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 110,654 | 96,220 | 86,598 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------|---------------|---------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$22,206,250 | \$23,375,000 | \$24,543,750 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$804,021 | \$1,005,026 | \$1,256,283 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,944,148 | \$3,271,275 | \$3,598,403 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |
| <i>Engineering & Overhead</i> | \$14,961,240 | \$14,961,240 | \$14,961,240 |
| <i>Project Contingency</i> | \$17,474,884 | \$17,474,884 | \$17,474,884 |
| <i>Initial Costs</i> | \$3,779,314 | \$3,779,314 | \$3,779,314 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$207,019,206 | \$226,841,069 | \$236,025,683 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$145,388 | \$161,542 | \$177,696 |
| Fixed O&M | \$123,500 | \$130,000 | \$136,500 |
| Land Lease | \$167,685 | \$176,510 | \$185,336 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$436,572 | \$468,052 | \$499,532 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Pearl Harbor Project Code: 622, 623, 624

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 50 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 2,068 </u> | Extent (PV module area, m ²) | <u> 484,000 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 4 </u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|---------------|
| Gross Energy (MWh/yr) | 125,158 | 108,855 | 97,999 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 123,931 | 107,766 | 96,990 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|---------------|---------------|---------------|
| PV Modules | \$113,400,000 | \$126,000,000 | \$132,300,000 |
| Array Structure & Foundations | \$33,309,375 | \$35,062,500 | \$36,815,625 |
| Power Conditioning Units | \$9,506,250 | \$14,625,000 | \$15,356,250 |
| Electrical & SCADA | \$18,022,435 | \$18,204,480 | \$18,386,525 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,501,950 | \$1,581,000 | \$1,660,050 |
| Legal Fees & Permitting | \$804,021 | \$1,005,026 | \$1,256,283 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,944,148 | \$3,271,275 | \$3,598,403 |
| Buildings and Fencing | \$304,972 | \$338,858 | \$372,744 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | \$17,474,884 | \$17,474,884 | \$17,474,884 |
| <i>Initial Costs</i> | | | |
| | \$3,779,314 | \$3,779,314 | \$3,779,314 |

| | | | |
|-----------|----------------------|----------------------|----------------------|
| SUB-TOTAL | \$218,122,331 | \$238,528,569 | \$248,297,558 |
|-----------|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$218,082 | \$242,313 | \$266,544 |
| Fixed O&M | \$154,375 | \$162,500 | \$170,625 |
| Land Lease | \$167,685 | \$176,510 | \$185,336 |

| | | | |
|----------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$540,141 | \$581,323 | \$622,505 |
|----------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Pearl Harbor Project Code: 82, 83, 84

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | future |
| Resource (kWh/m ²) | 2,068 | Extent (PV module area, m ²) | 383,200 |
| Project Life (years) | 30 | Construction Time (years) | 3 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------|---------|--------|
| Gross Energy (MWh/yr) | 115,802 | 100,717 | 85,636 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 114,667 | 99,710 | 84,754 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
| Array Structure & Foundations | \$15,988,500 | \$16,830,000 | \$17,671,500 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$691,227 | \$864,033 | \$1,080,042 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,355,318 | \$2,617,020 | \$2,878,722 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |
| <i>Engineering & Overhead</i> | \$9,916,283 | \$9,916,283 | \$9,916,283 |
| <i>Project Contingency</i> | \$12,177,875 | \$12,177,875 | \$12,177,875 |
| <i>Initial Costs</i> | \$2,644,069 | \$2,644,069 | \$2,644,069 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$145,339,843 | \$158,091,067 | \$164,501,118 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$136,161 | \$151,290 | \$166,419 |
| Fixed O&M | \$117,031 | \$123,191 | \$129,351 |
| Land Lease | \$132,782 | \$139,770 | \$146,759 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$385,974 | \$414,251 | \$442,528 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Pearl Harbor Project Code: 625, 626, 627

| | | | |
|--------------------------------|-------|------------------------------------------|---------|
| Capacity (MW) | 50 | Stage (current/future) | future |
| Resource (kWh/m ²) | 2,068 | Extent (PV module area, m ²) | 383,200 |
| Project Life (years) | 30 | Construction Time (years) | 3 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------|---------|--------|
| Gross Energy (MWh/yr) | 129,698 | 112,803 | 95,912 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 128,426 | 111,675 | 94,924 |

CAPITAL COSTS

Process Capital

| PV Modules | \$79,380,000 | \$88,200,000 | \$92,610,000 |
|-----------------------------------|--------------|--------------|--------------|
| Array Structure & Foundations | \$23,982,750 | \$25,245,000 | \$26,507,250 |
| Power Conditioning Units | \$4,277,813 | \$6,581,250 | \$6,910,313 |
| Electrical & SCADA | \$14,210,690 | \$14,354,232 | \$14,497,775 |
| Substation | \$2,113,742 | \$2,224,992 | \$2,336,242 |
| Overseas Shipping | \$1,351,755 | \$1,422,900 | \$1,494,045 |
| Legal Fees & Permitting | \$691,227 | \$864,033 | \$1,080,042 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$2,355,318 | \$2,617,020 | \$2,878,722 |
| Buildings and Fencing | \$232,571 | \$258,412 | \$284,253 |
| <i>Engineering & Overhead</i> | \$9,916,283 | \$9,916,283 | \$9,916,283 |
| <i>Project Contingency</i> | \$12,177,875 | \$12,177,875 | \$12,177,875 |
| <i>Initial Costs</i> | \$2,644,069 | \$2,644,069 | \$2,644,069 |

SUB-TOTAL

| | | |
|----------------------|----------------------|----------------------|
| \$153,334,093 | \$166,506,067 | \$173,336,868 |
|----------------------|----------------------|----------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | \$204,242 | \$226,935 | \$249,629 |
| Fixed O&M | \$146,290 | \$153,989 | \$161,689 |
| Land Lease | \$132,782 | \$139,770 | \$146,759 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$483,313 | \$520,694 | \$558,076 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Pearl Harbor Project Code: 73, 74, 75

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 2,068 </u> | Extent (PV module area, m ²) | <u> 96,800 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 2 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 22,350 | 19,438 | 17,500 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 22,131 | 19,244 | 17,320 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$4,963,750 | \$5,225,000 | \$5,486,250 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |
| <i>Engineering & Overhead</i> | \$3,747,787 | \$3,747,787 | \$3,747,787 |
| <i>Project Contingency</i> | \$4,371,853 | \$4,371,853 | \$4,371,853 |
| <i>Initial Costs</i> | \$712,289 | \$712,289 | \$712,289 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$51,381,023 | \$56,517,711 | \$58,919,674 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-------------|-------------|-------------|
| \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$29,077 | \$32,308 | \$35,539 |
| Fixed O&M | \$46,313 | \$48,750 | \$51,188 |
| Land Lease | \$32,196 | \$33,890 | \$35,585 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$107,585 | \$114,948 | \$122,311 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Pearl Harbor Project Code: 616, 617, 618

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 2,068 </u> | Extent (PV module area, m ²) | <u> 96,800 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 2 </u> |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 25,032 | 21,771 | 19,600 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 24,786 | 21,553 | 19,398 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$7,445,625 | \$7,837,500 | \$8,229,375 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |
| <i>Engineering & Overhead</i> | \$3,747,787 | \$3,747,787 | \$3,747,787 |
| <i>Project Contingency</i> | \$4,371,853 | \$4,371,853 | \$4,371,853 |
| <i>Initial Costs</i> | \$712,289 | \$712,289 | \$712,289 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | \$53,862,898 | \$59,130,211 | \$61,662,799 |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$43,616 | \$48,462 | \$53,308 |
| Fixed O&M | \$57,891 | \$60,938 | \$63,984 |
| Land Lease | \$32,196 | \$33,890 | \$35,585 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$133,702 | \$143,290 | \$152,877 |
|---------------------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Oahu Location: Pearl Harbor Project Code: 76, 77, 78

| | | | |
|--------------------------------|-------|------------------------------------------|--------|
| Capacity (MW) | 10 | Stage (current/future) | future |
| Resource (kWh/m ²) | 2,068 | Extent (PV module area, m ²) | 76,640 |
| Project Life (years) | 30 | Construction Time (years) | 1 |

| | | |
|------------|---------|--------------|
| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|--------|--------|--------|
| Gross Energy (MWh/yr) | 23,160 | 20,143 | 17,127 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 22,933 | 19,942 | 16,951 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$3,573,900 | \$3,762,000 | \$3,950,100 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | \$2,482,986 | \$2,482,986 | \$2,482,986 |
| <i>Project Contingency</i> | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | \$498,671 | \$498,671 | \$498,671 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$36,066,818 | \$39,390,369 | \$41,094,551 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$27,232 | \$30,258 | \$33,284 |
| Fixed O&M | \$43,887 | \$46,197 | \$48,507 |
| Land Lease | \$25,494 | \$26,836 | \$28,178 |

FIRST YEAR O&M

| | | |
|-----------------|------------------|------------------|
| \$96,614 | \$103,291 | \$109,968 |
|-----------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Oahu Location: Pearl Harbor Project Code: 619, 620, 621

| | | | |
|--------------------------------|----------------------|------------------------------------------|-----------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> future </u> |
| Resource (kWh/m ²) | <u> 2,068 </u> | Extent (PV module area, m ²) | <u> 76,640 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 1 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 25,940 | 22,561 | 19,182 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 25,685 | 22,335 | 18,985 |

CAPITAL COSTS

Process Capital

| | | | |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$5,360,850 | \$5,643,000 | \$5,925,150 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | \$2,482,986 | \$2,482,986 | \$2,482,986 |
| <i>Project Contingency</i> | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | \$498,671 | \$498,671 | \$498,671 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | \$37,853,768 | \$41,271,369 | \$43,069,601 |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|-------------|-------------|-------------|
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
|-----------------|-------------|-------------|-------------|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$40,848 | \$45,387 | \$49,926 |
| Fixed O&M | \$54,859 | \$57,746 | \$60,634 |
| Land Lease | \$25,494 | \$26,836 | \$28,178 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | \$121,201 | \$129,969 | \$138,737 |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Solar Thermal

Island: Oahu Location: Lualualei Project Code: 382, 383, 384
Ownrshp: DHHL

| | | | |
|--------------------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>80</u> | Stage (current/future) | <u>Current</u> |
| Resource (avg NIP, kWh/m2-day) | <u>5.01</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 156,870 | 149,400 | 134,460 |
| Expected Losses (%) | 10.5% | 11.0% | 12.1% |
| Net Energy (MWh/yr) | 139,614 | 132,966 | 119,669 |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|-------------|-------------|--------------|
| <i>Process Capital</i> | | | |
| Power Block | 544 | 573 | 602 |
| Solar Field | 1632 | 1813 | 1994 |
| HTF System | 312 | 329 | 362 |
| BOP | 516 | 573 | 630 |
| Interconnect | 24 | 25 | 26 |
| Overseas Shipping | 371 | 390 | 410 |
| Legal Fees & Permitting | 5 | 5 | 6 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 44 | 49 | 54 |
| Buildings; fence | 37 | 38 | 40 |
| Water supply | 19 | 22 | 24 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 312 | 329 | 345 |
| <i>Initial Costs</i> | | | |
| | 21 | 22 | 23 |
| TOTAL CAPITAL COSTS | | | |
| | 4,087 | 4,432 | 4,793 |
| | \$K 326,977 | \$K 354,552 | \$K 383,444 |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>2</u> |

ANNUAL EXPENSES

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 49.82 | 55.36 | 60.89 |
| Variable O&M | cents/kWh | 1.75 | 1.94 | 2.14 |
| Land Lease | \$K | 124 | 138 | 152 |
| FIRST YEAR O&M | \$K | 6,549 | 7,148 | 7,579 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Solar Thermal

Island: Oahu Location: Lualualei Project Code: 385, 386, 387
 Ownrshp: DHHL

| | | | |
|--------------------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>80</u> | Stage (current/future) | <u>Future</u> |
| Resource (avg NIP, kWh/m2-day) | <u>5.01</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 180,401 | 171,810 | 154,629 |
| Expected Losses (%) | 9.4% | 9.9% | 10.9% |
| Net Energy (MWh/yr) | 160,556 | 152,911 | 137,620 |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|------------|-----------|--------------|
| <i>Process Capital</i> | | | |
| Power Block | 435 | 458 | 481 |
| Solar Field | 1142 | 1269 | 1396 |
| HTF System | 234 | 247 | 271 |
| BOP | 464 | 516 | 567 |
| Interconnect | 21 | 23 | 24 |
| Overseas Shipping | 371 | 390 | 410 |
| Legal Fees & Permitting | 4 | 4 | 5 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 40 | 44 | 49 |
| Buildings; fence | 33 | 35 | 36 |
| Water supply | 19 | 22 | 24 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 234 | 247 | 259 |
| <i>Initial Costs</i> | | | |
| TOTAL CAPITAL COSTS | 15 | 16 | 17 |
| | \$3,226 | \$3,494 | \$3,773 |
| | \$258,102 | \$279,496 | \$301,877 |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>2</u> |

ANNUAL EXPENSES

1995\$

| | | | | |
|----------------|-----------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 29.89 | 33.21 | 36.54 |
| Variable O&M | cents/kWh | 1.40 | 1.55 | 1.71 |
| Land Lease | \$K | 124 | 138 | 152 |
| FIRST YEAR O&M | \$K | <u>4,760</u> | <u>5,170</u> | <u>5,426</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Oahu Location: Lualualei Project Code: 328, 329, 330
 Ownrshp: DHHL

Capacity (MW) 50 Stage (current/future) Current
 Resource (avg NIP, kWh/m²-day) 5.01 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 83,812 | 79,821 | 71,839 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 18.8% | 17.9% | 16.1% |
| Net Energy (MWh/yr) | 80,912 | 77,059 | 69,353 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|---------------------|-------------------|--------------------|
| <i>Process Capital</i> | | | |
| Support Structure | \$/kWe,net 910 | \$/kWe,net 958 | \$/kWe,net 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 294 | 310 | 325 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.2 | 0.2 | 0.2 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 89 | 99 | 114 |
| Roads, buildings, fence | 29 | 33 | 36 |
| Engineering & Overhead | 101 | 106 | 111 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 10 | 11 | 11 |
| TOTAL CAPITAL COSTS | \$/kWe,net 2,979 | 3,192 | 3,409 |
| | \$K 146,578 | 157,024 | 167,714 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 2 2 2

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|-----------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 23.21 | 25.79 | 28.37 |
| Variable O&M | cents/kWh | 0.90 | 1.00 | 1.10 |
| Land Lease | \$K | 67 | 75 | 82 |
| FIRST YEAR O&M | \$K | <u>1,954</u> | <u>2,132</u> | <u>2,261</u> |
| Total O&M, cents/kWh | | 2.38 | 2.64 | 2.91 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Oahu Location: Lualualei Project Code: 331, 332, 333
 Ownrshp: DHHL

| | | | |
|--------------------------------|-------------|---------------------------|-------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | |
| Resource (avg NIP, kWh/m2-day) | <u>5.01</u> | Extent (# of units) | <u>1200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 88,002 | 83,812 | 75,430 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 19.7% | 18.8% | 16.9% |
| Net Energy (MWh/yr) | 84,957 | 80,912 | 72,820 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|-------------------|-------------------|-------------------|
| <i>Process Capital</i> | <i>\$/kWe,net</i> | <i>\$/kWe,net</i> | <i>\$/kWe,net</i> |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 279 | 310 | 341 |
| Overseas Shipping | 30 | 33 | 36 |
| Legal Fees & Permitting | 0.2 | 0.2 | 0.2 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 80 | 89 | 102 |
| Roads, buildings, fence | 29 | 33 | 36 |
| Engineering & Overhead | 86 | 90 | 95 |
| Project Contingency | 189 | 199 | 209 |
| Initial Costs | 7 | 8 | 8 |
| TOTAL CAPITAL COSTS | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 1,773 | 1,954 | 2,139 |
| | \$K | \$K | \$K |
| | 87,247 | 96,131 | 105,234 |

TRANSMISSION

| | | | |
|----------------------|----------|------------------|----------|
| Size (kV) | <u>—</u> | Distance (Miles) | <u>—</u> |
| Cost of Upgrade, \$M | | | <u>2</u> |

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------|----------------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 13.93 | 15.47 | 17.02 |
| Variable O&M | cents/kWh | 0.72 | 0.80 | 0.88 |
| Land Lease | \$K | 67 | 75 | 82 |
| FIRST YEAR O&M | \$K | <u>1,373</u> | <u>1,494</u> | <u>1,572</u> |
| | Total O&M, cents/kWh | 1.56 | 1.74 | 1.91 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Oahu Location: N. Ewa Plain Project Code: 388, 389, 390
 Ownrshp: Private

| | | | |
|---------------------------------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>80</u> | Stage (current/future) | <u>Current</u> |
| Resource (avg NIP, kWh/m ² -day) | <u>4.86</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 152,173 | 144,927 | 130,434 |
| Expected Losses (%) | 10.5% | 11.0% | 12.1% |
| Net Energy (MWh/yr) | 135,434 | 128,985 | 116,086 |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------|--------------|--------------|
| <i>Process Capital</i> | | | |
| Power Block | 544 | 573 | 602 |
| Solar Field | 1632 | 1813 | 1994 |
| HTF System | 312 | 329 | 362 |
| BOP | 516 | 573 | 630 |
| Interconnect | 24 | 25 | 26 |
| Overseas Shipping | 371 | 390 | 410 |
| Legal Fees & Permitting | 5 | 5 | 6 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 44 | 49 | 54 |
| Buildings; fence | 37 | 38 | 40 |
| Water supply | 19 | 22 | 24 |
| <i>Engineering & Overhead</i> | 250 | 263 | 276 |
| <i>Project Contingency</i> | 312 | 329 | 345 |
| <i>Initial Costs</i> | 21 | 22 | 23 |
| TOTAL CAPITAL COSTS | 4,087 | 4,432 | 4,793 |
| \$/kWe, ne | 326,977 | 354,552 | 383,444 |
| \$K | | | |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>1</u> |

ANNUAL EXPENSES

| | 1995\$ | | | |
|---------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 49.82 | 55.36 | 60.89 |
| Variable O&M | cents/kWh | 1.75 | 1.94 | 2.14 |
| Land Lease | \$K | 1024 | 1137 | 1251 |
| FIRST YEAR O&M | \$K | 7,376 | 8,070 | 8,601 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Solar Thermal

Island: Oahu Location: N. Ewa Plain Project Code: 391, 392, 393
Ownrshp: Private

| | | | |
|-------------------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>80</u> | Stage (current/future) | <u>Future</u> |
| Resource (avg NIP,kWh/m2-day) | <u>4.86</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|----------------|----------------|
| Gross Energy (MWh/yr) | <u>174,999</u> | <u>166,666</u> | <u>149,999</u> |
| Expected Losses (%) | <u>9.4%</u> | <u>9.9%</u> | <u>10.9%</u> |
| Net Energy (MWh/yr) | <u>155,749</u> | <u>148,333</u> | <u>133,499</u> |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------------|----------------|----------------|
| <i>Process Capital</i> | | | |
| Power Block | 435 | 458 | 481 |
| Solar Field | 1142 | 1269 | 1396 |
| HTF System | 234 | 247 | 271 |
| BOP | 464 | 516 | 567 |
| Interconnect | 21 | 23 | 24 |
| Overseas Shipping | 371 | 390 | 410 |
| Legal Fees & Permitting | 4 | 4 | 5 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 40 | 44 | 49 |
| Buildings; fence | 33 | 35 | 36 |
| Water supply | 19 | 22 | 24 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 234 | 247 | 259 |
| <i>Initial Costs</i> | | | |
| TOTAL CAPITAL COSTS | <u>3,226</u> | <u>3,494</u> | <u>3,773</u> |
| | <u>\$K 258,102</u> | <u>279,496</u> | <u>301,877</u> |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>1</u> |

ANNUAL EXPENSES

| | | | | |
|----------------|--------------------|--------------|--------------|--------------|
| Fixed O&M | 1995\$ \$/kW-yr | <u>29.89</u> | <u>33.21</u> | <u>36.54</u> |
| Variable O&M | cents/kWh | <u>1.40</u> | <u>1.55</u> | <u>1.71</u> |
| Land Lease | \$K | <u>1024</u> | <u>1137</u> | <u>1251</u> |
| FIRST YEAR O&M | \$K | <u>5,592</u> | <u>6,098</u> | <u>6,454</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Oahu Location: N. Ewa Point Project Code: 334, 335, 336
 Ownrshp: Private

Capacity (MW) 50 Stage (current/future) Current
 Resource (avg NIP, kWh/m2-day) 4.86 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 81,302 | 77,431 | 69,688 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 18.2% | 17.3% | 15.6% |
| Net Energy (MWh/yr) | 78,489 | 74,752 | 67,276 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|---------------------|-------------------|--------------------|
| <i>Process Capital</i> | | | |
| Support Structure | \$/kWe,net 910 | \$/kWe,net 958 | \$/kWe,net 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 294 | 310 | 325 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.2 | 0.2 | 0.2 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 89 | 99 | 114 |
| Roads, buildings, fence | 29 | 33 | 36 |
| Engineering & Overhead | 101 | 106 | 111 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 13 | 13 | 14 |
| TOTAL CAPITAL COSTS | \$/kWe,net 2,982 | 3,194 | 3,412 |
| | \$K 146,701 | 157,154 | 167,850 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 1 1 1

ANNUAL EXPENSES

| | 1995\$ | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------------|-----------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 23.21 | 25.79 | 28.37 |
| Variable O&M | cents/kWh | 0.90 | 1.00 | 1.10 |
| Land Lease | \$K | 555 | 617 | 678 |
| FIRST YEAR O&M | \$K | <u>2,420</u> | <u>2,651</u> | <u>2,834</u> |
| Total O&M, cents/kWh | | 2.42 | 2.69 | 2.96 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Oahu Location: N. Ewa Point Project Code: 337, 338, 339
 Ownrshp: Private

Capacity (MW) 50 Stage (current/future) Future
 Resource (avg NIP, kWh/m²-day) 4.86 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 85,367 | 81,302 | 73,172 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 19.1% | 18.2% | 16.4% |
| Net Energy (MWh/yr) | 82,414 | 78,489 | 70,640 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|---------------|---------------|----------------|
| <i>Process Capital</i> | | | |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 279 | 310 | 341 |
| Overseas Shipping | 30 | 33 | 36 |
| Legal Fees & Permitting | 0.2 | 0.2 | 0.2 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 80 | 89 | 102 |
| Roads, buildings, fence | 29 | 33 | 36 |
| Engineering & Overhead | 86 | 90 | 95 |
| Project Contingency | 189 | 199 | 209 |
| Initial Costs | 10 | 10 | 11 |
| TOTAL CAPITAL COSTS | 1,776 | 1,957 | 2,142 |
| | \$K | \$K | \$K |
| | 87,371 | 96,262 | 105,371 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 1 1 1

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 13.93 | 15.47 | 17.02 |
| Variable O&M | cents/kWh | 0.72 | 0.80 | 0.88 |
| Land Lease | \$K | 555 | 617 | 678 |
| FIRST YEAR O&M | \$K | 1,843 | 2,016 | 2,149 |
| Total O&M, cents/kWh | | 1.59 | 1.77 | 1.94 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Oahu Location: Pearl Harbor BZ Project Code: 376, 377, 378
 Ownrshp: USN

| | | | |
|---------------------------------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>80</u> | Stage (current/future) | <u>Current</u> |
| Resource (avg NIP, kWh/m ² -day) | <u>5.26</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 164,698 | 156,855 | 141,170 |
| Expected Losses (%) | 10.5% | 11.0% | 12.1% |
| Net Energy (MWh/yr) | 146,581 | 139,601 | 125,641 |

CAPITAL COSTS

1995\$ -- \$/kWnet

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------|--------------|--------------|
| <i>Process Capital</i> | | | |
| Power Block | 544 | 573 | 602 |
| Solar Field | 1632 | 1813 | 1994 |
| HTF System | 312 | 329 | 362 |
| BOP | 516 | 573 | 630 |
| Interconnect | 24 | 25 | 26 |
| Overseas Shipping | 371 | 390 | 410 |
| Legal Fees & Permitting | 5 | 5 | 6 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 44 | 49 | 54 |
| Buildings; fence | 37 | 38 | 40 |
| Water supply | 19 | 22 | 24 |
| <i>Engineering & Overhead</i> | 250 | 263 | 276 |
| <i>Project Contingency</i> | 312 | 329 | 345 |
| <i>Initial Costs</i> | 21 | 22 | 23 |
| TOTAL CAPITAL COSTS | 4,087 | 4,432 | 4,793 |
| \$/kWe, ne | 326,977 | 354,552 | 383,444 |
| \$K | | | |

TRANSMISSION

| | | | |
|----------------------|-----------|------------------|-----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> |
| Cost of Upgrade, \$M | | | <u>1</u> |

ANNUAL EXPENSES

| | | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|--------------------|--------------|--------------|--------------|
| Fixed O&M | 1995\$ \$/kW-yr | 49.82 | 55.36 | 60.89 |
| Variable O&M | cents/kWh | 1.75 | 1.94 | 2.14 |
| Land Lease | \$K | 473 | 525 | 578 |
| FIRST YEAR O&M | \$K | 7,020 | 7,664 | 8,132 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Solar Thermal

Island: Oahu Location: Pearl Harbor BZ Project Code: 379, 380, 381
 Ownrshp: USN

| | | | |
|--------------------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>80</u> | Stage (current/future) | <u>Future</u> |
| Resource (avg NIP, kWh/m2-day) | <u>5.26</u> | Extent (# of units) | <u>1</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 189,403 | 180,383 | 162,345 |
| Expected Losses (%) | 9.4% | 9.9% | 10.9% |
| Net Energy (MWh/yr) | 168,568 | 160,541 | 144,487 |

CAPITAL COSTS

1995\$ -- \$/kWnet

Process Capital

| | | | |
|-----------------------------------|------|------|------|
| Power Block | 435 | 458 | 481 |
| Solar Field | 1142 | 1269 | 1396 |
| HTF System | 234 | 247 | 271 |
| BOP | 464 | 516 | 567 |
| Interconnect | 21 | 23 | 24 |
| Overseas Shipping | 371 | 390 | 410 |
| Legal Fees & Permitting | 4 | 4 | 5 |
| <i>General Facilities</i> | | | |
| Roads & Grading | 40 | 44 | 49 |
| Buildings; fence | 33 | 35 | 36 |
| Water supply | 19 | 22 | 24 |
| <i>Engineering & Overhead</i> | 212 | 224 | 235 |
| <i>Project Contingency</i> | 234 | 247 | 259 |
| <i>Initial Costs</i> | 15 | 16 | 17 |

TOTAL CAPITAL COSTS

| | | | |
|-----------|---------|---------|---------|
| \$/kWe,ne | 3,226 | 3,494 | 3,773 |
| \$K | 258,102 | 279,496 | 301,877 |

TRANSMISSION

| | | | | |
|----------------------|-----------|------------------|-----------|----------|
| Size (kV) | <u>--</u> | Distance (Miles) | <u>--</u> | |
| Cost of Upgrade, \$M | | | <u>1</u> | <u>1</u> |

ANNUAL EXPENSES

| | 1995\$ | | | |
|---------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 49.82 | 33.21 | 60.89 |
| Variable O&M | cents/kWh | 1.75 | 1.55 | 2.14 |
| Land Lease | \$K | 473 | 525 | 578 |
| FIRST YEAR O&M | \$K | <u>7,404</u> | <u>5,676</u> | <u>8,535</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Oahu Location: Pearl Harbor Project Code: 324, 325, 326
 Ownrshp: USN

| | | | |
|---------------------------------------------|-------------|---------------------------|------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | Current |
| Resource (avg NIP, kWh/m ² -day) | <u>5.26</u> | Extent (# of units) | 1200 |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 87,994 | 83,804 | 75,423 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 19.7% | 18.8% | 16.9% |
| Net Energy (MWh/yr) | 84,949 | 80,904 | 72,814 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|-------------------|-------------------|-------------------|
| <i>Process Capital</i> | <i>\$/kWe,net</i> | <i>\$/kWe,net</i> | <i>\$/kWe,net</i> |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 294 | 310 | 325 |
| Overseas Shipping | 39 | 41 | 44 |
| Legal Fees & Permitting | 0.2 | 0.2 | 0.2 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 89 | 99 | 114 |
| Roads, buildings, fence | 29 | 33 | 36 |
| Engineering & Overhead | 101 | 106 | 111 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 11 | 12 | 13 |
| TOTAL CAPITAL COSTS | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 2,980 | 3,193 | 3,410 |
| | \$K | \$K | \$K |
| | 146,637 | 157,087 | 167,779 |

TRANSMISSION

| | | | |
|----------------------|----|------------------|----------|
| Size (kV) | -- | Distance (Miles) | -- |
| Cost of Upgrade, \$M | | | <u>1</u> |

ANNUAL EXPENSES

1995\$

| | | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|---------------------------|------------|--------------|--------------|--------------|
| Fixed O&M | \$/kW-yr | 23.21 | 25.79 | 28.37 |
| Variable O&M | cents/kWh | 0.90 | 1.00 | 1.10 |
| Land Lease | \$K | 256 | 285 | 313 |
| FIRST YEAR O&M | \$K | <u>2,179</u> | <u>2,381</u> | <u>2,530</u> |
| Total O&M, cents/kWh | | 2.31 | 2.57 | 2.82 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Oahu Location: Pearl Harbor Project Code: 397, 398, 399
 Ownrshp: USN

Capacity (MW) 50 Stage (current/future) Future
 Resource (avg NIP, kWh/m²-day) 5.26 Extent (# of units) 1200
 Project Life (years) 30 Construction Time (years) 1.5
 Geology Type soil

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 92,394 | 87,994 | 79,194 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 20.7% | 19.7% | 17.7% |
| Net Energy (MWh/yr) | 89,197 | 84,949 | 76,454 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|------------|---------|--------------|
| <i>Process Capital</i> | | | |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 279 | 310 | 341 |
| Overseas Shipping | 30 | 33 | 36 |
| Legal Fees & Permitting | 0.2 | 0.2 | 0.2 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 80 | 89 | 102 |
| Roads, buildings, fence | 29 | 33 | 36 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | 189 | 199 | 209 |
| <i>Initial Costs</i> | | | |
| TOTAL CAPITAL COSTS | 1,774 | 1,955 | 2,140 |
| | \$/kWe,net | | |
| | 8 | 9 | 9 |
| | \$K | | |
| | 87,304 | 96,192 | 105,298 |

TRANSMISSION

Size (kV) — Distance (Miles) —
 Cost of Upgrade, \$M 1 1 1

ANNUAL EXPENSES

1995\$

| | | | | |
|----------------------|-----------|-------|-------|-------|
| Fixed O&M | \$/kW-yr | 13.93 | 15.47 | 17.02 |
| Variable O&M | cents/kWh | 0.72 | 0.80 | 0.88 |
| Land Lease | \$K | 256 | 285 | 313 |
| FIRST YEAR O&M | \$K | 1,593 | 1,736 | 1,835 |
| Total O&M, cents/kWh | | 1.52 | 1.69 | 1.86 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Oahu Location Kahuku Point Project Code 718,719,720

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 60 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 14.5 | Extent (no. x dia. buoys) | 360 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 732,231 | 732,231 | 732,231 |
| Wave energy absorption efficiency | 51% | 42% | 21% |
| Absorbed energy (MWh/yr) | 374,941 | 304,951 | 152,475 |
| Conversion & sea-to-shore transmission efficiency | 74% | 77% | 81% |
| Landed energy at 100% availability (MWh/yr) | 279,214 | 234,663 | 122,965 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 265,253 | 211,197 | 98,372 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|--------------------|--------------------|--------------------|
| Buoy and damper plate fabrication | 35,430,000 | 53,145,000 | 70,860,000 |
| Pelton turbine/generator | 17,625,000 | 17,625,000 | 17,625,000 |
| Balance of mechanical & electrical plant | 6,712,000 | 6,712,000 | 6,712,000 |
| Mooring hardware | 8,961,000 | 8,961,000 | 8,961,000 |
| Deployment | 4,909,000 | 7,364,000 | 9,818,000 |
| Sea-to-shore transmission | 4,891,000 | 4,891,000 | 4,891,000 |
| Onshore substation | 3,172,000 | 3,172,000 | 3,172,000 |
| Legal fees and permitting | 795,000 | 845,000 | 896,000 |
| <i>Process Capital Sub-Total</i> | 82,495,000 | 102,715,000 | 122,935,000 |
| <i>General Facilities</i> | 4,125,000 | 10,271,000 | 18,440,000 |
| <i>Engineering & Overhead</i> | 8,249,000 | 10,271,000 | 12,293,000 |
| <i>Project Contingency</i> | 9,487,000 | 12,326,000 | 15,367,000 |
| <i>Initial Costs</i> | 2,307,000 | 3,221,000 | 4,386,000 |
| TOTAL PLANT COST | 106,663,000 | 138,804,000 | 173,421,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 2,000,000 | 2,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|-------------------|
| Ongoing fixed O&M costs | 1,650,000 | 4,109,000 | 7,376,000 |
| Amortized periodic replacements | 994,000 | 2,000,000 | 4,685,000 |
| FIRST YEAR O&M COST | 2,644,000 | 6,108,000 | 12,061,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Oahu Location Kahuku Point Project Code 715,716,717

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 14.5 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 366,116 | 366,116 | 366,116 |
| Wave energy absorption efficiency | 51% | 42% | 21% |
| Absorbed energy (MWh/yr) | 187,471 | 152,475 | 76,238 |
| Conversion & sea-to-shore transmission efficiency | 74% | 77% | 81% |
| Landed energy at 100% availability (MWh/yr) | 139,621 | 117,342 | 61,486 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 132,640 | 105,608 | 49,188 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,137,000 | 3,137,000 | 3,137,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 697,000 | 723,000 | 749,000 |
| <i>Process Capital Sub-Total</i> | 43,149,000 | 53,715,000 | 64,282,000 |
| <i>General Facilities</i> | 2,157,000 | 5,372,000 | 9,642,000 |
| <i>Engineering & Overhead</i> | 4,315,000 | 5,372,000 | 6,428,000 |
| <i>Project Contingency</i> | 4,962,000 | 6,446,000 | 8,035,000 |
| <i>Initial Costs</i> | 1,205,000 | 1,682,000 | 2,287,000 |
| TOTAL PLANT COST | 55,789,000 | 72,586,000 | 90,675,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 863,000 | 2,149,000 | 3,857,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,366,000 | 3,162,000 | 6,236,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Oahu Location Makapuu Point Project Code 258,259,260

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 60 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 15.0 | Extent (no. x dia. buoys) | 360 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|----------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 757,471 | 757,471 | 757,471 |
| Wave energy absorption efficiency | 53% | 43% | 22% |
| Absorbed energy (MWh/yr) | 400,533 | 327,589 | 163,794 |
| Conversion & sea-to-shore transmission efficiency | 73% | 76% | 80% |
| Landed energy at 100% availability (MWh/yr) | 294,082 | 249,309 | 131,645 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 279,377 | 224,378 | 105,316 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|--------------------|--------------------|--------------------|
| Buoy and damper plate fabrication | 35,430,000 | 53,145,000 | 70,860,000 |
| Pelton turbine/generator | 17,625,000 | 17,625,000 | 17,625,000 |
| Balance of mechanical & electrical plant | 6,712,000 | 6,712,000 | 6,712,000 |
| Mooring hardware | 8,961,000 | 8,961,000 | 8,961,000 |
| Deployment | 4,909,000 | 7,364,000 | 9,818,000 |
| Sea-to-shore transmission | 5,405,000 | 5,405,000 | 5,405,000 |
| Onshore substation | 3,172,000 | 3,172,000 | 3,172,000 |
| Legal fees and permitting | 796,000 | 846,000 | 897,000 |
| <i>Process Capital Sub-Total</i> | 83,010,000 | 103,230,000 | 123,450,000 |
| <i>General Facilities</i> | 4,151,000 | 10,323,000 | 18,517,000 |
| <i>Engineering & Overhead</i> | 8,301,000 | 10,323,000 | 12,345,000 |
| <i>Project Contingency</i> | 9,546,000 | 12,388,000 | 15,431,000 |
| <i>Initial Costs</i> | 2,321,000 | 3,236,000 | 4,403,000 |
| TOTAL PLANT COST | 107,329,000 | 139,500,000 | 174,146,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 1,000,000 | 1,000,000 | 1,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|-------------------|
| Ongoing fixed O&M costs | 1,660,000 | 4,129,000 | 7,407,000 |
| Amortized periodic replacements | 994,000 | 2,000,000 | 4,685,000 |
| FIRST YEAR O&M COST | 2,654,000 | 6,129,000 | 12,092,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Oahu Location Makapuu Point Project Code 252,253,254

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 15.0 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 378,736 | 378,736 | 378,736 |
| Wave energy absorption efficiency | 53% | 43% | 22% |
| Absorbed energy (MWh/yr) | 200,267 | 163,794 | 81,897 |
| Conversion & sea-to-shore transmission efficiency | 73% | 76% | 80% |
| Landed energy at 100% availability (MWh/yr) | 147,068 | 124,675 | 65,829 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 139,714 | 112,208 | 52,663 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,549,000 | 3,549,000 | 3,549,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 698,000 | 724,000 | 750,000 |
| <i>Process Capital Sub-Total</i> | 43,561,000 | 54,128,000 | 64,694,000 |
| <i>General Facilities</i> | 2,178,000 | 5,413,000 | 9,704,000 |
| <i>Engineering & Overhead</i> | 4,356,000 | 5,413,000 | 6,469,000 |
| <i>Project Contingency</i> | 5,010,000 | 6,495,000 | 8,087,000 |
| <i>Initial Costs</i> | 1,217,000 | 1,694,000 | 2,301,000 |
| TOTAL PLANT COST | 56,322,000 | 73,142,000 | 91,255,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 871,000 | 2,165,000 | 3,882,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,374,000 | 3,179,000 | 6,261,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Oahu Location Mokapu Point Project Code 261,262,263

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 12.5 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 314,861 | 314,861 | 314,861 |
| Wave energy absorption efficiency | 55% | 45% | 22% |
| Absorbed energy (MWh/yr) | 171,837 | 140,429 | 70,214 |
| Conversion & sea-to-shore transmission efficiency | 75% | 78% | 80% |
| Landed energy at 100% availability (MWh/yr) | 129,382 | 108,851 | 56,358 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 122,913 | 97,966 | 45,087 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,878,000 | 3,878,000 | 3,878,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 698,000 | 725,000 | 751,000 |
| <i>Process Capital Sub-Total</i> | 43,891,000 | 54,458,000 | 65,024,000 |
| <i>General Facilities</i> | 2,195,000 | 5,446,000 | 9,754,000 |
| <i>Engineering & Overhead</i> | 4,389,000 | 5,446,000 | 6,502,000 |
| <i>Project Contingency</i> | 5,047,000 | 6,535,000 | 8,128,000 |
| <i>Initial Costs</i> | 1,225,000 | 1,704,000 | 2,312,000 |
| TOTAL PLANT COST | 56,748,000 | 73,588,000 | 91,719,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 878,000 | 2,178,000 | 3,901,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,380,000 | 3,192,000 | 6,280,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Oahu Location Northeast Coast 2A Project Code 121,722,723

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 13.9 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 349,652 | 349,652 | 349,652 |
| Wave energy absorption efficiency | 52% | 43% | 21% |
| Absorbed energy (MWh/yr) | 183,073 | 149,100 | 74,550 |
| Conversion & sea-to-shore transmission efficiency | 75% | 77% | 81% |
| Landed energy at 100% availability (MWh/yr) | 136,775 | 115,226 | 60,093 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 129,936 | 103,704 | 48,075 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,220,000 | 3,220,000 | 3,220,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 697,000 | 723,000 | 750,000 |
| <i>Process Capital Sub-Total</i> | 43,231,000 | 53,798,000 | 64,364,000 |
| <i>General Facilities</i> | 2,162,000 | 5,380,000 | 9,655,000 |
| <i>Engineering & Overhead</i> | 4,323,000 | 5,380,000 | 6,436,000 |
| <i>Project Contingency</i> | 4,972,000 | 6,456,000 | 8,046,000 |
| <i>Initial Costs</i> | 1,208,000 | 1,684,000 | 2,290,000 |
| TOTAL PLANT COST | 55,896,000 | 72,697,000 | 90,791,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 865,000 | 2,152,000 | 3,862,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,367,000 | 3,166,000 | 6,241,000 |

HAWAII ENERGY STRATEGY .
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Oahu Location Northeast Coast 2C Project Code 255,256,257

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 11.9 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|----------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 301,173 | 301,173 | 301,173 |
| Wave energy absorption efficiency | 58% | 47% | 24% |
| Absorbed energy (MWh/yr) | 173,434 | 142,518 | 71,259 |
| Conversion & sea-to-shore transmission efficiency | 77% | 79% | 81% |
| Landed energy at 100% availability (MWh/yr) | 132,922 | 113,145 | 57,498 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 126,276 | 101,831 | 45,998 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,137,000 | 3,137,000 | 3,137,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 697,000 | 723,000 | 749,000 |
| <i>Process Capital Sub-Total</i> | 43,149,000 | 53,715,000 | 64,282,000 |
| <i>General Facilities</i> | 2,157,000 | 5,372,000 | 9,642,000 |
| <i>Engineering & Overhead</i> | 4,315,000 | 5,372,000 | 6,428,000 |
| <i>Project Contingency</i> | 4,962,000 | 6,446,000 | 8,035,000 |
| <i>Initial Costs</i> | 1,205,000 | 1,682,000 | 2,287,000 |
| TOTAL PLANT COST | 55,789,000 | 72,586,000 | 90,675,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 863,000 | 2,149,000 | 3,857,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,366,000 | 3,162,000 | 6,236,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Oahu Location Waimanalo Bay Project Code 6664,6665,6666

| | | | |
|-----------------------|-----|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 9.3 | Extent (no. x dia. buoys) | 180 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 233,480 | 233,480 | 233,480 |
| Wave energy absorption efficiency | 64% | 53% | 27% |
| Absorbed energy (MWh/yr) | 149,164 | 123,782 | 61,891 |
| Conversion & sea-to-shore transmission efficiency | 79% | 80% | 81% |
| Landed energy at 100% availability (MWh/yr) | 117,555 | 98,841 | 49,924 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 111,677 | 88,957 | 39,939 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,302,000 | 3,302,000 | 3,302,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 697,000 | 723,000 | 750,000 |
| <i>Process Capital Sub-Total</i> | 43,314,000 | 53,880,000 | 64,447,000 |
| <i>General Facilities</i> | 2,166,000 | 5,388,000 | 9,667,000 |
| <i>Engineering & Overhead</i> | 4,331,000 | 5,388,000 | 6,445,000 |
| <i>Project Contingency</i> | 4,981,000 | 6,466,000 | 8,056,000 |
| <i>Initial Costs</i> | 1,210,000 | 1,687,000 | 2,293,000 |
| TOTAL PLANT COST | 56,002,000 | 72,809,000 | 90,907,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 866,000 | 2,155,000 | 3,867,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,369,000 | 3,169,000 | 6,246,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kahuku Project Code: 538,539,540
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>80</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>16.4</u> | Extent (# of units) | <u>320</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|----------------|----------------|----------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 185,690 | 168,809 | 151,928 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>142,900</u> | <u>121,469</u> | <u>101,726</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 43,874,914 | 48,749,904 | 53,624,894 |
| Foundations | 3,492,720 | 3,528,000 | 3,563,280 |
| Assembly & Checkout | 2,067,358 | 2,088,240 | 2,109,122 |
| Electrical Infrastructure | 7,784,357 | 7,862,987 | 7,941,617 |
| Sub-Station | 4,405,484 | 4,449,984 | 4,494,484 |
| Overseas Shipping | 1,546,776 | 1,562,400 | 1,578,024 |
| Legal Fees & Permitting | 372,468 | 465,585 | 581,982 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 680,665 | 687,540 | 694,415 |
| Control System | 704,532 | 711,648 | 718,764 |
| Control Buildings | 295,917 | 298,906 | 301,895 |
| Central Building | 85,121 | 94,579 | 118,223 |

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & Overhead</i> | 6,531,031 | 7,049,977 | 7,572,670 |
|-----------------------------------|-----------|-----------|-----------|

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project Contingency</i> | 7,184,134 | 7,754,975 | 8,329,937 |
|----------------------------|-----------|-----------|-----------|

| | | | |
|----------------------|-----------|-----------|-----------|
| <i>Initial Costs</i> | 2,825,466 | 2,964,615 | 3,138,993 |
|----------------------|-----------|-----------|-----------|

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$81,850,942</u> | <u>\$88,269,340</u> | <u>\$94,768,302</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|---------------------|---------------------|---------------------|
| Cost of Upgrade | <u>\$15,000,000</u> | <u>\$15,000,000</u> | <u>\$15,000,000</u> |
|-----------------|---------------------|---------------------|---------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 825,250 | 637,712 | 587,466 |
|--------------|---------|---------|---------|

| | | | |
|-----------|-----------|-----------|-----------|
| Fixed O&M | 1,099,791 | 1,110,900 | 1,122,009 |
|-----------|-----------|-----------|-----------|

| | | | |
|------------|---------|---------|---------|
| Land Lease | 677,981 | 713,664 | 749,347 |
|------------|---------|---------|---------|

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| FIRST YEAR O&M | <u>\$2,603,021</u> | <u>\$2,462,276</u> | <u>\$2,458,822</u> |
|---------------------------|--------------------|--------------------|--------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kahuku Project Code: 541,542,543
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>80</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>16.4</u> | Extent (# of units) | <u>266</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|----------------|----------------|----------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 231,686 | 210,624 | 189,561 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>178,298</u> | <u>151,558</u> | <u>126,924</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 38,695,754 | 42,995,283 | 49,444,575 |
| Foundations | 2,845,257 | 2,873,997 | 2,902,737 |
| Assembly & Checkout | 1,701,306 | 1,718,491 | 1,735,676 |
| Electrical Infrastructure | 7,647,638 | 7,724,887 | 7,802,135 |
| Sub-Station | 4,405,484 | 4,449,984 | 4,494,484 |
| Overseas Shipping | 1,285,758 | 1,298,745 | 1,311,732 |
| Legal Fees & Permitting | 357,519 | 446,899 | 558,623 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 566,153 | 571,872 | 577,591 |
| Control System | 579,785 | 585,642 | 591,498 |
| Control Buildings | 243,521 | 245,981 | 248,440 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 5,841,330 | 6,300,636 | 6,978,572 |
| <i>Project Contingency</i> | 6,425,463 | 6,930,699 | 7,676,429 |
| <i>Initial Costs</i> | 2,662,333 | 2,771,091 | 2,996,224 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$73,342,422</u> | <u>\$79,008,784</u> | <u>\$87,436,940</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|---------------------|---------------------|---------------------|
| Cost of Upgrade | <u>\$15,000,000</u> | <u>\$15,000,000</u> | <u>\$15,000,000</u> |
|-----------------|---------------------|---------------------|---------------------|

ANNUAL EXPENSES

| | | | |
|--------------|-----------|-----------|-----------|
| Variable O&M | 1,009,076 | 779,764 | 718,325 |
| Fixed O&M | 1,077,795 | 1,088,682 | 1,099,569 |
| Land Lease | 700,484 | 737,352 | 774,220 |

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| FIRST YEAR O&M | <u>\$2,787,355</u> | <u>\$2,605,798</u> | <u>\$2,592,114</u> |
|---------------------------|--------------------|--------------------|--------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kahuku Project Code: 532,533,534
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>16.4</u> | Extent (# of units) | <u>200</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 116,056 | 105,505 | 94,955 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>89,313</u> | <u>75,918</u> | <u>63,579</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 27,421,821 | 30,468,690 | 33,515,559 |
| Foundations | 2,182,950 | 2,205,000 | 2,227,050 |
| Assembly & Checkout | 1,292,099 | 1,305,150 | 1,318,202 |
| Electrical Infrastructure | 4,865,223 | 4,914,367 | 4,963,510 |
| Sub-Station | 2,753,428 | 2,781,240 | 2,809,052 |
| Overseas Shipping | 966,735 | 976,500 | 986,265 |
| Legal Fees & Permitting | 320,015 | 400,019 | 500,024 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 426,195 | 430,500 | 434,805 |
| Control System | 440,332 | 444,780 | 449,228 |
| Control Buildings | 184,948 | 186,816 | 188,684 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 4,093,887 | 4,420,764 | 4,751,060 |
| <i>Project Contingency</i> | 4,503,275 | 4,862,840 | 5,226,166 |
| <i>Initial Costs</i> | 1,827,113 | 1,914,695 | 2,024,556 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$51,363,142</u> | <u>\$55,405,940</u> | <u>\$59,512,385</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$2,000,000</u> | <u>\$2,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 515,781 | 398,570 | 367,166 |
| Fixed O&M | 687,369 | 694,313 | 701,256 |
| Land Lease | 423,738 | 446,040 | 468,342 |

| | | | |
|---------------------------|--------------------|--------------------|--------------------|
| FIRST YEAR O&M | <u>\$1,626,888</u> | <u>\$1,538,923</u> | <u>\$1,536,764</u> |
|---------------------------|--------------------|--------------------|--------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kahuku Project Code: 535536531
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>50</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>16.4</u> | Extent (# of units) | <u>166</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

OPTIMISTIC NOMINAL CONSERVATIVE

ENERGY PRODUCTION

| | | | |
|-----------------------|----------------|---------------|---------------|
| Gross Energy (MWh/yr) | 144,586 | 131,442 | 118,298 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>111,268</u> | <u>94,581</u> | <u>79,208</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 24,148,478 | 26,831,642 | 30,856,389 |
| Foundations | 1,775,612 | 1,793,547 | 1,811,482 |
| Assembly & Checkout | 1,061,717 | 1,072,442 | 1,083,166 |
| Electrical Infrastructure | 4,772,586 | 4,820,794 | 4,869,002 |
| Sub-Station | 2,753,428 | 2,781,240 | 2,809,052 |
| Overseas Shipping | 802,390 | 810,495 | 818,600 |
| Legal Fees & Permitting | 310,563 | 388,203 | 485,254 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 354,095 | 357,672 | 361,249 |
| Control System | 361,821 | 365,476 | 369,130 |
| Control Buildings | 151,972 | 153,507 | 155,042 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 3,657,778 | 3,946,960 | 4,373,659 |
| <i>Project Contingency</i> | 4,023,556 | 4,341,656 | 4,811,025 |
| <i>Initial Costs</i> | 1,726,725 | 1,795,215 | 1,936,592 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$45,985,841</u> | <u>\$49,553,427</u> | <u>\$54,857,866</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$2,000,000</u> | <u>\$2,000,000</u> | <u>\$2,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|----------------|--------------------|--------------------|--------------------|
| Variable O&M | 629,724 | 486,620 | 448,278 |
| Fixed O&M | 673,622 | 680,426 | 687,231 |
| Land Lease | 437,144 | 460,152 | 483,160 |
| FIRST YEAR O&M | <u>\$1,740,490</u> | <u>\$1,627,198</u> | <u>\$1,618,668</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kahuku Project Code: 526,527,528
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>16.4</u> | Extent (# of units) | <u>120</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 69,634 | 63,303 | 56,973 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>53,588</u> | <u>45,551</u> | <u>38,147</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 16,788,870 | 18,654,300 | 20,519,730 |
| Foundations | 1,309,770 | 1,323,000 | 1,336,230 |
| Assembly & Checkout | 775,259 | 783,090 | 790,921 |
| Electrical Infrastructure | 2,919,134 | 2,948,620 | 2,978,106 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 580,041 | 585,900 | 591,759 |
| Legal Fees & Permitting | 285,793 | 357,241 | 446,551 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 256,549 | 259,140 | 261,731 |
| Control System | 264,199 | 266,868 | 269,537 |
| Control Buildings | 110,969 | 112,090 | 113,210 |
| Central Building | 85,121 | 94,579 | 118,223 |

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & Overhead</i> | 2,502,776 | 2,705,357 | 2,911,143 |
|-----------------------------------|-----------|-----------|-----------|

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project Contingency</i> | 2,753,054 | 2,975,893 | 3,202,257 |
|----------------------------|-----------|-----------|-----------|

| | | | |
|----------------------|-----------|-----------|-----------|
| <i>Initial Costs</i> | 1,173,046 | 1,227,530 | 1,295,661 |
|----------------------|-----------|-----------|-----------|

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$31,456,637</u> | <u>\$33,962,352</u> | <u>\$36,520,492</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 309,469 | 239,142 | 220,300 |
|--------------|---------|---------|---------|

| | | | |
|-----------|---------|---------|---------|
| Fixed O&M | 412,422 | 416,588 | 420,753 |
|-----------|---------|---------|---------|

| | | | |
|------------|---------|---------|---------|
| Land Lease | 254,243 | 267,624 | 281,005 |
|------------|---------|---------|---------|

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$976,133</u> | <u>\$923,354</u> | <u>\$922,058</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kahuku Project Code: 529,530,531
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>30</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>16.4</u> | Extent (# of units) | <u>100</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 87,100 | 79,182 | 71,264 |
| Expected Losses (%) | 23% | 28% | 33% |
| Net Energy (MWh/yr) | <u>67,029</u> | <u>56,977</u> | <u>47,716</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|------------|------------|------------|
| Turbines & Towers | 14,844,159 | 16,493,510 | 18,967,537 |
| Foundations | 1,069,646 | 1,080,450 | 1,091,255 |
| Assembly & Checkout | 639,589 | 646,049 | 652,510 |
| Electrical Infrastructure | 2,875,052 | 2,904,093 | 2,933,134 |
| Sub-Station | 1,652,057 | 1,668,744 | 1,685,431 |
| Overseas Shipping | 483,368 | 488,250 | 493,133 |
| Legal Fees & Permitting | 280,209 | 350,262 | 437,827 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 214,137 | 216,300 | 218,463 |
| Control System | 217,964 | 220,166 | 222,368 |
| Control Buildings | 91,549 | 92,474 | 93,399 |
| Central Building | 85,121 | 94,579 | 118,223 |

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & Overhead</i> | 2,245,285 | 2,425,488 | 2,691,328 |
|-----------------------------------|-----------|-----------|-----------|

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project Contingency</i> | 2,469,814 | 2,668,036 | 2,960,461 |
|----------------------------|-----------|-----------|-----------|

| | | | |
|----------------------|-----------|-----------|-----------|
| <i>Initial Costs</i> | 1,118,452 | 1,161,488 | 1,249,273 |
|----------------------|-----------|-----------|-----------|

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$28,286,400</u> | <u>\$30,509,889</u> | <u>\$33,814,340</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 379,352 | 293,144 | 270,047 |
|--------------|---------|---------|---------|

| | | | |
|-----------|---------|---------|---------|
| Fixed O&M | 404,173 | 408,256 | 412,338 |
|-----------|---------|---------|---------|

| | | | |
|------------|---------|---------|---------|
| Land Lease | 263,340 | 277,200 | 291,060 |
|------------|---------|---------|---------|

| | | | |
|---------------------------|--------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$1,046,865</u> | <u>\$978,600</u> | <u>\$973,445</u> |
|---------------------------|--------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kaena Point Project Code: 520,521,522
(leave blank)
 Capacity (MW) 15 Stage (current/future) Current
 Resource (mph, avg.) 15.7 Extent (# of units) 60
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 36,002 | 32,729 | 29,456 |
| Expected Losses (%) | 18% | 23% | 28% |
| Net Energy (MWh/yr) | <u>29,553</u> | <u>25,230</u> | <u>21,234</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|------------|
| Turbines & Towers | 8,394,435 | 9,327,150 | 10,259,865 |
| Foundations | 586,278 | 592,200 | 598,122 |
| Assembly & Checkout | 387,630 | 391,545 | 395,460 |
| Electrical Infrastructure | 1,717,138 | 1,734,482 | 1,751,827 |
| Sub-Station | 826,028 | 834,372 | 842,716 |
| Overseas Shipping | 290,021 | 292,950 | 295,880 |
| Legal Fees & Permitting | 259,620 | 324,525 | 405,656 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 151,767 | 153,300 | 154,833 |
| Control System | 132,100 | 133,434 | 134,768 |
| Control Buildings | 55,484 | 56,045 | 56,605 |
| Central Building | 85,121 | 94,579 | 118,223 |

Engineering & Overhead

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & Overhead</i> | 1,288,562 | 1,393,458 | 1,501,396 |
| <i>Project Contingency</i> | 1,417,418 | 1,532,804 | 1,651,535 |
| <i>Initial Costs</i> | 656,042 | 682,279 | 716,348 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$16,247,643</u> | <u>\$17,543,124</u> | <u>\$18,883,235</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$1,500,000</u> | <u>\$1,500,000</u> | <u>\$1,500,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 170,667 | 132,456 | 122,626 |
| Fixed O&M | 206,211 | 208,294 | 210,377 |
| Land Lease | 42,374 | 44,604 | 46,834 |

| | | | |
|----------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$419,252</u> | <u>\$385,354</u> | <u>\$379,837</u> |
|----------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kaena Point Project Code: 523,524,525
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>15</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>50</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 45,033 | 40,939 | 36,845 |
| Expected Losses (%) | 18% | 23% | 28% |
| Net Energy (MWh/yr) | <u>36,966</u> | <u>31,558</u> | <u>26,560</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 7,422,080 | 8,246,755 | 9,483,768 |
| Foundations | 478,794 | 483,630 | 488,466 |
| Assembly & Checkout | 319,794 | 323,025 | 326,255 |
| Electrical Infrastructure | 1,691,207 | 1,708,290 | 1,725,373 |
| Sub-Station | 826,028 | 834,372 | 842,716 |
| Overseas Shipping | 241,684 | 244,125 | 246,566 |
| Legal Fees & Permitting | 256,838 | 321,048 | 401,310 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| Roads & Grading | 126,819 | 128,100 | 129,381 |
| Control System | 108,982 | 110,083 | 111,184 |
| Control Buildings | 45,775 | 46,237 | 46,699 |
| Central Building | 85,121 | 94,579 | 118,223 |
| <i>Engineering & Overhead</i> | 1,160,312 | 1,254,024 | 1,391,994 |
| <i>Project Contingency</i> | 1,276,343 | 1,379,427 | 1,531,194 |
| <i>Initial Costs</i> | 633,747 | 654,050 | 697,884 |

| | | | |
|------------------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$14,673,525</u> | <u>\$15,827,745</u> | <u>\$17,541,014</u> |
|------------------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$1,500,000</u> | <u>\$1,500,000</u> | <u>\$1,500,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 209,207 | 162,367 | 150,317 |
| Fixed O&M | 202,087 | 204,128 | 206,169 |
| Land Lease | 43,890 | 46,200 | 48,510 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$455,184</u> | <u>\$412,695</u> | <u>\$404,996</u> |
|---------------------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kaena Point Project Code: 514,515,516
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>2</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>15.7</u> | Extent (# of units) | <u>8</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|--------------|--------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 4,800 | 4,364 | 3,928 |
| Expected Losses (%) | 14% | 19% | 24% |
| Net Energy (MWh/yr) | <u>4,151</u> | <u>3,555</u> | <u>3,003</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 1,175,221 | 1,305,801 | 1,436,381 |
| Foundations | 78,170 | 78,960 | 79,750 |
| Assembly & Checkout | 51,684 | 52,206 | 52,728 |
| Electrical Infrastructure | 228,952 | 231,264 | 233,577 |
| Sub-Station | 110,137 | 111,250 | 112,362 |
| Overseas Shipping | 38,669 | 39,060 | 39,451 |
| Legal Fees & Permitting | 236,157 | 295,197 | 368,996 |

General Facilities

| | | | |
|-----------------------------------|---------|---------|---------|
| Roads & Grading | 22,037 | 22,260 | 22,483 |
| Control System | 17,613 | 17,791 | 17,969 |
| Control Buildings | 7,398 | 7,473 | 7,547 |
| Central Building | 11,349 | 12,611 | 15,763 |
| <i>Engineering & Overhead</i> | 197,739 | 217,387 | 238,701 |
| <i>Project Contingency</i> | 217,513 | 239,126 | 262,571 |
| <i>Initial Costs</i> | 229,336 | 234,214 | 240,491 |

| | | | |
|-----------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$2,621,977</u> | <u>\$2,864,599</u> | <u>\$3,128,769</u> |
|-----------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|--------|--------|--------|
| Variable O&M | 23,970 | 18,664 | 17,344 |
| Fixed O&M | 27,495 | 27,773 | 28,050 |
| Land Lease | 5,650 | 5,947 | 6,245 |

| | | | |
|----------------|-----------------|-----------------|-----------------|
| FIRST YEAR O&M | <u>\$57,114</u> | <u>\$52,384</u> | <u>\$51,638</u> |
|----------------|-----------------|-----------------|-----------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Oahu Location Kaena Point Project Code: 517,518,519
(leave blank)
 Capacity (MW) 2 Stage (current/future) Future
 Resource (mph, avg.) 15.7 Extent (# of units) 6
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|--------------|--------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 5,404 | 4,913 | 4,421 |
| Expected Losses (%) | 14% | 19% | 24% |
| Net Energy (MWh/yr) | <u>4,673</u> | <u>4,002</u> | <u>3,381</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|---------|-----------|-----------|
| Turbines & Towers | 935,182 | 1,039,091 | 1,194,955 |
| Foundations | 57,455 | 58,036 | 58,616 |
| Assembly & Checkout | 38,375 | 38,763 | 39,151 |
| Electrical Infrastructure | 202,945 | 204,995 | 207,045 |
| Sub-Station | 110,137 | 111,250 | 112,362 |
| Overseas Shipping | 29,002 | 29,295 | 29,588 |
| Legal Fees & Permitting | 235,460 | 294,325 | 367,906 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 17,048 | 17,220 | 17,392 |
| Control System | 13,078 | 13,210 | 13,342 |
| Control Buildings | 5,493 | 5,548 | 5,604 |
| Central Building | 11,349 | 12,611 | 15,763 |

Engineering & Overhead

| | | | |
|------------------------|---------|---------|---------|
| Engineering & Overhead | 165,552 | 182,434 | 206,172 |
| Project Contingency | 182,108 | 200,678 | 226,790 |
| Initial Costs | 229,015 | 232,813 | 239,889 |

| | | | |
|------------------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$2,232,200</u> | <u>\$2,440,268</u> | <u>\$2,734,575</u> |
|------------------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|---------------------------|-----------------|-----------------|-----------------|
| Variable O&M | 26,444 | 20,591 | 19,134 |
| Fixed O&M | 26,945 | 27,217 | 27,489 |
| Land Lease | 5,267 | 5,544 | 5,821 |
| FIRST YEAR O&M | <u>\$58,656</u> | <u>\$53,352</u> | <u>\$52,444</u> |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops - Methanol

Island: Kauai

Location: Lihue

Project Code: 210.211.212

| | | | |
|---------------------------|---------|--------------------------------|--------|
| Capacity (MW): | 47 | Stage (current/future): | future |
| Resource (dry tons/year): | 134,509 | Extent (harvested acres/year): | 2,205 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 319,738 | 290,671 | 261,604 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 319,738 | 290,671 | 261,604 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Feed handling, preparation | 7,229,993 | 9,037,491 | 10,844,989 |
| Gasification | 2,822,740 | 3,528,425 | 4,234,110 |
| Gas conditioning | 4,554,161 | 5,692,701 | 6,831,241 |
| Compression | 9,097,828 | 11,372,285 | 13,646,742 |
| Acid gas removal/cooling | 4,134,422 | 5,168,028 | 6,201,634 |
| MeOH syn/purification | 11,469,350 | 14,336,687 | 17,204,024 |
| Utilities/auxiliary | 9,832,370 | 12,290,463 | 14,748,555 |
| Legal fees & permitting | 594,852 | 743,565 | 892,278 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,436,006 | 1,795,007 | 2,154,009 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project contingency</i> | 4,973,572 | 6,216,964 | 7,460,357 |
| <i>Initial cost</i> | 5,770,922 | 7,213,652 | 8,656,383 |
| | 2,399,133 | 2,998,917 | 3,598,700 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 65,879,276 | 82,349,093 | 98,818,912 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | .0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|------------|
| Variable O&M (\$) | 6,812,836 | 8,516,045 | 10,219,254 |
| Fixed O&M (\$) | 5,449,772 | 6,812,215 | 8,174,658 |
| Land Lease | 634,200 | 792,750 | 951,300 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 12,896,808 | 16,121,010 | 19,345,212 |
|---------------------------|-------------------|-------------------|-------------------|

Note: 1 MW = 0.5274 MGPY MeOH
47 MW = 25 MGPY MeOH

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops - Electricity

Island: Kauai

Location: Lihue

Project Code: 192,193,194

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 104,011 | Extent (harvested acres/year): | 1,647 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,072,751 | 1,340,939 | 1,609,127 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project contingency</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Initial cost</i> | 3,624,188 | 4,530,235 | 5,436,282 |
| | 1,426,034 | 1,782,543 | 2,139,051 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 41,292,106 | 51,615,133 | 61,938,158 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|---------------------------|------------------|------------------|-------------------|
| Variable O&M (\$) | 4,113,589 | 5,141,986 | 6,170,384 |
| Fixed O&M (\$) | 2,476,486 | 3,095,608 | 3,714,730 |
| Land Lease | 476,200 | 595,250 | 714,300 |
| FIRST YEAR O&M | 7,066,275 | 8,832,844 | 10,599,414 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops & Organic Wastes - Electricity

Island: Kauai

Location: Kaumakani

Project Code: 222,223,224

| | | | |
|---------------------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 50 | Stage (current/future): | future |
| Resource (tree crops)(dry tons/year): | 163,226 | Extent (harvested acres/year): | 3,070 |
| organic wastes (wet tons/yr) | 80,300 | | |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 337,260 | 306,600 | 275,940 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| MSW to RDF front-end processing | 7,600,190 | 9,500,238 | 11,400,286 |
| Feed handling and prep. | 8,370,725 | 10,463,407 | 12,556,088 |
| Gasification & compressor/precooler | 14,769,967 | 18,462,459 | 22,154,951 |
| Physical cleanup | 9,047,943 | 1,131,179 | 1,357,415 |
| Ash handling | 872,624 | 1,090,780 | 1,308,936 |
| Gas turbine | 19,617,878 | 24,522,347 | 29,426,816 |
| Balance of plant | 11,139,421 | 13,924,276 | 16,709,131 |
| Legal fees & permitting | 611,189 | 763,986 | 916,783 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,999,510 | 2,006,523 | 2,999,266 |
| Plantation lab | 112,487 | 2,499,388 | 168,730 |
| Equip. repair shop | 1,451,440 | 140,608 | 2,177,160 |
| | | 1,814,300 | |

| | | | |
|-----------------------------------|-----------|-----------|------------|
| <i>Engineering & overhead</i> | 6,388,694 | 7,985,867 | 9,583,041 |
| <i>Project contingency</i> | 7,307,905 | 9,134,881 | 10,961,857 |
| <i>Initial cost</i> | 2,705,201 | 3,381,502 | 4,057,802 |

| | | | |
|------------------|-------------------|--------------------|--------------------|
| SUB-TOTAL | 91,995,174 | 106,821,741 | 125,778,262 |
|------------------|-------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|------------|
| Variable O&M (\$) | 6,159,274 | 8,381,643 | 10,604,012 |
| Fixed O&M (\$) | 3,981,361 | 4,976,701 | 5,972,041 |
| Land Lease | 879,300 | 1,099,125 | 1,318,950 |

| | | | |
|---------------------------|-------------------|-------------------|-------------------|
| FIRST YEAR O&M | 11,019,935 | 14,457,469 | 17,895,003 |
|---------------------------|-------------------|-------------------|-------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops - Methanol

Island: Kauai

Location: Kaumakani

Project Code: 207, 208, 209

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 47 | Stage (current/future): | future |
| Resource (dry tons/year): | 134,509 | Extent (harvested acres/year): | 2,465 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 319,738 | 290,671 | 261,604 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 319,738 | 290,671 | 261,604 |

CAPITAL COSTS

Process Capital

| | | | |
|----------------------------|------------|------------|------------|
| Feed handling, preparation | 7,229,993 | 9,037,491 | 10,844,989 |
| Gasification | 2,822,740 | 3,528,425 | 4,234,110 |
| Gas conditioning | 4,554,161 | 5,692,701 | 6,831,241 |
| Compression | 9,097,828 | 11,372,285 | 13,646,742 |
| Acid gas removal/cooling | 4,134,422 | 5,168,028 | 6,201,634 |
| MeOH syn/purification | 11,469,350 | 14,336,687 | 17,204,024 |
| Utilities/auxiliary | 9,832,370 | 12,290,463 | 14,748,555 |
| Legal fees & permitting | 594,852 | 743,565 | 892,278 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,605,218 | 2,006,523 | 2,407,827 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project contingency</i> | 4,973,572 | 6,216,964 | 7,460,357 |
| <i>Initial cost</i> | 5,787,843 | 7,234,804 | 8,681,765 |
| | 2,466,888 | 3,083,610 | 3,700,332 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 66,133,164 | 82,666,454 | 99,199,744 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------------------|-----------------------|-----------------------|-----------------------|
| Variable O&M (\$) | 7,375,141 | 9,218,926 | 11,062,711 |
| Fixed O&M (\$) | 5,483,614 | 6,854,518 | 8,225,421 |
| Land Lease | 707,800 | 884,750 | 1,061,700 |
| FIRST YEAR O&M | 13,566,555 | 16,958,194 | 20,349,832 |

Note: 1 MW = 0.5274 MGPY MeOH
 47 MW - 25 MGPY MeOH

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops - Electricity

Island: Kauai

Location: Kaumakani

Project Code: 195,196,197

| | | | |
|----------------------------|---------|--------------------------------|---------|
| Capacity (MW electricity): | 25 | Stage (current/future): | current |
| Resource (dry tons/year): | 125,003 | Extent (harvested acres/year): | 2,273 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 5,780,851 | 7,226,064 | 8,671,276 |
| Gasification & compressor/precooler | 793,450 | 991,813 | 1,190,175 |
| Physical cleanup | 16,221,647 | 20,277,059 | 24,332,471 |
| Ash handling | 302,267 | 377,833 | 453,400 |
| Gas turbine | 314,861 | 393,576 | 472,292 |
| Balance of plant | 6,108,307 | 7,635,383 | 9,162,460 |
| Legal fee & permitting | 545,803 | 682,254 | 818,705 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,480,378 | 1,850,473 | 2,220,567 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| | 3,006,719 | 3,758,398 | 4,510,078 |
| <i>Project contingency</i> | 3,611,821 | 4,514,776 | 5,417,731 |
| <i>Initial cost</i> | 1,534,999 | 1,918,748 | 2,302,498 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 41,265,030 | 51,581,285 | 61,897,543 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 5,124,205 | 6,405,257 | 7,686,808 |
| Fixed O&M (\$) | 2,426,716 | 3,033,395 | 3,640,074 |
| Land Lease | 653,500 | 816,875 | 980,250 |

| | | | |
|---------------------------|------------------|-------------------|-------------------|
| FIRST YEAR O&M | 8,204,421 | 10,255,527 | 12,307,132 |
|---------------------------|------------------|-------------------|-------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Tree crops - Electricity

Island: Kauai

Location: Kaumakani

Project Code: 198,199,200

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 104,011 | Extent (harvested acres/year): | 1,856 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Wood handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|--------------------|-----------|-----------|-----------|
| Road construction | 1,209,086 | 1,511,358 | 1,813,630 |
| Plantation lab | 112,487 | 140,608 | 168,730 |
| Equip. repair shop | 1,451,440 | 1,814,300 | 2,177,160 |

Engineering & overhead

| | | | |
|----------------------------|-----------|-----------|-----------|
| <i>Project contingency</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Initial cost</i> | 3,637,822 | 4,547,277 | 5,456,733 |

| | | | |
|------------------|-------------------|-------------------|-------------------|
| SUB-TOTAL | 41,493,595 | 51,866,993 | 62,240,392 |
|------------------|-------------------|-------------------|-------------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 4,535,382 | 5,669,228 | 6,803,074 |
| Fixed O&M (\$) | 2,503,754 | 3,129,692 | 3,755,630 |
| Land Lease | 535,500 | 669,375 | 803,250 |

| | | | |
|---------------------------|------------------|------------------|-------------------|
| FIRST YEAR O&M | 7,574,636 | 9,468,295 | 11,361,954 |
|---------------------------|------------------|------------------|-------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Grass Crops - Electricity

Island: Kauai

Location: Kaumakani

Project Code: 204,205,206

| | | | |
|----------------------------|---------|--------------------------------|--------|
| Capacity (MW electricity): | 25 | Stage (current/future): | future |
| Resource (dry tons/year): | 106,500 | Extent (harvested acres/year): | 3,236 |
| Project Life (years): | 30 | Construction Time (years): | 2 |

| ENERGY PRODUCTION | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|----------------|---------------------|
| Gross Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |
| Expected Losses (%) | 0 | 0 | 0 |
| Net Energy (MWh/yr) | 168,630 | 153,300 | 137,970 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------------|------------|------------|------------|
| Feed handling and prep. | 5,041,827 | 6,302,284 | 7,562,740 |
| Gasification & compressor/precooler | 7,379,597 | 9,224,496 | 11,069,396 |
| Physical cleanup | 560,203 | 700,254 | 840,304 |
| Ash handling | 570,976 | 713,720 | 856,464 |
| Gas turbine | 11,333,337 | 14,166,672 | 17,000,006 |
| Balance of plant | 5,117,239 | 6,396,549 | 7,675,858 |
| Legal fee & permitting | 547,008 | 683,760 | 820,512 |

General Facilities

| | | | |
|-----------------------------------|-----------|-----------|-----------|
| <i>Engineering & overhead</i> | 3,055,019 | 3,818,773 | 4,582,528 |
| <i>Project contingency</i> | 3,360,521 | 4,200,651 | 5,040,781 |
| <i>Initial cost</i> | 1,483,362 | 1,854,203 | 2,225,043 |

| | | | |
|------------------|------------|------------|------------|
| SUB-TOTAL | 38,449,089 | 48,061,362 | 57,673,632 |
|------------------|------------|------------|------------|

TRANSMISSION

| | | | |
|------------------|-----|-------------------|---|
| Size (kV) | N/A | Distance (Miles): | 0 |
| Cost of Upgrade: | 0 | | |

ANNUAL EXPENSES

| | | | |
|-------------------|-----------|-----------|-----------|
| Variable O&M (\$) | 5,314,480 | 6,643,100 | 7,971,720 |
| Fixed O&M (\$) | 2,309,300 | 2,886,625 | 3,463,950 |
| Land Lease | 139,040 | 173,800 | 208,560 |

| | | | |
|---------------------------|-----------|-----------|------------|
| FIRST YEAR O&M | 7,762,820 | 9,703,525 | 11,644,230 |
|---------------------------|-----------|-----------|------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: HYDRO

Island: Kauai

Location: Wailua River

Project Code: 234,235,236

Capacity (MW) 6.6
Resource(cfs, max) 365
Project Life (years) 50

Stage (current/future) current
Extent (ft of head) 262
Construction Time (years) 2.0

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------------|---------------------|---------------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 17200 | 16856 | 16684 |
| Expected Losses (%) | 2.5% | 2.5% | 2.5% |
| Net Energy (MWh/yr) | 16770 | 16435 | 16267 |
| CAPITAL COSTS | | | |
| Process Capital | | | |
| Intake Structure | \$183,400 | \$192,570 | \$202,199 |
| Penstock | \$3,024,000 | \$3,175,200 | \$3,333,960 |
| Tailrace | \$89,600 | \$94,080 | \$98,784 |
| Diversion Structure | \$731,920 | \$768,516 | \$806,942 |
| Powerhouse | \$421,200 | \$442,260 | \$464,373 |
| Turbine | \$780,038 | \$819,040 | \$859,992 |
| Generator | \$1,170,059 | \$1,228,562 | \$1,289,990 |
| Switchgear | \$359,496 | \$377,471 | \$396,344 |
| Equipment Installation | \$91,000 | \$95,550 | \$100,328 |
| Interconnection | \$277,699 | \$291,584 | \$306,163 |
| Legal Fees & Permitting | \$141,120 | \$148,176 | \$155,585 |
| Environmental Moinitoring | \$63,000 | \$66,150 | \$69,458 |
| General Capital Facilities | | | |
| Access Road | \$67,200 | \$70,560 | \$74,088 |
| Sable Storm Ditch | \$84,000 | \$88,200 | \$92,610 |
| Relocate USGS Gage | \$22,400 | \$23,520 | \$24,696 |
| Station Service | \$79,110 | \$83,066 | \$87,219 |
| Telecommunications | \$35,000 | \$36,750 | \$38,588 |
| Engineering Services | | | |
| Engineering | \$609,619 | \$640,100 | \$672,105 |
| Construction Management | \$609,619 | \$640,100 | \$672,105 |
| Post Construction Environmental | \$63,000 | \$66,150 | \$69,458 |
| Project Contingency | 10.0% | 10.0% | 10.0% |
| SUB-TOTAL | \$9,792,729 | \$10,282,365 | \$10,796,483 |
| TRANSMISSION | | | |
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
| ANNUAL EXPENSES | | | |
| Variable O&M | \$81,250 | \$85,313 | \$89,578 |
| Fixed O&M | \$107,020 | \$112,371 | \$117,990 |
| Rep. Spare Parts (Sinking Fund) | \$9,793 | \$10,283 | \$10,797 |
| Land Lease | \$12,500 | \$13,125 | \$13,781 |
| Federal Fees | \$6,250 | \$6,563 | \$6,891 |
| FIRST YEAR O&M | \$216,813 | \$227,654 | \$239,036 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: HYDRO

Island: Kauai

Location: Wailua River

Project Code: 237,238,239

Capacity (MW) 6.6
Resource(cfs, max) 365
Project Life (years) 50

Stage (current/future) future
Extent (ft of head) 262
Construction Time (years) 2.0

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------------|---------------------|---------------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 17200 | 16856 | 16684 |
| Expected Losses (%) | 2.5% | 2.5% | 2.5% |
| Net Energy (MWh/yr) | 16770 | 16435 | 16267 |
| CAPITAL COSTS | | | |
| Process Capital | | | |
| Intake Structure | \$183,400 | \$192,570 | \$202,199 |
| Penstock | \$3,024,000 | \$3,175,200 | \$3,333,960 |
| Tailrace | \$89,600 | \$94,080 | \$98,784 |
| Diversion Structure | \$731,920 | \$768,516 | \$806,942 |
| Powerhouse | \$421,200 | \$442,260 | \$464,373 |
| Turbine | \$780,038 | \$819,040 | \$859,992 |
| Generator | \$1,170,059 | \$1,228,562 | \$1,289,990 |
| Switchgear | \$359,496 | \$377,471 | \$396,344 |
| Equipment Installation | \$91,000 | \$95,550 | \$100,328 |
| Interconnection | \$277,699 | \$291,584 | \$306,163 |
| Legal Fees & Permitting | \$141,120 | \$148,176 | \$155,585 |
| Environmental Moinitoring | \$63,000 | \$66,150 | \$69,458 |
| General Capital Facilities | | | |
| Access Road | \$67,200 | \$70,560 | \$74,088 |
| Sable Storm Ditch | \$84,000 | \$88,200 | \$92,610 |
| Relocate USGS Gage | \$22,400 | \$23,520 | \$24,696 |
| Station Service | \$79,110 | \$83,066 | \$87,219 |
| Telecommunications | \$35,000 | \$36,750 | \$38,588 |
| Engineering Services | | | |
| Engineering | \$609,619 | \$640,100 | \$672,105 |
| Construction Management | \$609,619 | \$640,100 | \$672,105 |
| Post Construction Environmental | \$63,000 | \$66,150 | \$69,458 |
| Project Contingency | 10.0% | 10.0% | 10.0% |
| SUB-TOTAL | \$9,792,729 | \$10,282,365 | \$10,796,483 |
| TRANSMISSION | | | |
| Cost of Upgrade | \$1,000,000 | \$1,000,000 | \$1,000,000 |
| ANNUAL EXPENSES | | | |
| Variable O&M | \$81,250 | \$85,313 | \$89,578 |
| Fixed O&M | \$53,510 | \$56,186 | \$58,995 |
| Rep. Spare Parts (Sinking Fund) | \$9,793 | \$10,283 | \$10,797 |
| Land Lease | \$12,500 | \$13,125 | \$13,781 |
| Federal Fees | \$6,250 | \$6,563 | \$6,891 |
| FIRST YEAR O&M | \$163,303 | \$171,468 | \$180,042 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Kauai Location: Barking Sands Project Code: 115, 116, 117

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 2,068 </u> | Extent (PV module area, m ²) | <u> 96,800 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 2 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|----------------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 22,978 | 19,985 | 17,992 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 22,753 | 19,785 | 17,807 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$4,963,750 | \$5,225,000 | \$5,486,250 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |

Engineering & Overhead

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$3,747,787 | \$3,747,787 | \$3,747,787 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|------------------|---------------------|---------------------|---------------------|
| Initial Costs | \$712,289 | \$712,289 | \$712,289 |
| SUB-TOTAL | \$51,381,023 | \$56,517,711 | \$58,919,674 |

TRANSMISSION

| | | |
|-----------------|-----|-----|
| Cost of Upgrade | \$0 | \$0 |
|-----------------|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$29,077 | \$32,308 | \$35,539 |
| Fixed O&M | \$46,313 | \$48,750 | \$51,188 |
| Land Lease | \$32,196 | \$33,890 | \$35,585 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$107,585 | \$114,948 | \$122,311 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Kauai Location: Barking Sands Project Code: 658, 659, 660

| | | | |
|--------------------------------|----------------------|------------------------------------------|------------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> current </u> |
| Resource (kWh/m ²) | <u> 2,068 </u> | Extent (PV module area, m ²) | <u> 96,800 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 2 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 25,735 | 22,383 | 20,151 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 25,483 | 22,159 | 19,943 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$29,160,000 | \$32,400,000 | \$34,020,000 |
| Array Structure & Foundations | \$7,445,625 | \$7,837,500 | \$8,229,375 |
| Power Conditioning Units | \$2,486,250 | \$3,825,000 | \$4,016,250 |
| Electrical & SCADA | \$3,844,786 | \$3,883,622 | \$3,922,459 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$313,310 | \$329,800 | \$346,290 |
| Legal Fees & Permitting | \$524,384 | \$655,480 | \$819,350 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$614,156 | \$682,395 | \$750,635 |
| Buildings and Fencing | \$140,444 | \$156,049 | \$171,654 |

Engineering & Overhead

| | | | |
|--|-------------|-------------|-------------|
| | \$3,747,787 | \$3,747,787 | \$3,747,787 |
|--|-------------|-------------|-------------|

Project Contingency

| | | | |
|--|-------------|-------------|-------------|
| | \$4,371,853 | \$4,371,853 | \$4,371,853 |
|--|-------------|-------------|-------------|

Initial Costs

| | | | |
|--|-----------|-----------|-----------|
| | \$712,289 | \$712,289 | \$712,289 |
|--|-----------|-----------|-----------|

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$53,862,898 | \$59,130,211 | \$61,662,799 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

| | | | |
|--------------|----------|----------|----------|
| Variable O&M | \$43,616 | \$48,462 | \$53,308 |
| Fixed O&M | \$57,891 | \$60,938 | \$63,984 |
| Land Lease | \$32,196 | \$33,890 | \$35,585 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$133,702 | \$143,290 | \$152,877 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (fixed, tilted at 15°)

Island Kauai Location: Barking Sands Project Code: 118, 119, 120

| | | | |
|--------------------------------|----------------------|------------------------------------------|-----------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> future </u> |
| Resource (kWh/m ²) | <u> 2,068 </u> | Extent (PV module area, m ²) | <u> 76,640 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 1 </u> |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|----------------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 23,810 | 20,709 | 17,608 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 23,577 | 20,502 | 17,427 |

CAPITAL COSTS

Process Capital

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$3,573,900 | \$3,762,000 | \$3,950,100 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |
| <i>General Facilities</i> | | | |
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |
| <i>Engineering & Overhead</i> | | | |
| Project Contingency | \$3,046,815 | \$3,046,815 | \$3,046,815 |
| <i>Initial Costs</i> | | | |
| | \$498,671 | \$498,671 | \$498,671 |

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$36,066,818 | \$39,390,369 | \$41,094,551 |
|---------------------|---------------------|---------------------|

TRANSMISSION

| | | |
|-----------------|-----|-----|
| Cost of Upgrade | \$0 | \$0 |
|-----------------|-----|-----|

ANNUAL EXPENSES

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------|------------|----------|--------------|
| Variable O&M | \$27,232 | \$30,258 | \$33,284 |
| Fixed O&M | \$43,887 | \$46,197 | \$48,507 |
| Land Lease | \$25,494 | \$26,836 | \$28,178 |

FIRST YEAR O&M

| | | |
|-----------------|------------------|------------------|
| \$96,614 | \$103,291 | \$109,968 |
|-----------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Photovoltaics (tracking)

Island Kauai Location: Barking Sands Project Code: 661, 662, 663

| | | | |
|--------------------------------|-------|------------------------------------------|--------|
| Capacity (MW) | 10 | Stage (current/future) | future |
| Resource (kWh/m ²) | 2,068 | Extent (PV module area, m ²) | 76,640 |
| Project Life (years) | 30 | Construction Time (years) | 1 |

| OPTIMISTIC | NOMINAL | CONSERVATIVE |
|------------|---------|--------------|
|------------|---------|--------------|

ENERGY PRODUCTION

| | | | |
|-----------------------|---------------|---------------|---------------|
| Gross Energy (MWh/yr) | 26,668 | 23,194 | 19,721 |
| Expected Losses (%) | 0.98% | 1.00% | 1.03% |
| Net Energy (MWh/yr) | 26,407 | 22,962 | 19,518 |

CAPITAL COSTS

Process Capital

| | | | |
|-------------------------------|--------------|--------------|--------------|
| PV Modules | \$20,412,000 | \$22,680,000 | \$23,814,000 |
| Array Structure & Foundations | \$5,360,850 | \$5,643,000 | \$5,925,150 |
| Power Conditioning Units | \$1,118,813 | \$1,721,250 | \$1,807,313 |
| Electrical & SCADA | \$3,031,614 | \$3,062,236 | \$3,092,859 |
| Substation | \$502,014 | \$528,436 | \$554,857 |
| Overseas Shipping | \$281,979 | \$296,820 | \$311,661 |
| Legal Fees & Permitting | \$496,101 | \$620,127 | \$775,159 |

General Facilities

| | | | |
|-----------------------|-----------|-----------|-----------|
| Roads and Grading | \$491,324 | \$545,916 | \$600,508 |
| Buildings and Fencing | \$130,601 | \$145,112 | \$159,624 |

Engineering & Overhead

| | | | |
|------------------------|-------------|-------------|-------------|
| Engineering & Overhead | \$2,482,986 | \$2,482,986 | \$2,482,986 |
|------------------------|-------------|-------------|-------------|

Project Contingency

| | | | |
|---------------------|-------------|-------------|-------------|
| Project Contingency | \$3,046,815 | \$3,046,815 | \$3,046,815 |
|---------------------|-------------|-------------|-------------|

Initial Costs

| | | | |
|---------------|-----------|-----------|-----------|
| Initial Costs | \$498,671 | \$498,671 | \$498,671 |
|---------------|-----------|-----------|-----------|

SUB-TOTAL

| | | |
|---------------------|---------------------|---------------------|
| \$37,853,768 | \$41,271,369 | \$43,069,601 |
|---------------------|---------------------|---------------------|

TRANSMISSION

Cost of Upgrade

| | | |
|-----|-----|-----|
| \$0 | \$0 | \$0 |
|-----|-----|-----|

ANNUAL EXPENSES

Variable O&M

Fixed O&M

Land Lease

| | | |
|----------|----------|----------|
| \$40,848 | \$45,387 | \$49,926 |
| \$54,859 | \$57,746 | \$60,633 |
| \$25,494 | \$26,836 | \$28,178 |

FIRST YEAR O&M

| | | |
|------------------|------------------|------------------|
| \$121,201 | \$129,969 | \$138,736 |
|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Kauai Location: Barking Sands Project Code: 340, 341, 342
 Ownrshp: USN

| | | | |
|--------------------------------|-------------|---------------------------|------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | |
| Resource (avg NIP, kWh/m2-day) | <u>5.26</u> | Extent (# of units) | <u>400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 17,868 | 17,017 | 15,316 |
| Expected Losses (%) | 3.3% | 3.5% | 3.8% |
| Capacity Factor (net) | 20.0% | 19.1% | 17.2% |
| Net Energy (MWh/yr) | 17,250 | 16,428 | 14,786 |

CAPITAL COSTS

1995\$

| | \$/kWe _{net} | \$/kWe _{net} | \$/kWe _{net} |
|----------------------------|-----------------------|-----------------------|-----------------------|
| <i>Process Capital</i> | | | |
| Support Structure | 910 | 958 | 1006 |
| Aximuth/Elevation Drives | 222 | 234 | 246 |
| Facets | 194 | 204 | 214 |
| Dish Control System | 8 | 8 | 8 |
| Stirling Engine/Generator | 831 | 924 | 1016 |
| Installation | 317 | 334 | 351 |
| Overseas Shipping | 40 | 42 | 44 |
| Legal Fees & Permitting | 0.6 | 0.6 | 0.6 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 113 | 126 | 145 |
| Roads, buildings, fence | 48 | 53 | 58 |
| Engineering & Overhead | 113 | 119 | 125 |
| Project Contingency | 252 | 265 | 278 |
| Initial Costs | 14 | 15 | 16 |
| TOTAL CAPITAL COSTS | 3,062 | 3,281 | 3,507 |
| | \$/kWe _{net} | | |
| | \$K | 32,288 | 34,506 |

TRANSMISSION

| | | | |
|----------------------|----------|------------------|----------|
| Size (kV) | <u>—</u> | Distance (Miles) | <u>—</u> |
| Cost of Upgrade, \$M | | | <u>0</u> |

ANNUAL EXPENSES

1995\$

| | | | | |
|---------------------------|----------------------|------------|------------|------------|
| Fixed O&M | \$/kW-yr | 28.92 | 32.13 | 35.34 |
| Variable O&M | cents/kWh | 1.12 | 1.24 | 1.37 |
| Land Lease | \$K | 51 | 57 | 63 |
| FIRST YEAR O&M | \$K | 533 | 582 | 618 |
| | Total O&M, cents/kWh | 2.85 | 3.17 | 3.48 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Dish Stirling

Island: Kauai Location: Barking Sands Project Code: 343, 344, 345
 Ownrshp: USN

| | | | |
|--------------------------------|-------------|---------------------------|------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | |
| Resource (avg NIP, kWh/m2-day) | <u>5.26</u> | Extent (# of units) | <u>400</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1.5</u> |
| Geology Type | <u>soil</u> | | |

ENERGY PRODUCTION

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------|------------|---------|--------------|
| Gross Energy (MWh/yr) | 18,762 | 17,868 | 16,081 |
| Expected Losses (%) | 3.1% | 3.3% | 3.6% |
| Capacity Factor (net) | 21.0% | 20.0% | 18.0% |
| Net Energy (MWh/yr) | 18,112 | 17,250 | 15,525 |

CAPITAL COSTS

1995\$

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|-----------------------------------|------------|------------|--------------|
| <i>Process Capital</i> | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| Support Structure | 391 | 435 | 478 |
| Aximuth/Elevation Drives | 115 | 128 | 140 |
| Facets | 151 | 168 | 184 |
| Dish Control System | 5 | 5 | 6 |
| Stirling Engine/Generator | 412 | 458 | 503 |
| Installation | 301 | 334 | 367 |
| Overseas Shipping | 30 | 34 | 37 |
| Legal Fees & Permitting | 0.5 | 0.5 | 0.6 |
| <i>General Facilities</i> | | | |
| Grubbing & Grading | 102 | 113 | 130 |
| Roads, buildings, fence | 48 | 53 | 58 |
| <i>Engineering & Overhead</i> | 96 | 101 | 106 |
| <i>Project Contingency</i> | 189 | 199 | 209 |
| <i>Initial Costs</i> | 10 | 11 | 11 |
| TOTAL CAPITAL COSTS | \$/kWe,net | \$/kWe,net | \$/kWe,net |
| | 1,850 | 2,038 | 2,232 |
| | \$K | \$K | \$K |
| | 18,200 | 20,053 | 21,961 |

TRANSMISSION

| | | | |
|----------------------|----------|------------------|----------|
| Size (kV) | <u>—</u> | Distance (Miles) | <u>—</u> |
| Cost of Upgrade, \$M | <u>0</u> | | <u>0</u> |

ANNUAL EXPENSES

| | | | |
|---------------------------|-----------|------------|-------------|
| | 1995\$ | | |
| Fixed O&M | \$/kW-yr | 17.35 | 19.28 |
| Variable O&M | cents/kWh | 0.89 | 0.99 |
| Land Lease | \$K | 51 | 57 |
| FIRST YEAR O&M | \$K | <u>387</u> | <u>421</u> |
| | | 1.88 | 2.09 |
| Total O&M, cents/kWh | | | <u>2.30</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Kauai Location Anahola Project Code 712,713,714

| | | | |
|-----------------------|---------------------|---------------------------|--------------------------|
| Project size (MWe) | <u> 30 </u> | Stage (current/future) | <u> future </u> |
| Resource (kW/m, avg.) | <u> 12.5 </u> | Extent (no. x dia. buoys) | <u> 180 x 16m </u> |
| Project life (years) | <u> 30 </u> | Construction time (years) | <u> 2 </u> |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|----------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 315,213 | 315,213 | 315,213 |
| Wave energy absorption efficiency | 55% | 45% | 22% |
| Absorbed energy (MWh/yr) | 171,972 | 140,535 | 70,267 |
| Conversion & sea-to-shore transmission efficiency | 76% | 78% | 81% |
| Landed energy at 100% availability (MWh/yr) | 130,838 | 109,941 | 56,691 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 124,296 | 98,947 | 45,353 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 18,420,000 | 27,630,000 | 36,840,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,137,000 | 3,137,000 | 3,137,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 697,000 | 723,000 | 749,000 |
| <i>Process Capital Sub-Total</i> | 43,149,000 | 53,715,000 | 64,282,000 |
| <i>General Facilities</i> | 2,157,000 | 5,372,000 | 9,642,000 |
| <i>Engineering & Overhead</i> | 4,315,000 | 5,372,000 | 6,428,000 |
| <i>Project Contingency</i> | 4,962,000 | 6,446,000 | 8,035,000 |
| <i>Initial Costs</i> | 1,205,000 | 1,682,000 | 2,287,000 |
| TOTAL PLANT COST | 55,789,000 | 72,586,000 | 90,675,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 2,000,000 | 2,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 863,000 | 2,149,000 | 3,857,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,366,000 | 3,162,000 | 6,236,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Kauai Location Anahola Project Code 709,710,711

| | | | |
|-----------------------|------|---------------------------|----------|
| Project size (MWe) | 10 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 12.5 | Extent (no. x dia. buoys) | 60 x 16m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 105,071 | 105,071 | 105,071 |
| Wave energy absorption efficiency | 55% | 45% | 22% |
| Absorbed energy (MWh/yr) | 57,324 | 46,845 | 23,422 |
| Conversion & sea-to-shore transmission efficiency | 76% | 78% | 81% |
| Landed energy at 100% availability (MWh/yr) | 43,597 | 36,635 | 18,894 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 41,417 | 32,972 | 15,115 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 7,080,000 | 10,620,000 | 14,160,000 |
| Pelton turbine/generator | 2,937,000 | 2,937,000 | 2,937,000 |
| Balance of mechanical & electrical plant | 1,119,000 | 1,119,000 | 1,119,000 |
| Mooring hardware | 1,493,000 | 1,493,000 | 1,493,000 |
| Deployment | 1,161,000 | 1,741,000 | 2,322,000 |
| Sea-to-shore transmission | 1,648,000 | 1,648,000 | 1,648,000 |
| Onshore substation | 529,000 | 529,000 | 529,000 |
| Legal fees and permitting | 630,000 | 641,000 | 651,000 |
| <i>Process Capital Sub-Total</i> | 16,598,000 | 20,728,000 | 24,859,000 |
| <i>General Facilities</i> | 830,000 | 2,073,000 | 3,729,000 |
| <i>Engineering & Overhead</i> | 1,660,000 | 2,073,000 | 2,486,000 |
| <i>Project Contingency</i> | 1,909,000 | 2,487,000 | 3,107,000 |
| <i>Initial Costs</i> | 462,000 | 646,000 | 878,000 |
| TOTAL PLANT COST | 21,458,000 | 28,007,000 | 35,059,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 1,000,000 | 1,000,000 | 1,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|----------------|------------------|------------------|
| Ongoing fixed O&M costs | 332,000 | 829,000 | 1,492,000 |
| Amortized periodic replacements | 175,000 | 356,000 | 842,000 |
| FIRST YEAR O&M COST | 507,000 | 1,185,000 | 2,333,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Kauai Location Barking Sands Project Code 706,707,708

| | | | |
|-----------------------|------|---------------------------|-----------|
| Project size (MWe) | 30 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 14.8 | Extent (no. x dia. buoys) | 180 x 17m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 395,730 | 395,730 | 395,730 |
| Wave energy absorption efficiency | 24% | 18% | 9% |
| Absorbed energy (MWh/yr) | 94,282 | 71,747 | 35,873 |
| Conversion & sea-to-shore transmission efficiency | 80% | 80% | 81% |
| Landed energy at 100% availability (MWh/yr) | 75,174 | 57,547 | 29,002 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 71,415 | 51,793 | 23,201 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 20,613,000 | 30,919,000 | 41,225,000 |
| Pelton turbine/generator | 8,812,000 | 8,812,000 | 8,812,000 |
| Balance of mechanical & electrical plant | 3,356,000 | 3,356,000 | 3,356,000 |
| Mooring hardware | 4,480,000 | 4,480,000 | 4,480,000 |
| Deployment | 2,660,000 | 3,990,000 | 5,320,000 |
| Sea-to-shore transmission | 3,055,000 | 3,055,000 | 3,055,000 |
| Onshore substation | 1,586,000 | 1,586,000 | 1,586,000 |
| Legal fees and permitting | 702,000 | 731,000 | 760,000 |
| <i>Process Capital Sub-Total</i> | <i>45,265,000</i> | <i>56,930,000</i> | <i>68,596,000</i> |
| <i>General Facilities</i> | <i>2,263,000</i> | <i>5,693,000</i> | <i>10,289,000</i> |
| <i>Engineering & Overhead</i> | <i>4,526,000</i> | <i>5,693,000</i> | <i>6,860,000</i> |
| <i>Project Contingency</i> | <i>5,205,000</i> | <i>6,832,000</i> | <i>8,574,000</i> |
| <i>Initial Costs</i> | <i>1,263,000</i> | <i>1,777,000</i> | <i>2,428,000</i> |
| TOTAL PLANT COST | 58,522,000 | 76,925,000 | 96,747,000 |

| | | | |
|-------------------------------------|------------------|------------------|------------------|
| ONSHORE TRANSMISSION UPGRADE | 2,000,000 | 2,000,000 | 2,000,000 |
|-------------------------------------|------------------|------------------|------------------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|------------------|------------------|------------------|
| Ongoing fixed O&M costs | 905,000 | 2,277,000 | 4,116,000 |
| Amortized periodic replacements | 503,000 | 1,014,000 | 2,379,000 |
| FIRST YEAR O&M COST | 1,408,000 | 3,291,000 | 6,495,000 |

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wave (heaving buoy, hose pump)

Island Kauai Location Barking Sands Project Code 703,704,705

| | | | |
|-----------------------|------|---------------------------|----------|
| Project size (MWe) | 10 | Stage (current/future) | future |
| Resource (kW/m, avg.) | 14.8 | Extent (no. x dia. buoys) | 60 x 17m |
| Project life (years) | 30 | Construction time (years) | 2 |

| | OPTIMISTIC | NOMINAL | CONSV. |
|---------------------------------------------------|---------------|---------------|--------------|
| ENERGY PRODUCTION | | | |
| Incident wave energy (MWh/yr) | 131,910 | 131,910 | 131,910 |
| Wave energy absorption efficiency | 24% | 18% | 9% |
| Absorbed energy (MWh/yr) | 31,427 | 23,916 | 11,958 |
| Conversion & sea-to-shore transmission efficiency | 80% | 80% | 81% |
| Landed energy at 100% availability (MWh/yr) | 25,053 | 19,179 | 9,666 |
| Annual average availability | 95% | 90% | 80% |
| NET LANDED ENERGY (MWh/yr) | 23,800 | 17,261 | 7,733 |

CAPITAL COSTS (\$)

| | | | |
|------------------------------------------|-------------------|-------------------|-------------------|
| Buoy and damper plate fabrication | 7,811,000 | 11,716,000 | 15,622,000 |
| Pelton turbine/generator | 2,937,000 | 2,937,000 | 2,937,000 |
| Balance of mechanical & electrical plant | 1,119,000 | 1,119,000 | 1,119,000 |
| Mooring hardware | 1,493,000 | 1,493,000 | 1,493,000 |
| Deployment | 1,161,000 | 1,741,000 | 2,322,000 |
| Sea-to-shore transmission | 1,580,000 | 1,580,000 | 1,580,000 |
| Onshore substation | 529,000 | 529,000 | 529,000 |
| Legal fees and permitting | 632,000 | 643,000 | 655,000 |
| <i>Process Capital Sub-Total</i> | 17,263,000 | 21,760,000 | 26,257,000 |
| <i>General Facilities</i> | 863,000 | 2,176,000 | 3,939,000 |
| <i>Engineering & Overhead</i> | 1,726,000 | 2,176,000 | 2,626,000 |
| <i>Project Contingency</i> | 1,985,000 | 2,611,000 | 3,282,000 |
| <i>Initial Costs</i> | 480,000 | 677,000 | 923,000 |
| TOTAL PLANT COST | 22,317,000 | 29,399,000 | 37,026,000 |

| | | | |
|-------------------------------------|----------|----------|----------|
| ONSHORE TRANSMISSION UPGRADE | 0 | 0 | 0 |
|-------------------------------------|----------|----------|----------|

ANNUAL EXPENSES (\$)

| | | | |
|---------------------------------|----------------|------------------|------------------|
| Ongoing fixed O&M costs | 345,000 | 870,000 | 1,575,000 |
| Amortized periodic replacements | 175,000 | 356,000 | 842,000 |
| FIRST YEAR O&M COST | 520,000 | 1,227,000 | 2,417,000 |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Kauai Location Anahola Project Code: 442,443,444
(leave blank)
 Capacity (MW) 7 Stage (current/future) Current
 Resource (mph, avg.) 14.0 Extent (# of units) 28
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|--------------|--------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 9,694 | 8,813 | 7,932 |
| Expected Losses (%) | 20% | 25% | 30% |
| Net Energy (MWh/yr) | <u>7,800</u> | <u>6,651</u> | <u>5,589</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 3,917,403 | 4,352,670 | 4,787,937 |
| Foundations | 273,596 | 276,360 | 279,124 |
| Assembly & Checkout | 180,894 | 182,721 | 184,548 |
| Electrical Infrastructure | 600,998 | 607,069 | 613,140 |
| Sub-Station | 385,480 | 389,374 | 393,267 |
| Overseas Shipping | 135,343 | 136,710 | 138,077 |
| Legal Fees & Permitting | 244,665 | 305,831 | 382,289 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 54,470 | 55,020 | 55,570 |
| Control System | 61,647 | 62,269 | 62,892 |
| Control Buildings | 25,893 | 26,154 | 26,416 |
| Central Building | 39,723 | 44,137 | 55,171 |

Engineering & Overhead

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 592,011 | 643,831 | 697,843 |
| <i>Project Contingency</i> | 651,212 | 708,215 | 767,627 |
| <i>Initial Costs</i> | 375,685 | 390,418 | 407,555 |

| | | | |
|-----------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$7,539,019</u> | <u>\$8,180,779</u> | <u>\$8,851,456</u> |
|-----------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$1,000,000</u> | <u>\$1,000,000</u> | <u>\$1,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|--------|--------|--------|
| Variable O&M | 45,048 | 34,916 | 32,277 |
| Fixed O&M | 96,232 | 97,204 | 98,176 |
| Land Lease | 9,887 | 10,408 | 10,928 |

| | | | |
|----------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$151,167</u> | <u>\$142,527</u> | <u>\$141,380</u> |
|----------------|------------------|------------------|------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Kauai Location Anahola Project Code: 445,446,447
(leave blank)
 Capacity (MW) 7 Stage (current/future) Future
 Resource (mph, avg.) 14.0 Extent (# of units) 23
 Project Life (years) 30 Construction Time (years) 1

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|--------------|--------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 11,953 | 10,866 | 9,780 |
| Expected Losses (%) | 20% | 25% | 30% |
| Net Energy (MWh/yr) | <u>9,618</u> | <u>8,200</u> | <u>6,891</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 3,414,157 | 3,793,507 | 4,362,533 |
| Foundations | 220,245 | 222,470 | 224,694 |
| Assembly & Checkout | 147,105 | 148,591 | 150,077 |
| Electrical Infrastructure | 583,466 | 589,360 | 595,254 |
| Sub-Station | 385,480 | 389,374 | 393,267 |
| Overseas Shipping | 111,175 | 112,298 | 113,420 |
| Legal Fees & Permitting | 243,234 | 304,043 | 380,054 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 45,114 | 45,570 | 46,026 |
| Control System | 50,132 | 50,638 | 51,145 |
| Control Buildings | 21,056 | 21,269 | 21,482 |
| Central Building | 39,723 | 44,137 | 55,171 |

Engineering & Overhead

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 526,089 | 572,126 | 639,312 |
| <i>Project Contingency</i> | 578,698 | 629,338 | 703,244 |
| <i>Initial Costs</i> | 366,098 | 378,343 | 399,866 |

| | | | |
|-----------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$6,731,773</u> | <u>\$7,301,064</u> | <u>\$8,135,546</u> |
|-----------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|--------------------|--------------------|--------------------|
| Cost of Upgrade | <u>\$1,000,000</u> | <u>\$1,000,000</u> | <u>\$1,000,000</u> |
|-----------------|--------------------|--------------------|--------------------|

ANNUAL EXPENSES

| | | | |
|--------------|--------|--------|--------|
| Variable O&M | 54,431 | 42,189 | 39,000 |
| Fixed O&M | 94,307 | 95,260 | 96,212 |
| Land Lease | 10,095 | 10,626 | 11,157 |

| | | | |
|----------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$158,833</u> | <u>\$148,075</u> | <u>\$146,370</u> |
|----------------|------------------|------------------|------------------|

HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET

TECHNOLOGY: Wind

Island Kauai Location N. Hanapepe Project Code: 448,449,450
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>10</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>16.0</u> | Extent (# of units) | <u>40</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|---------------|---------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 24,378 | 22,161 | 19,945 |
| Expected Losses (%) | 13% | 18% | 23% |
| Net Energy (MWh/yr) | <u>21,296</u> | <u>18,252</u> | <u>15,430</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 5,596,290 | 6,218,100 | 6,839,910 |
| Foundations | 436,590 | 441,000 | 445,410 |
| Assembly & Checkout | 258,420 | 261,030 | 263,640 |
| Electrical Infrastructure | 1,144,758 | 1,156,322 | 1,167,885 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 193,347 | 195,300 | 197,253 |
| Legal Fees & Permitting | 250,704 | 313,379 | 391,724 |

General Facilities

| | | | |
|-------------------|---------|---------|---------|
| Roads & Grading | 101,871 | 102,900 | 103,929 |
| Control System | 88,066 | 88,956 | 89,846 |
| Control Buildings | 36,990 | 37,363 | 37,737 |
| Central Building | 85,121 | 94,579 | 118,223 |

Engineering & Overhead

| | | | |
|----------------------------|---------|-----------|-----------|
| Engineering & Overhead | 874,284 | 946,518 | 1,021,737 |
| <i>Project Contingency</i> | 961,713 | 1,041,169 | 1,123,910 |
| <i>Initial Costs</i> | 509,294 | 527,664 | 551,868 |

| | | | |
|-----------|---------------------|---------------------|---------------------|
| SUB-TOTAL | <u>\$11,088,133</u> | <u>\$11,980,529</u> | <u>\$12,914,883</u> |
|-----------|---------------------|---------------------|---------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|----------------|------------------|------------------|------------------|
| Variable O&M | 122,986 | 95,824 | 89,106 |
| Fixed O&M | 137,474 | 138,863 | 140,251 |
| Land Lease | 84,748 | 89,208 | 93,668 |
| FIRST YEAR O&M | <u>\$345,207</u> | <u>\$323,894</u> | <u>\$323,026</u> |

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Kauai Location N. Hanapepe Project Code: 451,452,453
(leave blank)

| | | | |
|----------------------|-----------------|---------------------------|-------------------|
| Capacity (MW) | <u> 10 </u> | Stage (current/future) | <u> Future </u> |
| Resource (mph, avg.) | <u> 16.0 </u> | Extent (# of units) | <u> 33 </u> |
| Project Life (years) | <u> 30 </u> | Construction Time (years) | <u> 1 </u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|-------------------|-------------------|-------------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 30,187 | 27,443 | 24,699 |
| Expected Losses (%) | 13% | 18% | 23% |
| Net Energy (MWh/yr) | <u> 26,372 </u> | <u> 22,602 </u> | <u> 19,107 </u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 4,898,573 | 5,442,858 | 6,259,287 |
| Foundations | 352,983 | 356,549 | 360,114 |
| Assembly & Checkout | 211,064 | 213,196 | 215,328 |
| Electrical Infrastructure | 1,116,197 | 1,127,471 | 1,138,746 |
| Sub-Station | 550,686 | 556,248 | 561,810 |
| Overseas Shipping | 159,511 | 161,123 | 162,734 |
| Legal Fees & Permitting | 248,681 | 310,851 | 388,564 |

General Facilities

| | | | |
|-------------------|--------|--------|---------|
| Roads & Grading | 84,407 | 85,260 | 86,113 |
| Control System | 71,928 | 72,655 | 73,381 |
| Control Buildings | 30,211 | 30,516 | 30,822 |
| Central Building | 85,121 | 94,579 | 118,223 |

Engineering & Overhead

| | | | |
|------------------------|---------|---------|-----------|
| Engineering & Overhead | 780,936 | 845,131 | 939,512 |
| Project Contingency | 859,030 | 929,644 | 1,033,463 |
| Initial Costs | 495,627 | 509,848 | 540,298 |

| | | | |
|------------------|------------------------|-------------------------|-------------------------|
| SUB-TOTAL | <u> \$9,944,955 </u> | <u> \$10,735,928 </u> | <u> \$11,908,396 </u> |
|------------------|------------------------|-------------------------|-------------------------|

TRANSMISSION

| | | | |
|-----------------|----------------|----------------|----------------|
| Cost of Upgrade | <u> \$0 </u> | <u> \$0 </u> | <u> \$0 </u> |
|-----------------|----------------|----------------|----------------|

ANNUAL EXPENSES

| | | | |
|--------------|---------|---------|---------|
| Variable O&M | 149,251 | 116,288 | 108,136 |
| Fixed O&M | 134,724 | 136,085 | 137,446 |
| Land Lease | 86,902 | 91,476 | 96,050 |

| | | | |
|---------------------------|----------------------|----------------------|----------------------|
| FIRST YEAR O&M | <u> \$370,877 </u> | <u> \$343,849 </u> | <u> \$341,632 </u> |
|---------------------------|----------------------|----------------------|----------------------|

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Kauai Location Port Allen Project Code: 454,455,456
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|----------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>Current</u> |
| Resource (mph, avg.) | <u>15.4</u> | Extent (# of units) | <u>20</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|--------------|--------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 11,433 | 10,394 | 9,354 |
| Expected Losses (%) | 20% | 25% | 30% |
| Net Energy (MWh/yr) | <u>9,111</u> | <u>7,763</u> | <u>6,519</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 2,938,052 | 3,264,503 | 3,590,953 |
| Foundations | 195,426 | 197,400 | 199,374 |
| Assembly & Checkout | 129,210 | 130,515 | 131,820 |
| Electrical Infrastructure | 429,284 | 433,621 | 437,957 |
| Sub-Station | 275,343 | 278,124 | 280,905 |
| Overseas Shipping | 96,674 | 97,650 | 98,627 |
| Legal Fees & Permitting | 241,498 | 301,873 | 377,341 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 39,501 | 39,900 | 40,299 |
| Control System | 44,033 | 44,478 | 44,923 |
| Control Buildings | 18,495 | 18,682 | 18,868 |
| Central Building | 39,723 | 44,137 | 55,171 |

Engineering & Overhead 444,724 485,088 527,624

Project Contingency 489,196 533,597 580,386

Initial Costs 326,325 336,752 349,892

SUB-TOTAL \$5,707,484 \$6,206,318 \$6,734,140

TRANSMISSION

Cost of Upgrade \$0 \$0 \$0

ANNUAL EXPENSES

Variable O&M 52,613 40,754 37,645

Fixed O&M 68,737 69,431 70,126

Land Lease 14,125 14,868 15,611

FIRST YEAR O&M \$135,475 \$125,053 \$123,382

**HAWAII ENERGY STRATEGY
PROJECT 3: RENEWABLE ENERGY ASSESSMENT
TECHNOLOGY DATA SHEET**

TECHNOLOGY: Wind

Island Kauai Location Port Allen Project Code: 451,458,459
(leave blank)

| | | | |
|----------------------|-------------|---------------------------|---------------|
| Capacity (MW) | <u>5</u> | Stage (current/future) | <u>Future</u> |
| Resource (mph, avg.) | <u>15.4</u> | Extent (# of units) | <u>16</u> |
| Project Life (years) | <u>30</u> | Construction Time (years) | <u>1</u> |

| | OPTIMISTIC | NOMINAL | CONSERVATIVE |
|--------------------------|---------------|--------------|--------------|
| ENERGY PRODUCTION | | | |
| Gross Energy (MWh/yr) | 13,729 | 12,481 | 11,233 |
| Expected Losses (%) | 20% | 25% | 30% |
| Net Energy (MWh/yr) | <u>10,940</u> | <u>9,321</u> | <u>7,828</u> |

CAPITAL COSTS

Process Capital

| | | | |
|---------------------------|-----------|-----------|-----------|
| Turbines & Towers | 2,493,819 | 2,770,910 | 3,186,546 |
| Foundations | 153,214 | 154,762 | 156,309 |
| Assembly & Checkout | 102,334 | 103,368 | 104,402 |
| Electrical Infrastructure | 405,890 | 409,990 | 414,089 |
| Sub-Station | 275,343 | 278,124 | 280,905 |
| Overseas Shipping | 77,339 | 78,120 | 78,901 |
| Legal Fees & Permitting | 240,244 | 300,304 | 375,381 |

General Facilities

| | | | |
|-------------------|--------|--------|--------|
| Roads & Grading | 32,017 | 32,340 | 32,663 |
| Control System | 34,874 | 35,227 | 35,579 |
| Control Buildings | 14,648 | 14,796 | 14,944 |
| Central Building | 39,723 | 44,137 | 55,171 |

Engineering & Overhead

| | | | |
|-----------------------------------|---------|---------|---------|
| <i>Engineering & Overhead</i> | 386,944 | 422,208 | 473,489 |
| <i>Project Contingency</i> | 425,639 | 464,428 | 520,838 |
| <i>Initial Costs</i> | 319,344 | 327,515 | 343,521 |

| | | | |
|------------------|--------------------|--------------------|--------------------|
| SUB-TOTAL | <u>\$5,001,371</u> | <u>\$5,436,227</u> | <u>\$6,072,739</u> |
|------------------|--------------------|--------------------|--------------------|

TRANSMISSION

| | | | |
|-----------------|------------|------------|------------|
| Cost of Upgrade | <u>\$0</u> | <u>\$0</u> | <u>\$0</u> |
|-----------------|------------|------------|------------|

ANNUAL EXPENSES

| | | | |
|--------------|--------|--------|--------|
| Variable O&M | 61,914 | 47,958 | 44,300 |
| Fixed O&M | 67,362 | 68,043 | 68,723 |
| Land Lease | 14,045 | 14,784 | 15,523 |

| | | | |
|---------------------------|------------------|------------------|------------------|
| FIRST YEAR O&M | <u>\$143,321</u> | <u>\$130,785</u> | <u>\$128,546</u> |
|---------------------------|------------------|------------------|------------------|

RENEWABLE ENERGY INTEGRATION PLAN

Phase 3: Renewable Energy Resource Assessment And Development Program

November 1995

prepared for:

State of Hawaii
Department of Business, Economic Development & Tourism
335 Merchant Street, Room 110
Honolulu, Hawaii 96813
(808) 587-3800

prepared by:

RLA Consulting
18223 102nd Avenue NE, Suite A
Bothell, Washington 98011
(206) 488-0848




TABLE OF CONTENTS

| Section | Page |
|----------------------------------------------------------------------|------|
| SECTION 1. INTRODUCTION AND BACKGROUND..... | 1 |
| BACKGROUND | 1 |
| OBJECTIVES OF PHASE 3 | 6 |
| REPORT ORGANIZATION | 6 |
| SECTION 2. RESULTS FOR THE RESOURCE SUPPLY CURVE MODEL FOR 1995..... | 7 |
| ANALYSIS APPROACH | 7 |
| 1995 RESULTS FOR THE ISLAND OF HAWAII | 8 |
| Base Case..... | 8 |
| Optimistic and Conservative Cases..... | 8 |
| 1995 RESULTS FOR THE ISLAND OF MAUI..... | 8 |
| Base Case..... | 9 |
| Optimistic and Conservative Cases..... | 10 |
| 1995 RESULTS FOR THE ISLAND OF OAHU | 10 |
| Base Case..... | 11 |
| Optimistic and Conservative Cases..... | 11 |
| 1995 RESULTS FOR THE ISLAND OF KAUAI | 12 |
| Base Case..... | 12 |
| Optimistic and Conservative Cases..... | 13 |
| IMPACT OF VARYING THE 1995 BASE CASE ASSUMPTIONS | 13 |
| Non-Utility Financing..... | 13 |
| Transmission Investment Requirement | 14 |
| Tax Incentives | 15 |
| SUMMARY OF 1995 RESULTS | 15 |
| SECTION 3. RESULTS OF THE RESOURCE SUPPLY CURVE MODEL FOR 2005..... | 18 |
| ANALYSIS APPROACH | 18 |
| 2005 RESULTS FOR THE ISLAND OF HAWAII | 19 |
| Base Case..... | 19 |
| Optimistic and Conservative Cases..... | 19 |
| 2005 RESULTS FOR THE ISLAND OF MAUI..... | 20 |
| Base Case..... | 20 |
| Optimistic and Conservative Cases..... | 22 |
| 2005 RESULTS FOR THE ISLAND OF OAHU | 22 |
| Base Case..... | 22 |
| Optimistic and Conservative Cases..... | 22 |
| 2005 RESULTS FOR THE ISLAND OF KAUAI | 22 |
| Base Case..... | 22 |
| Optimistic and Conservative Cases..... | 23 |
| IMPACTS OF VARYING ASSUMPTIONS | 23 |
| Sensitivity of Results to Avoided Cost Assumptions | 24 |
| 2005 RESULTS FOR BIOMASS FUELS | 25 |

SUMMARY OF 2005 RESULTS 26

SECTION 4. PROJECT IMPLEMENTATION ANALYSES FOR INTERMITTENT RENEWABLE ENERGY RESOURCES 31

UTILITY LOAD MATCHING 31

 Capacity Value for Intermittent Resources..... 34

 Time-of-Day Delivery and Pricing 38

SECTION 5. RENEWABLE ENERGY IMPLEMENTATION PLAN..... 44

 CONSTRAINTS TO RENEWABLE ENERGY PROJECT IMPLEMENTATION 44

 DEVELOPMENT OF RENEWABLE ENERGY PROJECT IMPLEMENTATION PLAN 45

 Island of Hawaii..... 46

 Island of Maui 47

 Island of Oahu 48

 Island of Kauai 49

 OPPORTUNITIES FOR SMALL-SCALE RENEWABLE ENERGY PROJECT IMPLEMENTATION 50

SECTION 6. CONCLUSIONS AND RECOMMENDATIONS..... 51

 CONCLUSIONS 51

 RECOMMENDATIONS 51

List of Appendices

- A Resource Supply Curves, Island of Hawaii
- B Resource Supply Curves, Island of Maui
- C Resource Supply Curves, Island of Oahu
- D Resource Supply Curves, Island of Kauai
- E Time-of-Day Pricing Summaries
- F Case Studies for Small-Scale Applications

SECTION 1. INTRODUCTION AND BACKGROUND

RLA Consulting (RLA) has been retained by the State of Hawaii Department of Business, Economic Development, & Tourism (DBEDT) to conduct a Renewable Energy Resource Assessment and Development Program. This three-phase program is part of the Hawaii Energy Strategy (HES), which is a multi-faceted program intended to produce an integrated energy strategy for the State of Hawaii. This report summarizes the results of Phase 3 of the program, including a Renewable Energy Integration Plan for the State of Hawaii.

BACKGROUND

In Phase 1 of the Renewable Energy Resource Assessment and Development Program, suitable locations with development potential for renewable energy projects were identified. The emphasis for project identification was on utility-scale, grid-connected renewable energy projects. For each of the technologies under consideration, a potential project list was developed based on an elimination process of the available land on each of the six major Hawaiian islands: Hawaii, Maui, Lanai, Molokai, Oahu, and Kauai. For each island, geographic areas were identified in which resource potential exists, then an in-depth screening process was conducted that included consideration of factors such as land ownership, zoning, current and planned land uses, technology-specific development requirements, utility access and impact, environmental constraints, and public acceptance. Additional information on the methodology, assumptions, and results of Phase 1, along with a description of each project site are included in the Phase 1 report, *Renewable Energy Resource Assessment Plan*.

In Phase 2, detailed cost and performance estimates were developed for each of the potential projects identified in Phase 1. Tables 1-1 to 1-4 list the potential renewable energy projects and project sizes that were evaluated as part of this program. These projects represent viable development opportunities, with no foreseeable technical or institutional barrier, on each island and for each technology. Although no project sites are included in the database for either Lanai or Molokai, there is potential on these islands for small-scale renewable energy applications. On these islands, the size of the utility grid, the extent of the existing renewable energy projects, and the projections for demand growth limit consideration of any additional utility-scale renewable energy projects at this time. Small-scale applications for renewable energy technologies are discussed Section 5.

In order to estimate costs and performance for renewable energy projects in Hawaii, RLA compiled the most current cost and performance data for each of the renewable energy conversion technologies evaluated in the project. Technologies included wind, solar thermal (troughs and dishes), photovoltaics (fixed and tracking), biomass electricity (with energy crops and/or organic waste as a fuel source), biomass fuel (both methanol and ethanol), hydroelectric, wave, ocean thermal, and geothermal.

For most technologies, two conceptual plant designs were developed. One design was based on plant components that are commercially available for installation in 1995 (current technology). The other design was based on components that are realistically expected to be commercially deployed by the year 2005 (future technology). In the case of technologies that have not been commercially deployed, estimates were only made for the future scenario. For mature technologies in which no substantial technological advances are expected, estimates were developed for only the current scenario.

In order to account for the uncertainty in cost and resource projections, three estimates (representing optimistic, nominal, and conservative cases) were made for each potential project and for both states of technology development (current and future). As a result, a total of six cost and energy estimates were made for each potential project location and size for the majority of the technologies evaluated. The

Table 1-1. Potential Projects, Island of Hawaii

| TECHNOLOGY | PROJECT LOCATION | SIZE (MW) | | |
|------------------------------------|------------------------|---------------|---------------|----|
| WIND | KAHUA RANCH | 5, 15 | | |
| | LALAMILO WELLS | 3, 30, 50 | | |
| | N. KOHALA | 5, 15 | | |
| SOLAR THERMAL | DISHES | KEAHOLE | 30 | |
| | | N. KOHALA | 5, 15 | |
| | | WAIKOLOA | 30 | |
| | TROUGH | KEAHOLE | 30 | |
| | | WAIKOLOA | 30 | |
| | | | | |
| PHOTOVOLTAIC | FIXED | KEAHOLE | 30, 50 | |
| | | N. KOHALA | 5, 15 | |
| | | WAIKOLOA | 30, 50 | |
| | TRACKING | KEAHOLE | 30, 50 | |
| | | N. KOHALA | 5, 15 | |
| | | WAIKOLOA | 30, 50 | |
| | BIOMASS ELECTRIC | GRASS CROPS | HAMAKUA COAST | 25 |
| | | | HILO COAST | 25 |
| | | | KA'U | 25 |
| TREE & ORGANIC WASTE TREE CROPS | | HILO COAST | 50 | |
| | | HAMAKUA COAST | 25 | |
| | | HILO COAST | 25 | |
| | | | | |
| BIOMASS FUEL-METHANOL | GRASS CROPS | KAUMAKAI | 25 MGPY | |
| | TREE CROPS | HAMAKUA COAST | 25 MGPY | |
| | | HILO COAST | 25 MGPY | |
| | | | | |
| HYDRO | UMAUMA STREAM | 13.8 | | |
| WAVE | HONOKAA | 10 | | |
| | N. KOHALA | 10, 30 | | |
| | PEPEEKEO | 10 | | |
| OCEAN THERMAL | KEAHOLE POINT | 60 | | |
| GEOTHERMAL | KILAUEA EAST RIFT ZONE | 25, 50 | | |

NOTE: PROJECT SIZE IS GIVEN IN MW OF INSTALLED CAPACITY EXCEPT BIOMASS-FUELS, WHICH ARE GIVEN IN MILLIONS OF GALLONS PER YEAR.

Table 1-2. Potential Projects, Island of Maui

| TECHNOLOGY | PROJECT LOCATION | SIZE (MW) | |
|-----------------------|------------------|--------------|-------------|
| WIND | MCGREGOR POINT | 30 | |
| | NW HALEAKALA | 10, 30, 50 | |
| | PUUNENE | 10, 30 | |
| | WEST MAUI | 10, 30, 50 | |
| SOLAR THERMAL | DISHES | KAHULUI | 10, 30 |
| | | KIHEI | 10, 30 |
| | | PUUNENE | 10, 30 |
| | TROUGH | KAHULUI | 30 |
| | | KIHEI | 30 |
| | | PUUNENE | 30 |
| PHOTOVOLTAIC | FIXED | KAHULUI | 10, 30 |
| | | KIHEI | 10, 30 |
| | | PUUNENE | 10, 30 |
| | TRACKING | KAHULUI | 10, 30 |
| | | KIHEI | 10, 30 |
| | | PUUNENE | 10, 30 |
| BIOMASS ELECTRIC | ORGANIC WASTE | PAIA-PUUNENE | 25 |
| | GRASS CROPS | PAIA-PUUNENE | 25, 50 |
| | TREE CROPS | PAIA-PUUNENE | 50 |
| BIOMASS FUEL-ETHANOL | GRASS CROPS | PAIA-PUUNENE | 25, 50 MGPY |
| | TREE CROPS | PAIA-PUUNENE | 25 MGPY |
| BIOMASS FUEL-METHANOL | ORGANIC WASTE | PAIA-PUUNENE | 25 MGPY |
| | GRASS CROPS | PAIA-PUUNENE | 50 MGPY |
| | TREE CROPS | PAIA-PUUNENE | 50 MGPY |
| WAVE | LOWER PAIA | 10, 30, 60 | |
| | OPANA POINT | 10, 30, 60 | |
| | WAIEHU POINT | 10, 30 | |

NOTE: PROJECT SIZE IS GIVEN IN MW OF INSTALLED CAPACITY EXCEPT BIOMASS-FUELS, WHICH ARE GIVEN IN MILLIONS OF GALLONS PER YEAR.

Table 1-3. Potential Projects, Island of Oahu

| TECHNOLOGY | PROJECT LOCATION | SIZE (MW) | |
|------------------|------------------------|---------------|------------|
| WIND | KAENA POINT | 2, 15 | |
| | KAHUKU | 30, 50, 80 | |
| SOLAR THERMAL | DISHES | LUALUALEI | 50 |
| | | N. EWA PLAIN | 50 |
| | | PEARL HARBOR | 50 |
| | TROUGH | LUALUALEI | 80 |
| | | N. EWA PLAIN | 80 |
| | | PEARL HARBOR | 80 |
| PHOTOVOLTAIC | FIXED | LUALUALEI | 10, 20, 50 |
| | | N. EWA PLAIN | 10, 50 |
| | | PEARL HARBOR | 10, 50 |
| | TRACKING | LUALUALEI | 10, 20, 50 |
| | | N. EWA PLAIN | 10, 50 |
| | | PEARL HARBOR | 10, 50 |
| BIOMASS ELECTRIC | ORGANIC WASTE | BARBERS POINT | 50 |
| | GRASS CROPS | WAIALUA | 25 |
| BIOMASS FUEL | ORGANIC WASTE-ETHANOL | BARBERS POINT | 25 MGPY |
| | ORGANIC WASTE-METHANOL | BARBERS POINT | 50 MGPY |
| WAVE | MAKAPUU | 30, 60 | |
| | MOKAPU POINT | 30 | |
| | N.E. COAST (UPPER) | 30 | |
| | N.E. COAST (LOWER) | 30 | |
| | WAIMANALO | 30 | |
| | KAHUKU POINT | 30, 60 | |
| OCEAN THERMAL | KAHE POINT | 60 | |

NOTE: PROJECT SIZE IS GIVEN IN MW OF INSTALLED CAPACITY EXCEPT BIOMASS-FUELS, WHICH ARE GIVEN IN MILLIONS OF GALLONS PER YEAR.

Table 1-4. Potential Projects, Island of Kauai

| TECHNOLOGY | PROJECT LOCATION | SIZE (MW) | |
|-------------------------------------|-------------------------|------------------|----|
| WIND | ANAHOLA | 7 | |
| | N. HANAPEPE | 10 | |
| | PORT ALLEN | 5 | |
| SOLAR THERMAL DISHES | BARKING SANDS | 10 | |
| PHOTOVOLTAIC FIXED | BARKING SANDS | 10 | |
| | TRACKING | BARKING SANDS | 10 |
| BIOMASS ELECTRIC GRASS CROPS | KAUMAKANI | 25 | |
| | LIHUE | 25 | |
| | TREE & ORGANIC WASTE | KAUMAKANI | 50 |
| | TREE CROPS | KAUMAKANI | 25 |
| | | LIHUE | 25 |
| BIOMASS FUEL-METHANOL TREE CROPS | KAUMAKANI | 25 MGPY | |
| | LIHUE | 25 MGPY | |
| HYDRO | WAILUA RIVER | 6.6 | |
| WAVE | ANAHOLA | 10, 30 | |
| | BARKING SANDS | 10, 30 | |

NOTE: PROJECT SIZE IS GIVEN IN MW OF INSTALLED CAPACITY EXCEPT BIOMASS-FUELS, WHICH ARE GIVEN IN MILLIONS OF GALLONS PER YEAR.

optimistic, nominal, and conservative cases differ from each other because of uncertainty in the energy projections, project costs, or a combination of both.

A user-friendly, Resource Supply Curve (RSC) computer model was then developed to calculate the levelized cost of energy (in 1995 dollars) for each project based on the Electric Power Research Institute Technical Assessment Guide (EPRI TAG) methodology, a common set of economic parameters, and the site-specific cost and performance estimates. The program calculates the cost of energy for each project and displays a graphical summary of the results of a specific query.

The RSC model provides a choice of evaluating projects based on two valuation methods and two basic financing options. The valuation methods include constant dollar analysis (no inflation) or current dollar analysis. Financing options include either utility or non-utility financing. To maximize the flexibility of the program, the user has the further option of changing the debt/equity ratios, the tax life, the inflation rate, the debt cost, the equity cost, the property tax, and the state and federal income tax credits to values other than the default values. Additional information on the use and assumptions incorporated into the RSC model, as well as the detailed cost and performance estimates for each project, are included in the Phase 2 report, *Development of Renewable Energy Resource Supply Curves*.

OBJECTIVES OF PHASE 3

The RSC program was developed to provide the user with a tool to compare various options under differing conditions. The objective of Phase 3 of the Renewable Energy Resource Assessment and Development Program is to concentrate on the integration and interpretation of the data by using the RSC model as an analysis tool. This report presents the results of this analysis and draws conclusions for integrating renewable energy projects into the state's generation mix.

Another objective of Phase 3 was to collect additional wind and solar resource data from sites which appeared to have development potential but for which high-quality data were not publicly available. More than a year of data was collected at 8 wind sites and 5 solar sites. The cost and performance estimates for the wind and solar projects have been updated based on these new data. Summaries of the actual data that were collected under Phase 3, as well as summaries of the historical data that were utilized in the project, are included in a separate report.

REPORT ORGANIZATION

The report is organized into six sections. Following this introduction, Section 2 summarizes the results of the program for 1995, assuming current renewable energy technology and current economic conditions. Section 3 summarizes the results of the program for 2005, assuming future renewable energy technology and projections of future energy demand and costs. Section 4 discusses renewable energy project implementation in the State of Hawaii and includes a renewable energy integration plan for each island. The renewable energy integration plans are based on the 2005 results for each island given the constraints and limitations to project development that exist on that island. They represent a set of realistic goals for incorporating renewables into Hawaii's generation mix. Section 5 presents project implementation analyses for intermittent generating resources such as wind, solar, and wave projects. These analyses, which include load matching, capacity value, and time-of-day pricing, can impact the value an intermittent resource has to a utility system. Section 6 contains conclusions and recommendations.

SECTION 2. RESULTS FOR THE RESOURCE SUPPLY CURVE MODEL FOR 1995

This section discusses the renewable energy projects that appear to be economically and technically feasible for installation in 1995 under the set of assumptions presented. The assumptions in the RSC model may be changed to test other development scenarios or to adapt the results to changing conditions. Because these projects are not currently under development and are therefore not likely to be put in service in 1995, this evaluation is somewhat academic. However, the results highlight what might have been done if more information was available on the resource potential several years ago assuming the institutional requirements such as power purchase contracts, tax credits, land owner interest, and utility and/or independent power producer development interest also existed.

The 1995 results also provide a solid basis on which to plan future actions. Projects already shown to be economical, based on 1995 conditions, can be evaluated in more detail and placed in service over the next few years to provide cost savings for both the Hawaiian utilities and their customers. These projects can then form the basis for other, well characterized projects that will be economical by the year 2005.

ANALYSIS APPROACH

As previously discussed, the RSC model enables the user to evaluate the results from three possible cost and performance scenarios: nominal, conservative, and optimistic. The range in these estimates represents the variation in the technological development of each technology as well as the uncertainty in the resource. Hawaii can play a part in narrowing the range by participating in fundamental research or demonstration projects and by additional resource assessment; however, much of the variation is due to uncertainty in the pace of technology development over which the state generally has little influence.

In this section, results are presented for each of the three scenarios. Because the islands are not electrically interconnected, the analyses were carried out on an island-by-island basis. The nominal scenario, which reflects the most likely productivity and costs of the projects, is discussed as the base case.

Unless otherwise stated, utility financing and current state and federal tax credits were assumed for all 1995 projects. The base case analyses also include all required transmission costs to support the projects under consideration. The impacts of varying these assumptions are discussed later in this section. All analyses in this report were conducted in constant dollars.

To establish how much energy from renewable energy projects is cost-competitive with the local utility's current energy production costs, levelized cost of energy for each project is compared to the utility's avoided energy cost. Avoided energy cost represents the cost for the utility to generate additional electricity, it does not account for all potential utility impacts such as avoided or deferred system improvements or non-utility avoided costs (externalities). A vertical line representing this avoided cost was generated on the RSC graphs for each island. Projects to the left of this line on the RSC graphs represent projects that are cost-competitive (can be implemented at a levelized cost of energy that is lower than the current cost for the utility to supply the same amount of energy). Projects to the right of the line are more expensive than the utility's avoided energy cost. While the utility's avoided energy cost is expected to escalate over the lifetime of any proposed renewable energy project (further improving the comparison) the effect of this escalation has not been incorporated into the comparisons.

The annual benefits to Hawaii from implementing the viable renewable energy projects can be quantified by calculating the area under the curve and to the left of the vertical, avoided energy cost

line. This benefit represents the net savings to the utility and its customers from using renewable energy projects rather than the generating units which form the basis of avoided energy costs.

In the following sections, the 1995 results are summarized for each island in terms of the amount of electricity that could be generated and the annual cost savings realized from implementing the viable projects. Results are provided for each development scenario by island. The impact of varying the assumptions is also evaluated. Note that although each of the projects discussed is viable independently, the entire list of projects for each island may not be viable as a group. For example, the total amount of electricity that could be generated from viable projects may be greater than the demand on that particular island, or more than the local utility can accommodate. In this section, all viable projects are presented and discussed. The constraints to developing the projects individually and as a group are discussed in more detail in Section 4. The results are combined into a realistic renewable energy implementation goal that considers the limitations of both the technology and the utility structure.

1995 RESULTS FOR THE ISLAND OF HAWAII

Resource supply curves for the base case, conservative, and optimistic scenarios which list all the projects on Hawaii and their calculated cost of energy are included in Appendix A.

BASE CASE

Figure 2-1 shows the base case resource supply curve for the Island of Hawaii. For 1995, the average avoided energy cost for Hawaiian Electric Light Company (HELCO) was estimated to be approximately \$0.0556/kWh. The avoided energy cost estimate was based on information provided in HELCO's most recent Integrated Resource Planning (IRP) document.

As shown in the graph, there are three viable wind energy projects on Hawaii that could be implemented in 1995 at a more economical cost than the utility's avoided energy cost: North Kohala, Lalamilo Wells, and Kahua Ranch. The graph shows the most cost-effective project size at each project site. Other project sizes evaluated at all three sites are also viable options, including a larger wind project at Kahua Ranch which requires a transmission line upgrade.

Even with just these three projects, the annual benefits to Hawaii are considerable. The area under the curve reflects the annual savings potential from implementing these three projects. Rather than spending \$12.3 million per year (5.56 cents for each of the 221.6 million kWh), the island utility could instead spend \$6.7 million for the same energy. The difference between these values is approximately \$5.6 million, or the area under the curve (remember, however, that these projects may not be viable as a group, and the project owner(s) would likely require payment of more than their cost to generate).

OPTIMISTIC AND CONSERVATIVE CASES


Under the optimistic assumptions in the model, one additional project on Hawaii, a 13.8 MW hydroelectric facility on Umauma Stream, is shown to be viable.

Under conservative assumptions, all the project sizes for the wind projects at both the Lalamilo Wells and North Kohala are still viable. This result is significant in that it illustrates the quality of the wind resource that is available at these two sites. Lalamilo Wells has long been identified as a good wind site and several wind energy development projects have been proposed for this site. The discovery of the high wind resource at the North Kohala site is one of the positive outcomes resulting from the monitoring program. Prior to the implementation of the monitoring program, there was no wind data available at this site.

1995 RESULTS FOR THE ISLAND OF MAUI

Resource supply curves for the base case, conservative, and optimistic scenarios which list all the projects on Maui and their calculated cost of energy are included in Appendix B.

| | | | |
|--------------|--------------------|---------------|----------------------------|
| Island(s): | Hawaii | Valuation: | Constant Dollars |
| Technology: | All_Tech | Financing: | Utility |
| Certainty: | Nominal | Tax Credits: | Included |
| Stage: | Current Technology | Data: | Unique Location Lowest COE |
| Trans. Cost: | Cost Included | Avoided Cost: | \$0.0556 |



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | MWh | COE |
|------------------------------------------|------|--------|----------------|---------|---------|-----------|----|-------------|--------|
| Wind | | Hawaii | North Kohala | Current | Incl | Nominal | 15 | 56,905 | 0.0272 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Nominal | 50 | 154,183 | 0.0297 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Nominal | 5 | 10,516 | 0.0527 |
| Energy Produced below Avoided Cost | | | | | | | | 221,604 | |
| Annual Savings Potential from Renewables | | | | | | | | \$5,634,024 | |

Figure 2-1. 1995 Base Case Resource Supply Curve, Island of Hawaii


BASE CASE

Figure 2-2 shows the base case resource supply curve for the Island of Maui. For 1995, the avoided energy cost for Maui Electric (MECO) was estimated to be approximately \$0.0604/kWh. The avoided energy cost estimate was based on information provided in MECO's most recent IRP document.

As shown in the graph, there are two viable renewable energy projects on Maui that could be implemented in 1995 at a more economical cost than the utility's avoided energy cost: a biomass electric project using organic waste as the fuel source and a wind project at McGregor Point. The costs associated with the biomass electric project assume that the project receives a revenue for waste disposal roughly equivalent to the tipping fees currently charged at the local landfill. As a result of this assumption, the biomass projects using organic waste as a fuel source are generally more cost-effective than other biomass projects.

The area under the curve reflects the annual savings potential from implementing these two projects. Rather than spending \$10.5 million per year (6.04 cents for each of the 173.2 million kWh), the island utility could instead spend \$6.6 million for the same energy. The difference between these values is approximately \$3.9 million, or the area under the curve.

| | | | |
|--------------|--------------------|---------------|----------------------------|
| Island(s): | Maui | Valuation: | Constant Dollars |
| Technology: | All_Tech | Financing: | Utility |
| Certainty: | Nominal | Tax Credits: | Included |
| Stage: | Current Technology | Data: | Unique Location Lowest COE |
| Trans. Cost: | Cost Included | Avoided Cost: | \$0.0604 |



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | MWh | COE |
|------------------------------------------|-----------|--------|----------------|---------|---------|-----------|----|-------------|--------|
| Biomass Elec | org waste | Maui | Puunene | Current | Incl | Nominal | 25 | 153,300 | 0.0357 |
| Wind | | Maui | McGregor Point | Current | Incl | Nominal | 10 | 19,874 | 0.0515 |
| Energy Produced below Avoided Cost | | | | | | | | 173,174 | |
| Annual Savings Potential from Renewables | | | | | | | | \$3,967,581 | |

Figure 2-2. 1995 Base Case Resource Supply Curve, Island of Maui

OPTIMISTIC AND CONSERVATIVE CASES

Under the optimistic assumptions in the model, two additional projects on Maui, a wind project on the northwest side of Haleakala and a biomass electric project using tree crops as the fuel source, become viable. For the NW Haleakala wind site, all three project sizes (10, 30, and 50 MW) are viable under the optimistic scenario.

Under conservative assumptions, only the biomass electric project using organic waste as a fuel source appears to be viable. The wind project at McGregor Point is not considered to be viable under the conservative scenario because the uncertainty of the wind resource is reflected in the conservative energy production estimates. Previous studies have indicated a high wind resource at this site; however, the existing data are of poor quality and it was not possible to monitor the site as part of the Phase 3 monitoring activities due to the disposition of the land lease holder at the time the monitoring program was organized. Additional monitoring could reduce the uncertainty associated with this project.


1995 RESULTS FOR THE ISLAND OF OAHU

Resource supply curves for the base case, conservative, and optimistic scenarios which list all the projects on Oahu and their calculated cost of energy are included in Appendix C.

BASE CASE

Figure 2-3 shows the base case resource supply curve for the Island of Oahu. For 1995, the avoided energy cost for Hawaiian Electric Company (HECO) was estimated to be approximately \$0.0473/kWh. The avoided energy cost estimate was based on information provided in HECO's most recent IRP document.

| | | | |
|--------------|--------------------|---------------|----------------------------|
| Island(s): | Oahu | Valuation: | Constant Dollars |
| Technology: | All_Tech | Financing: | Utility |
| Certainty: | Nominal | Tax Credits: | Included |
| Stage: | Current Technology | Data: | Unique Location Lowest COE |
| Trans. Cost: | Cost Included | Avoided Cost: | \$0.0473 |



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | MWh | COE |
|------------|------|--------|----------|-------|---------|-----------|----|------------------------------------------|-----|
| | | | | | | | | Energy Produced below Avoided Cost | 0 |
| | | | | | | | | Annual Savings Potential from Renewables | \$0 |

Figure 2-3. 1995 Base Case Resource Supply Curve, Island of Oahu

As shown in the graph, there are no viable renewable energy projects on Oahu that could be implemented in 1995 at a more economical cost than the utility's avoided energy cost. This result is consistent with the fact that renewable energy projects are not currently under consideration on this island for 1995. An expansion or upgrade of the existing wind project at Kahuku may be more economical than shown in the analysis because some of the infrastructure to support a project already exists at that site; but this is not considered in the RSC database costs. Additional development has been proposed at this site.

OPTIMISTIC AND CONSERVATIVE CASES

Even under the optimistic assumptions in the model, there are no viable renewable energy projects on Oahu that could be implemented in 1995 at a cost more economical than the utility's avoided energy cost. The avoided energy cost on Oahu is the lowest in the state and the levels for 1995 used in the study are even lower than have been experienced in the past.

Wind projects at Kaena Point and Kahuku are the projects closest to being viable. Under optimistic assumptions, a 15 MW project at Kaena Point is approximately 12% more expensive than the utility's avoided energy cost. The next most cost-effective technology is a biomass electric project at the Waialua sugar facility. Although this project does not appear to be economical for 1995, additional benefit may be gained from implementing a project of this type so as to maintain a percentage of land on this island in agriculture. In addition, the biomass project would provide a dispatchable power source. Additional analyses, such as a cost sensitivity analysis assuming different fuel crops, may be warranted at this site.


1995 RESULTS FOR THE ISLAND OF KAUAI

Resource supply curves for the base case, conservative, and optimistic scenarios which list all the projects on Kauai and their calculated cost of energy are included in Appendix D.

BASE CASE

Figure 2-4 shows the base case resource supply curve for the Island of Kauai. For 1995, the avoided cost for Kauai Electric Company (KECO) was estimated to be approximately \$0.0564/kWh. The avoided energy cost estimate was based on information provided in KECO's most recent IRP document.

| | | | |
|---------------------|--------------------|----------------------|----------------------------|
| Island(s): | Kauai | Valuation: | Constant Dollars |
| Technology: | All_Tech | Financing: | Utility |
| Certainty: | Nominal | Tax Credits: | Included |
| Stage: | Current Technology | Data: | Unique Location Lowest COE |
| Trans. Cost: | Cost Included | Avoided Cost: | \$0.0564 |



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | MWh | COE |
|------------------------------------------|------|--------|----------|-------|---------|-----------|----|-----|-----|
| | | | | | | | | 0 | |
| Energy Produced below Avoided Cost | | | | | | | | 0 | |
| Annual Savings Potential from Renewables | | | | | | | | \$0 | |

Figure 2-4. 1995 Base Case Resource Supply Curve, Island of Kauai

As shown in the graph, there are no viable renewable energy projects on Kauai that could be implemented in 1995 at a cost more economical than the utility's avoided energy cost. This result is due in part to the fact that utility demand, zoning restrictions, and competing land uses prevent consideration of large (greater than 10 MW) wind energy installations on Kauai.

OPTIMISTIC AND CONSERVATIVE CASES

Under the optimistic assumptions in the model, two small wind projects appear to be viable: a 10 MW project north of Hanapepe and a 5 MW project near Port Allen. These two projects combine for a total of 30.4 million kWh and an annual savings potential of approximately \$0.2 million.

The next most cost-effective technology for deployment in 1995 is a biomass electric project using tree crops. This 25 MW project is approximately 10% more expensive than the utility's avoided energy cost.

IMPACT OF VARYING THE 1995 BASE CASE ASSUMPTIONS

There are a number of policy-related uncertainties that are unrelated to the technology development scenario yet impact the base case results. These factors include financing terms and conditions, the inclusion of transmission upgrade costs, and the application of state and federal tax credits. For the nominal base case results and the optimistic and conservative results discussed above, the following factors were assumed:

1. Utility financing;
2. The inclusion of all costs associated with any additional transmission investment that might be required (some projects did not require transmission upgrades); and
3. Tax credits currently offered at federal and state levels.

To determine the impact that each of these assumptions has on the results, sensitivity studies were run for each of the following conditions:

1. Non-utility financing, which raises the cost of energy for the developer due to less favorable financing terms;
2. The assumption that the project does not have to pay for any additional transmission costs (due to the fact that upgrades may be underway for other reasons); and
3. No tax credits or accelerated depreciation are available to renewable energy projects due to changes in legislation.

The results of these sensitivity studies are summarized below.

NON-UTILITY FINANCING

If non-utility financing is assumed, the financial requirements for developing a power generation project are more demanding and the resulting costs of energy are higher. The higher cost of financing shifts the resource supply curves to the right, which in some cases results in project investments appearing less attractive when compared to the utility financing option. To evaluate the impact of varying this assumption, sensitivity studies were run for the nominal base cases using non-utility financing assumptions and leaving all other variables unchanged.

Figure 2-5 shows an example for the island of Hawaii which illustrates the shift in the graph due to non-utility financing. As shown on the graph, the projects which were viable under the utility financing option are still viable with non-utility financing. However, the net financial benefit, or the




Figure 2-5. Sensitivity Analysis, Financing Options

area under the curve, is smaller. The same result holds true for the other islands. Projects with non-utility financing are still viable but have slightly higher costs and the annual savings potential for the island is smaller.

TRANSMISSION INVESTMENT REQUIREMENT

Eliminating the need for investment in transmission lines for projects that require transmission upgrades would obviously reduce the cost of energy from those projects. Sensitivity studies were run for the nominal base cases assuming any required upgrade costs were not included in the project costs and leaving all other variables unchanged. This scenario could result if the utility upgraded the transmission line for reasons other than to support the renewable energy project under consideration. For example, a 15 MW wind energy project at North Kohala requires a transmission upgrade; however, resort development and county water wells are also being considered in the North Kohala area and transmission upgrades to support these activities may be undertaken and paid for by another entity (or shared between interested parties). In some cases, more than one project may include costs for the same transmission line. For example, a new transmission line to support a project at North Kohala may result in sufficient capacity that a project at Kahua Ranch could also be developed without incurring any additional transmission costs.

This sensitivity analysis is not conducted to illustrate that transmission upgrades may not be necessary. It is just a question of who pays for the upgrade and whether these costs should be incurred by the project. In terms of cost of energy, the investment must be recovered regardless of who makes the investment and ultimately the electricity consumers pay for it in either case. The sensitivity shows only whether transmission investment is important enough to affect the developer's economics.

Figure 2-6 shows an example of this sensitivity study for the island of Hawaii. For the 1995 results, transmission costs only impact the viability of the larger Kahua Ranch wind energy project. Without including the required transmission costs, the larger Kahua Ranch project becomes viable under the nominal base case scenario.




Figure 2-6. Sensitivity Analysis, Transmission Costs

TAX INCENTIVES

Both the federal government and the State of Hawaii offer tax credits for renewable energy projects. To determine whether these incentives impact the 1995 results, sensitivity studies were run for the nominal base cases assuming no tax credits or accelerated depreciation and leaving all other variables unchanged.

The loss of tax credits increases the cost of energy for the viable projects and decreases the net financial benefit significantly. Figure 2-7 shows an example for the island of Hawaii which illustrates the shift in the graph due to the loss of tax credits. Currently, wind, solar, and biomass are the only renewable technologies that receive tax credits.

SUMMARY OF 1995 RESULTS

Several conclusions are apparent from an examination of the RSC model results for 1995. The islands of Hawaii and Maui have the most opportunity in the near term for cost-competitive renewable energy project development. On Oahu, no projects appear to be immediately viable and on Kauai, limited opportunities exist, even under optimistic conditions. Table 2-1 summarizes the projected benefits or savings to the state from each of the cases that were analyzed.

On Hawaii, the three wind projects identified are extremely cost competitive with the current generating units. For all practical purposes, these projects are economic regardless of the assumptions that are made. Under optimistic assumptions, two more renewable energy projects can be implemented cost-effectively on this island. The amount of energy that can be supplied to Hawaii each year from wind power projects is noteworthy. In the nominal case, 221.6 million kWh can be generated which forms about approximately 23% of HELCO's generation.




Figure 2-7. Sensitivity Analysis, Tax Credits

There are several reasons why these projects have not been implemented despite the favorable economics. First, wind projects have been implemented at some sites on Hawaii although most of them were installed more than ten years ago. These projects utilized older technology that was not as cost effective as today's wind turbines and, as a result, were not financially successful. This experience has resulted in a low confidence level in wind technology. Other issues limiting deployment are institutional and related to the utility operation. These issues are discussed further in Section 4.

Maui's two projects are not as cost competitive in that the loss of tax credits or the use of conservative assumptions eliminates the wind project and the biomass project becomes only marginally cost competitive. Optimistic assumptions increase the total number of viable projects to four, for a total generation of 617 million kWh annually.

On Oahu, no projects appear to be viable in the immediate future unless other factors are considered. For example, a wind project at Kahuku may be less expensive than projected because the infrastructure already exists.

On Kauai, only two projects appear to be cost competitive and only if optimistic assumptions are made. Given this result and the present over-capacity situation on Kauai, no large utility-scale projects are likely to be undertaken in the near future. Note that these projects are more feasible than previously thought and continuing investigations are warranted.

Small-scale renewable energy projects based on wind and solar technologies may turn out to be cost-effective on a distributed basis on Kauai and the other Hawaiian islands. This issue is addressed in Section 5.

Statewide, the only technologies that are economic in 1995 are wind, biomass electric, and hydro. Examination of the resource supply curves reveals that the other technologies considered in this project (solar thermal, photovoltaic, wave, geothermal, and ocean thermal) are not viable options in the immediate future. Some of these technologies look promising by 2005, as discussed in Section 3.


Table 2-1. Summary of Potential Benefits, 1995

1995
Tax Credits: Included
Data: Viable Projects

Valuation: Constant Dollars
Financing: Utility
Transmission Costs: Included

1995 Projected Utility Sales
 Hawaii 957.0 GWh
 Maui 881.0 GWh
 Kauai 398.7 GWh

| Renewable Energy Project | | | Optimistic | | | Nominal | | | Conservative | | | | | |
|--------------------------|--------------------------------------------------------|--------------|----------------|--------------|------------|----------------|------------------|------------|----------------|------------------|------------|----------------|------------------|--|
| Island | Technology | Type | Location | MW | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales | |
| Hawaii | Hydro | | Umauma Stream | 13.8 | 41,019 | \$140,770 | 4.3% | 10,516 | \$30,315 | 1.1% | 8,750 | \$133,310 | 0.9% | |
| | Wind | | Kahua Ranch | 5 | 12,334 | \$175,709 | 1.3% | 92,510 | \$2,272,534 | 9.7% | 77,474 | \$1,113,879 | 8.1% | |
| | Wind | | Kahua Ranch | 15 | 35,735 | \$439,508 | 3.7% | 154,183 | \$3,988,439 | 16.1% | 129,123 | \$2,069,816 | 13.5% | |
| | Wind | | Lalamilo Wells | 3 | 12,109 | \$389,297 | 1.3% | 18,569 | \$510,089 | 1.9% | 15,676 | \$282,460 | 1.6% | |
| | Wind | | Lalamilo Wells | 30 | 108,832 | \$3,405,760 | 11.4% | 56,905 | \$1,615,269 | 5.9% | 48,105 | \$944,383 | 5.0% | |
| | Wind | | Lalamilo Wells | 50 | 181,386 | \$5,866,563 | 19.0% | 153,300 | \$3,791,131 | 17.4% | 137,970 | \$101,831 | 15.7% | |
| | Wind | | N. Kohala | 5 | 21,693 | \$729,458 | 2.3% | 19,874 | \$176,450 | 2.3% | | | | |
| | Wind | | N. Kohala | 15 | 66,183 | \$2,263,502 | 6.9% | | | | | | | |
| | Maui | Biomass Elec | org waste | Puunene | 25 | 168,630 | \$7,480,431 | 19.1% | | | | | | |
| | | Biomass Elec | tree crops | Pala-Puunene | 50 | 337,260 | \$2,344,907 | 38.3% | | | | | | |
| Wind | | | McGregor Point | 10 | 23,189 | \$453,811 | 2.6% | | | | | | | |
| Wind | | | NW Haleakala | 10 | 19,980 | \$224,193 | 2.3% | | | | | | | |
| Wind | | | NW Haleakala | 30 | 52,801 | \$140,771 | 6.0% | | | | | | | |
| Oahu | Wind | | NW Haleakala | 50 | 88,001 | \$424,815 | 10.0% | | | | | | | |
| | <i>No projects were viable for 1995 cost scenario.</i> | | | | | | | | | | | | | |
| Kauai | Wind | | Port Allen | 5 | 9,111 | \$16,524 | 2.3% | | | | | | | |
| | Wind | | N. Hanapepe | 10 | 21,296 | \$188,922 | 5.3% | | | | | | | |



SECTION 3. RESULTS OF THE RESOURCE SUPPLY CURVE MODEL FOR 2005

This section of the report discusses the renewable energy projects that appear to be economically and technically feasible for installation in 2005. These projects represent viable opportunities for the State of Hawaii and should be considered in the planning processes of both the government and the utilities. Although the analyses were conducted for the year 2005, many of these projects will be economically cost competitive before that date. Therefore, the results of this analysis can be immediately utilized by decision makers in Hawaii's energy community. The information should provide valuable insight into the potential energy options for the future and assist in guiding long-range planning activities.

There are a significant number of potential renewable energy projects and technologies that become viable generating options by 2005. However, examination and evaluation of renewable energy projects in 2005 involves less certainty than for the year 1995. Although costs are lower for all the technologies, the ranges over which they could vary are significantly greater in the future. In addition, factors such as economic conditions, fuel costs, utility demand, and legislative changes are more difficult to estimate with a high confidence level. Despite this uncertainty, the analyses for 2005 are based on a realistic set of assumptions regarding future conditions and the results are consistent with industry expectations. Whenever possible, a conservative approach was taken in analyzing the data. As conditions change, the RSC model can be used to update the analyses appropriately.

ANALYSIS APPROACH

The results for 2005 were analyzed in a manner similar to the analysis for 1995. The range between the conservative, nominal, and optimistic scenarios is larger for projects in 2005, and therefore the results cover a broader range of possible development scenarios. In addition, several technologies that were considered to be unavailable in 1995 are included in the 2005 analysis.

As with the 1995 projects, utility financing was assumed for all 2005 projects. Because the federal tax production incentives for wind and biomass are scheduled to expire for projects installed after 1999, these tax credits were not included in the analyses in this section. The state and federal investment tax credits were included. Although it is possible that additional tax credits will be put in place, removing the production tax credits for biomass and wind result in a conservative estimate of the renewable energy contribution. The base case analyses also include all required transmission costs to support the projects under consideration and constant dollars are assumed.

The avoided energy cost estimates for 2005 were based on escalating the 1995 avoided energy costs by 5% annually. This escalation is intended to represent projected increases in fuel or other operating costs. Although the choice of escalation rate can significantly affect the 2005 results, a 5% escalation is considered to be reasonable. A discussion of the sensitivity of the avoided cost assumptions is included in this section. As with the 1995 analyses, a vertical line representing this avoided cost was generated on the resource supply curve graphs for each island and each scenario that was evaluated. Projects to the left of this line on the RSC graphs represent projects that can be implemented at a levelized cost of energy that is lower than the projected cost for the utility to supply the same amount of energy in 2005. Projects to the right of the line are more expensive than the utility's avoided cost.

Note that as less expensive renewable energy projects are incorporated into the generation mix, the avoided cost will go down if the utility owns the project. If an independent power producer develops the project, the project's impact on avoided energy cost will depend on the terms of the power purchase contract with the utility. In actuality, avoided cost is an inappropriate measure to evaluate projects in 2005 because the structure under which it has been calculated will not be valid in 2005 if renewable energy projects are incorporated in any significant quantity. Because of this uncertainty, the avoided cost estimate used in this analysis for each island is not meaningful as an absolute number. It

is important only in its use as a measure by which to compare existing generation options and utility practices to the renewable energy generation options that could be implemented in the future.

In the sections below, the 2005 results are summarized for each island in terms of the amount of electricity that could be generated and the annual cost savings realized from implementing each of the viable projects. Because so many projects on each island appear to be viable in 2005, the annual cost savings are discussed in terms of individual projects rather than in terms of the entire group. The entire group of projects presented for each island is, in most cases, greater than could be installed, therefore, a sum of the cost savings is not as meaningful as it was for 1995 projects. Given that more opportunity for cost-effective renewable energy project development exists than can be developed, the number and size of the renewable energy projects that are ultimately installed will be determined based on factors other than cost. These factors include penetration limits for intermittent resources, load growth, or competing land uses and are discussed in the next section.

Results are provided for each development scenario by island. The impact of varying the assumptions is also evaluated. The 2005 results are further analyzed in Section 4 to develop a realistic renewable energy implementation goal.

2005 RESULTS FOR THE ISLAND OF HAWAII

Resource supply curves for the base case, conservative and optimistic scenarios which list all the projects on Hawaii and their calculated cost of energy are included in Appendix A.

BASE CASE

Figure 3-1 shows the base case 2005 resource supply curve for the island of Hawaii. For this analysis, the avoided cost for HELCO was projected to be \$0.0906/kWh in 2005. As shown in the graph, there are eleven renewable energy projects on Hawaii that could be implemented by 2005 at a more economical cost than the projected utility avoided cost. These projects include 3 wind projects, 1 geothermal project, 1 hydro project, 2 biomass electric projects utilizing tree crops and/or organic waste as the fuel source, 2 solar thermal dish projects, and 2 photovoltaic projects.


Although the graph shows only the most cost-effective project size, other project sizes are also viable at most of these sites under the nominal assumptions.

OPTIMISTIC AND CONSERVATIVE CASES

Under the optimistic assumptions in the model, five additional projects on Hawaii were determined to be cost competitive. These projects include a biomass project utilizing grass crops as the fuel source, a photovoltaic project at North Kohala, and three wave energy projects along the northern coast of the island. The North Kohala project site is one of the few sites in the state that has both solar and wind energy potential. Three of the fifteen projects identified as being viable under optimistic conditions are located at this site: one solar thermal project, one photovoltaic project, and one wind project. Development of one of these projects is likely to exclude development of the other two projects. The project and technology that is most likely to be developed will depend on a number of factors. The wind energy project is likely to be cost effective at an earlier date and the anticipated wind loads on solar technology equipment may cause a problem for the solar designs (high wind loads can affect performance). On the other hand, utility grid stability (wind may be more intermittent than solar at this site) or public acceptance could result in development opportunities for the solar technologies.

Under conservative assumptions, only three wind projects and one hydroelectric project are still viable. These projects are the same projects that were determined to be cost effective in 1995 under the optimistic scenarios. This result implies that these projects are likely to become viable earlier than 2005. It also indicates that the costs are better defined for these technologies than for the other, less mature technologies. The higher confidence level in the costs results from the fact that numerous wind and hydroelectric facilities have been commercially developed at other locations.

| | | | |
|--------------|-------------------|---------------|----------------------------|
| Island(s): | Hawaii | Valuation: | Constant Dollars |
| Technology: | All_Tech | Financing: | Utility |
| Certainty: | Nominal | Tax Credits: | Included |
| Stage: | Future Technology | Data: | Unique Location Lowest COE |
| Trans. Cost: | Cost Included | Avoided Cost: | \$0.0906 |



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | MWh | COE |
|------------------------------------------|------------------|--------|----------------|--------|---------|-----------|------|--------------|--------|
| Wind | | Hawaii | North Kohala | Future | Incl | Nominal | 15 | 71,178 | 0.0288 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Nominal | 50 | 192,086 | 0.0304 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Nominal | 50 | 362,314 | 0.0425 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Nominal | 5 | 12,628 | 0.0480 |
| Hydro | | Hawaii | Umauma Stream | Future | Incl | Nominal | 13.8 | 40,199 | 0.0544 |
| Biomass Elec | tree & org waste | Hawaii | Hilo Coast | Future | Incl | Nominal | 50 | 306,600 | 0.0772 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 29,416 | 0.0814 |
| Solar Thermal | dish | Hawaii | Keahole | Future | Incl | Nominal | 30 | 55,125 | 0.0852 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Nominal | 50 | 124,319 | 0.0862 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Future | Incl | Nominal | 25 | 153,300 | 0.0870 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Nominal | 50 | 124,319 | 0.0873 |
| Energy Produced below Avoided Cost | | | | | | | | 1,471,484 | |
| Annual Savings Potential from Renewables | | | | | | | | \$41,558,949 | |

Figure 3-1. 2005 Base Case Resource Supply Curve, Island of Hawaii

Photovoltaic and solar thermal dish projects are close to being cost competitive under the conservative scenario. Several projects are within \$0.01/kWh (approximately 6%) of the utility avoided cost under the conservative scenario.


2005 RESULTS FOR THE ISLAND OF MAUI

Resource supply curves for the base case, conservative and optimistic scenarios which list all the projects on Maui and their calculated cost of energy are included in Appendix B.

BASE CASE

Figure 3-2 shows the base case resource supply curve of the island of Maui. For this analysis, the avoided cost for MECO was projected to be \$0.0984/kWh in 2005. As shown in the graph, there are

| | | | |
|--------------|-------------------|---------------|----------------------------|
| Island(s): | Maui | Valuation: | Constant Dollars |
| Technology: | All_Tech | Financing: | Utility |
| Certainty: | Nominal | Tax Credits: | Included |
| Stage: | Future Technology | Data: | Unique Location Lowest COE |
| Trans. Cost: | Cost Included | Avoided Cost: | \$0.0984 |



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | MWh | COE |
|------------------------------------------|------------|--------|----------------|--------|---------|-----------|----|--------------|--------|
| Wind | | Maui | McGregor Point | Future | Incl | Nominal | 10 | 24,611 | 0.0465 |
| Biomass Elec | org waste | Maui | Puunene | Future | Incl | Nominal | 25 | 153,300 | 0.0515 |
| Wind | | Maui | NW Haleakala | Future | Incl | Nominal | 10 | 21,205 | 0.0545 |
| Wind | | Maui | Puunene | Future | Incl | Nominal | 10 | 15,784 | 0.0677 |
| Wind | | Maui | West Maui | Future | Incl | Nominal | 50 | 77,546 | 0.0707 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Future | Incl | Nominal | 50 | 306,600 | 0.0795 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Nominal | 30 | 82,893 | 0.0807 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Nominal | 30 | 77,792 | 0.0850 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Nominal | 30 | 78,159 | 0.0857 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Nominal | 10 | 16,430 | 0.0901 |
| Wave | | Maui | Opana Point | Future | Incl | Nominal | 60 | 211,984 | 0.0920 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Nominal | 10 | 16,922 | 0.0929 |
| Wave | | Maui | Lower Paia | Future | Incl | Nominal | 60 | 203,974 | 0.0956 |
| Energy Produced below Avoided Cost | | | | | | | | 1,287,200 | |
| Annual Savings Potential from Renewables | | | | | | | | \$23,487,236 | |

Figure 3-2. 2005 Base Case Resource Supply Curve, Island of Maui

13 renewable energy projects on Maui that could be implemented by 2005 at a more economical cost than the projected utility avoided cost. These projects include four wind projects, two biomass electric projects utilizing tree crops and/or organic waste as the fuel source, two solar thermal dish projects, three photovoltaic projects, and two wave energy projects.

Although the graph shows only the most cost-effective project size, other project sizes are also viable at most of these sites.

OPTIMISTIC AND CONSERVATIVE CASES

Under the optimistic assumptions in the model, one additional wave project and one additional solar thermal dish project are shown to be viable. Smaller-sized projects at sites already included in the nominal scenario also become viable options.

Under conservative assumptions, the four wind projects (in all sizes) and a single biomass electric project using organic waste as a fuel source are the only cost-competitive options. These results include one more wind project than was viable under the optimistic scenario in 1995.

Biomass electric using tree crops as a fuel source, photovoltaic, and solar thermal projects are all within 10% of being cost competitive under the conservative scenario.

2005 RESULTS FOR THE ISLAND OF OAHU

Resource supply curves for the base case, conservative and optimistic scenarios which list all the projects on Oahu and their calculated cost of energy are included in Appendix C.

BASE CASE

Figure 3-3 shows the base case resource supply curve of the island of Oahu. For this analysis, the avoided cost for HECO was projected to be \$0.077/kWh in 2005. As shown in the graph, there are two wind projects and one biomass electric project using organic waste as a fuel source that could be implemented by 2005 at a more economical cost than the projected utility avoided cost. The wind projects include Kaena Point (at either 2 or 15 MW) and Kahuku (at either 30, 50, or 80 MW). Although all three size projects at Kahuku are viable options, the 30 MW project has the lowest cost of energy due to the cost of the transmission upgrade requirement. A 50 MW solar thermal dish project at Pearl Harbor is approximately 7% more expensive than the projected utility avoided cost.

OPTIMISTIC AND CONSERVATIVE CASES

Under the optimistic assumptions in the model, 15 projects appear to be viable. In addition to the base case project, 6 wave projects, 3 photovoltaic projects, 2 solar thermal projects, and 1 biomass electric project using grass crops as a fuel appear to be viable. The large number of wave projects and wave energy's cost effectiveness on Oahu (lowest cost of energy following the organic waste and wind energy projects) illustrate that wave energy offers significant contribution potential if the technology matures as expected under optimistic assumptions. A strong wave resource is available on the northeast coast of Oahu. Additional research on this technology and demonstration projects are needed to validate the cost and performance estimates.

All three viable projects identified in the base case remain viable under conservative assumptions. None of these projects were considered to be viable in 1995.


2005 RESULTS FOR THE ISLAND OF KAUAI

Resource supply curves for the base case, conservative and optimistic scenarios which list all the projects on Kauai and their calculated cost of energy are included in Appendix D.

BASE CASE

Figure 3-4 shows the base case resource supply curve of the island of Kauai. For this analysis, the avoided cost for KECO was projected to be \$0.0919/kWh in 2005. As shown in the graph, there are two wind projects, one hydroelectric, one solar thermal dish, and two biomass electric projects (one tree crops combined with one tree crop and organic waste) that could be implemented by 2005 at a more economical cost than the projected utility avoided cost. Additional biomass projects are within 5% of the projected avoided cost.

| | | | |
|--------------|-------------------|---------------|----------------------------|
| Island(s): | Oahu | Valuation: | Constant Dollars |
| Technology: | All_Tech | Financing: | Utility |
| Certainty: | Nominal | Tax Credits: | Included |
| Stage: | Future Technology | Data: | Unique Location Lowest COE |
| Trans. Cost: | Cost Included | Avoided Cost: | \$0.0770 |



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | MWh | COE |
|------------------------------------------|-----------|--------|----------------|--------|---------|-----------|----|--------------|--------|
| Biomass Elec | org waste | Oahu | Barber's Point | Future | Incl | Nominal | 50 | 306,600 | 0.0389 |
| Wind | | Oahu | Kaena Point | Future | Incl | Nominal | 15 | 31,558 | 0.0567 |
| Wind | | Oahu | Kahuku | Future | Incl | Nominal | 30 | 56,977 | 0.0597 |
| Energy Produced below Avoided Cost | | | | | | | | 395,135 | |
| Annual Savings Potential from Renewables | | | | | | | | \$13,307,378 | |

Figure 3-3. 2005 Base Case Resource Supply Curve, Island of Oahu

OPTIMISTIC AND CONSERVATIVE CASES


Under the optimistic assumptions in the model, nine projects appear to be viable. In addition to the base case projects, one wind project, one wave project, one photovoltaic project, and one solar thermal dish project become cost-effective under optimistic assumptions.

Under conservative assumptions, only the two wind projects and the hydroelectric project in the base case are still viable. The next most cost-effective project is approximately 15% more expensive than the projected avoided cost. This result again demonstrates the uncertainty associated with the developing technologies.

IMPACTS OF VARYING ASSUMPTIONS

The impacts of varying the assumptions for financing, the inclusion of transmission costs, and the consideration of tax credits are essentially the same as the impacts discussed in Section 2. Whether the project is utility financed or privately financed slightly increases the costs but does not cause viable projects to move to the right of the avoided cost line on the resource supply curves. The exclusion of transmission costs affects the same projects in the 2005 results as it did in the 1995 results.

| | | | |
|--------------|-------------------|---------------|----------------------------|
| Island(s): | Kauai | Valuation: | Constant Dollars |
| Technology: | All_Tech | Financing: | Utility |
| Certainty: | Nominal | Tax Credits: | Included |
| Stage: | Future Technology | Data: | Unique Location Lowest COE |
| Trans. Cost: | Cost Included | Avoided Cost: | \$0.0919 |



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | MWh | COE |
|------------------------------------------|------------------|--------|---------------|--------|---------|-----------|-----|-------------|--------|
| Wind | | Kauai | N. Hanapepe | Future | Incl | Nominal | 10 | 22,602 | 0.0529 |
| Wind | | Kauai | Port Allen | Future | Incl | Nominal | 5 | 9,321 | 0.0603 |
| Hydro | | Kauai | Wailua River | Future | Incl | Nominal | 6.6 | 16,435 | 0.0678 |
| Biomass Elec | tree & org waste | Kauai | Kaumakani | Future | Incl | Nominal | 50 | 306,600 | 0.0794 |
| Solar Thermal | dish | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 17,250 | 0.0878 |
| Biomass Elec | tree crops | Kauai | Lihue | Future | Incl | Nominal | 25 | 153,300 | 0.0894 |
| Energy Produced below Avoided Cost | | | | | | | | 525,508 | |
| Annual Savings Potential from Renewables | | | | | | | | \$5,870,070 | |

Figure 3-4. 2005 Base Case Resource Supply Curve, Island of Kauai

As in 1995, the exclusion of tax credits has the greatest impact on the 2005 results. The effects of removing the tax credit considerations in the sensitivity analysis are not as large for biomass and wind projects because the production tax incentives are not included for the 2005 analysis. For solar projects, however, removing tax credits from consideration has a significant impact on their viability.

SENSITIVITY OF RESULTS TO AVOIDED COST ASSUMPTIONS

Visual examination of any of the resource supply curves quickly reveals the extent to which higher or lower avoided cost assumptions will affect the set of cost-competitive project choices. The impact of moving the vertical avoided cost line to the right (for higher avoided cost) or left (for lower avoided cost) can be easily seen on the graphs. The steeper the curve, the more sensitive the results are to the avoided cost assumptions.

On Hawaii, the flatness of the nominal RSC graph at the avoided-cost line intersection point illustrates that relatively small changes in the avoided cost assumptions will not affect the number of viable projects. On Oahu, however, the avoided cost line crosses the nominal RSC curve at a fairly steep part of the curve. Oahu results, therefore, are more sensitive to the avoided cost assumptions.

2005 RESULTS FOR BIOMASS FUELS

The RSC model also includes cost-of-energy estimates for a number of biomass fuel projects in 2005. Although these projects are not discussed in detail in this report, they also represent viable opportunities to use renewable resources to reduce the state's petroleum dependency. In the RSC model, the cost of energy for biomass fuel projects was converted into cents/kWh based on the heat content of the fuels to allow for comparison to electricity generating projects. In actual practice, these biomass projects will produce liquid fuels, not electricity, and will be competing for markets now dominated by gasoline. To evaluate whether these projects are economically viable options for the future, a more appropriate comparison can be made between the competing fuel alternatives.

Table 3-1 shows the estimated cost of the biomass fuels on a \$/gallon basis for each of the projects contained in the RSC database. Estimates are provided for the optimistic, nominal, and conservative scenarios for both methanol and ethanol production projects. Note that these fuels have a different energy conversion efficiency from other fuel alternatives so a direct comparison of the costs presented in Table 3-1 to gasoline prices, for example, is not appropriate. It is also important to note that the published price (or pump price) of alternative fuels often includes hidden costs such as taxes and transportation. Although it is beyond the scope of this project to evaluate the costs of other fuel alternatives in detail, a few conclusions can be drawn regarding these energy conversion technologies.

Table 3-1. Cost Summary of Biomass Fuels

| Island | Type | Location | MW | Cost per Gallon* | | |
|--------|----------------------|---------------|-----|------------------|---------|--------------|
| | | | | Optimistic | Nominal | Conservative |
| Hawaii | tree crops-methanol | Hamakua Coast | 47 | 0.97 | 1.34 | 1.78 |
| Hawaii | tree crops-methanol | Hilo Coast | 47 | 1.00 | 1.38 | 1.84 |
| Hawaii | grass crops-methanol | Kaunakani | 47 | 1.15 | 1.58 | 2.10 |
| Kauai | tree crops-methanol | Lihue | 47 | 0.99 | 1.37 | 1.82 |
| Kauai | tree crops-methanol | Kaunakani | 47 | 1.03 | 1.42 | 1.89 |
| Maui | org waste-methanol | Puunene | 47 | 0.58 | 0.93 | 1.35 |
| Maui | tree crops-methanol | Paia-Puunene | 95 | 0.70 | 0.97 | 1.29 |
| Maui | grass crops-methanol | Paia-Puunene | 95 | 0.82 | 1.12 | 1.49 |
| Maui | grass crop-ethanol | Paia-Puunene | 141 | 1.42 | 1.95 | 2.60 |
| Maui | tree crop-ethanol | Paia-Puunene | 70 | 1.68 | 2.31 | 3.08 |
| Oahu | org waste-methanol | Barbers Point | 95 | 0.25 | 0.49 | 0.79 |
| Oahu | org waste-ethanol | Barbers Point | 70 | 0.77 | 1.30 | 1.94 |

* MGPY converted to MW based on the following equations.

$$1 \text{ MW} = 1,000 \text{ MW} \times 8,760 \text{ hr/yr} / 16.61 \text{ kWh/gal MeOH} / 1,000,000 \text{ gal} = 0.5274 \text{ MGPY MeOH}$$

$$1 \text{ MW} = 1,000 \text{ MW} \times 8,760 \text{ hr/yr} / 24.70 \text{ kWh/gal EtOH} / 1,000,000 \text{ gal} = 0.3547 \text{ MGPY EtOH}$$

A recently completed report from DBEDT entitled *Ethanol Production in Hawaii* by Dr. Robert Shleser indicates that the competitive production price per gallon for ethanol varies considerably depending on the potential markets for fuel ethanol. Competitive production prices range from a low of approximately \$0.60 to more than \$2.00 per gallon. The 2005 results from the model show optimistic production prices for ethanol ranging from \$0.77 (with organic waste as the fuel source) to \$1.42 per gallon (with grass crops as the fuel source). For an ethanol production facility using tree crops as the fuel source, costs ranged from a conservative estimate of \$3.08 to an optimistic estimate of \$1.68 per gallon. Similar comparisons can be made for methanol production projects. Although

these numbers are far from conclusive, they illustrate that biomass fuels are in a realistic cost range to warrant further analysis.

SUMMARY OF 2005 RESULTS

Several conclusions are apparent from an examination of the RSC model results for 2005. Tables 3-2 through 3-5 summarize the energy production and potential benefits or savings to the state for all of the viable renewable energy projects for each island and development scenario. It is evident by the number of projects that all of the renewable energy generation cannot be utilized by the state's utilities. The renewable energy integration plans presented in the Section 4 prioritize and summarize the projects based on their cost effectiveness and ability to be incorporated into the state's utility grids.

Even under the conservative scenario, cost-effective projects exist on each island. For Hawaii and Maui, the number of projects under all scenarios is significant, again indicating the large potential for renewable energy on these islands.

On Oahu, large-scale projects are cost competitive under nominal and conservative conditions for biomass and wind technologies. Even though these projects are larger than considered on the other islands, they make a fairly small contribution in terms of energy production due to the larger demand on Oahu. Nonetheless, the annual savings potential to the state is significant even when other benefits are not considered.

On Kauai, projects are viable under all scenarios. The nominal cases include a wide diversity of technologies including biomass, hydro, solar thermal, and wind.

Table 3-2. Summary of Potential Benefit on Hawaii, 2005

2005 - Hawaii
Tax Credits: Excluded
Data: Viable Projects

Valuation: Constant Dollars
Financing: Utility
Transmission Costs: Included

2005 Projected Utility Sales
1,416.6 GWh

| Renewable Energy Project | | | Optimistic | | | Nominal | | | Conservative | | | |
|--------------------------|------------------|----------------|------------|------------|----------------|------------------|------------|----------------|------------------|------------|----------------|------------------|
| Technology | Type | Location | MW | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales |
| Biomass Elec | grass crops | Ka'u | 25 | 168,630 | \$2,982,819 | 11.9% | 306,600 | \$4,106,177 | 21.6% | 308,352 | \$8,181,736 | 21.8% |
| Biomass Elec | tree & org waste | Hilo Coast | 50 | 337,260 | \$12,146,639 | 23.8% | 153,300 | \$549,070 | 10.8% | 150,672 | \$2,006,646 | 10.6% |
| Biomass Elec | tree crops | Hamakua Coast | 25 | 168,630 | \$4,605,950 | 11.9% | 362,314 | \$17,434,626 | 25.6% | 177,302 | \$6,982,903 | 12.5% |
| Geothermal | | Kilauea | 50 | 390,871 | \$22,596,693 | 27.6% | 40,199 | \$1,454,791 | 2.8% | 39,788 | \$1,312,372 | 2.8% |
| Geothermal | | Kilauea | 25 | 193,421 | \$10,101,330 | 13.7% | 124,319 | \$408,330 | 8.8% | | | |
| Hydro | | Umauma Stream | 13.8 | 41,019 | \$1,629,257 | 2.9% | | | | | | |
| Photovoltaic | tracking | Keahole | 30 | 85,780 | \$1,304,617 | 6.1% | | | | | | |
| Photovoltaic | tracking | Keahole | 50 | 142,967 | \$3,061,806 | 10.1% | | | | | | |
| Photovoltaic | tracking | N. Kohala | 5 | 13,624 | \$11,736 | 1.0% | | | | | | |
| Photovoltaic | tracking | N. Kohala | 15 | 40,873 | \$317,418 | 2.9% | | | | | | |
| Photovoltaic | tracking | Waikoloa | 30 | 85,780 | \$1,228,256 | 6.1% | | | | | | |
| Photovoltaic | tracking | Waikoloa | 50 | 142,967 | \$2,934,504 | 10.1% | | | | | | |
| Solar Thermal | dish | Keahole | 30 | 57,882 | \$971,051 | 4.1% | 55,125 | \$294,975 | 3.9% | | | |
| Solar Thermal | dish | N. Kohala | 5 | 10,399 | \$179,801 | 0.7% | 9,904 | \$59,957 | 0.7% | | | |
| Solar Thermal | dish | N. Kohala | 15 | 30,886 | \$609,856 | 2.2% | 29,416 | \$269,194 | 2.1% | | | |
| Wave | | Honokaa 2A | 10 | 42,134 | \$1,326,554 | 3.0% | | | | | | |
| Wave | | N. Kohala | 10 | 39,276 | \$906,723 | 2.8% | | | | | | |
| Wave | | N. Kohala | 30 | 117,856 | \$3,699,708 | 8.3% | | | | | | |
| Wave | | Papeeteo 2E | 10 | 40,968 | \$1,210,619 | 2.9% | | | | | | |
| Wind | | Kahua Ranch | 5 | 14,811 | \$753,456 | 1.0% | 12,628 | \$537,485 | 0.9% | 10,612 | \$307,122 | 0.7% |
| Wind | | Kahua Ranch | 15 | 44,699 | \$2,221,414 | 3.2% | 38,021 | \$1,573,746 | 2.7% | 31,865 | \$886,868 | 2.2% |
| Wind | | Lalamilo Wells | 3 | 15,147 | \$976,880 | 1.1% | 12,966 | \$774,079 | 0.9% | 10,945 | \$561,126 | 0.8% |
| Wind | | Lalamilo Wells | 30 | 136,131 | \$8,709,915 | 9.6% | 115,714 | \$6,852,583 | 8.2% | 96,907 | \$4,925,705 | 6.8% |
| Wind | | Lalamilo Wells | 50 | 225,977 | \$14,637,464 | 16.0% | 192,086 | \$11,564,058 | 13.6% | 160,865 | \$8,379,774 | 11.4% |
| Wind | | N. Kohala | 5 | 26,048 | \$1,702,148 | 1.8% | 22,298 | \$1,357,940 | 1.6% | 18,823 | \$997,994 | 1.3% |
| Wind | | N. Kohala | 15 | 83,049 | \$5,469,135 | 5.9% | 71,178 | \$4,398,300 | 5.0% | 60,171 | \$3,282,410 | 4.2% |

Table 3-3. Summary of Potential Benefit on Maui, 2005

2005 - Maui
 Tax Credits: Excluded
 Data: Viable Projects

Valuation: Constant Dollars
 Financing: Utility
 Transmission Costs: Included

2005 Projected Utility Sales
 1,042.7 GWh

| Renewable Energy Project | | | | Optimistic | | | Nominal | | | Conservative | | |
|--------------------------|------------|----------------|----|------------|----------------|------------------|------------|----------------|------------------|--------------|----------------|------------------|
| Technology | Type | Location | MW | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales |
| Biomass Elec | org waste | Puunene | 25 | 168,630 | \$11,543,043 | 16.2% | 153,300 | \$7,901,769 | 14.7% | 137,970 | \$2,822,858 | 13.2% |
| Biomass Elec | tree crops | Paia-Puunene | 50 | 337,260 | \$13,681,730 | 32.3% | 306,600 | \$5,788,622 | 29.4% | | | |
| Photovoltaic | tracking | Kahului | 10 | 31,776 | \$930,580 | 3.0% | 27,632 | \$327,256 | 2.7% | | | |
| Photovoltaic | tracking | Kahului | 30 | 95,327 | \$3,208,893 | 9.1% | 82,893 | \$1,465,341 | 7.9% | | | |
| Photovoltaic | tracking | Kihel | 10 | 29,961 | \$749,709 | 2.9% | 26,053 | \$169,354 | 2.5% | | | |
| Photovoltaic | tracking | Kihel | 30 | 89,883 | \$2,666,376 | 8.6% | 78,159 | \$991,933 | 7.5% | | | |
| Photovoltaic | tracking | Puunene | 10 | 29,821 | \$761,549 | 2.9% | 25,931 | \$184,308 | 2.5% | | | |
| Photovoltaic | tracking | Puunene | 30 | 89,461 | \$2,704,904 | 8.6% | 77,792 | \$1,040,066 | 7.5% | | | |
| Solar Thermal | dish | Kahului | 10 | 16,735 | \$219,054 | 1.6% | 16,922 | \$93,244 | 1.6% | | | |
| Solar Thermal | dish | Kihel | 10 | 17,768 | \$317,702 | 1.7% | 16,430 | \$137,141 | 1.6% | | | |
| Solar Thermal | dish | Puunene | 10 | 17,252 | \$350,073 | 1.7% | 16,430 | \$137,141 | 1.6% | | | |
| Solar Thermal | dish | Puunene | 30 | 51,234 | \$815,217 | 4.9% | 48,795 | \$170,062 | 4.7% | | | |
| Wave | | Lower Paia | 10 | 42,635 | \$1,656,209 | 4.1% | | | | | | |
| Wave | | Lower Paia | 30 | 127,957 | \$5,766,292 | 12.3% | | | | | | |
| Wave | | Lower Paia | 60 | 255,885 | \$12,277,127 | 24.5% | 203,974 | \$578,513 | 19.6% | | | |
| Wave | | Opana Point | 10 | 44,283 | \$1,818,372 | 4.2% | | | | | | |
| Wave | | Opana Point | 30 | 132,906 | \$6,253,273 | 12.7% | 106,004 | \$129,071 | 10.2% | | | |
| Wave | | Opana Point | 60 | 265,780 | \$13,250,795 | 25.5% | 211,984 | \$1,366,697 | 20.3% | | | |
| Wave | | Walehu Point | 10 | 42,269 | \$1,581,201 | 4.1% | | | | | | |
| Wave | | Walehu Point | 30 | 126,887 | \$5,613,846 | 12.2% | 24,611 | \$1,277,500 | 2.4% | 20,805 | \$816,035 | 2.0% |
| Wind | | McGregor Point | 10 | 28,715 | \$1,152,551 | 2.8% | 21,205 | \$931,420 | 2.0% | 17,926 | \$517,772 | 1.7% |
| Wind | | NW Haleakala | 10 | 24,741 | \$1,316,885 | 2.4% | 56,140 | \$1,937,798 | 5.4% | 47,015 | \$703,622 | 4.5% |
| Wind | | NW Haleakala | 30 | 66,045 | \$3,100,800 | 6.3% | 93,192 | \$3,457,891 | 8.9% | 78,045 | \$1,475,870 | 7.5% |
| Wind | | NW Haleakala | 50 | 109,635 | \$5,326,333 | 10.5% | 15,784 | \$485,012 | 1.5% | 13,275 | \$148,568 | 1.3% |
| Wind | | Puunene | 10 | 18,501 | \$794,278 | 1.8% | 45,113 | \$1,087,976 | 4.3% | 37,781 | \$114,265 | 3.6% |
| Wind | | Puunene | 30 | 53,073 | \$1,987,891 | 5.1% | 15,416 | \$374,341 | 1.5% | 12,965 | \$40,254 | 1.2% |
| Wind | | West Maui | 10 | 18,069 | \$681,186 | 1.7% | 46,715 | \$1,243,842 | 4.5% | 39,288 | \$250,678 | 3.8% |
| Wind | | West Maui | 30 | 54,754 | \$2,160,169 | 5.3% | 77,546 | \$2,148,795 | 7.4% | 65,218 | \$514,476 | 6.3% |
| Wind | | West Maui | 50 | 90,891 | \$3,660,130 | 8.7% | | | | | | |

Table 3-4. Summary of Potential Benefit on Oahu, 2005

2005 - Oahu
 Tax Credits: Excluded
 Data: Viable Projects

Valuation: Constant Dollars
 Financing: Utility
 Transmission Costs: Included

2005 Projected Utility Sales
 8,550.9 GWh

| Renewable Energy Project | | | Optimistic | | | Nominal | | | Conservative | | |
|--------------------------|-----------|----------------|------------|----------------|------------------|------------|----------------|------------------|--------------|----------------|------------------|
| Technology | Type | Location | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales |
| Biomass Elec | org waste | Barber's Point | 50 | \$19,415,948 | 3.9% | 306,600 | \$11,677,840 | 3.6% | 275,940 | \$3,939,732 | 3.2% |
| Photovoltaic | tracking | Lualualei | 20 | \$3,932 | 0.6% | | | | | | |
| Photovoltaic | tracking | Lualualei | 50 | \$901,656 | 1.5% | | | | | | |
| Photovoltaic | tracking | N. Ewa Plain | 50 | \$795,581 | 1.5% | | | | | | |
| Photovoltaic | tracking | Pearl Harbor | 50 | \$846,393 | 1.5% | | | | | | |
| Solar Thermal | dish | Lualualei | 50 | \$299,260 | 1.0% | | | | | | |
| Solar Thermal | dish | Pearl Harbor | 50 | \$457,192 | 1.0% | | | | | | |
| Wave | | Kahuku Point | 30 | \$3,588,223 | 1.6% | | | | | | |
| Wave | | Kahuku Point | 60 | \$7,537,155 | 3.1% | | | | | | |
| Wave | | Maikapuu | 30 | \$4,074,677 | 1.6% | | | | | | |
| Wave | | Maikapuu | 60 | \$8,646,189 | 3.3% | | | | | | |
| Wave | | Mokapu Point | 30 | \$2,734,842 | 1.4% | | | | | | |
| Wave | | NE Coast 2A | 30 | \$3,368,929 | 1.5% | | | | | | |
| Wave | | NE Coast 2C | 30 | \$3,098,195 | 1.5% | | | | | | |
| Wave | | Waimanalo Bay | 30 | \$1,950,993 | 1.3% | | | | | | |
| Wind | | Kaena Point | 2 | \$123,986 | 0.1% | 4,002 | \$61,156 | 0.0% | | | |
| Wind | | Kaena Point | 15 | \$1,107,657 | 0.4% | 31,558 | \$642,174 | 0.4% | 26,560 | \$129,058 | 0.3% |
| Wind | | Kahuku | 30 | \$1,869,607 | 0.8% | 56,977 | \$987,364 | 0.7% | \$47,716 | \$17,197 | 0.6% |
| Wind | | Kahuku | 50 | \$3,019,081 | 1.3% | 94,581 | \$1,564,323 | 1.1% | | | |
| Wind | | Kahuku | 80 | \$3,930,812 | 2.1% | 151,558 | \$1,603,709 | 1.8% | | | |


Table 3-5. Summary of Potential Benefit on Kauai, 2005

2005 - Kauai
Tax Credits: Included
Data: Viable Projects

Valuation: Constant Dollars
Financing: Utility
Trans. Cost: Cost Included

2005 Projected Utility Sales
568.3 GWh

| Renewable Energy Project | | | Optimistic | | | Nominal | | | Conservative | | |
|--------------------------|------------------|---------------|------------|----------------|------------------|------------|----------------|------------------|--------------|----------------|------------------|
| Technology | Type | Location | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales | Annual MWh | Annual Benefit | % of Util. Sales |
| Blomass Elec | tree & org waste | Kaunakani | 50 | \$12,069,774 | 59.3% | 306,600 | \$3,838,465 | 53.9% | 16,267 | \$328,852 | 2.9% |
| Blomass Elec | tree crops | Lihue | 25 | \$4,538,343 | 29.7% | 153,300 | \$389,827 | 27.0% | | | |
| Hydro | | Waialua River | 6.6 | \$475,719 | 3.0% | 16,435 | \$395,840 | 2.9% | | | |
| Photovoltaic | tracking | Barking Sands | 10 | \$240,253 | 4.6% | | | | | | |
| Solar Thermal | dish | Barking Sands | 10 | \$284,532 | 3.2% | | | | | | |
| Wave | | Anahola | 10 | \$1,182,176 | 7.3% | 17,250 | \$70,213 | 3.0% | | | |
| Wave | | Anahola | 30 | \$4,609,212 | 21.9% | | | | | | |
| Wind | | Anahola | 7 | \$111,449 | 1.7% | | | | | | |
| Wind | | N. Hanapepe | 10 | \$1,263,460 | 4.6% | 22,602 | \$881,293 | 4.0% | 19,107 | \$469,261 | 3.4% |
| Wind | | Port Allen | 5 | \$465,153 | 1.9% | 9,321 | \$294,433 | 1.6% | 7,828 | \$108,881 | 1.4% |



SECTION 4. PROJECT IMPLEMENTATION ANALYSES FOR INTERMITTENT RENEWABLE ENERGY RESOURCES

In evaluating the renewable energy generating options, it is important to consider the value of the energy to a utility as well as the cost of generation. Utilities commonly consider intermittent generating resources, such as wind, solar, and wave energy, to be less valuable than firm generating resources because intermittent resources are non-dispatchable. The value of the resource to the utility has significant impacts on the likelihood of project implementation. If these intermittent resources can be shown to have some quantifiable value to the utility, the likelihood of implementation is increased.

The following sections provide summaries of analyses aimed at identifying the value of these intermittent resources. These analyses include utility load matching with renewable energy project output on a diurnal and seasonal basis, determination of capacity value, and a comparison of the impact of time-of-day delivery and pricing scenarios for each island. Renewable energy projects also have value in their environmental and societal benefits, reduced fuel risk, short lead time, and modularity. Although these attributes should be fully considered in any planning process, their quantification is beyond the scope of this study.

For each of the analyses and results presented below, typical outputs or representative projects are discussed for wind, solar, and wave energy technologies. The other technologies evaluated in this study are considered to be firm generating resources. A differentiation between solar thermal and photovoltaics is not generally made because the output from both types of projects is similar on a diurnal and seasonal basis.

UTILITY LOAD MATCHING

As part of Phase 3, RLA developed diurnal and seasonal energy estimates for all the intermittent renewable energy projects contained in the RSC database. Diurnal estimates were developed on both a monthly and annual basis. A user-friendly computer model (separate from the RSC model) was developed to allow for graphical presentation and analysis of this information. The program allows the user to choose a single project or a combination of projects to graph against the utility load curves for each island. If a combination of projects is chosen, the program sums the diurnal and or seasonal output from the different projects and graphs the combined output as a single line. This option allows the user to evaluate whether the combination of projects within an island provides a better load match than a single project.

Figures 4-1 to 4-3 are sample graphs from the utility load matching program for each technology on a diurnal and seasonal basis for the island of Hawaii. The basic shape of the utility load curve is similar on all the islands. Because there is a great number of possible graphing combinations, these graphs are provided as illustrative results only. This information provided the basis for conducting the capacity value and time-of-day analyses described below. In addition, a number of general conclusions can be drawn for each technology.

Figure 4-1 shows the diurnal and seasonal energy output patterns for a 30 MW solar thermal project at Waikoloa. The shape of the curves is similar for solar projects on each island regardless of the project size or solar technology utilized. As shown in the graphs, the shape of the seasonal curve follows the utility load curve fairly well. On a diurnal basis, however, the energy output from solar projects drops off before the utility system hits its daily peak load.

Figure 4-2 shows the diurnal and seasonal energy output patterns for a 30 MW wave energy project off the north Kohala coast. Again, the shape of these curves is similar for wave projects in other locations. Note, however, that high-quality wave resource data were not available to use as a basis for energy output estimates. Actual data from specific project sites may yield different results. As shown





Figure 4-1. Diurnal and Seasonal Load Comparison, Solar





Figure 4-2. Diurnal and Seasonal Load Comparison, Wave









Figure 4-3. Diurnal and Seasonal Load Comparison, Wind

in the graphs, the shape of seasonal curve is not as well matched to the utility load as the solar curve. On a diurnal basis, the output from a wave project is variable and the shape of the curve is not particularly well matched to the utility load.

Figure 4-3 shows the diurnal and seasonal energy output patterns for three wind energy projects in different locations. Three graphs are shown to illustrate that the wind resource exhibits different seasonal and diurnal patterns in different project locations. In this example, the three sites – North Kohala, Lalamilo, and Kahua Ranch – are fairly close to each other. As shown in the graphs, the shape of the seasonal curves follows the utility load fairly well despite slight variations between projects. On a diurnal basis, the output of the three projects is significantly different. The North Kohala project exhibits the best match to the utility diurnal load; however, the Kahua Ranch project peaks at the same time as the utility system diurnal peak. Wind projects on other islands exhibit different diurnal patterns.

Because diurnal patterns can vary by season, diurnal estimates were developed for each month as well as on an annual basis. Figure 4-4 shows an example of how the diurnal pattern can vary by month at a typical wind project. Diurnal and seasonal outputs were not summarized for either biomass or ocean thermal projects because these project types are firm generating resources. It is possible to stockpile biomass fuel to generate energy only during periods of higher demand; however, this scenario would only be worthwhile if an economic incentive such as time-of-day payment rates was available.

CAPACITY VALUE FOR INTERMITTENT RESOURCES

Electrical generating plants are generally characterized by both an energy value and a capacity value. For intermittent resources, characterizing the *energy* value to a utility is relatively straightforward and generally represents the savings due to fuel displacement and possibly O&M cost. The *capacity* value of intermittent resources, however, is more difficult to quantify.

In the context of electric utility planning, capacity value refers to the ability of a generating resource to help meet peak loads. The capacity value depends on the quality and characteristics of the intermittent resource and on how well it complements the utility system under consideration. Capacity has value only if the addition of the resource to the system measurably increases the reliability of the system by reducing the probability that the system will fail to meet its peak loads. Practical experience with utilities in other locations (particularly with wind energy facilities) indicates that, in some cases, intermittent resources are able to defer the acquisition of other generating resources. Capacity value is extremely site-specific, however, and must be analyzed on a case-by-case basis.

Although there are little actual data available, some studies have suggested that the average capacity factor may be a reasonable indicator of wind energy capacity at low penetrations levels. In certain situations, however, this simplistic approach may result in an overestimation of capacity value. More sophisticated methods employed by utilities include conducting loss-of-load probability (LOLP) calculations as the basis for estimating capacity. A LOLP analysis requires detailed information about the capacity and forced outage rates of each unit in the utility system as well as detailed information about the intermittent generation output and the system load. A base case analysis is run using current loads and resources, then the new resource under consideration is added to the system (for intermittent technologies, it is generally modeled with a high forced outage rate), and the LOLP for both analyses is compared to a reference value. An LOLP analysis requires significant effort and very detailed operating information and was therefore beyond the scope of this study.

An intermediate approach to determining capacity value is to analyze the periods during which system loads are high and system marginal costs are likely to be correspondingly high. The underlying assumption with this approach is that capacity is acquired for its load carrying capability during periods of high loads. To analyze the capacity value of intermittent renewable energy projects in Hawaii, RLA examined the output from projects during periods of high hourly system loads. To conduct the analysis, the hourly system load values for the peak week in each month were summarized









Figure 4-4. Monthly Diurnal Patterns, Wind









Figure 4-4. Monthly Diurnal Patterns, Wind (Continued)

for each utility in Hawaii. The hourly output which corresponded to the peak system values was then calculated for each intermittent renewable energy project (based on actual resource data). The results of this analysis for a typical wind, solar, and wave energy project are summarized graphically in Figures 4-5 to 4-7. In the graphs, the peak load hours and corresponding renewable energy project output are sorted in descending order and graphed as two separate lines. The renewable energy project output is given as a percent of its rated capacity. The variability of the intermittent resources during the high-load periods is easily seen on the graphs.

As shown in Figure 4-5, a typical wind energy project produces between 10% and 50% of its rated capacity during the peak hours of the year. This result can be interpreted to indicate that, at a minimum, wind energy projects provide a 10% capacity value to the utility. If the average rated capacity during peak hours is used to estimate capacity value, the project shown in Figure 4-5 would have a capacity value of approximately 25%. As shown on Figure 4-6, a typical solar project produces between 0% and 70% of its rated capacity during peak hours. The 0% values occur during the early evening peaks when the solar resource is unavailable. As shown in Figure 4-7, a typical wave project produces between 30% and 60% of its rated capacity during peak hours. If capacity value is determined based on a project's minimum rated capacity during peak hours, wave projects have the greatest capacity value to a utility.




Figure 4-5. Peak Load versus Rated Capacity, Wind

Tables 4-1 to 4-4 show minimum and average capacity values for representative wind, solar, and wave projects on each island. The values are presented on both a monthly and annual basis. Because the wind projects exhibit varying diurnal patterns depending on the site, results for multiple wind energy projects are provided. The solar and wave energy diurnal patterns are similar between sites so only a representative project is shown.

Based on this analysis, there is evidence that wind and wave projects provide capacity value to a utility if minimum rated capacity during peak hours is used as the basis for estimating capacity value. On this basis, solar projects do not have a capacity value. If the average rated capacity during peak hours is used as the basis for estimating capacity value, solar projects have a fairly high capacity value (approximately 25%). This result indicates that although the output from a solar project is not




Figure 4-6. Peak Load versus Rated Capacity, Solar




Figure 4-7. Peak Load versus Rated Capacity, Wave

available during the entire peak period, a high percentage of its rated capacity is available during the hours in which it is producing. The range of values for both analyses is fairly broad on a monthly basis as well as between projects. This illustrates the need to evaluate capacity value on a site-specific basis.

TIME-OF-DAY DELIVERY AND PRICING

To evaluate the impact that time-of-day delivery and pricing would have on potential renewable energy project implementation, a comparison of potential project revenues was made under different time-of-day energy delivery and payment scenarios.

Table 4-1. Percent of Capacity During On-Peak Hours, Island of Hawaii

Minimum Diurnal Percent of Capacity During On-Peak Hours

| | Wind | | | Solar Thermal | Wave |
|-----|-------------|----------|-----------|---------------|-----------|
| | Kahua Ranch | Lalamilo | N. Kohala | N. Kohala | N. Kohala |
| Jan | 31.2% | 27.6% | 27.5% | 0.0% | 25.2% |
| Feb | 18.5% | 21.6% | 28.6% | 0.0% | 30.5% |
| Mar | 27.3% | 33.4% | 46.3% | 0.0% | 38.4% |
| Apr | 29.0% | 59.0% | 49.8% | 0.0% | 34.7% |
| May | 17.6% | 51.4% | 42.3% | 0.0% | 45.5% |
| Jun | 21.1% | 54.9% | 47.7% | 0.0% | 35.2% |
| Jul | 24.6% | 48.9% | 58.2% | 0.0% | 35.4% |
| Aug | 25.6% | 46.2% | 48.1% | 0.0% | 27.8% |
| Sep | 5.4% | 35.3% | 33.2% | 0.0% | 31.4% |
| Oct | 11.4% | 31.7% | 23.7% | 0.0% | 33.3% |
| Nov | 28.6% | 62.3% | 40.4% | 0.0% | 29.3% |
| Dec | 36.3% | 50.1% | 53.5% | 0.0% | 25.6% |
| Avg | 23.0% | 43.5% | 41.6% | 0.0% | 32.7% |
| Max | 36.3% | 62.3% | 58.2% | 0.0% | 45.5% |
| Min | 5.4% | 21.6% | 23.7% | 0.0% | 25.2% |

Average Diurnal Percent of Capacity During On-Peak Hours

| | Wind | | | Solar Thermal | Wave |
|-----|-------------|----------|-----------|---------------|-----------|
| | Kahua Ranch | Lalamilo | N. Kohala | N. Kohala | N. Kohala |
| Jan | 35.3% | 32.7% | 32.9% | 42.4% | 28.4% |
| Feb | 23.8% | 26.1% | 34.4% | 32.1% | 32.2% |
| Mar | 36.1% | 44.5% | 56.9% | 41.3% | 41.2% |
| Apr | 41.2% | 65.4% | 66.6% | 36.5% | 36.5% |
| May | 23.9% | 57.0% | 66.7% | 39.2% | 46.9% |
| Jun | 29.0% | 61.7% | 68.5% | 32.7% | 36.4% |
| Jul | 28.3% | 57.2% | 73.4% | 25.5% | 37.5% |
| Aug | 30.3% | 54.1% | 64.3% | 36.3% | 31.0% |
| Sep | 9.7% | 42.6% | 54.1% | 48.4% | 34.5% |
| Oct | 13.9% | 37.4% | 30.4% | 33.2% | 35.6% |
| Nov | 36.8% | 66.5% | 52.5% | 30.4% | 33.7% |
| Dec | 42.6% | 53.9% | 56.9% | 35.8% | 28.2% |
| Avg | 29.2% | 49.9% | 54.8% | 36.2% | 35.2% |
| Max | 42.6% | 66.5% | 73.4% | 48.4% | 46.9% |
| Min | 9.7% | 26.1% | 30.4% | 25.5% | 28.2% |

Table 4-2. Percent of Capacity During On-Peak Hours, Island of Maui

Minimum Diurnal Percent of Capacity During On-Peak Hours

| | Wind | | | | Solar Thermal | Wave | |
|-----|----------------|--------------|---------|-----------|---------------|-------------|------------|
| | McGregor Point | NW Haleakala | Puunene | West Maui | Kihel | Opana Point | Waiehu Pt. |
| Jan | 8.5% | 6.7% | 11.5% | 3.5% | 0.0% | 28.7% | 27.4% |
| Feb | 8.7% | 6.9% | 6.3% | 16.0% | 0.0% | 34.7% | 33.2% |
| Mar | 20.9% | 18.1% | 22.5% | 10.2% | 0.0% | 43.7% | 41.8% |
| Apr | 19.8% | 16.6% | 12.0% | 8.4% | 0.0% | 39.5% | 37.8% |
| May | 13.5% | 11.0% | 3.2% | 5.9% | 0.0% | 51.8% | 49.5% |
| Jun | 14.2% | 11.1% | 9.3% | 14.9% | 0.0% | 40.1% | 38.3% |
| Jul | 21.6% | 17.4% | 8.0% | 24.3% | 0.0% | 40.3% | 38.5% |
| Aug | 19.0% | 15.6% | 2.4% | 30.6% | 0.0% | 31.6% | 30.2% |
| Sep | 7.7% | 6.2% | 0.0% | 7.6% | 0.0% | 35.7% | 34.1% |
| Oct | 7.2% | 5.9% | 0.7% | 7.9% | 0.0% | 37.9% | 36.2% |
| Nov | 8.3% | 6.5% | 5.3% | 13.6% | 0.0% | 33.4% | 31.9% |
| Dec | 19.5% | 16.5% | 18.9% | 14.0% | 0.0% | 29.1% | 27.8% |
| Avg | 14.1% | 11.5% | 8.3% | 13.1% | 0.0% | 37.2% | 35.6% |
| Max | 21.6% | 18.1% | 22.5% | 30.6% | 0.0% | 51.8% | 49.5% |
| Min | 7.2% | 5.9% | 0.0% | 3.5% | 0.0% | 28.7% | 27.4% |

Average Diurnal Percent of Capacity During On-Peak Hours

| | Wind | | | | Solar Thermal | Wave | |
|-----|----------------|--------------|---------|-----------|---------------|-------------|------------|
| | McGregor Point | NW Haleakala | Puunene | West Maui | Kihel | Opana Point | Waiehu Pt. |
| Jan | 13.7% | 11.4% | 18.3% | 8.3% | 30.8% | 32.3% | 30.9% |
| Feb | 20.3% | 17.4% | 10.5% | 19.1% | 25.6% | 36.6% | 35.0% |
| Mar | 33.7% | 29.6% | 33.9% | 15.3% | 26.9% | 46.9% | 44.8% |
| Apr | 42.5% | 37.2% | 28.8% | 13.9% | 33.5% | 41.6% | 39.7% |
| May | 45.5% | 39.9% | 21.5% | 10.3% | 33.9% | 53.4% | 51.0% |
| Jun | 49.8% | 43.8% | 29.9% | 21.7% | 33.0% | 41.5% | 39.6% |
| Jul | 52.7% | 46.7% | 30.6% | 29.2% | 29.5% | 42.7% | 40.8% |
| Aug | 48.7% | 42.7% | 22.9% | 34.7% | 31.0% | 35.3% | 33.7% |
| Sep | 36.7% | 31.7% | 34.1% | 16.4% | 34.1% | 39.3% | 37.5% |
| Oct | 33.4% | 29.1% | 10.9% | 11.9% | 26.0% | 40.6% | 38.7% |
| Nov | 26.0% | 22.2% | 24.3% | 17.1% | 35.3% | 38.4% | 36.7% |
| Dec | 29.3% | 25.1% | 27.1% | 23.1% | 31.2% | 32.2% | 30.7% |
| Avg | 36.0% | 31.4% | 24.4% | 18.4% | 30.9% | 40.1% | 38.3% |
| Max | 52.7% | 46.7% | 34.1% | 34.7% | 35.3% | 53.4% | 51.0% |
| Min | 13.7% | 11.4% | 10.5% | 8.3% | 25.6% | 32.2% | 30.7% |

Table 4-3. Percent of Capacity During On-Peak Hours, Island of Oahu

Minimum Diurnal Percent of Capacity During On-Peak Hours

| | Wind | | Solar Thermal | Wave | |
|-----|-------------|--------|---------------|------------|------------|
| | Kaena Point | Kahuku | Lualualei | Kahuku Pt. | Makapu Pt. |
| Jan | 16.7% | 10.7% | 0.0% | 28.6% | 26.5% |
| Feb | 7.9% | 10.1% | 0.0% | 34.6% | 32.1% |
| Mar | 35.4% | 27.9% | 0.0% | 43.6% | 40.4% |
| Apr | 22.6% | 20.7% | 0.0% | 39.4% | 36.6% |
| May | 7.0% | 17.8% | 0.0% | 51.7% | 47.9% |
| Jun | 12.6% | 17.6% | 0.0% | 39.9% | 37.1% |
| Jul | 11.3% | 24.4% | 0.0% | 40.2% | 37.3% |
| Aug | 8.8% | 18.2% | 0.0% | 31.5% | 29.2% |
| Sep | 5.7% | 11.7% | 0.0% | 35.6% | 33.0% |
| Oct | 6.6% | 13.0% | 0.0% | 37.8% | 35.1% |
| Nov | 21.1% | 12.6% | 0.0% | 33.3% | 30.9% |
| Dec | 16.9% | 21.5% | 0.0% | 29.0% | 26.9% |
| Avg | 14.4% | 17.2% | 0.0% | 37.1% | 34.4% |
| Max | 35.4% | 27.9% | 0.0% | 51.7% | 47.9% |
| Min | 5.7% | 10.1% | 0.0% | 28.6% | 26.5% |

Average Diurnal Percent of Capacity During On-Peak Hours

| | Wind | | Solar Thermal | Wave | |
|-----|-------------|--------|---------------|------------|------------|
| | Kaena Point | Kahuku | Lualualei | Kahuku Pt. | Makapu Pt. |
| Jan | 25.0% | 13.0% | 27.5% | 32.2% | 29.9% |
| Feb | 12.9% | 13.9% | 25.0% | 36.5% | 33.9% |
| Mar | 42.5% | 30.7% | 27.8% | 46.8% | 43.4% |
| Apr | 36.7% | 25.6% | 30.0% | 41.4% | 38.4% |
| May | 24.2% | 24.7% | 29.1% | 53.2% | 49.4% |
| Jun | 28.4% | 28.8% | 40.9% | 41.3% | 38.3% |
| Jul | 31.8% | 34.0% | 35.2% | 42.6% | 39.5% |
| Aug | 27.7% | 26.6% | 34.7% | 35.2% | 32.7% |
| Sep | 17.3% | 20.4% | 28.3% | 39.1% | 36.3% |
| Oct | 13.8% | 19.9% | 21.5% | 40.4% | 37.5% |
| Nov | 35.5% | 17.8% | 30.2% | 38.3% | 35.5% |
| Dec | 26.5% | 26.4% | 24.3% | 32.1% | 29.7% |
| Avg | 26.9% | 23.5% | 29.6% | 39.9% | 37.0% |
| Max | 42.5% | 34.0% | 40.9% | 53.2% | 49.4% |
| Min | 12.9% | 13.0% | 21.5% | 32.1% | 29.7% |

Table 4-4. Percent of Capacity During On-Peak Hours, Island of Kauai

Minimum Diurnal Percent of Capacity During On-Peak Hours

| | Wind | | | Solar Thermal | Wave |
|-----|---------|-------------|------------|---------------|---------------|
| | Anahola | N. Hanapepe | Port Allen | Barking Sands | Barking Sands |
| Jan | 12.5% | 11.9% | 5.1% | 0.0% | 14.0% |
| Feb | 6.1% | 10.6% | 11.4% | 0.0% | 17.0% |
| Mar | 23.7% | 25.8% | 3.0% | 0.0% | 21.4% |
| Apr | 12.5% | 22.7% | 2.8% | 0.0% | 19.3% |
| May | 7.5% | 19.9% | 3.8% | 0.0% | 25.3% |
| Jun | 7.4% | 22.4% | 11.6% | 0.0% | 19.6% |
| Jul | 6.8% | 26.4% | 11.3% | 0.0% | 19.7% |
| Aug | 5.7% | 24.6% | 19.1% | 0.0% | 15.5% |
| Sep | 4.5% | 13.3% | 9.5% | 0.0% | 17.5% |
| Oct | 11.3% | 18.2% | 10.2% | 0.0% | 18.5% |
| Nov | 19.4% | 23.9% | 10.5% | 0.0% | 16.3% |
| Dec | 12.6% | 24.7% | 23.6% | 0.0% | 14.2% |
| Avg | 10.8% | 20.4% | 10.2% | 0.0% | 18.2% |
| Max | 23.7% | 26.4% | 23.6% | 0.0% | 25.3% |
| Min | 4.5% | 10.6% | 2.8% | 0.0% | 14.0% |

Average Diurnal Percent of Capacity During On-Peak Hours

| | Wind | | | Solar Thermal | Wave |
|-----|---------|-------------|------------|---------------|---------------|
| | Anahola | N. Hanapepe | Port Allen | Barking Sands | Barking Sands |
| Jan | 15.1% | 16.1% | 18.7% | 30.5% | 15.8% |
| Feb | 8.6% | 15.9% | 22.1% | 24.4% | 17.9% |
| Mar | 26.2% | 29.3% | 27.1% | 30.5% | 22.9% |
| Apr | 16.9% | 27.5% | 17.1% | 32.7% | 20.3% |
| May | 11.2% | 26.4% | 16.1% | 32.8% | 26.1% |
| Jun | 11.1% | 29.5% | 47.2% | 34.9% | 20.3% |
| Jul | 9.9% | 34.5% | 40.8% | 31.7% | 20.9% |
| Aug | 9.5% | 28.9% | 54.9% | 32.1% | 17.3% |
| Sep | 7.9% | 18.5% | 23.6% | 43.1% | 19.2% |
| Oct | 14.7% | 22.1% | 14.9% | 30.9% | 19.8% |
| Nov | 25.9% | 29.0% | 27.4% | 30.9% | 18.8% |
| Dec | 14.5% | 29.1% | 33.2% | 22.5% | 15.7% |
| Avg | 14.3% | 25.6% | 28.6% | 31.4% | 19.6% |
| Max | 26.2% | 34.5% | 54.9% | 43.1% | 26.1% |
| Min | 7.9% | 15.9% | 14.9% | 22.5% | 15.7% |


Table 4-5 contains a summary of the analysis results for each technology type on the island of Hawaii. The results are similar on each island. The table includes one representative project for each intermittent resource technology. Multiple wind projects are included because their diurnal patterns vary and the results vary by project site.

As shown in the table, potential revenues from electricity sales were calculated for each project based on average avoided cost payments and on an assumed time-of-day payment scheme. The time of day payment rates are based on 1993 on-peak and off-peak avoided costs provided by the Hawaiian utilities projected to the year 2005 using a 5% escalation rate. The nature of the results of this analysis are not sensitive to the chosen rate of escalation. Under current practice, the avoided cost payment rate is averaged according to the number of on-peak and off-peak hours experienced by the utility regardless of the timing of energy delivery.

As shown in the table, time-of-day pricing makes a significant difference for the solar technologies. The potential revenues are increased by approximately 7%. This result is consistent with the diurnal energy delivery patterns from a solar project, which illustrates that all the energy is delivered during peak load periods. For wave projects, time-of-day pricing actually decreases the potential revenue from projects. This result illustrates the lack of match with the diurnal utility demand curve. The potential revenues from wind energy projects increases with time-of-day pricing; however, the extent of the increase is fairly small (1%-2%). Time-of-day pricing analysis results from all the intermittent projects on each island are included in Appendix E.

Table 4-5. Energy Payment Comparison, Island of Hawaii

| Technology | Type | Location | Project Capacity (MW) | Payment - 2005 | | Daily Energy (MWh) | Annual Sales | | Time of Day Pricing Advantage |
|---------------|----------|----------------|-----------------------|------------------|----------------------|--------------------|------------------|----------------------|-------------------------------|
| | | | | Average (\$/kWh) | Time of Day (\$/kWh) | | Based on Average | Based on Time of Day | |
| Photovoltaic | tracking | Keahole | 50 | \$0.0906 | \$0.0972 | 376.5 | \$12,451,070 | \$13,355,167 | \$904,096 |
| Solar Thermal | dish | Waikoloa | 30 | \$0.0906 | \$0.0973 | 146.9 | \$4,857,058 | \$5,217,107 | \$360,050 |
| Wave | | Honokaa 2A | 10 | \$0.0906 | \$0.0905 | 92.0 | \$3,043,067 | \$3,041,298 | (\$1,769) |
| Wave | | N. Kohala | 30 | \$0.0906 | \$0.0905 | 254.8 | \$8,427,373 | \$8,422,474 | (\$4,890) |
| Wind | | Kahua Ranch | 15 | \$0.0906 | \$0.0906 | 105.2 | \$3,478,068 | \$3,478,090 | \$22 |
| Wind | | Lalamilo Wells | 50 | \$0.0906 | \$0.0908 | 525.5 | \$17,379,153 | \$17,408,101 | \$28,948 |
| Wind | | N. Kohala | 15 | \$0.0906 | \$0.0915 | 194.8 | \$6,440,754 | \$6,505,343 | \$64,589 |



SECTION 5. RENEWABLE ENERGY IMPLEMENTATION PLAN

As discussed in Sections 2 and 3, the set of projects that were identified as viable in the 1995 and 2005 analyses are viable only as individual projects, not as a group. There are a number of additional factors which impact project implementation that are not considered in the resource supply curve analyses. This section provides an overview of factors that impact the development and implementation of renewable energy projects and presents a plans for integrating renewable energy projects into the state's generation mix by island.

The RSC program ranks projects based on the lowest cost of energy. The projects presented in the previous sections are, in actuality, unlikely to be developed in this order. Although cost effectiveness is certainly one of the primary considerations, other factors will more likely determine the actual development sequence as well as the appropriate project size to be developed. These factors range from subjective considerations, such as the interest of the land owner in leasing the land for a renewable energy project, to more quantifiable considerations, such as the limits imposed on project development due to the energy demand growth rate. Phase 1 of this program included a detailed screening process to eliminate projects with obvious barriers to development and resulted in a list of projects that appear to be technically feasible. Phase 2 provided information on the economic feasibility of these projects. Phase 3 consisted of integrating this information and including consideration of other practical factors that impact the project development to arrive at an implementation plan.

CONSTRAINTS TO RENEWABLE ENERGY PROJECT IMPLEMENTATION

Hawaii has an abundance of renewable energy resources. For most renewable energy technologies, a sufficient resource exists on each island to warrant consideration of an energy project. There are a number of constraints to renewable energy project implementation, however, that are unique to the State of Hawaii. For example, one of the largest factors in eliminating potential projects from consideration in Phase 1 was the availability of land without conflicting or potentially competing land uses. Only on the island of Hawaii and on the lightly populated islands of Lanai and Molokai were sites identified in which the potential for competing land uses were not considered to be an issue. This is not to say that development of projects is impossible on the other islands; only that the demand for land is high and the impact of an energy project on a particular site will be weighed against other potential uses for that land as well as any potential impacts on activities on surrounding lands.

The total generating capacity of the utility grid and the projected demand growth on each island provides the greatest limitation to renewable energy project implementation in the next ten years. Of course, it is possible that renewable energy projects could replace existing fossil fuel plants; however, because the investment in these units has already been committed, this is not expected to be an economical alternative unless fuel prices rise to unprecedented levels, or if some of these fossil fuel plants are retired earlier than expected..

The relatively small size of the utility grids also limits renewable energy potential development, particularly of intermittent generating technologies. Although a number of studies have indicated that penetration limits of intermittent generating resources can meet or exceed 20% of the peak demand without operating penalties, results of such analyses are extremely variable and require detailed load flow and system stability analyses based on specific grid conditions to ensure utility reliability is achieved under all operating conditions. While such detailed utility analyses are beyond the scope of this study, the wealth of potential renewable energy project development opportunities identified by this work should serve to encourage these activities by utilities and other interested parties.

Public acceptance is another constraint to development that is difficult to quantify. Public opinion surveys show a clear preference for renewable energy projects over conventional generation

technologies; however, the vast majority of all development projects are subject to some type of public opposition.

DEVELOPMENT OF RENEWABLE ENERGY PROJECT IMPLEMENTATION PLAN

The renewable energy projects that are viable under the set of assumptions presented have been summarized and prioritized in terms of which technologies and project sites hold the greatest promise for assimilation into each island's electrical grid. Renewable energy integration plans were developed based on the 2005 resource supply curve results and consideration of the constraints to implementing renewable energy projects that are discussed above. In developing the renewable energy integration plan, the following process was considered.

The primary consideration for a renewable energy integration plan is the projected load growth on each island. Table 5-1 summarizes the peak load and estimated electricity sales for 1995 and 2005 for each island. As shown in the table, the amount of renewable energy that can be integrated into each utility in the next ten years is bounded by the projected load growth. Note that existing units could be retired or replaced by renewable energy projects if this appeared to be economically feasible; however, that would be the subject of a different analysis.

Table 5-1. Peak Load and Estimated Electricity Sales

| | Hawaii | Maui | Oahu | Kauai |
|--------------------------------------|-----------|-----------|-----------|---------|
| 2005 Peak Load (MW) | 223.0 | 229.5 | 1,467.2 | 84.6 |
| Estimated Energy Sales - 1995 | 957,013 | 880,956 | 6,950,000 | 398,699 |
| Estimated Energy Sales - 2005 | 1,416,614 | 1,042,711 | 8,550,887 | 568,304 |
| Growth (MWh) | 459,601 | 161,755 | 1,600,887 | 169,605 |
| Maximum Intermittent (20%) | 44.6 | 45.9 | 293.4 | 16.9 |

The penetration limit for intermittent renewable resources is another major consideration in determining the appropriate renewable energy project mix. Previously conducted, generalized studies in Hawaii have indicated that a practical cumulative intermittent resource penetration limit on each of the isolated island utility systems can be estimated at 10% of the annual peak load without operating penalties. As previously discussed, more detailed studies are required to determine appropriate levels above this estimate and given the large number of economically viable, intermittent renewable energy projects, such studies are immediately warranted. It is anticipated that such studies will permit higher penetration limits on each island, particularly given the likelihood of more efficient utility operating practice by 2005, expected technological improvements in the generating equipment, and the availability of more detailed energy production estimates for the proposed projects. As a result of these considerations, a penetration limit of 20% of peak load was assumed for the purposes of developing an integration plan. These values are also provided for each utility in Table 5-1.

The value of 20% as a maximum penetration limit was chosen in anticipation of likely results from more detailed studies of the power system of each island. It should be noted that intermittent renewable energy projects such as wind and run-of-river hydro may not produce at their rated capacity at any given time. Combinations of intermittent renewable energy projects in any system are even less likely to produce at their combined rated capacity. By considering such combined effects, or possible

other operating strategies, detailed studies may even allow levels of intermittent renewable energy development higher than 20%.

The relative cost of energy for the renewable projects was the next major consideration in determining the appropriate renewable energy plan on each island. The projects that appeared to be economically viable under the conservative scenarios were considered first. The most economic project size (generally the largest) was included if the assumed penetration limits (for intermittent technologies) and/or the load growth limits had not yet been exceeded. Nominal scenarios and then optimistic scenarios were then evaluated to determine the additional projects sites, technologies, and project sizes that were appropriate to consider in the analysis.

Prioritized projects are summarized for each of the islands in the following sections. In all cases, the integration plans include intermittent projects totaling less than 20% of the annual peak load. Even with this limitation, it appears feasible to meet all new generating requirements in the next ten years with renewable energy additions. This is a valid objective for the State of Hawaii to consider.

The recommended integration plan provided for each island represents realistic goals that can be easily achieved if reducing the oil dependency is a priority for both the government and the utilities. Should conditions occur such as changes in the operating characteristics of the utilities, incorporation of energy storage, widespread use of electric vehicles, or island interconnection, significantly more renewable energy could be incorporated into the generation mix. As a result, the projects listed in the previous sections are all considered viable options for the future, even if they are not discussed in the integration plans.

ISLAND OF HAWAII

Table 5-2 presents the recommended renewable energy integration plan for the island of Hawaii. The table includes a prioritized list of renewable energy projects, their location, rated capacity, and potential energy contribution. The table also summarizes the estimated peak load for 2005 and the energy demand increase that is projected to occur between 1995 and 2005 for Hawaii. Projects were included in the integration until the cumulative energy contributions from all the recommended projects met or exceeded the projected demand increase.

Table 5-2. Renewable Energy Integration Plan, Island of Hawaii

| | | |
|----------------------------------|---------|-----|
| 2005 PEAK LOAD | 223.0 | MW |
| ESTIMATED ENERGY DEMAND INCREASE | 459,601 | MWH |
| 20% OF PEAK LOAD* | 44.6 | MW |

| TECHNOLOGY | LOCATION | CAPACITY (MW) | ENERGY CONTRIBUTION (MWH) |
|-------------------------------|---------------|---------------|---------------------------|
| WIND | N. KOHALA | 15 | 71,178 |
| WIND | LALAMILO | 30 | 115,714 |
| GEOTHERMAL | KILAUEA | 50 | 362,314 |
| HYDROELECTRIC | UMAUMA STREAM | 13.8 | 40,199 |
| TOTAL RENEWABLE ENERGY | | 108.8 | 589,405 |

*PENETRATION LIMIT FOR INTERMITTENT RESOURCES

NOTE: ENERGY CONTRIBUTION VALUES ARE BASED ON NOMINAL ENERGY PROJECTION ESTIMATES.

As previously discussed, the total capacity of intermittent technologies such as wind was restricted to 20% of the peak load for 2005. As a result, only 45 MW of wind energy projects are included in the plan. Additional wind energy development is possible if conditions are shown to allow a higher penetration. The North Kohala project was chosen because it is the most cost-effective wind energy project on the island. Inclusion of this project limits additional development at Lalamilo (the next most cost-effective project) to 30 MW in order to remain within the assumed penetration limits. Note that a larger project at Lalamilo is feasible as is a project at Kahua Ranch, should the North Kohala project be undevelopable for factors other than cost.

The hydroelectric project on Umauma Stream is the next project included in the plan. Implementation of this project may be hindered by public opposition; however, its energy contribution is relatively small and if it is not considered, the output from the remaining projects would still exceed the projected demand increase.

A geothermal project in the Kilauea East Rift Zone is also included in the plan. The 50 MW project size is included because it is more cost effective than the 25 MW size even though the annual energy production from this project results in a combined total far greater than the anticipated demand increase. In the event that further geothermal development on the island is not able to proceed in the desired time frame, a biomass project located on the Hilo Coast or other locations could meet the same need for firm generating capacity.

ISLAND OF MAUI

Table 5-3 presents the recommended renewable energy integration plan for the island of Maui. The table includes a prioritized list of renewable energy projects, their location, rated capacity, and potential energy contribution. The table also summarizes the estimated peak load for 2005 and the energy demand increase that is projected to occur between 1995 and 2005 for Maui. Projects were included in the integration until the cumulative energy contributions from all the recommended projects met or exceeded the projected demand increase.

Table 5-3. Renewable Energy Integration Plan, Island of Maui

| | | |
|----------------------------------|---------|-----|
| 2005 PEAK LOAD | 229.5 | MW |
| ESTIMATED ENERGY DEMAND INCREASE | 161,755 | MWh |
| 20% OF PEAK LOAD* | 45.9 | MW |

| TECHNOLOGY | LOCATION | CAPACITY (MW) | ENERGY CONTRIBUTION (MWh) |
|-------------------------|----------------|---------------|---------------------------|
| WIND | MCGREGOR POINT | 10 | 24,611 |
| BIOMASS - ORGANIC WASTE | PUUNENE | 25 | 153,300 |
| WIND | NW HALEAKALA | 30 | 56,140 |
| TOTAL RENEWABLE ENERGY | | 65 | 234,051 |

*PENETRATION LIMIT FOR INTERMITTENT RESOURCES

NOTE: ENERGY CONTRIBUTION VALUES ARE BASED ON NOMINAL ENERGY PROJECTION ESTIMATES.

Although there is some resource uncertainty at the site, a wind project at McGregor Point is the most cost-effective project on Maui. A wind project on the northwest slope of Haleakala is also included in the plan. Additional wind projects at other sites are also feasible and could replace these two if they should prove to be undevelopable for factors other than cost.

A biomass project using organic waste as the fuel source is also included in the plan. This project assumes that a revenue stream similar to tipping fees is available to the project. A biomass electric project using tree crops as the fuel source would be the next project to be included if the assumption about tipping fees proves to be inaccurate.

ISLAND OF OAHU

Table 5-4 presents the recommended renewable energy integration plan for the island of Oahu. The table includes a prioritized list of renewable energy projects, their location, rated capacity, and potential energy contribution. The table also summarizes the estimated peak load for 2005 and the energy demand increase that is projected to occur between 1995 and 2005 for Oahu. Projects were included in the integration until the cumulative energy contributions from all the recommended projects met or exceeded the projected demand increase.

Table 5-4. Renewable Energy Integration Plan, Island of Oahu

| | | |
|-----------------------------------------|------------------|------------|
| 2005 PEAK LOAD | 1,467.2 | MW |
| ESTIMATED ENERGY DEMAND INCREASE | 1,600,887 | MWH |
| 20% OF PEAK LOAD * | 293.4 | MW |

| TECHNOLOGY | LOCATION | CAPACITY (MW) | ENERGY CONTRIBUTION (MWH) |
|-------------------------------|-----------------|----------------------|----------------------------------|
| BIOMASS-ORGANIC WASTE | BARBERS POINT | 50 | 306,600 |
| WIND | KAENA POINT | 15 | 31,558 |
| WIND | KAHUKU | 80 | 151,558 |
| SOLAR THERMAL - DISH | PEARL HARBOR | 50 | 84,942 |
| SOLAR THERMAL - DISH | LAULAULEI | 50 | 80,912 |
| PHOTOVOLTAIC - TRACKING | N. EWA PLAIN | 50 | 111,675 |
| BIOMASS - GRASS CROPS | WAIALUA | 25 | 153,300 |
| WAVE | MAKAPUU | 60 | 224,378 |
| WAVE | KAHUKU POINT | 60 | 211,197 |
| WAVE | NE COAST | 60 | 205,535 |
| TOTAL RENEWABLE ENERGY | | 500 | 1,609,130 |

*PENETRATION LIMIT FOR INTERMITTENT RESOURCES

NOTE: ENERGY CONTRIBUTION VALUES ARE BASED ON NOMINAL ENERGY PROJECTION ESTIMATES.

Because Oahu has a significantly higher energy demand than the other islands, a large number of projects are included in the integration plan. Unlike Hawaii and Maui, where there are a number of viable integration plan possibilities, the demand increase on Oahu requires consideration of the majority of projects that are considered to be viable under the optimistic scenarios. If only projects that were shown to be viable under nominal conditions were included in the plan, they would only be able to contribute 30% of the demand increase.

A biomass electric project using organic waste as the fuel source is the most economical project on Oahu. A waste-to-energy facility is already in operation on this island and this facility could be located in the same region to take advantage of existing transportation plans. Wind projects at Kaena Point and Kahuku are also included in the plan at their largest size. These three projects are viable even under nominal conditions.

Additional projects included in the plan include significant quantities of photovoltaics, solar thermal, biomass electric, and wave energy generation. Although these projects are all viable under optimistic assumptions, their development status is more uncertain. Due to their significant energy contribution potential, however, they should be seriously considered as future alternatives.

ISLAND OF KAUAI

Table 5-5 presents the recommended renewable energy integration plan for the island of Kauai. The table includes a prioritized list of renewable energy projects, their location, rated capacity, and potential energy contribution. The table also summarizes the estimated peak load for 2005 and the energy demand increase that is projected to occur between 1995 and 2005 for Kauai. Projects were included in the integration until the cumulative energy contributions from all the recommended projects met or exceeded the projected demand increase.

Table 5-5. Renewable Energy Integration Plan, Island of Kauai

| | | |
|----------------------------------|---------|-----|
| 2005 PEAK LOAD | 84.6 | MW |
| ESTIMATED ENERGY DEMAND INCREASE | 169,605 | MWh |
| 20% OF PEAK LOAD* | 16.92 | MW |

| TECHNOLOGY | LOCATION | CAPACITY (MW) | ENERGY CONTRIBUTION (MWh) |
|--------------------------------|---------------|---------------|---------------------------|
| WIND | N. HANAPEPE | 10 | 22,602 |
| WIND | PORT ALLEN | 5 | 9,321 |
| HYDROELECTRIC | WAILUA RIVER | 6.6 | 16,435 |
| BIOMASS - TREE & ORGANIC WASTE | KAUMAKANI | 25 | 153,300 |
| SOLAR THERMAL - DISH | BARKING SANDS | 10 | 17,250 |
| TOTAL RENEWABLE ENERGY | | 56.6 | 218,908 |

*PENETRATION LIMIT FOR INTERMITTENT RESOURCES

NOTE: ENERGY CONTRIBUTION VALUES ARE BASED ON NOMINAL ENERGY PROJECTION ESTIMATES.

The integration plan for Kauai includes a wide variety of technology types. Wind projects are viable in two locations under conservative conditions. As with the hydroelectric project on Hawaii, this technology is subject to public opposition. It is included in the plan for its cost-effectiveness; however, its contribution is relatively small and if it is not considered, the output from the remaining projects would still exceed the projected demand increase.

The next most cost-effective project included in the database is a 50 MW biomass electric project at Kaumakani including both tree crops and organic waste as the fuel source. A 50 MW project is too large to be considered by 2005. As a result, a 25 MW project was included in the plan even though this project size was not included in the database. A 25 MW project using only tree crops as a fuel source was considered at Lihue and this project could also feasibly be included in the plan; however,

the Lihue biomass project is less cost effective than a solar thermal project at Barking Sands under nominal conditions. As a result, the solar thermal projects and a smaller biomass project at Kaumakani were included in the plan.


OPPORTUNITIES FOR SMALL-SCALE RENEWABLE ENERGY PROJECT IMPLEMENTATION

Small-scale renewable energy projects are also well suited for the islands, particularly Lanai and Molokai, where limited demand restricts utility-scale development yet also results in high energy costs. Small-scale renewable energy projects, either through demand-side or dispersed-generation applications, should be economical on a widespread basis and have the potential to make a significant contribution to reducing petroleum dependency. Although small-scale projects are likely to be possible at many locations on each island, the larger projects described for the larger islands will make a more substantial contribution. Nonetheless, these opportunities should be pursued to the greatest extent possible.

The economics and market potential for small-scale renewable energy applications is difficult to quantify. The economics are dependent on the costs of alternative sources of supply which are extremely site specific. For isolated users, the economics are usually compared to the cost of grid extension. For grid-connected users, the economics are dependent on the cost of electricity and the power purchase terms available to sell any excess generation to the utility.

Promising applications for small-scale renewable energy projects that may be feasible for locations in Hawaii include dispersed generation, demand-side, off-grid, and grid support projects. These small-scale applications may be viable for both residential and commercial or industrial energy users. Although it was beyond the scope of this study to estimate the market potential for each of the applications, RLA developed representative project costs and performance estimates for a number of the most promising small-scale renewable energy applications on Hawaii. These "case studies," which include a description of the potential application, cost and performance summaries, and references for additional information, are included in Appendix F.

Other case studies presented illustrate promising applications for using the near shore cold water resource. Note that even in the 2005 optimistic case the levelized cost of energy for a closed cycle OTEC power plant at Keahole Point is 12.5 cents per kWh. Services available from open cycle desalination and deep seawater cooling can be more economically competitive than their conventional alternates (see Appendix F for details).



SECTION 6. CONCLUSIONS AND RECOMMENDATIONS

CONCLUSIONS

Renewable energy projects can provide all the new generation required to meet projected energy demand increases between 1995 and 2005. On Maui, this can be accomplished with projects that are cost competitive even under the most conservative assumptions. On Hawaii and Kauai, this can be accomplished with projects that are cost competitive under nominal scenarios. If conservative assumptions are used, Hawaii and Kauai can still obtain 50% and 25% of the projected energy demand growth from renewable energy projects, respectively. On Oahu, under nominal assumptions, renewable energy projects can provide over 30% of the new generation required to meet energy demand increases and under optimistic conditions, all the energy required to meet energy demand increases.

Based on these results, it is a realistic goal for the State of Hawaii to add only renewable energy projects to meet future energy demand growth between 1995 and 2005 and even beyond. It is appropriate to begin working on this goal immediately because several projects are cost competitive now.

Under optimistic assumptions, enough energy could be produced from renewable energy projects to meet most, if not all, the electricity requirements on Maui, Hawaii, and Kauai. Constraints to project implementation, conventional generation units already in place, and projected demand growth make this result unrealistic. It does illustrate, however, that under optimistic circumstances, investments in conventional fossil fuel plants will turn out to be uneconomical in the future. This conclusion is supported by both the 1995 results that indicate that there are already substantial investments in renewable energy resources that are more economical than the avoided energy cost from fossil fuel technologies (the basis for avoided cost); and by the nominal case calculation presented for 2005.

At the other extreme, conservative scenarios provide a minimum number of projects that should be considered and implemented in the state. Because investors have experienced financial losses due to excessively optimistic assumptions for renewable energy projects in the past, they may be inclined to lean towards the conservative estimates. Nonetheless, a number of viable projects exist even under this scenario. These projects can be pursued with a high confidence level in their costs and conservative performance estimates and with a minimum amount of risk to the investor. If the projects identified as viable in 1995 and those that are viable in 2005 under conservative conditions are installed as soon as possible, the experience gained from these projects will help narrow the range of projected development cost estimates for other projects installed in the future.

The annual savings benefits shown in the tables in this report for the 2005 scenario may be unrealistic because they are based on a comparison with projected avoided energy cost. The magnitude of the benefit is not as important as the fact that there is indeed a benefit in implementing renewable energy projects over continuing with the current practice of relying heavily on fossil fuel. There are other benefits also which have not been included in the data presented. Employment benefits would flow to the residents of the state because construction and operation of renewable energy projects involve more labor than for comparatively sized fossil fuel plants. A greater use of Hawaiian resources also insulates the state from fuel price escalation. Furthermore, the obvious environmental advantages of using renewable energy have not been incorporated into the results.

RECOMMENDATIONS

Whether the projects are evaluated based on the optimistic, conservative, or nominal scenarios plays a big part in determining the pace of renewable energy development in Hawaii. Many renewable technologies have developed at a slower rate than historically projected. On the other hand, the extent

of commercial wind energy development over the last ten years provides a good illustration of the speed in which renewable energy technologies can mature. This is in part driven by research and development funding levels and other policy choices. Although the nominal cases represent the most reasonable estimates, both the optimistic and conservative cases are possible scenarios – neither represents an unrealistic extreme.

Economic conditions unrelated to the pace of technology development will also be a major factor in determining the level of renewable energy integration in Hawaii. Avoided cost levels or power purchase contract terms will play a large role in determining the projects that are developed. Although the state cannot control the price of oil, it can influence the power purchase contract terms that are available to independent power producers. In addition to encouraging utilities to construct contracts with favorable terms for renewables, the state must also allow the costs associated with these contracts to be included in the utility's rate base. Factors that have been shown to be favorable to renewables include consideration of capacity value and time-of-day pricing. Contract structures that assist in obtaining financing at favorable rates (such as front loaded contracts and long-term contracts with specified payment schedules) will also promote renewable energy integration.

The state can also continue to support and encourage research and analysis that promote renewable energy implementation. Because a significant number of additional renewable energy projects could be developed if not for the penetration limits for intermittent technologies on isolated grids, studies addressing this issue should be a priority. Because such studies require a significant level of effort and detailed information about utility system characteristics, these analyses should be conducted in cooperation with the utilities.

Energy storage options, if economical, would also address the penetration limits issue. It is recommended that the costs and operation of promising energy storage possibilities be evaluated to determine if such technology is viable. An evaluation conducted with the same approach and economic methodology as the resource supply curve data would facilitate the evaluation.

For the projects that appear to be viable based on the results of this program, detailed feasibility studies can be performed to further refine their costs and performance. These activities may be carried out by a developer, utility, or government agencies interested in the project development.

Additional resource assessment and technological research would address the uncertainty in the estimates and reduce the range between conservative and optimistic estimates. Resource assessment should focus on areas in which insufficient data are available to accurately define performance. For example, wave energy projections are particularly broad and resource assessment activities would greatly reduce the performance uncertainty. Wave energy projects would also benefit from technological research. Wave projects had significant potential for Hawaii under the optimistic scenarios but were extremely costly under conservative assumptions. Demonstration projects or practical research geared toward commercial development could provide more confidence in the cost and performance of these technologies.

For wind projects, a number of viable projects already exist. On Hawaii and Maui, more electricity can be generated by wind projects than the utility can accept. On Oahu, large-scale projects have been identified and additional wind projects are unlikely because of land use constraints. As a result, additional resource assessment activities should be geared towards micrositing for the specific projects already identified or establishing long-term reference stations to support project development and operation. Because such limited wind resource data exist on Kauai, additional data collection to identify sites may be valuable. At a minimum, monitoring should continue at the promising sites.

Although wind projects could also benefit from research activities, achieving cost and performance improvements is not necessary to make these projects viable under even the most conservative assumptions. As a result, wind energy project integration will likely benefit more from policy


initiatives such as facilitating the permitting requirements or establishing financeable power purchase contracts than they will from research.

A number of solar technology projects are close to being cost-effective under nominal conditions. Both solar thermal dish projects and photovoltaic tracking projects are close enough to being viable that they warrant serious consideration. Capacity credit, time-of-day pricing, or tax credit changes could result in these projects being viable generation options in the next ten years even under nominal or conservative conditions. Hawaii could assist in the development of these technologies by participating in demonstration projects or research activities. Hybrid systems that utilize gas, biomass, or other fuel in conjunction with solar thermal heat are receiving considerable attention and may hold promise for Hawaii applications. These systems can operate as firm generating resources. At a minimum, the technology improvements should be tracked and incorporated into planning processes. Solar thermal troughs do not appear to be viable options for development in Hawaii.

Biomass electric and biomass fuels are both promising technologies for Hawaii and their development and implementation should be pursued. In addition to offering the only firm renewable energy option that is economically viable, biomass plantations allow the state to preserve a portion of its land in agricultural crops which provides valuable benefits to the state's residents as well as promotes the tourist industry. Although biomass fuels were not the primary focus of this study, results indicate that the costs are in the general range of expected market prices for fuel alternatives. Biomass fuels offer the additional benefit of being transportable.

Hydroelectric and geothermal projects are commercially viable in Hawaii today; however, a limited number of developable sites exist. Their development is also subject to significant public opposition. Additional resource assessment or research is unlikely to change the analysis results. The projects identified in this study should be pursued to the extent in which they are viewed as acceptable to the public.

Although only two ocean thermal projects were evaluated in this project, neither was shown to be cost effective even in the most optimistic case. Although ocean thermal technology may offer a significant contribution to Hawaii's generation mix in the long-term, it does not appear at this time that it will be competitive with other renewable energy options in the next ten years.




APPENDIX A

RESOURCE SUPPLY CURVES, ISLAND OF HAWAII

Island(s): Hawaii
Technology: All_Tech
Certainty: Nominal
Stage: Current Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0556




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|---------|---------|-----------|------|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Current | Incl | Nominal | 15 | 1 | 30 | 56,905 | 0.0272 |
| Wind | | Hawaii | North Kohala | Current | Incl | Nominal | 5 | 1 | 30 | 18,569 | 0.0281 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Nominal | 50 | 1 | 30 | 154,183 | 0.0297 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Nominal | 3 | 1 | 30 | 10,366 | 0.0301 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Nominal | 30 | 1 | 30 | 92,510 | 0.0310 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Nominal | 5 | 1 | 30 | 10,516 | 0.0527 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Nominal | 15 | 1 | 30 | 30,396 | 0.0548 |
| Hydro | | Hawaii | Umauma Stream | Current | Incl | Nominal | 13.8 | 2 | 50 | 40,199 | 0.0558 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0805 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0847 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1053 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Nominal | 50 | 4 | 30 | 119,968 | 0.1264 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Nominal | 50 | 4 | 30 | 119,968 | 0.1278 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 1.5 | 30 | 28,015 | 0.1294 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Nominal | 50 | 4 | 30 | 107,114 | 0.1328 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Nominal | 5 | 1.5 | 30 | 9,433 | 0.1344 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Nominal | 50 | 4 | 30 | 107,114 | 0.1344 |
| Solar Thermal | dish | Hawaii | Keahole | Current | Incl | Nominal | 30 | 1.5 | 30 | 52,500 | 0.1355 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Nominal | 30 | 3 | 30 | 71,980 | 0.1386 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Nominal | 30 | 3 | 30 | 71,980 | 0.1400 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Nominal | 30 | 3 | 30 | 64,268 | 0.1459 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Nominal | 30 | 3 | 30 | 64,268 | 0.1475 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 2.5 | 30 | 34,298 | 0.1519 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Nominal | 15 | 2.5 | 30 | 30,623 | 0.1614 |
| Solar Thermal | dish | Hawaii | Waikoloa | Current | Incl | Nominal | 30 | 1.5 | 30 | 51,118 | 0.1629 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Nominal | 5 | 1.5 | 30 | 11,433 | 0.1647 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Nominal | 5 | 1.5 | 30 | 10,208 | 0.1753 |
| Solar Thermal | trough | Hawaii | Keahole | Current | Incl | Nominal | 30 | 1.5 | 30 | 56,086 | 0.2402 |
| Solar Thermal | trough | Hawaii | Waikoloa | Current | Incl | Nominal | 30 | 1.5 | 30 | 54,610 | 0.2514 |

Island(s): Hawaii
Technology: All_Tech
Certainty: Conservative
Stage: Current Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0556


RESOURCE SUPPLY CURVES



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|---------|---------|--------------|------|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Current | Incl | Conservative | 15 | 1 | 30 | 48,105 | 0.0360 |
| Wind | | Hawaii | North Kohala | Current | Incl | Conservative | 5 | 1 | 30 | 15,676 | 0.0376 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Conservative | 50 | 1 | 30 | 129,123 | 0.0396 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Conservative | 3 | 1 | 30 | 8,750 | 0.0404 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Conservative | 30 | 1 | 30 | 77,474 | 0.0412 |
| Hydro | | Hawaii | Umauma Stream | Current | Incl | Conservative | 13.8 | 2 | 50 | 39,788 | 0.0591 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Conservative | 5 | 1 | 30 | 8,838 | 0.0691 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Conservative | 15 | 1 | 30 | 25,475 | 0.0713 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1107 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1111 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1373 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Conservative | 50 | 4 | 30 | 107,971 | 0.1466 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Conservative | 50 | 4 | 30 | 107,971 | 0.1483 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Conservative | 15 | 1.5 | 30 | 25,213 | 0.1532 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Conservative | 50 | 4 | 30 | 96,402 | 0.1539 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Conservative | 50 | 4 | 30 | 96,402 | 0.1558 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Conservative | 5 | 1.5 | 30 | 8,489 | 0.1592 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Conservative | 30 | 3 | 30 | 64,782 | 0.1609 |
| Solar Thermal | dish | Hawaii | Keahole | Current | Incl | Conservative | 30 | 1.5 | 30 | 47,250 | 0.1612 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Conservative | 30 | 3 | 30 | 64,782 | 0.1625 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Conservative | 30 | 3 | 30 | 57,841 | 0.1692 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Conservative | 30 | 3 | 30 | 57,841 | 0.1711 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Conservative | 15 | 2.5 | 30 | 30,868 | 0.1760 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Conservative | 15 | 2.5 | 30 | 27,561 | 0.1869 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Conservative | 5 | 1.5 | 30 | 10,290 | 0.1914 |
| Solar Thermal | dish | Hawaii | Waikoloa | Current | Incl | Conservative | 30 | 1.5 | 30 | 46,006 | 0.1946 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Conservative | 5 | 1.5 | 30 | 9,187 | 0.2035 |
| Solar Thermal | trough | Hawaii | Keahole | Current | Incl | Conservative | 30 | 1.5 | 30 | 50,477 | 0.2878 |
| Solar Thermal | trough | Hawaii | Waikoloa | Current | Incl | Conservative | 30 | 1.5 | 30 | 49,149 | 0.3014 |

Island(s): Hawaii
Technology: All_Tech
Certainty: Optimistic
Stage: Current Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0556




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|---------|---------|------------|------|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Current | Incl | Optimistic | 15 | 1 | 30 | 66,395 | 0.0215 |
| Wind | | Hawaii | North Kohala | Current | Incl | Optimistic | 5 | 1 | 30 | 21,693 | 0.0220 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Optimistic | 50 | 1 | 30 | 181,386 | 0.0233 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Optimistic | 3 | 1 | 30 | 12,109 | 0.0235 |
| Wind | | Hawaii | Lalamilo Wells | Current | Incl | Optimistic | 30 | 1 | 30 | 108,832 | 0.0243 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Optimistic | 5 | 1 | 30 | 12,334 | 0.0414 |
| Wind | | Hawaii | Kahua Ranch | Current | Incl | Optimistic | 15 | 1 | 30 | 35,735 | 0.0433 |
| Hydro | | Hawaii | Umauma Stream | Current | Incl | Optimistic | 13.8 | 2 | 50 | 41,019 | 0.0522 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0558 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0632 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0791 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Optimistic | 50 | 4 | 30 | 137,963 | 0.1008 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Optimistic | 50 | 4 | 30 | 137,963 | 0.1019 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Optimistic | 50 | 4 | 30 | 123,181 | 0.1056 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Optimistic | 50 | 4 | 30 | 123,181 | 0.1069 |
| Photovoltaic | tracking | Hawaii | Keahole | Current | Incl | Optimistic | 30 | 3 | 30 | 82,777 | 0.1103 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Current | Incl | Optimistic | 30 | 3 | 30 | 82,777 | 0.1115 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Optimistic | 15 | 1.5 | 30 | 29,416 | 0.1147 |
| Photovoltaic | fixed | Hawaii | Keahole | Current | Incl | Optimistic | 30 | 3 | 30 | 73,909 | 0.1158 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Current | Incl | Optimistic | 30 | 3 | 30 | 73,909 | 0.1172 |
| Solar Thermal | dish | Hawaii | N. Kohala | Current | Incl | Optimistic | 5 | 1.5 | 30 | 9,904 | 0.1188 |
| Solar Thermal | dish | Hawaii | Keahole | Current | Incl | Optimistic | 30 | 1.5 | 30 | 55,125 | 0.1197 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Optimistic | 15 | 2.5 | 30 | 39,442 | 0.1207 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Optimistic | 15 | 2.5 | 30 | 35,216 | 0.1281 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Current | Incl | Optimistic | 5 | 1.5 | 30 | 13,148 | 0.1303 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Current | Incl | Optimistic | 5 | 1.5 | 30 | 11,739 | 0.1383 |
| Solar Thermal | dish | Hawaii | Waikoloa | Current | Incl | Optimistic | 30 | 1.5 | 30 | 53,674 | 0.1433 |
| Solar Thermal | trough | Hawaii | Keahole | Current | Incl | Optimistic | 30 | 1.5 | 30 | 58,890 | 0.2102 |
| Solar Thermal | trough | Hawaii | Waikoloa | Current | Incl | Optimistic | 30 | 1.5 | 30 | 57,340 | 0.2199 |

Island(s): Hawaii
Technology: All_Tech
Certainty: Nominal
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0906

RESOURCE SUPPLY CURVES




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------------|--------|----------------|--------|---------|-----------|------|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Future | Incl | Nominal | 15 | 1 | 30 | 71,178 | 0.0288 |
| Wind | | Hawaii | North Kohala | Future | Incl | Nominal | 5 | 1 | 30 | 22,298 | 0.0297 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Nominal | 50 | 1 | 30 | 192,086 | 0.0304 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Nominal | 3 | 1 | 30 | 12,966 | 0.0309 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Nominal | 30 | 1 | 30 | 115,714 | 0.0314 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Nominal | 50 | 6 | 30 | 362,314 | 0.0425 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Nominal | 5 | 1 | 30 | 12,628 | 0.0480 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Nominal | 15 | 1 | 30 | 38,021 | 0.0492 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Nominal | 25 | 5 | 30 | 177,302 | 0.0512 |
| Hydro | | Hawaii | Umauma Stream | Future | Incl | Nominal | 13.8 | 2 | 50 | 40,199 | 0.0544 |
| Biomass Elec | tree & org waste | Hawaii | Hilo Coast | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0772 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 29,416 | 0.0814 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Nominal | 5 | 1.5 | 30 | 9,904 | 0.0845 |
| Solar Thermal | dish | Hawaii | Keahole | Future | Incl | Nominal | 30 | 1.5 | 30 | 55,125 | 0.0852 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Nominal | 50 | 3 | 30 | 124,319 | 0.0862 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0870 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Nominal | 50 | 3 | 30 | 124,319 | 0.0873 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Nominal | 50 | 3 | 30 | 110,999 | 0.0903 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0911 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Nominal | 50 | 3 | 30 | 110,999 | 0.0915 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Nominal | 30 | 2 | 30 | 74,591 | 0.0942 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Nominal | 30 | 2 | 30 | 74,591 | 0.0952 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Nominal | 30 | 2 | 30 | 66,599 | 0.0988 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Nominal | 30 | 2 | 30 | 66,599 | 0.1000 |
| Biomass Elec | grass crops | Hawaii | Ka'u | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1003 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 35,542 | 0.1035 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1064 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Nominal | 15 | 1.5 | 30 | 31,734 | 0.1096 |
| Solar Thermal | dish | Hawaii | Waikoloa | Future | Incl | Nominal | 30 | 1.5 | 30 | 53,674 | 0.1103 |
| Wave | | Hawaii | N. Kohala | Future | Incl | Nominal | 30 | 2 | 30 | 93,084 | 0.1112 |
| Wave | | Hawaii | Honokaa 2A | Future | Incl | Nominal | 10 | 2 | 30 | 33,612 | 0.1125 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Nominal | 5 | 1 | 30 | 11,847 | 0.1127 |
| Wave | | Hawaii | Pepeekeo 2E | Future | Incl | Nominal | 10 | 2 | 30 | 32,389 | 0.1171 |
| Biomass Elec | grass crops | Hawaii | Hilo Coast | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1183 |

| | | | | | | | | | | | |
|---------------|--------|--------|---------------|--------|------|---------|----|-----|----|---------|--------|
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Nominal | 5 | 1 | 30 | 10,578 | 0.1194 |
| Wave | | Hawaii | N. Kohala | Future | Incl | Nominal | 10 | 2 | 30 | 31,021 | 0.1271 |
| Solar Thermal | trough | Hawaii | Keahole | Future | Incl | Nominal | 30 | 1.5 | 30 | 64,499 | 0.1609 |
| Solar Thermal | trough | Hawaii | Waikoloa | Future | Incl | Nominal | 30 | 1.5 | 30 | 62,801 | 0.1694 |
| OTEC | | Hawaii | Keahole Point | Future | Incl | Nominal | 60 | 2 | 30 | 296,438 | 0.1963 |

Island(s): Hawaii
Technology: All_Tech
Certainty: Conservative
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0906

RESOURCE SUPPLY CURVES




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------------|--------|----------------|--------|---------|--------------|------|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Future | Incl | Conservative | 15 | 1 | 30 | 60,171 | 0.0360 |
| Wind | | Hawaii | North Kohala | Future | Incl | Conservative | 5 | 1 | 30 | 18,823 | 0.0376 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Conservative | 50 | 1 | 30 | 160,865 | 0.0385 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Conservative | 3 | 1 | 30 | 10,945 | 0.0393 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Conservative | 30 | 1 | 30 | 96,907 | 0.0398 |
| Hydro | | Hawaii | Umauma Stream | Future | Incl | Conservative | 13.8 | 2 | 50 | 39,788 | 0.0576 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Conservative | 5 | 1 | 30 | 10,612 | 0.0617 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Conservative | 15 | 1 | 30 | 31,865 | 0.0628 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Conservative | 50 | 6 | 30 | 308,352 | 0.0641 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Conservative | 25 | 5 | 30 | 150,672 | 0.0773 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Conservative | 15 | 1.5 | 30 | 26,474 | 0.0978 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Conservative | 5 | 1.5 | 30 | 8,914 | 0.1017 |
| Solar Thermal | dish | Hawaii | Keahole | Future | Incl | Conservative | 30 | 1.5 | 30 | 49,613 | 0.1031 |
| Biomass Elec | tree & org waste | Hawaii | Hilo Coast | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1049 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Conservative | 50 | 3 | 30 | 105,671 | 0.1060 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Conservative | 50 | 3 | 30 | 105,671 | 0.1073 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Conservative | 50 | 3 | 30 | 94,349 | 0.1109 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Conservative | 50 | 3 | 30 | 94,349 | 0.1124 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Conservative | 30 | 2 | 30 | 63,402 | 0.1158 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1160 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Conservative | 30 | 2 | 30 | 63,402 | 0.1171 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Conservative | 30 | 2 | 30 | 56,609 | 0.1214 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1215 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Conservative | 30 | 2 | 30 | 56,609 | 0.1229 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Conservative | 15 | 1.5 | 30 | 30,211 | 0.1270 |
| Solar Thermal | dish | Hawaii | Waikoloa | Future | Incl | Conservative | 30 | 1.5 | 30 | 48,307 | 0.1337 |
| Biomass Elec | grass crops | Hawaii | Ka'u | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1337 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Conservative | 15 | 1.5 | 30 | 26,974 | 0.1344 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Conservative | 5 | 1 | 30 | 10,070 | 0.1388 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1419 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Conservative | 5 | 1 | 30 | 8,991 | 0.1471 |
| Biomass Elec | grass crops | Hawaii | Hilo Coast | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1578 |
| Solar Thermal | trough | Hawaii | Keahole | Future | Incl | Conservative | 30 | 1.5 | 30 | 58,049 | 0.1922 |
| Solar Thermal | trough | Hawaii | Waikoloa | Future | Incl | Conservative | 30 | 1.5 | 30 | 56,521 | 0.2025 |

| | | | | | | | | | | |
|------|--------|---------------|--------|------|--------------|----|---|----|---------|--------|
| OTEC | Hawaii | Keahole Point | Future | Incl | Conservative | 60 | 2 | 30 | 257,894 | 0.2887 |
| Wave | Hawaii | N. Kohala | Future | Incl | Conservative | 30 | 2 | 30 | 42,077 | 0.3596 |
| Wave | Hawaii | Honokaa 2A | Future | Incl | Conservative | 10 | 2 | 30 | 15,435 | 0.3619 |
| Wave | Hawaii | Pepeekeo 2E | Future | Incl | Conservative | 10 | 2 | 30 | 14,691 | 0.3811 |
| Wave | Hawaii | N. Kohala | Future | Incl | Conservative | 10 | 2 | 30 | 14,024 | 0.4103 |

Island(s): Hawaii
Technology: All_Tech
Certainty: Optimistic
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0906

RESOURCE SUPPLY CURVES



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------------|--------|----------------|--------|---------|------------|------|------|------|---------|--------|
| Wind | | Hawaii | North Kohala | Future | Incl | Optimistic | 15 | 1 | 30 | 83,049 | 0.0247 |
| Wind | | Hawaii | North Kohala | Future | Incl | Optimistic | 5 | 1 | 30 | 26,048 | 0.0253 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Optimistic | 50 | 1 | 30 | 225,977 | 0.0258 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Optimistic | 3 | 1 | 30 | 15,147 | 0.0261 |
| Wind | | Hawaii | Lalamilo Wells | Future | Incl | Optimistic | 30 | 1 | 30 | 136,131 | 0.0266 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Optimistic | 50 | 6 | 30 | 390,871 | 0.0328 |
| Geothermal | | Hawaii | Kilauea | Future | Incl | Optimistic | 25 | 5 | 30 | 193,421 | 0.0384 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Optimistic | 5 | 1 | 30 | 14,811 | 0.0397 |
| Wind | | Hawaii | Kahua Ranch | Future | Incl | Optimistic | 15 | 1 | 30 | 44,699 | 0.0409 |
| Hydro | | Hawaii | Umauma Stream | Future | Incl | Optimistic | 13.8 | 2 | 50 | 41,019 | 0.0509 |
| Biomass Elec | tree & org waste | Hawaii | Hilo Coast | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0546 |
| Wave | | Hawaii | Honokaa 2A | Future | Incl | Optimistic | 10 | 2 | 30 | 42,134 | 0.0591 |
| Wave | | Hawaii | N. Kohala | Future | Incl | Optimistic | 30 | 2 | 30 | 117,856 | 0.0592 |
| Wave | | Hawaii | Pepeekeo 2E | Future | Incl | Optimistic | 10 | 2 | 30 | 40,968 | 0.0610 |
| Biomass Elec | tree crops | Hawaii | Hamakua Coast | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0633 |
| Biomass Elec | tree crops | Hawaii | Hilo Coast | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0663 |
| Wave | | Hawaii | N. Kohala | Future | Incl | Optimistic | 10 | 2 | 30 | 39,276 | 0.0675 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Optimistic | 50 | 3 | 30 | 142,967 | 0.0692 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Optimistic | 50 | 3 | 30 | 142,967 | 0.0701 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Optimistic | 15 | 1.5 | 30 | 30,886 | 0.0709 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Optimistic | 50 | 3 | 30 | 127,649 | 0.0723 |
| Biomass Elec | grass crops | Hawaii | Ka'u | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0729 |
| Solar Thermal | dish | Hawaii | N. Kohala | Future | Incl | Optimistic | 5 | 1.5 | 30 | 10,399 | 0.0733 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Optimistic | 50 | 3 | 30 | 127,649 | 0.0733 |
| Solar Thermal | dish | Hawaii | Keahole | Future | Incl | Optimistic | 30 | 1.5 | 30 | 57,882 | 0.0738 |
| Photovoltaic | tracking | Hawaii | Keahole | Future | Incl | Optimistic | 30 | 2 | 30 | 85,780 | 0.0754 |
| Photovoltaic | tracking | Hawaii | Waikoloa | Future | Incl | Optimistic | 30 | 2 | 30 | 85,780 | 0.0763 |
| Biomass Elec | grass crops | Hawaii | Hamakua Coast | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0774 |
| Photovoltaic | fixed | Hawaii | Keahole | Future | Incl | Optimistic | 30 | 2 | 30 | 76,589 | 0.0789 |
| Photovoltaic | fixed | Hawaii | Waikoloa | Future | Incl | Optimistic | 30 | 2 | 30 | 76,589 | 0.0799 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Optimistic | 15 | 1.5 | 30 | 40,873 | 0.0828 |
| Biomass Elec | grass crops | Hawaii | Hilo Coast | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0861 |
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Optimistic | 15 | 1.5 | 30 | 36,494 | 0.0876 |
| Photovoltaic | tracking | Hawaii | N. Kohala | Future | Incl | Optimistic | 5 | 1 | 30 | 13,624 | 0.0897 |


| | | | | | | | | | | | |
|---------------|--------|--------|---------------|--------|------|------------|----|-----|----|---------|--------|
| Photovoltaic | fixed | Hawaii | N. Kohala | Future | Incl | Optimistic | 5 | 1 | 30 | 12,165 | 0.0949 |
| Solar Thermal | dish | Hawaii | Waikoloa | Future | Incl | Optimistic | 30 | 1.5 | 30 | 56,358 | 0.0953 |
| OTEC | | Hawaii | Keahole Point | Future | Incl | Optimistic | 60 | 2 | 30 | 319,565 | 0.1249 |
| Solar Thermal | trough | Hawaii | Keahole | Future | Incl | Optimistic | 30 | 1.5 | 30 | 67,724 | 0.1411 |
| Solar Thermal | trough | Hawaii | Waikoloa | Future | Incl | Optimistic | 30 | 1.5 | 30 | 65,941 | 0.1483 |

APPENDIX B

RESOURCE SUPPLY CURVES, ISLAND OF MAUI

Island(s): Maui
Technology: All_Tech
Certainty: Nominal
Stage: Current Technology
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0604



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|---------|---------|-----------|----|------|------|---------|--------|
| Biomass Elec | org waste | Maui | Puunene | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0357 |
| Wind | | Maui | McGregor Point | Current | Incl | Nominal | 10 | 1 | 30 | 19,874 | 0.0515 |
| Wind | | Maui | NW Haleakala | Current | Incl | Nominal | 10 | 1 | 30 | 17,124 | 0.0620 |
| Wind | | Maui | NW Haleakala | Current | Incl | Nominal | 50 | 1 | 30 | 74,804 | 0.0713 |
| Wind | | Maui | NW Haleakala | Current | Incl | Nominal | 30 | 1 | 30 | 44,882 | 0.0747 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Current | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0772 |
| Wind | | Maui | Puunene | Current | Incl | Nominal | 10 | 1 | 30 | 12,746 | 0.0805 |
| Wind | | Maui | West Maui | Current | Incl | Nominal | 50 | 1 | 30 | 62,245 | 0.0843 |
| Wind | | Maui | West Maui | Current | Incl | Nominal | 30 | 1 | 30 | 37,347 | 0.0858 |
| Wind | | Maui | West Maui | Current | Incl | Nominal | 10 | 1 | 30 | 12,449 | 0.0885 |
| Wind | | Maui | Puunene | Current | Incl | Nominal | 30 | 1 | 30 | 36,067 | 0.0895 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Current | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0931 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Nominal | 30 | 3 | 30 | 79,992 | 0.1186 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Nominal | 10 | 2 | 30 | 28,158 | 0.1238 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Nominal | 30 | 3 | 30 | 75,424 | 0.1259 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Nominal | 30 | 3 | 30 | 75,069 | 0.1271 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Nominal | 10 | 2 | 30 | 26,664 | 0.1279 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Nominal | 10 | 2 | 30 | 25,023 | 0.1376 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Nominal | 30 | 3 | 30 | 61,532 | 0.1446 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Nominal | 30 | 3 | 30 | 61,532 | 0.1462 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Nominal | 30 | 3 | 30 | 61,320 | 0.1468 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Nominal | 10 | 1.5 | 30 | 15,648 | 0.1474 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Nominal | 10 | 1.5 | 30 | 16,116 | 0.1489 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Nominal | 30 | 1.5 | 30 | 46,471 | 0.1508 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Nominal | 10 | 2 | 30 | 20,511 | 0.1563 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Nominal | 10 | 1.5 | 30 | 15,179 | 0.1578 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Nominal | 10 | 2 | 30 | 20,511 | 0.1579 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Nominal | 10 | 2 | 30 | 20,440 | 0.1585 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Nominal | 30 | 1.5 | 30 | 47,862 | 0.1737 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Nominal | 30 | 1.5 | 30 | 45,080 | 0.1862 |
| Solar Thermal | trough | Maui | Kihei | Current | Incl | Nominal | 30 | 1.5 | 30 | 51,131 | 0.2646 |
| Solar Thermal | trough | Maui | Puunene | Current | Incl | Nominal | 30 | 1.5 | 30 | 49,645 | 0.2659 |
| Solar Thermal | trough | Maui | Kahului | Current | Incl | Nominal | 30 | 1.5 | 30 | 48,159 | 0.2803 |

Island(s): Maui
Technology: All_Tech
Certainty: Conservative
Stage: Current Technology
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0604



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|---------|---------|--------------|----|------|------|---------|--------|
| Biomass Elec | org waste | Maui | Puunene | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.0597 |
| Wind | | Maui | McGregor Point | Current | Incl | Conservative | 10 | 1 | 30 | 16,801 | 0.0669 |
| Wind | | Maui | NW Haleakala | Current | Incl | Conservative | 10 | 1 | 30 | 14,476 | 0.0803 |
| Wind | | Maui | NW Haleakala | Current | Incl | Conservative | 50 | 1 | 30 | 62,645 | 0.0935 |
| Wind | | Maui | NW Haleakala | Current | Incl | Conservative | 30 | 1 | 30 | 37,587 | 0.0986 |
| Wind | | Maui | Puunene | Current | Incl | Conservative | 10 | 1 | 30 | 10,720 | 0.1043 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Current | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1063 |
| Wind | | Maui | West Maui | Current | Incl | Conservative | 50 | 1 | 30 | 52,349 | 0.1085 |
| Wind | | Maui | West Maui | Current | Incl | Conservative | 30 | 1 | 30 | 31,409 | 0.1105 |
| Wind | | Maui | West Maui | Current | Incl | Conservative | 10 | 1 | 30 | 10,470 | 0.1143 |
| Wind | | Maui | Puunene | Current | Incl | Conservative | 30 | 1 | 30 | 30,204 | 0.1179 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Current | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1218 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Conservative | 30 | 3 | 30 | 71,992 | 0.1372 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Conservative | 10 | 2 | 30 | 25,343 | 0.1424 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Conservative | 30 | 3 | 30 | 67,881 | 0.1457 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Conservative | 30 | 3 | 30 | 67,562 | 0.1471 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Conservative | 10 | 2 | 30 | 23,994 | 0.1483 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Conservative | 10 | 2 | 30 | 22,521 | 0.1596 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Conservative | 30 | 3 | 30 | 55,379 | 0.1672 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Conservative | 30 | 3 | 30 | 55,379 | 0.1692 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Conservative | 30 | 3 | 30 | 55,188 | 0.1698 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Conservative | 10 | 1.5 | 30 | 14,083 | 0.1748 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Conservative | 10 | 1.5 | 30 | 14,505 | 0.1767 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Conservative | 30 | 1.5 | 30 | 41,824 | 0.1788 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Conservative | 10 | 2 | 30 | 18,460 | 0.1812 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Conservative | 10 | 2 | 30 | 18,460 | 0.1830 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Conservative | 10 | 2 | 30 | 18,396 | 0.1838 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Conservative | 10 | 1.5 | 30 | 13,661 | 0.1874 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Conservative | 30 | 1.5 | 30 | 43,076 | 0.2069 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Conservative | 30 | 1.5 | 30 | 40,572 | 0.2219 |
| Solar Thermal | trough | Maui | Kihei | Current | Incl | Conservative | 30 | 1.5 | 30 | 46,018 | 0.3169 |
| Solar Thermal | trough | Maui | Puunene | Current | Incl | Conservative | 30 | 1.5 | 30 | 44,681 | 0.3184 |
| Solar Thermal | trough | Maui | Kahului | Current | Incl | Conservative | 30 | 1.5 | 30 | 43,343 | 0.3358 |

Island(s): Maui
Technology: All_Tech
Certainty: Optimistic
Stage: Current Technology
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0604



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|---------|---------|------------|----|------|------|---------|--------|
| Biomass Elec | org waste | Maui | Puunene | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0160 |
| Wind | | Maui | McGregor Point | Current | Incl | Optimistic | 10 | 1 | 30 | 23,189 | 0.0408 |
| Wind | | Maui | NW Haleakala | Current | Incl | Optimistic | 10 | 1 | 30 | 19,980 | 0.0492 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Current | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0534 |
| Wind | | Maui | NW Haleakala | Current | Incl | Optimistic | 50 | 1 | 30 | 88,001 | 0.0556 |
| Wind | | Maui | NW Haleakala | Current | Incl | Optimistic | 30 | 1 | 30 | 52,801 | 0.0577 |
| Wind | | Maui | Puunene | Current | Incl | Optimistic | 10 | 1 | 30 | 14,940 | 0.0636 |
| Wind | | Maui | West Maui | Current | Incl | Optimistic | 50 | 1 | 30 | 72,957 | 0.0670 |
| Wind | | Maui | West Maui | Current | Incl | Optimistic | 30 | 1 | 30 | 43,774 | 0.0681 |
| Wind | | Maui | Puunene | Current | Incl | Optimistic | 30 | 1 | 30 | 42,430 | 0.0691 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Current | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0697 |
| Wind | | Maui | West Maui | Current | Incl | Optimistic | 10 | 1 | 30 | 14,591 | 0.0701 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Optimistic | 30 | 3 | 30 | 91,990 | 0.0944 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Optimistic | 30 | 3 | 30 | 86,737 | 0.1002 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Optimistic | 30 | 3 | 30 | 86,330 | 0.1012 |
| Photovoltaic | tracking | Maui | Kahului | Current | Incl | Optimistic | 10 | 2 | 30 | 30,664 | 0.1014 |
| Photovoltaic | tracking | Maui | Puunene | Current | Incl | Optimistic | 10 | 2 | 30 | 28,776 | 0.1091 |
| Photovoltaic | tracking | Maui | Kihei | Current | Incl | Optimistic | 10 | 2 | 30 | 28,912 | 0.1101 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Optimistic | 30 | 3 | 30 | 70,762 | 0.1149 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Optimistic | 30 | 3 | 30 | 70,762 | 0.1162 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Optimistic | 30 | 3 | 30 | 70,518 | 0.1167 |
| Photovoltaic | fixed | Maui | Puunene | Current | Incl | Optimistic | 10 | 2 | 30 | 23,587 | 0.1237 |
| Photovoltaic | fixed | Maui | Kahului | Current | Incl | Optimistic | 10 | 2 | 30 | 23,587 | 0.1250 |
| Photovoltaic | fixed | Maui | Kihei | Current | Incl | Optimistic | 10 | 2 | 30 | 23,506 | 0.1255 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Optimistic | 10 | 1.5 | 30 | 16,430 | 0.1305 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Optimistic | 10 | 1.5 | 30 | 16,922 | 0.1316 |
| Solar Thermal | dish | Maui | Puunene | Current | Incl | Optimistic | 30 | 1.5 | 30 | 48,795 | 0.1336 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Optimistic | 10 | 1.5 | 30 | 15,938 | 0.1395 |
| Solar Thermal | dish | Maui | Kihei | Current | Incl | Optimistic | 30 | 1.5 | 30 | 50,256 | 0.1531 |
| Solar Thermal | dish | Maui | Kahului | Current | Incl | Optimistic | 30 | 1.5 | 30 | 47,334 | 0.1640 |
| Solar Thermal | trough | Maui | Kihei | Current | Incl | Optimistic | 30 | 1.5 | 30 | 53,688 | 0.2318 |
| Solar Thermal | trough | Maui | Puunene | Current | Incl | Optimistic | 30 | 1.5 | 30 | 52,127 | 0.2330 |
| Solar Thermal | trough | Maui | Kahului | Current | Incl | Optimistic | 30 | 1.5 | 30 | 50,567 | 0.2454 |

Island(s): Maui
Technology: All_Tech
Certainty: Nominal
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0984




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------|--------|----------------|--------|---------|-----------|----|------|------|---------|--------|
| Wind | | Maui | McGregor Point | Future | Incl | Nominal | 10 | 1 | 30 | 24,611 | 0.0465 |
| Biomass Elec | org waste | Maui | Puunene | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0515 |
| Wind | | Maui | NW Haleakala | Future | Incl | Nominal | 10 | 1 | 30 | 21,205 | 0.0545 |
| Wind | | Maui | NW Haleakala | Future | Incl | Nominal | 50 | 1 | 30 | 93,192 | 0.0613 |
| Wind | | Maui | NW Haleakala | Future | Incl | Nominal | 30 | 1 | 30 | 56,140 | 0.0639 |
| Wind | | Maui | Puunene | Future | Incl | Nominal | 10 | 1 | 30 | 15,784 | 0.0677 |
| Wind | | Maui | West Maui | Future | Incl | Nominal | 50 | 1 | 30 | 77,546 | 0.0707 |
| Wind | | Maui | West Maui | Future | Incl | Nominal | 30 | 1 | 30 | 46,715 | 0.0718 |
| Wind | | Maui | West Maui | Future | Incl | Nominal | 10 | 1 | 30 | 15,416 | 0.0741 |
| Wind | | Maui | Puunene | Future | Incl | Nominal | 30 | 1 | 30 | 45,113 | 0.0743 |
| Biomass Elec | tree crops | Maui | Pala-Puunene | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0795 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Nominal | 30 | 2 | 30 | 82,893 | 0.0807 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Nominal | 30 | 2 | 30 | 77,792 | 0.0850 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Nominal | 30 | 2 | 30 | 78,159 | 0.0857 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Nominal | 10 | 1 | 30 | 27,632 | 0.0866 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Nominal | 10 | 1.5 | 30 | 16,430 | 0.0901 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Nominal | 10 | 1 | 30 | 25,931 | 0.0913 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Nominal | 10 | 1 | 30 | 26,053 | 0.0919 |
| Wave | | Maui | Opana Point | Future | Incl | Nominal | 60 | 2 | 30 | 211,984 | 0.0920 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Nominal | 10 | 1.5 | 30 | 16,922 | 0.0929 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Nominal | 30 | 1.5 | 30 | 48,795 | 0.0949 |
| Wave | | Maui | Lower Pala | Future | Incl | Nominal | 60 | 2 | 30 | 203,974 | 0.0956 |
| Wave | | Maui | Opana Point | Future | Incl | Nominal | 30 | 2 | 30 | 106,004 | 0.0972 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Nominal | 30 | 2 | 30 | 63,764 | 0.0980 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Nominal | 10 | 1.5 | 30 | 15,938 | 0.0984 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Nominal | 30 | 2 | 30 | 63,764 | 0.0992 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Nominal | 30 | 2 | 30 | 63,544 | 0.0997 |
| Wave | | Maui | Lower Pala | Future | Incl | Nominal | 30 | 2 | 30 | 101,998 | 0.1010 |
| Wave | | Maui | Waiehu Point | Future | Incl | Nominal | 30 | 2 | 30 | 101,256 | 0.1023 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Nominal | 10 | 1 | 30 | 21,255 | 0.1053 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Nominal | 10 | 1 | 30 | 21,255 | 0.1065 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Nominal | 10 | 1 | 30 | 21,181 | 0.1069 |
| Wave | | Maui | Opana Point | Future | Incl | Nominal | 10 | 2 | 30 | 35,321 | 0.1086 |
| Wave | | Maui | Lower Pala | Future | Incl | Nominal | 10 | 2 | 30 | 33,987 | 0.1129 |

| | | | | | | | | | | | |
|---------------|-------------|------|--------------|--------|------|---------|----|-----|----|---------|--------|
| Wave | | Maui | Walehu Point | Future | Incl | Nominal | 10 | 2 | 30 | 33,733 | 0.1151 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Nominal | 30 | 1.5 | 30 | 50,256 | 0.1181 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Nominal | 30 | 1.5 | 30 | 47,334 | 0.1271 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.1442 |
| Solar Thermal | trough | Maui | Puunene | Future | Incl | Nominal | 30 | 1.5 | 30 | 57,092 | 0.1778 |
| Solar Thermal | trough | Maui | Kihei | Future | Incl | Nominal | 30 | 1.5 | 30 | 58,801 | 0.1781 |
| Solar Thermal | trough | Maui | Kahului | Future | Incl | Nominal | 30 | 1.5 | 30 | 55,382 | 0.1886 |

Island(s): Maui
Technology: All_Tech
Certainty: Conservative
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0984




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|--------|---------|--------------|----|------|------|---------|--------|
| Wind | | Maui | McGregor Point | Future | Incl | Conservative | 10 | 1 | 30 | 20,805 | 0.0592 |
| Wind | | Maui | NW Haleakala | Future | Incl | Conservative | 10 | 1 | 30 | 17,926 | 0.0695 |
| Biomass Elec | org waste | Maui | Puunene | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.0779 |
| Wind | | Maui | NW Haleakala | Future | Incl | Conservative | 50 | 1 | 30 | 78,045 | 0.0795 |
| Wind | | Maui | NW Haleakala | Future | Incl | Conservative | 30 | 1 | 30 | 47,015 | 0.0834 |
| Wind | | Maui | Puunene | Future | Incl | Conservative | 10 | 1 | 30 | 13,275 | 0.0872 |
| Wind | | Maui | West Maui | Future | Incl | Conservative | 50 | 1 | 30 | 65,218 | 0.0905 |
| Wind | | Maui | West Maui | Future | Incl | Conservative | 30 | 1 | 30 | 39,288 | 0.0920 |
| Wind | | Maui | West Maui | Future | Incl | Conservative | 10 | 1 | 30 | 12,965 | 0.0953 |
| Wind | | Maui | Puunene | Future | Incl | Conservative | 30 | 1 | 30 | 37,781 | 0.0954 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Conservative | 30 | 2 | 30 | 70,459 | 0.0990 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Conservative | 30 | 2 | 30 | 66,123 | 0.1042 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Conservative | 30 | 2 | 30 | 66,435 | 0.1051 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1060 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Conservative | 10 | 1 | 30 | 23,487 | 0.1064 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Conservative | 10 | 1.5 | 30 | 14,787 | 0.1085 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Conservative | 10 | 1.5 | 30 | 15,230 | 0.1119 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Conservative | 10 | 1 | 30 | 22,041 | 0.1122 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Conservative | 10 | 1 | 30 | 22,145 | 0.1130 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Conservative | 30 | 1.5 | 30 | 43,915 | 0.1143 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Conservative | 10 | 1.5 | 30 | 14,344 | 0.1187 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Conservative | 30 | 2 | 30 | 54,199 | 0.1200 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Conservative | 30 | 2 | 30 | 54,199 | 0.1216 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Conservative | 30 | 2 | 30 | 54,012 | 0.1221 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Conservative | 10 | 1 | 30 | 18,066 | 0.1294 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Conservative | 10 | 1 | 30 | 18,067 | 0.1308 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Conservative | 10 | 1 | 30 | 18,004 | 0.1314 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Conservative | 30 | 1.5 | 30 | 45,230 | 0.1426 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Conservative | 30 | 1.5 | 30 | 42,600 | 0.1536 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1922 |
| Solar Thermal | trough | Maui | Puunene | Future | Incl | Conservative | 30 | 1.5 | 30 | 51,383 | 0.2122 |
| Solar Thermal | trough | Maui | Kihei | Future | Incl | Conservative | 30 | 1.5 | 30 | 52,921 | 0.2127 |
| Solar Thermal | trough | Maui | Kahului | Future | Incl | Conservative | 30 | 1.5 | 30 | 49,844 | 0.2254 |
| Wave | | Maui | Opana Point | Future | Incl | Conservative | 60 | 2 | 30 | 98,882 | 0.2913 |

| | | | | | | | | | | |
|------|------|--------------|--------|------|--------------|----|---|----|--------|--------|
| Wave | Maui | Lower Paia | Future | Incl | Conservative | 60 | 2 | 30 | 94,151 | 0.3060 |
| Wave | Maui | Opana Point | Future | Incl | Conservative | 30 | 2 | 30 | 49,444 | 0.3069 |
| Wave | Maui | Lower Paia | Future | Incl | Conservative | 30 | 2 | 30 | 47,078 | 0.3224 |
| Wave | Maui | Waiehu Point | Future | Incl | Conservative | 30 | 2 | 30 | 46,754 | 0.3260 |
| Wave | Maui | Opana Point | Future | Incl | Conservative | 10 | 2 | 30 | 16,478 | 0.3429 |
| Wave | Maui | Lower Paia | Future | Incl | Conservative | 10 | 2 | 30 | 15,690 | 0.3602 |
| Wave | Maui | Waiehu Point | Future | Incl | Conservative | 10 | 2 | 30 | 15,580 | 0.3661 |

Island(s): Maui
Technology: All_Tech
Certainty: Optimistic
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0984



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------|--------|----------------|--------|---------|------------|----|------|------|---------|--------|
| Biomass Elec | org waste | Maui | Puunene | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0299 |
| Wind | | Maui | McGregor Point | Future | Incl | Optimistic | 10 | 1 | 30 | 28,715 | 0.0388 |
| Wind | | Maui | NW Haleakala | Future | Incl | Optimistic | 10 | 1 | 30 | 24,741 | 0.0452 |
| Wave | | Maui | Opana Point | Future | Incl | Optimistic | 60 | 2 | 30 | 265,780 | 0.0485 |
| Wind | | Maui | NW Haleakala | Future | Incl | Optimistic | 50 | 1 | 30 | 109,635 | 0.0498 |
| Wave | | Maui | Lower Paia | Future | Incl | Optimistic | 60 | 2 | 30 | 255,885 | 0.0504 |
| Wave | | Maui | Opana Point | Future | Incl | Optimistic | 30 | 2 | 30 | 132,906 | 0.0513 |
| Wind | | Maui | NW Haleakala | Future | Incl | Optimistic | 30 | 1 | 30 | 66,045 | 0.0515 |
| Wave | | Maui | Lower Paia | Future | Incl | Optimistic | 30 | 2 | 30 | 127,957 | 0.0533 |
| Wave | | Maui | Waiehu Point | Future | Incl | Optimistic | 30 | 2 | 30 | 126,887 | 0.0542 |
| Wind | | Maui | Puunene | Future | Incl | Optimistic | 10 | 1 | 30 | 18,501 | 0.0555 |
| Wave | | Maui | Opana Point | Future | Incl | Optimistic | 10 | 2 | 30 | 44,283 | 0.0573 |
| Biomass Elec | tree crops | Maui | Paia-Puunene | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0578 |
| Wind | | Maui | West Maui | Future | Incl | Optimistic | 50 | 1 | 30 | 90,891 | 0.0581 |
| Wind | | Maui | West Maui | Future | Incl | Optimistic | 30 | 1 | 30 | 54,754 | 0.0589 |
| Wave | | Maui | Lower Paia | Future | Incl | Optimistic | 10 | 2 | 30 | 42,635 | 0.0596 |
| Wind | | Maui | West Maui | Future | Incl | Optimistic | 10 | 1 | 30 | 18,069 | 0.0607 |
| Wind | | Maui | Puunene | Future | Incl | Optimistic | 30 | 1 | 30 | 53,073 | 0.0609 |
| Wave | | Maui | Waiehu Point | Future | Incl | Optimistic | 10 | 2 | 30 | 42,269 | 0.0610 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Optimistic | 30 | 2 | 30 | 95,327 | 0.0647 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Optimistic | 30 | 2 | 30 | 89,461 | 0.0682 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Optimistic | 30 | 2 | 30 | 89,883 | 0.0687 |
| Photovoltaic | tracking | Maui | Kahului | Future | Incl | Optimistic | 10 | 1 | 30 | 31,776 | 0.0691 |
| Photovoltaic | tracking | Maui | Puunene | Future | Incl | Optimistic | 10 | 1 | 30 | 29,821 | 0.0729 |
| Photovoltaic | tracking | Maui | Kihei | Future | Incl | Optimistic | 10 | 1 | 30 | 29,961 | 0.0734 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Optimistic | 10 | 1.5 | 30 | 17,252 | 0.0781 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Optimistic | 30 | 2 | 30 | 73,329 | 0.0784 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Optimistic | 30 | 2 | 30 | 73,329 | 0.0795 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Optimistic | 30 | 2 | 30 | 73,076 | 0.0798 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Optimistic | 10 | 1.5 | 30 | 17,768 | 0.0805 |
| Solar Thermal | dish | Maui | Puunene | Future | Incl | Optimistic | 30 | 1.5 | 30 | 51,234 | 0.0825 |
| Photovoltaic | fixed | Maui | Puunene | Future | Incl | Optimistic | 10 | 1 | 30 | 24,443 | 0.0839 |
| Photovoltaic | fixed | Maui | Kahului | Future | Incl | Optimistic | 10 | 1 | 30 | 24,443 | 0.0849 |
| Photovoltaic | fixed | Maui | Kihei | Future | Incl | Optimistic | 10 | 1 | 30 | 24,359 | 0.0853 |


| | | | | | | | | | | | |
|---------------|-------------|------|--------------|--------|------|------------|----|-----|----|---------|--------|
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Optimistic | 10 | 1.5 | 30 | 16,735 | 0.0853 |
| Solar Thermal | dish | Maui | Kihei | Future | Incl | Optimistic | 30 | 1.5 | 30 | 52,768 | 0.1023 |
| Biomass Elec | grass crops | Maui | Paia-Puunene | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.1049 |
| Solar Thermal | dish | Maui | Kahului | Future | Incl | Optimistic | 30 | 1.5 | 30 | 49,700 | 0.1101 |
| Solar Thermal | trough | Maui | Puunene | Future | Incl | Optimistic | 30 | 1.5 | 30 | 59,946 | 0.1562 |
| Solar Thermal | trough | Maui | Kihei | Future | Incl | Optimistic | 30 | 1.5 | 30 | 61,741 | 0.1564 |
| Solar Thermal | trough | Maui | Kahului | Future | Incl | Optimistic | 30 | 1.5 | 30 | 58,152 | 0.1656 |

APPENDIX C

RESOURCE SUPPLY CURVES, ISLAND OF OAHU

Island(s): Oahu
Technology: All_Tech
Certainty: Nominal
Stage: Current Technology
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0473



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|--------------|---------|---------|-----------|----|------|------|---------|--------|
| Wind | | Oahu | Kaena Point | Current | Incl | Nominal | 15 | 1 | 30 | 25,230 | 0.0652 |
| Wind | | Oahu | Kaena Point | Current | Incl | Nominal | 2 | 1 | 30 | 3,555 | 0.0687 |
| Wind | | Oahu | Kahuku | Current | Incl | Nominal | 30 | 1 | 30 | 45,551 | 0.0694 |
| Wind | | Oahu | Kahuku | Current | Incl | Nominal | 50 | 1 | 30 | 75,918 | 0.0703 |
| Wind | | Oahu | Kahuku | Current | Incl | Nominal | 80 | 1 | 30 | 121,469 | 0.0777 |
| Biomass Elec | grass crops | Oahu | Waialua | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1139 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1288 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1297 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 4 | 30 | 107,766 | 0.1303 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 1.5 | 30 | 80,904 | 0.1360 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1364 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1373 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 4 | 30 | 96,220 | 0.1381 |
| Solar Thermal | dish | Oahu | Lualualei | Current | Incl | Nominal | 50 | 1.5 | 30 | 77,059 | 0.1403 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Nominal | 20 | 3 | 30 | 43,107 | 0.1425 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Current | Incl | Nominal | 50 | 1.5 | 30 | 74,752 | 0.1509 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Nominal | 20 | 3 | 30 | 38,488 | 0.1511 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Nominal | 10 | 2 | 30 | 21,553 | 0.1563 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Nominal | 10 | 2 | 30 | 21,553 | 0.1601 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Nominal | 10 | 2 | 30 | 21,553 | 0.1607 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Nominal | 10 | 2 | 30 | 19,244 | 0.1661 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Nominal | 10 | 2 | 30 | 19,244 | 0.1704 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Nominal | 10 | 2 | 30 | 19,244 | 0.1711 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Current | Incl | Nominal | 80 | 1.5 | 30 | 139,601 | 0.1939 |
| Solar Thermal | trough | Oahu | Lualualei | Current | Incl | Nominal | 80 | 1.5 | 30 | 132,966 | 0.2001 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Current | Incl | Nominal | 80 | 1.5 | 30 | 128,985 | 0.2130 |

Island(s): Oahu
Technology: All_Tech
Certainty: Conservative
Stage: Current Technology
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0473



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|--------------|---------|---------|--------------|----|------|------|---------|--------|
| Wind | | Oahu | Kaena Point | Current | Incl | Conservative | 15 | 1 | 30 | 21,234 | 0.0841 |
| Wind | | Oahu | Kaena Point | Current | Incl | Conservative | 2 | 1 | 30 | 3,003 | 0.0899 |
| Wind | | Oahu | Kahuku | Current | Incl | Conservative | 30 | 1 | 30 | 38,147 | 0.0901 |
| Wind | | Oahu | Kahuku | Current | Incl | Conservative | 50 | 1 | 30 | 63,579 | 0.0910 |
| Wind | | Oahu | Kahuku | Current | Incl | Conservative | 80 | 1 | 30 | 101,726 | 0.0998 |
| Biomass Elec | grass crops | Oahu | Waialua | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1483 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Conservative | 50 | 4 | 30 | 96,990 | 0.1491 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Conservative | 50 | 4 | 30 | 96,990 | 0.1501 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Conservative | 50 | 4 | 30 | 96,990 | 0.1509 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Conservative | 50 | 4 | 30 | 86,598 | 0.1577 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Conservative | 50 | 4 | 30 | 86,598 | 0.1588 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Conservative | 50 | 4 | 30 | 86,598 | 0.1597 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Current | Incl | Conservative | 50 | 1.5 | 30 | 72,814 | 0.1612 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Conservative | 20 | 3 | 30 | 38,796 | 0.1651 |
| Solar Thermal | dish | Oahu | Lualualei | Current | Incl | Conservative | 50 | 1.5 | 30 | 69,353 | 0.1661 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Conservative | 20 | 3 | 30 | 34,639 | 0.1750 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Current | Incl | Conservative | 50 | 1.5 | 30 | 67,276 | 0.1791 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Conservative | 10 | 2 | 30 | 19,398 | 0.1812 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Conservative | 10 | 2 | 30 | 19,398 | 0.1856 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Conservative | 10 | 2 | 30 | 19,398 | 0.1863 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Conservative | 10 | 2 | 30 | 17,320 | 0.1925 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Conservative | 10 | 2 | 30 | 17,320 | 0.1974 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Conservative | 10 | 2 | 30 | 17,320 | 0.1982 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Current | Incl | Conservative | 80 | 1.5 | 30 | 125,641 | 0.2317 |
| Solar Thermal | trough | Oahu | Lualualei | Current | Incl | Conservative | 80 | 1.5 | 30 | 119,669 | 0.2391 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Current | Incl | Conservative | 80 | 1.5 | 30 | 116,086 | 0.2548 |

Island(s): Oahu
Technology: All_Tech
Certainty: Optimistic
Stage: Current Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0473




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|--------------|---------|---------|------------|----|------|------|---------|--------|
| Wind | | Oahu | Kaena Point | Current | Incl | Optimistic | 15 | 1 | 30 | 29,553 | 0.0518 |
| Wind | | Oahu | Kaena Point | Current | Incl | Optimistic | 2 | 1 | 30 | 4,151 | 0.0539 |
| Wind | | Oahu | Kahuku | Current | Incl | Optimistic | 30 | 1 | 30 | 53,588 | 0.0548 |
| Wind | | Oahu | Kahuku | Current | Incl | Optimistic | 50 | 1 | 30 | 89,313 | 0.0556 |
| Wind | | Oahu | Kahuku | Current | Incl | Optimistic | 80 | 1 | 30 | 142,900 | 0.0620 |
| Biomass Elec | grass crops | Oahu | Waalua | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0857 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Optimistic | 50 | 4 | 30 | 123,931 | 0.1026 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Optimistic | 50 | 4 | 30 | 123,931 | 0.1032 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 50 | 4 | 30 | 123,931 | 0.1038 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Optimistic | 50 | 4 | 30 | 110,654 | 0.1084 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Optimistic | 50 | 4 | 30 | 110,654 | 0.1091 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 50 | 4 | 30 | 110,654 | 0.1097 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Optimistic | 20 | 3 | 30 | 49,573 | 0.1131 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Optimistic | 20 | 3 | 30 | 44,261 | 0.1198 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Current | Incl | Optimistic | 50 | 1.5 | 30 | 84,949 | 0.1205 |
| Photovoltaic | tracking | Oahu | Lualualei | Current | Incl | Optimistic | 10 | 2 | 30 | 24,786 | 0.1239 |
| Solar Thermal | dish | Oahu | Lualualei | Current | Incl | Optimistic | 50 | 1.5 | 30 | 80,912 | 0.1243 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Current | Incl | Optimistic | 10 | 2 | 30 | 24,786 | 0.1272 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 10 | 2 | 30 | 24,786 | 0.1277 |
| Photovoltaic | fixed | Oahu | Lualualei | Current | Incl | Optimistic | 10 | 2 | 30 | 22,131 | 0.1314 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 50 | 1.5 | 30 | 78,489 | 0.1335 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Current | Incl | Optimistic | 10 | 2 | 30 | 22,131 | 0.1351 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 10 | 2 | 30 | 22,131 | 0.1357 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Current | Incl | Optimistic | 80 | 1.5 | 30 | 146,581 | 0.1700 |
| Solar Thermal | trough | Oahu | Lualualei | Current | Incl | Optimistic | 80 | 1.5 | 30 | 139,614 | 0.1755 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Current | Incl | Optimistic | 80 | 1.5 | 30 | 135,434 | 0.1866 |

Island(s): Oahu
Technology: All Technologies
Stage: Future Technology
Certainty: Nominal
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0770

RESOURCE SUPPLY CURVES




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|--------|---------|-----------|----|------|------|---------|--------|
| Biomass Elec | org waste | Oahu | Barber's Point | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0389 |
| Wind | | Oahu | Kaena Point | Future | Incl | Nominal | 15 | 1 | 30 | 31,558 | 0.0567 |
| Wind | | Oahu | Kahuku | Future | Incl | Nominal | 30 | 1 | 30 | 56,977 | 0.0597 |
| Wind | | Oahu | Kahuku | Future | Incl | Nominal | 50 | 1 | 30 | 94,581 | 0.0605 |
| Wind | | Oahu | Kaena Point | Future | Incl | Nominal | 2 | 1 | 30 | 4,002 | 0.0617 |
| Wind | | Oahu | Kahuku | Future | Incl | Nominal | 80 | 1 | 30 | 151,558 | 0.0664 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 1.5 | 30 | 84,949 | 0.0829 |
| Solar Thermal | dish | Oahu | Lualualei | Future | Incl | Nominal | 50 | 1.5 | 30 | 80,912 | 0.0846 |
| Wave | | Oahu | Makapuu | Future | Incl | Nominal | 60 | 2 | 30 | 224,378 | 0.0863 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0873 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0878 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 3 | 30 | 111,675 | 0.0883 |
| Wave | | Oahu | Makapuu | Future | Incl | Nominal | 30 | 2 | 30 | 112,208 | 0.0898 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Nominal | 60 | 2 | 30 | 211,197 | 0.0918 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0921 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0926 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 3 | 30 | 99,710 | 0.0932 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Future | Incl | Nominal | 50 | 1.5 | 30 | 78,489 | 0.0933 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Nominal | 30 | 2 | 30 | 105,608 | 0.0947 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Nominal | 20 | 2 | 30 | 44,670 | 0.0962 |
| Wave | | Oahu | NE Coast 2A | Future | Incl | Nominal | 30 | 2 | 30 | 103,704 | 0.0966 |
| Wave | | Oahu | NE Coast 2C | Future | Incl | Nominal | 30 | 2 | 30 | 101,831 | 0.0982 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Nominal | 20 | 2 | 30 | 39,884 | 0.1016 |
| Wave | | Oahu | Mokapu Point | Future | Incl | Nominal | 30 | 2 | 30 | 97,966 | 0.1034 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Nominal | 10 | 1 | 30 | 22,335 | 0.1056 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Nominal | 10 | 1 | 30 | 22,335 | 0.1091 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Nominal | 10 | 1 | 30 | 22,335 | 0.1095 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Nominal | 10 | 1 | 30 | 19,942 | 0.1119 |
| Wave | | Oahu | Waimanalo Bay | Future | Incl | Nominal | 30 | 2 | 30 | 88,957 | 0.1128 |
| Biomass Elec | grass crops | Oahu | Waiialua | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1141 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Nominal | 10 | 1 | 30 | 19,942 | 0.1157 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Nominal | 10 | 1 | 30 | 19,942 | 0.1162 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Future | Incl | Nominal | 80 | 1.5 | 30 | 160,541 | 0.1307 |
| Solar Thermal | trough | Oahu | Lualualei | Future | Incl | Nominal | 80 | 1.5 | 30 | 152,911 | 0.1343 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Future | Incl | Nominal | 80 | 1.5 | 30 | 148,333 | 0.1443 |
| OTEC | | Oahu | Kahe Point | Future | Incl | Nominal | 60 | 2 | 30 | 311,260 | 0.2041 |

Island(s): Oahu
Technology: All Technologies
Stage: Future Technology
Certainty: Conservative
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0770

RESOURCE SUPPLY CURVES




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|--------|---------|--------------|----|------|------|---------|--------|
| Biomass Elec | org waste | Oahu | Barber's Point | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.0627 |
| Wind | | Oahu | Kaena Point | Future | Incl | Conservative | 15 | 1 | 30 | 26,560 | 0.0721 |
| Wind | | Oahu | Kahuku | Future | Incl | Conservative | 30 | 1 | 30 | 47,716 | 0.0766 |
| Wind | | Oahu | Kahuku | Future | Incl | Conservative | 50 | 1 | 30 | 79,208 | 0.0774 |
| Wind | | Oahu | Kaena Point | Future | Incl | Conservative | 2 | 1 | 30 | 3,381 | 0.0797 |
| Wind | | Oahu | Kahuku | Future | Incl | Conservative | 80 | 1 | 30 | 126,924 | 0.0845 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Future | Incl | Conservative | 50 | 1.5 | 30 | 76,454 | 0.0999 |
| Solar Thermal | dish | Oahu | Lualualei | Future | Incl | Conservative | 50 | 1.5 | 30 | 72,820 | 0.1019 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Conservative | 50 | 3 | 30 | 94,924 | 0.1070 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Conservative | 50 | 3 | 30 | 94,924 | 0.1077 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Conservative | 50 | 3 | 30 | 94,924 | 0.1083 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Future | Incl | Conservative | 50 | 1.5 | 30 | 70,640 | 0.1126 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Conservative | 50 | 3 | 30 | 84,754 | 0.1128 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Conservative | 50 | 3 | 30 | 84,754 | 0.1135 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Conservative | 50 | 3 | 30 | 84,754 | 0.1142 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Conservative | 20 | 2 | 30 | 37,970 | 0.1181 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Conservative | 20 | 2 | 30 | 33,901 | 0.1247 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Conservative | 10 | 1 | 30 | 20,102 | 0.1265 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Conservative | 10 | 1 | 30 | 18,985 | 0.1298 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Conservative | 10 | 1 | 30 | 18,985 | 0.1345 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Conservative | 10 | 1 | 30 | 16,951 | 0.1374 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Conservative | 10 | 1 | 30 | 16,951 | 0.1420 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Conservative | 10 | 1 | 30 | 16,951 | 0.1427 |
| Biomass Elec | grass crops | Oahu | Waialua | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1521 |
| Solar Thermal | trough | Oahu | Lualualei | Future | Incl | Conservative | 80 | 1.5 | 30 | 137,620 | 0.1599 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Future | Incl | Conservative | 80 | 1.5 | 30 | 133,499 | 0.1721 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Future | Incl | Conservative | 80 | 1.5 | 30 | 144,487 | 0.1734 |
| Wave | | Oahu | Makapuu | Future | Incl | Conservative | 60 | 2 | 30 | 105,316 | 0.2716 |
| Wave | | Oahu | Makapuu | Future | Incl | Conservative | 30 | 2 | 30 | 52,663 | 0.2822 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Conservative | 60 | 2 | 30 | 98,372 | 0.2907 |
| OTEC | | Oahu | Kahe Point | Future | Incl | Conservative | 60 | 2 | 30 | 270,789 | 0.2997 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Conservative | 30 | 2 | 30 | 49,188 | 0.3006 |
| Wave | | Oahu | NE Coast 2A | Future | Incl | Conservative | 30 | 2 | 30 | 48,075 | 0.3078 |
| Wave | | Oahu | NE Coast 2C | Future | Incl | Conservative | 30 | 2 | 30 | 45,998 | 0.3214 |
| Wave | | Oahu | Mokapu Point | Future | Incl | Conservative | 30 | 2 | 30 | 45,087 | 0.3311 |
| Wave | | Oahu | Waimanalo Bay | Future | Incl | Conservative | 30 | 2 | 30 | 39,939 | 0.3710 |

Island(s): Oahu
Technology: All Technologies
Stage: Future Technology
Certainty: Optimistic
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost \$0.0770

RESOURCE SUPPLY CURVES




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|-------------|--------|----------------|--------|---------|------------|----|------|------|---------|--------|
| Biomass Elec | org waste | Oahu | Barber's Point | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0194 |
| Wave | | Oahu | Makapuu | Future | Incl | Optimistic | 60 | 2 | 30 | 279,377 | 0.0461 |
| Wind | | Oahu | Kaena Point | Future | Incl | Optimistic | 15 | 1 | 30 | 36,966 | 0.0470 |
| Wave | | Oahu | Makapuu | Future | Incl | Optimistic | 30 | 2 | 30 | 139,714 | 0.0478 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Optimistic | 60 | 2 | 30 | 265,253 | 0.0486 |
| Wind | | Oahu | Kahuku | Future | Incl | Optimistic | 30 | 1 | 30 | 67,029 | 0.0491 |
| Wind | | Oahu | Kahuku | Future | Incl | Optimistic | 50 | 1 | 30 | 111,268 | 0.0499 |
| Wave | | Oahu | Kahuku Point | Future | Incl | Optimistic | 30 | 2 | 30 | 132,640 | 0.0499 |
| Wind | | Oahu | Kaena Point | Future | Incl | Optimistic | 2 | 1 | 30 | 4,673 | 0.0505 |
| Wave | | Oahu | NE Coast 2A | Future | Incl | Optimistic | 30 | 2 | 30 | 129,936 | 0.0511 |
| Wave | | Oahu | NE Coast 2C | Future | Incl | Optimistic | 30 | 2 | 30 | 126,276 | 0.0525 |
| Wave | | Oahu | Mokapu Point | Future | Incl | Optimistic | 30 | 2 | 30 | 122,913 | 0.0547 |
| Wind | | Oahu | Kahuku | Future | Incl | Optimistic | 80 | 1 | 30 | 178,298 | 0.0550 |
| Wave | | Oahu | Waimanalo Bay | Future | Incl | Optimistic | 30 | 2 | 30 | 111,677 | 0.0595 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Optimistic | 50 | 3 | 30 | 128,426 | 0.0700 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Optimistic | 50 | 3 | 30 | 128,426 | 0.0704 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 50 | 3 | 30 | 128,426 | 0.0708 |
| Solar Thermal | dish | Oahu | Pearl Harbor | Future | Incl | Optimistic | 50 | 1.5 | 30 | 89,197 | 0.0719 |
| Solar Thermal | dish | Oahu | Lualualei | Future | Incl | Optimistic | 50 | 1.5 | 30 | 84,957 | 0.0735 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Optimistic | 50 | 3 | 30 | 114,667 | 0.0737 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Optimistic | 50 | 3 | 30 | 114,667 | 0.0741 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 50 | 3 | 30 | 114,667 | 0.0746 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Optimistic | 20 | 2 | 30 | 51,371 | 0.0769 |
| Solar Thermal | dish | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 50 | 1.5 | 30 | 82,414 | 0.0808 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Optimistic | 20 | 2 | 30 | 45,867 | 0.0811 |
| Biomass Elec | grass crops | Oahu | Waialua | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0830 |
| Photovoltaic | tracking | Oahu | Lualualei | Future | Incl | Optimistic | 10 | 1 | 30 | 25,685 | 0.0843 |
| Photovoltaic | tracking | Oahu | Pearl Harbor | Future | Incl | Optimistic | 10 | 1 | 30 | 25,685 | 0.0873 |
| Photovoltaic | tracking | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 10 | 1 | 30 | 25,685 | 0.0876 |
| Photovoltaic | fixed | Oahu | Lualualei | Future | Incl | Optimistic | 10 | 1 | 30 | 22,933 | 0.0891 |
| Photovoltaic | fixed | Oahu | Pearl Harbor | Future | Incl | Optimistic | 10 | 1 | 30 | 22,933 | 0.0924 |
| Photovoltaic | fixed | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 10 | 1 | 30 | 22,933 | 0.0929 |
| Solar Thermal | trough | Oahu | Lualualei | Future | Incl | Optimistic | 80 | 1.5 | 30 | 160,556 | 0.1180 |
| Solar Thermal | trough | Oahu | N. Ewa Plain | Future | Incl | Optimistic | 80 | 1.5 | 30 | 155,749 | 0.1267 |
| Solar Thermal | trough | Oahu | Pearl Harbor | Future | Incl | Optimistic | 80 | 1.5 | 30 | 168,568 | 0.1278 |
| OTEC | | Oahu | Kahe Point | Future | Incl | Optimistic | 60 | 2 | 30 | 335,543 | 0.1334 |

APPENDIX D

RESOURCE SUPPLY CURVES, ISLAND OF KAUAI

Island(s): Kauai
Technology: All_Tech
Certainty: Nominal
Stage: Current Technology
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0564



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------|--------|---------------|---------|---------|-----------|-----|------|------|---------|--------|
| Wind | | Kauai | N. Hanapepe | Current | Incl | Nominal | 10 | 1 | 30 | 18,252 | 0.0598 |
| Wind | | Kauai | Port Allen | Current | Incl | Nominal | 5 | 1 | 30 | 7,763 | 0.0696 |
| Hydro | | Kauai | Wailua River | Current | Incl | Nominal | 6.6 | 2 | 50 | 16,435 | 0.0712 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0834 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Current | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0886 |
| Wind | | Kauai | Anahola | Current | Incl | Nominal | 7 | 1 | 30 | 6,651 | 0.1210 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 1.5 | 30 | 16,428 | 0.1427 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 2 | 30 | 22,159 | 0.1533 |
| Photovoltaic | fixed | Kauai | Barking Sands | Current | Incl | Nominal | 10 | 2 | 30 | 19,785 | 0.1629 |

Island(s): Kauai
Technology: All_Tech
Certainty: Conservative
Stage: Current Technology
Trans. Cost: Cost Included


Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0564



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------|--------|---------------|---------|---------|--------------|-----|------|------|---------|--------|
| Hydro | | Kauai | Wailua River | Current | Incl | Conservative | 6.6 | 2 | 50 | 16,267 | 0.0753 |
| Wind | | Kauai | N. Hanapepe | Current | Incl | Conservative | 10 | 1 | 30 | 15,430 | 0.0774 |
| Wind | | Kauai | Port Allen | Current | Incl | Conservative | 5 | 1 | 30 | 6,519 | 0.0909 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1094 |
| Biomass Elec | tree crops | Kauai | Kaunakani | Current | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1215 |
| Wind | | Kauai | Anahola | Current | Incl | Conservative | 7 | 1 | 30 | 5,589 | 0.1552 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Conservative | 10 | 1.5 | 30 | 14,786 | 0.1691 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Conservative | 10 | 2 | 30 | 19,943 | 0.1777 |
| Photovoltaic | fixed | Kauai | Barking Sands | Current | Incl | Conservative | 10 | 2 | 30 | 17,806 | 0.1889 |

Island(s): Kauai
Technology: All_Tech
Certainty: Optimistic
Stage: Current Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0564




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------|--------|---------------|---------|---------|------------|-----|------|------|---------|--------|
| Wind | | Kauai | N. Hanapepe | Current | Incl | Optimistic | 10 | 1 | 30 | 21,296 | 0.0475 |
| Wind | | Kauai | Port Allen | Current | Incl | Optimistic | 5 | 1 | 30 | 9,111 | 0.0546 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0617 |
| Biomass Elec | tree crops | Kauai | Lihue | Current | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0622 |
| Hydro | | Kauai | Wailua River | Current | Incl | Optimistic | 6.6 | 2 | 50 | 16,770 | 0.0667 |
| Wind | | Kauai | Anahola | Current | Incl | Optimistic | 7 | 1 | 30 | 7,800 | 0.0963 |
| Photovoltaic | tracking | Kauai | Barking Sands | Current | Incl | Optimistic | 10 | 2 | 30 | 25,483 | 0.1215 |
| Solar Thermal | dish | Kauai | Barking Sands | Current | Incl | Optimistic | 10 | 1.5 | 30 | 17,250 | 0.1262 |
| Photovoltaic | fixed | Kauai | Barking Sands | Current | Incl | Optimistic | 10 | 2 | 30 | 22,752 | 0.1290 |

Island(s): Kauai
Technology: All_Tech
Certainty: Nominal
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0919

RESOURCE SUPPLY CURVES




| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------------|--------|---------------|--------|---------|-----------|-----|------|------|---------|--------|
| Wind | | Kauai | N. Hanapepe | Future | Incl | Nominal | 10 | 1 | 30 | 22,602 | 0.0529 |
| Wind | | Kauai | Port Allen | Future | Incl | Nominal | 5 | 1 | 30 | 9,321 | 0.0603 |
| Hydro | | Kauai | Wallua River | Future | Incl | Nominal | 6.6 | 2 | 50 | 16,435 | 0.0678 |
| Biomass Elec | tree & org waste | Kauai | Kaumakani | Future | Incl | Nominal | 50 | 2 | 30 | 306,600 | 0.0794 |
| Solar Thermal | dish | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 1.5 | 30 | 17,250 | 0.0878 |
| Biomass Elec | tree crops | Kauai | Lihue | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0894 |
| Biomass Elec | grass crops | Kauai | Kaumakani | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0929 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.0937 |
| Wind | | Kauai | Anahola | Future | Incl | Nominal | 7 | 1 | 30 | 8,200 | 0.0984 |
| Wave | | Kauai | Anahola | Future | Incl | Nominal | 30 | 2 | 30 | 98,947 | 0.1030 |
| Photovoltaic | tracking | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 1 | 30 | 22,962 | 0.1037 |
| Photovoltaic | fixed | Kauai | Barking Sands | Future | Incl | Nominal | 10 | 1 | 30 | 20,502 | 0.1099 |
| Wave | | Kauai | Anahola | Future | Incl | Nominal | 10 | 2 | 30 | 32,972 | 0.1189 |
| Biomass Elec | grass crops | Kauai | Lihue | Future | Incl | Nominal | 25 | 2 | 30 | 153,300 | 0.1336 |
| Wave | | Kauai | Barking Sands | Future | Incl | Nominal | 30 | 2 | 30 | 51,793 | 0.2072 |
| Wave | | Kauai | Barking Sands | Future | incl | Nominal | 10 | 2 | 30 | 17,261 | 0.2316 |

Island(s): Kauai
Technology: All_Tech
Certainty: Conservative
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0919


RESOURCE SUPPLY CURVES



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------------|--------|---------------|--------|---------|--------------|-----|------|------|---------|--------|
| Wind | | Kauai | N. Hanapepe | Future | Incl | Conservative | 10 | 1 | 30 | 19,107 | 0.0673 |
| Hydro | | Kauai | Wailua River | Future | Incl | Conservative | 6.6 | 2 | 50 | 16,267 | 0.0717 |
| Wind | | Kauai | Port Allen | Future | Incl | Conservative | 5 | 1 | 30 | 7,828 | 0.0780 |
| Solar Thermal | dish | Kauai | Barking Sands | Future | Incl | Conservative | 10 | 1.5 | 30 | 15,525 | 0.1058 |
| Biomass Elec | tree & org waste | Kauai | Kaunakani | Future | Incl | Conservative | 50 | 2 | 30 | 275,940 | 0.1078 |
| Biomass Elec | tree crops | Kauai | Lihue | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1191 |
| Biomass Elec | grass crops | Kauai | Kaunakani | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1238 |
| Biomass Elec | tree crops | Kauai | Kaunakani | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1249 |
| Wind | | Kauai | Anahola | Future | Incl | Conservative | 7 | 1 | 30 | 6,891 | 0.1264 |
| Photovoltaic | tracking | Kauai | Barking Sands | Future | Incl | Conservative | 10 | 1 | 30 | 19,518 | 0.1275 |
| Photovoltaic | fixed | Kauai | Barking Sands | Future | Incl | Conservative | 10 | 1 | 30 | 17,427 | 0.1350 |
| Biomass Elec | grass crops | Kauai | Lihue | Future | Incl | Conservative | 25 | 2 | 30 | 137,970 | 0.1781 |
| Wave | | Kauai | Anahola | Future | Incl | Conservative | 30 | 2 | 30 | 45,353 | 0.3301 |
| Wave | | Kauai | Anahola | Future | Incl | Conservative | 10 | 2 | 30 | 15,115 | 0.3792 |
| Wave | | Kauai | Barking Sands | Future | Incl | Conservative | 30 | 2 | 30 | 23,201 | 0.6812 |
| Wave | | Kauai | Barking Sands | Future | Incl | Conservative | 10 | 2 | 30 | 7,733 | 0.7639 |

Island(s): Kauai
Technology: All_Tech
Certainty: Optimistic
Stage: Future Technology
Trans. Cost: Cost Included

Valuation: Constant Dollars
Financing: Utility
Tax Credits: Included
Data: All Data from Query
Avoided Cost: \$0.0919



| Technology | Type | Island | Location | Stage | Trans\$ | Certainty | MW | Lead | Life | MWh | COE |
|---------------|------------------|--------|---------------|--------|---------|------------|-----|------|------|---------|--------|
| Wind | | Kauai | N. Hanapepe | Future | Incl | Optimistic | 10 | 1 | 30 | 26,372 | 0.0440 |
| Wind | | Kauai | Port Allen | Future | Incl | Optimistic | 5 | 1 | 30 | 10,940 | 0.0494 |
| Wave | | Kauai | Anahola | Future | Incl | Optimistic | 30 | 2 | 30 | 124,296 | 0.0548 |
| Biomass Elec | tree & org waste | Kauai | Kaumakani | Future | Incl | Optimistic | 50 | 2 | 30 | 337,260 | 0.0561 |
| Wave | | Kauai | Anahola | Future | Incl | Optimistic | 10 | 2 | 30 | 41,417 | 0.0634 |
| Hydro | | Kauai | Wailua River | Future | Incl | Optimistic | 6.6 | 2 | 50 | 16,770 | 0.0635 |
| Biomass Elec | tree crops | Kauai | Lihue | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0650 |
| Biomass Elec | grass crops | Kauai | Kaumakani | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0675 |
| Biomass Elec | tree crops | Kauai | Kaumakani | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0681 |
| Solar Thermal | dish | Kauai | Barking Sands | Future | Incl | Optimistic | 10 | 1.5 | 30 | 18,112 | 0.0762 |
| Wind | | Kauai | Anahola | Future | Incl | Optimistic | 7 | 1 | 30 | 9,618 | 0.0803 |
| Photovoltaic | tracking | Kauai | Barking Sands | Future | Incl | Optimistic | 10 | 1 | 30 | 26,407 | 0.0828 |
| Photovoltaic | fixed | Kauai | Barking Sands | Future | Incl | Optimistic | 10 | 1 | 30 | 23,577 | 0.0876 |
| Biomass Elec | grass crops | Kauai | Lihue | Future | Incl | Optimistic | 25 | 2 | 30 | 168,630 | 0.0972 |
| Wave | | Kauai | Barking Sands | Future | Incl | Optimistic | 30 | 2 | 30 | 71,415 | 0.0996 |
| Wave | | Kauai | Barking Sands | Future | Incl | Optimistic | 10 | 2 | 30 | 23,800 | 0.1102 |

APPENDIX E

TIME-OF-DAY PRICING SUMMARIES

Energy Payment Comparison - Island of Hawaii

| Technology | Type | Location | Project Capacity (MW) | Payment - 2005 | | Daily Energy (MWh) | Annual Sales | | Time of Day Pricing Advantage |
|---------------|----------|----------------|-----------------------|------------------|----------------------|--------------------|------------------|----------------------|-------------------------------|
| | | | | Average (\$/kWh) | Time of Day (\$/kWh) | | Based on Average | Based on Time of Day | |
| Photovoltaic | tracking | Keahole | 30 | \$0.0906 | \$0.0972 | 225.9 | \$7,470,642 | \$8,013,100 | \$542,458 |
| Photovoltaic | fixed | Keahole | 30 | \$0.0906 | \$0.0973 | 182.3 | \$6,028,753 | \$6,475,856 | \$447,102 |
| Photovoltaic | tracking | Keahole | 50 | \$0.0906 | \$0.0972 | 376.5 | \$12,451,070 | \$13,355,167 | \$904,096 |
| Photovoltaic | fixed | Keahole | 50 | \$0.0906 | \$0.0973 | 303.8 | \$10,047,922 | \$10,793,093 | \$745,170 |
| Photovoltaic | tracking | N. Kohala | 5 | \$0.0906 | \$0.0973 | 34.3 | \$1,133,429 | \$1,217,003 | \$83,574 |
| Photovoltaic | fixed | N. Kohala | 5 | \$0.0906 | \$0.0973 | 29.0 | \$957,843 | \$1,028,803 | \$70,959 |
| Photovoltaic | tracking | N. Kohala | 15 | \$0.0906 | \$0.0973 | 102.8 | \$3,400,287 | \$3,651,010 | \$250,723 |
| Photovoltaic | fixed | N. Kohala | 15 | \$0.0906 | \$0.0973 | 86.9 | \$2,873,530 | \$3,086,409 | \$212,878 |
| Photovoltaic | tracking | Waikoloa | 30 | \$0.0906 | \$0.0972 | 225.9 | \$7,470,642 | \$8,013,100 | \$542,458 |
| Photovoltaic | fixed | Waikoloa | 30 | \$0.0906 | \$0.0973 | 182.3 | \$6,028,753 | \$6,475,856 | \$447,102 |
| Photovoltaic | tracking | Waikoloa | 50 | \$0.0906 | \$0.0972 | 376.5 | \$12,451,070 | \$13,355,167 | \$904,096 |
| Photovoltaic | fixed | Waikoloa | 50 | \$0.0906 | \$0.0973 | 303.8 | \$10,047,922 | \$10,793,093 | \$745,170 |
| Solar Thermal | dish | Keahole | 30 | \$0.0906 | \$0.0973 | 150.8 | \$4,986,958 | \$5,356,638 | \$369,679 |
| Solar Thermal | trough | Keahole | 30 | \$0.0906 | \$0.0973 | 176.4 | \$5,834,752 | \$6,268,308 | \$433,555 |
| Solar Thermal | dish | N. Kohala | 5 | \$0.0906 | \$0.0973 | 27.1 | \$896,725 | \$963,380 | \$66,655 |
| Solar Thermal | dish | N. Kohala | 15 | \$0.0906 | \$0.0973 | 80.5 | \$2,663,183 | \$2,861,142 | \$197,959 |
| Solar Thermal | dish | Waikoloa | 30 | \$0.0906 | \$0.0973 | 146.9 | \$4,857,058 | \$5,217,107 | \$360,050 |
| Solar Thermal | trough | Waikoloa | 30 | \$0.0906 | \$0.0973 | 171.8 | \$5,682,385 | \$6,104,619 | \$422,234 |
| Wave | | Honokaa 2A | 10 | \$0.0906 | \$0.0905 | 92.0 | \$3,043,067 | \$3,041,298 | (\$1,769) |
| Wave | | N. Kohala | 10 | \$0.0906 | \$0.0905 | 84.9 | \$2,808,491 | \$2,806,858 | (\$1,633) |
| Wave | | N. Kohala | 30 | \$0.0906 | \$0.0905 | 254.8 | \$8,427,373 | \$8,422,474 | (\$4,900) |
| Wave | | Pepeekeo 2E | 10 | \$0.0906 | \$0.0905 | 88.7 | \$2,932,343 | \$2,930,638 | (\$1,705) |
| Wind | | Kahua Ranch | 5 | \$0.0906 | \$0.0906 | 35.0 | \$1,155,848 | \$1,155,855 | \$7 |
| Wind | | Kahua Ranch | 15 | \$0.0906 | \$0.0906 | 105.2 | \$3,478,068 | \$3,478,090 | \$22 |
| Wind | | Lalamilo Wells | 3 | \$0.0906 | \$0.0908 | 35.4 | \$1,171,988 | \$1,173,940 | \$1,952 |
| Wind | | Lalamilo Wells | 30 | \$0.0906 | \$0.0908 | 316.6 | \$10,469,370 | \$10,486,808 | \$17,438 |
| Wind | | Lalamilo Wells | 50 | \$0.0906 | \$0.0908 | 525.5 | \$17,379,153 | \$17,408,101 | \$28,948 |
| Wind | | N. Kohala | 5 | \$0.0906 | \$0.0915 | 61.0 | \$2,016,019 | \$2,036,235 | \$20,217 |
| Wind | | N. Kohala | 15 | \$0.0906 | \$0.0915 | 194.8 | \$6,440,754 | \$6,505,343 | \$64,589 |

Energy Payment Comparison - Island of Maui

| Technology | Type | Location | Project Capacity (MW) | Payment - 2005 | | Daily Energy (MWh) | Annual Sales | | Time of Day Pricing Advantage |
|---------------|----------|----------------|-----------------------|------------------|----------------------|--------------------|------------------|----------------------|-------------------------------|
| | | | | Average (\$/MWh) | Time of Day (\$/MWh) | | Based on Average | Based on Time of Day | |
| Photovoltaic | tracking | Kahului | 10 | 0.0984 | 0.1012 | 70.5 | \$2,531,644 | \$2,605,644 | \$74,000 |
| Photovoltaic | fixed | Kahului | 10 | 0.0984 | 0.1013 | 58.2 | \$2,090,056 | \$2,151,903 | \$61,846 |
| Photovoltaic | tracking | Kahului | 30 | 0.0984 | 0.1012 | 211.5 | \$7,594,931 | \$7,816,931 | \$222,000 |
| Photovoltaic | fixed | Kahului | 30 | 0.0984 | 0.1013 | 174.6 | \$6,270,169 | \$6,455,708 | \$185,539 |
| Photovoltaic | tracking | Kihel | 10 | 0.0984 | 0.1012 | 71.1 | \$2,554,129 | \$2,628,180 | \$74,051 |
| Photovoltaic | fixed | Kihel | 10 | 0.0984 | 0.1013 | 58.0 | \$2,082,663 | \$2,144,227 | \$61,563 |
| Photovoltaic | tracking | Kihel | 30 | 0.0984 | 0.1012 | 213.4 | \$7,662,386 | \$7,884,540 | \$222,153 |
| Photovoltaic | fixed | Kihel | 30 | 0.0984 | 0.1013 | 174.0 | \$6,247,989 | \$6,432,680 | \$184,690 |
| Photovoltaic | tracking | Puunene | 10 | 0.0984 | 0.1012 | 70.5 | \$2,531,644 | \$2,605,644 | \$74,000 |
| Photovoltaic | fixed | Puunene | 10 | 0.0984 | 0.1013 | 58.2 | \$2,090,056 | \$2,151,903 | \$61,846 |
| Photovoltaic | tracking | Puunene | 30 | 0.0984 | 0.1012 | 211.5 | \$7,594,931 | \$7,816,931 | \$222,000 |
| Photovoltaic | fixed | Puunene | 30 | 0.0984 | 0.1013 | 174.6 | \$6,270,169 | \$6,455,708 | \$185,539 |
| Solar Thermal | dish | Kahului | 10 | 0.0984 | 0.1013 | 43.6 | \$1,567,176 | \$1,613,663 | \$46,487 |
| Solar Thermal | dish | Kahului | 30 | 0.0984 | 0.1013 | 129.6 | \$4,654,331 | \$4,792,391 | \$138,060 |
| Solar Thermal | trough | Kahului | 30 | 0.0984 | 0.1013 | 151.6 | \$5,444,627 | \$5,606,153 | \$161,526 |
| Solar Thermal | dish | Kihel | 10 | 0.0984 | 0.1013 | 46.3 | \$1,664,050 | \$1,713,389 | \$49,339 |
| Solar Thermal | dish | Kihel | 30 | 0.0984 | 0.1013 | 137.6 | \$4,941,931 | \$5,088,458 | \$146,527 |
| Solar Thermal | trough | Kihel | 30 | 0.0984 | 0.1013 | 161.0 | \$5,780,297 | \$5,951,781 | \$171,484 |
| Solar Thermal | dish | Puunene | 10 | 0.0984 | 0.1013 | 45.0 | \$1,615,555 | \$1,663,476 | \$47,922 |
| Solar Thermal | dish | Puunene | 30 | 0.0984 | 0.1013 | 133.6 | \$4,797,715 | \$4,940,028 | \$142,313 |
| Solar Thermal | dish | Puunene | 30 | 0.0984 | 0.1013 | 156.3 | \$5,613,042 | \$5,779,565 | \$166,522 |
| Solar Thermal | trough | Lower Pala | 10 | 0.0984 | 0.0983 | 93.0 | \$3,340,807 | \$3,340,032 | (\$775) |
| Wave | | Lower Pala | 30 | 0.0984 | 0.0983 | 279.2 | \$10,026,058 | \$10,023,732 | (\$2,327) |
| Wave | | Lower Pala | 60 | 0.0984 | 0.0983 | 558.4 | \$20,049,954 | \$20,045,301 | (\$4,653) |
| Wave | | Opana Point | 10 | 0.0984 | 0.0983 | 96.7 | \$3,471,935 | \$3,471,129 | (\$806) |
| Wave | | Opana Point | 30 | 0.0984 | 0.0983 | 290.2 | \$10,419,835 | \$10,417,417 | (\$2,418) |
| Wave | | Opana Point | 60 | 0.0984 | 0.0983 | 580.4 | \$20,837,310 | \$20,832,475 | (\$4,835) |
| Wave | | Waiehu Pt. | 10 | 0.0984 | 0.0983 | 92.4 | \$3,315,840 | \$3,315,070 | (\$769) |
| Wave | | Waiehu Pt. | 30 | 0.0984 | 0.0983 | 277.2 | \$9,953,122 | \$9,950,813 | (\$2,310) |
| Wind | | McGregor Point | 10 | 0.0984 | 0.0998 | 67.3 | \$2,415,326 | \$2,449,470 | \$34,144 |
| Wind | | NW Haleakala | 10 | 0.0984 | 0.0998 | 58.0 | \$2,080,853 | \$2,111,792 | \$30,939 |
| Wind | | NW Haleakala | 30 | 0.0984 | 0.0998 | 153.5 | \$5,509,761 | \$5,591,682 | \$81,922 |
| Wind | | NW Haleakala | 50 | 0.0984 | 0.0998 | 254.7 | \$9,146,203 | \$9,282,193 | \$135,990 |
| Wind | | Puunene | 10 | 0.0984 | 0.0998 | 43.1 | \$1,547,524 | \$1,569,465 | \$21,941 |
| Wind | | Puunene | 30 | 0.0984 | 0.0998 | 123.2 | \$4,425,185 | \$4,487,926 | \$62,741 |
| Wind | | West Maui | 10 | 0.0984 | 0.0985 | 52.6 | \$1,889,824 | \$1,892,648 | \$2,824 |
| Wind | | West Maui | 30 | 0.0984 | 0.0985 | 159.5 | \$5,726,740 | \$5,735,298 | \$8,559 |
| Wind | | West Maui | 50 | 0.0984 | 0.0985 | 264.8 | \$9,506,388 | \$9,520,595 | \$14,208 |

Energy Payment Comparison - Island of Oahu

| Technology | Type | Location | Project Capacity (MW) | Payment - 2005 | | Daily Energy (MWh) | Annual Sales | | Time of Day Pricing Advantage |
|---------------|----------|---------------|-----------------------|------------------|----------------------|--------------------|------------------|----------------------|-------------------------------|
| | | | | Average (\$/kWh) | Time of Day (\$/kWh) | | Based on Average | Based on Time of Day | |
| Photovoltaic | tracking | Luaiualei | 10 | \$0.0770 | \$0.0845 | 65.7 | \$1,848,388 | \$2,028,398 | \$180,010 |
| Photovoltaic | fixed | Luaiualei | 10 | \$0.0770 | \$0.0846 | 54.6 | \$1,535,656 | \$1,685,984 | \$150,328 |
| Photovoltaic | tracking | Luaiualei | 20 | \$0.0770 | \$0.0845 | 131.5 | \$3,696,776 | \$4,056,797 | \$360,020 |
| Photovoltaic | fixed | Luaiualei | 20 | \$0.0770 | \$0.0846 | 109.2 | \$3,071,313 | \$3,371,968 | \$300,655 |
| Photovoltaic | tracking | Luaiualei | 50 | \$0.0770 | \$0.0845 | 328.7 | \$9,241,940 | \$10,141,992 | \$900,051 |
| Photovoltaic | fixed | Luaiualei | 50 | \$0.0770 | \$0.0846 | 273.1 | \$7,678,282 | \$8,429,919 | \$751,638 |
| Photovoltaic | tracking | N. Ewa Plain | 10 | \$0.0770 | \$0.0845 | 65.7 | \$1,848,388 | \$2,028,398 | \$180,010 |
| Photovoltaic | fixed | N. Ewa Plain | 10 | \$0.0770 | \$0.0846 | 54.6 | \$1,535,656 | \$1,685,984 | \$150,328 |
| Photovoltaic | tracking | N. Ewa Plain | 50 | \$0.0770 | \$0.0845 | 328.7 | \$9,241,940 | \$10,141,992 | \$900,051 |
| Photovoltaic | fixed | N. Ewa Plain | 50 | \$0.0770 | \$0.0846 | 273.1 | \$7,678,282 | \$8,429,919 | \$751,638 |
| Photovoltaic | tracking | Pearl Harbor | 10 | \$0.0770 | \$0.0845 | 65.7 | \$1,848,388 | \$2,028,398 | \$180,010 |
| Photovoltaic | fixed | Pearl Harbor | 10 | \$0.0770 | \$0.0846 | 54.6 | \$1,535,656 | \$1,685,984 | \$150,328 |
| Photovoltaic | tracking | Pearl Harbor | 50 | \$0.0770 | \$0.0845 | 328.7 | \$9,241,940 | \$10,141,992 | \$900,051 |
| Photovoltaic | fixed | Pearl Harbor | 50 | \$0.0770 | \$0.0846 | 273.1 | \$7,678,282 | \$8,429,919 | \$751,638 |
| Solar Thermal | dish | Luaiualei | 50 | \$0.0770 | \$0.0846 | 221.6 | \$6,231,028 | \$6,842,393 | \$611,365 |
| Solar Thermal | trough | Luaiualei | 80 | \$0.0770 | \$0.0846 | 418.8 | \$11,774,247 | \$12,929,492 | \$1,155,245 |
| Solar Thermal | dish | N. Ewa Plain | 50 | \$0.0770 | \$0.0846 | 215.0 | \$6,044,432 | \$6,637,490 | \$593,057 |
| Solar Thermal | trough | N. Ewa Plain | 80 | \$0.0770 | \$0.0846 | 406.3 | \$11,421,738 | \$12,542,396 | \$1,120,658 |
| Solar Thermal | dish | Pearl Harbor | 50 | \$0.0770 | \$0.0846 | 232.7 | \$6,541,361 | \$7,183,175 | \$641,814 |
| Solar Thermal | trough | Pearl Harbor | 80 | \$0.0770 | \$0.0846 | 439.7 | \$12,360,730 | \$13,573,518 | \$1,212,789 |
| Wave | | Kahuku Pt. | 30 | \$0.0770 | \$0.0770 | 289.1 | \$8,128,786 | \$8,122,547 | (\$6,239) |
| Wave | | Kahuku Pt. | 60 | \$0.0770 | \$0.0770 | 578.2 | \$16,256,109 | \$16,243,633 | (\$12,476) |
| Wave | | Makapuu | 30 | \$0.0770 | \$0.0770 | 307.2 | \$8,636,797 | \$8,630,168 | (\$6,628) |
| Wave | | Makapuu | 60 | \$0.0770 | \$0.0770 | 614.3 | \$17,270,668 | \$17,257,414 | (\$13,255) |
| Wave | | Makapu Pt. | 30 | \$0.0770 | \$0.0770 | 268.2 | \$7,540,571 | \$7,534,784 | (\$5,787) |
| Wave | | NE Coast 2A | 30 | \$0.0770 | \$0.0770 | 283.9 | \$7,982,233 | \$7,976,107 | (\$6,126) |
| Wave | | NE Coast 2C | 30 | \$0.0770 | \$0.0770 | 278.8 | \$7,838,065 | \$7,832,050 | (\$6,015) |
| Wave | | Waimanalo Bay | 30 | \$0.0770 | \$0.0770 | 243.5 | \$6,847,137 | \$6,841,882 | (\$5,255) |
| Wind | | Kaena Point | 2 | \$0.0770 | \$0.0793 | 10.9 | \$307,419 | \$316,516 | \$9,097 |
| Wind | | Kaena Point | 15 | \$0.0770 | \$0.0793 | 86.2 | \$2,423,518 | \$2,495,237 | \$71,719 |
| Wind | | Kahuku | 30 | \$0.0770 | \$0.0782 | 155.2 | \$4,362,192 | \$4,428,411 | \$66,218 |
| Wind | | Kahuku | 50 | \$0.0770 | \$0.0782 | 257.6 | \$7,241,240 | \$7,351,162 | \$109,922 |
| Wind | | Kahuku | 80 | \$0.0770 | \$0.0782 | 412.7 | \$11,603,432 | \$11,779,572 | \$176,140 |

Energy Payment Comparison - Island of Kauai

| Technology | Type | Location | Project Capacity (MW) | Payment - 2005 | | Daily Energy (MWh) | Annual Sales | | Time of Day Pricing Advantage |
|---------------|----------|---------------|-----------------------|------------------|----------------------|--------------------|------------------|----------------------|-------------------------------|
| | | | | Average (\$/KWh) | Time of Day (\$/KWh) | | Based on Average | Based on Time of Day | |
| Photovoltaic | tracking | Barking Sands | 10 | \$0.0919 | \$0.0928 | 69.0 | \$2,312,735 | \$2,337,075 | \$24,340 |
| Photovoltaic | fixed | Barking Sands | 10 | \$0.0919 | \$0.0928 | 56.1 | \$1,882,487 | \$1,902,388 | \$19,901 |
| Solar Thermal | dish | Barking Sands | 10 | \$0.0919 | \$0.0928 | 47.2 | \$1,581,112 | \$1,597,853 | \$16,741 |
| Wave | | Anahola | 10 | \$0.0919 | \$0.0919 | 90.3 | \$3,027,038 | \$3,026,788 | (\$251) |
| Wave | | Anahola | 30 | \$0.0919 | \$0.0919 | 270.9 | \$9,083,961 | \$9,083,209 | (\$752) |
| Wave | | Barking Sands | 10 | \$0.0919 | \$0.0919 | 47.3 | \$1,584,669 | \$1,584,538 | (\$131) |
| Wave | | Barking Sands | 30 | \$0.0919 | \$0.0919 | 141.8 | \$4,754,925 | \$4,754,532 | (\$394) |
| Wind | | Anahola | 7 | \$0.0919 | \$0.0920 | 22.4 | \$751,947 | \$752,908 | \$961 |
| Wind | | N. Hanapepe | 10 | \$0.0919 | \$0.0919 | 61.8 | \$2,071,519 | \$2,071,464 | (\$55) |
| Wind | | Port Allen | 5 | \$0.0919 | \$0.0923 | 27.1 | \$910,300 | \$914,616 | \$4,316 |

APPENDIX F

CASE STUDIES FOR SMALL-SCALE APPLICATIONS

Photovoltaics in Dispersed Utility Applications
Photovoltaics in Off-Grid Applications
Small-Scale Wind-Electric Applications
Domestic Solar Water Heating
Solar Desalination/Distillation
Solar Thermal Industrial Heat
Ocean Thermal Resource Applications

PHOTOVOLTAICS IN DISPERSED UTILITY APPLICATIONS

Photovoltaic (PV) technology can be used by utilities to reduce their peak demand during certain hours or times of year, or to defer the costs associated with transmission line upgrades in areas where the power transmission lines are near capacity and slow steady load growth is expected. In either case, the system consists of PV panels, storage batteries, and power inverters connected to the utility power system.

To reduce peak power demand, PV technology can be used as a demand side measure. On a residential scale this can be accomplished without the need for battery storage by utilizing PV generated power on an as-available basis on the customer's side of the utility meter. The customer realizes a benefit through reduced electricity usage and in areas where the daily peak demand corresponds well with PV output the utility benefits through a reduction in the peak system load. With consumer owned systems the investment can be reduced according to State and Federal tax credits, and implementation can be encouraged through utility participation up to the value of the load reduction evaluated by the utility.

In commercial sized systems, battery capacity and controls can be included to reduce the utility peak load as well as the customer's demand charge. The PV panels are used to charge a battery bank, when the battery is full, the system operates much like the residential measure described above. Using the control system, the battery can be made to discharge supplemented by the available power from the PV panels to achieve as much as 150% of the PV rated capacity. The customer can choose the time of day at which the discharge will occur according to their usage or may even contract with the utility for power delivery during certain times of the year. Reducing demand charges can have a significant impact on utility bills, and the power on demand provides additional security for the utility.

Other US utilities have also shown that larger PV/battery systems can be used to support existing utility power distribution networks. Such systems have been evaluated to recognize their value to the utility in terms of their capacity value, energy value, deferral of distribution upgrades, reduction of system losses, increased reliability, and others. Locations where these types of projects can be favorably implemented would normally exhibit one or more of the following characteristics: planned transmission and distribution investments, small substations, summer peaking loads, slow feeder load growth, and available and inexpensive land.

COST AND PERFORMANCE

| <i>Criteria</i> | <i>PV-DSM Residential</i> | <i>PV-DSM Commercial</i> | <i>Utility Grid Support</i> |
|-----------------------|---------------------------|--------------------------|-----------------------------|
| Capital Cost (\$/kW): | | | |
| 1995 | 6,000 - 7,000 | 7,800 | 5,200 - 6,500 |
| 2005 | 3,500 - 4,500 | 5,650 | 3,200 - 4,000 |
| Operating Cost: | | | |
| fixed (\$/kW-yr) | 15.00 - 19.20 | 15.00 - 19.20 | 2.50 - 4.00 |
| variable (\$/MWh) | 2.00 - 3.00 | 2.00 - 3.00 | 1.00 - 1.50 |
| Capacity Factor: | 20 - 25% | 20 - 25% | 25 - 26% |

REFERENCES

1. *Grid Support Photovoltaics: Summary of Case Studies*, Freeman, Sullivan & Co. August 25, 1994.
2. *The Value of Distributed PV Systems in Today's Electric Utilities*, Bigger, J. and W., Solar Industry Journal. Third Quarter 1992.

3. *Commercial Building Demand Side Management Tools: Requirements for Dispatchable Photovoltaic Systems*, Byrne, J. et al., Proceedings of the 23rd IEE PV Specialist Conference in Louisville, Kentucky. May 1993.
4. *PV DSM as a Green Investment Strategy*, Byrne, J. et al., Proceedings of the 5th National Conference on Integrated Resource Planning. May 1994.
5. Pacific Energy Group.

PHOTOVOLTAICS IN OFF-GRID APPLICATIONS

Photovoltaics (PV) are often used for applications where utility power access is not available and low service requirements are highly desirable such as remote residences, radio repeater stations, or highway sign lighting. The systems consist of PV panels, batteries, wiring, and varying degrees of monitoring and safety devices. There are no moving parts and very little maintenance is required.

The first step in sizing a residential system generally begins with reducing the demand through conservation measures or identifying alternative sources for the desired service. This most important step greatly reduces the cost of the PV system. The number of PV panels required and the size of the battery bank are directly related to the anticipated energy requirement.

Usually PV applications are compared against other methods of remote power (such as diesel-generator sets) or utility power line extensions. In fact, several utilities in the US have programs for providing utility power to remote residences with photovoltaic power systems when doing so is determined to be more cost effective than a line extension. State and Federal Tax Credits are applicable for certain ownership/application combinations.

COST AND PERFORMANCE

| <i>Criteria</i> | <i>Value</i> |
|--------------------------------------------------------------|--------------|
| Capital Cost: | |
| PV Panels (\$/watt) | 6.00 |
| Batteries (\$/amp-hour; 12 V) | 1.00 |
| Wiring & Other Equipment | 20% of above |
| Replacement Batteries every 4-8 years (\$/amp-hour; 12 V) | 1.00 |
| Operating Cost: | minimal |

REFERENCES

1. *Evaluating Photovoltaic Applications - A Guide for Utilities*. Stevens, J. et al., Sandia National Laboratories. 1990.

SMALL SCALE WIND-ELECTRIC APPLICATIONS

Small wind turbines can be used for a variety of applications involving electrical uses such as water pumping and battery charging. Models are available in a number of different configurations and sizes ranging from very small up to 7 meters in rotor diameter. Systems would always include a wind turbine and tower, a control device, as well as the necessary wiring and safety equipment and may include batteries, inverters, pumps, or other end use equipment.

In the very smallest of systems (used for marine applications), the tower may take the form of a firmly fixed post, but small wind turbine towers are more commonly found as guyed poles, or free-standing truss towers.

Examples of small scale wind-electric applications include water pumping for irrigation, drinking water, or aquaculture, and battery charging for cathodic protection, remote residences, and communication equipment. While cost and performance will vary widely depending on the application, and system size, typical values are given in the table below.

COST AND PERFORMANCE

| <i>Criteria</i> | <i>Stand-Alone Wind Electric</i> | <i>Wind Electric Water Pumping</i> |
|---------------------------------------------|----------------------------------|------------------------------------|
| Capital Cost (\$/kW): | 3,000 - 4,000 | 3,500 - 7,500 |
| Replacement Costs (\$/kW, every 4-8 yrs) | 800 - 1,400 | 250 - 500 |
| Operating Cost (\$/yr): | 50 - 125 | 50 - 125 |
| Performance: | 20 - 40% Capacity Factor | 10 - 25 m ³ /kw-day* |

* average daily water delivery assuming 20m total dynamic head and 5.5 m/s average wind speed

REFERENCES

1. *Wind Power for Home and Business: Renewable Energy for the 1990s and Beyond*, Gipe, P. 1993.

DOMESTIC SOLAR WATER HEATING

Solar domestic hot water heaters are common throughout the state. The solar hot water heating system consists of a solar collector, a storage tank, a thermostat, and electric heating coils for back-up power. Various state and federal tax credits are available for solar hot water heaters depending on whether the unit is for a single family residence, multiple unit building, or for a commercial building. The initial cost of a solar hot water heater is high when compared to a traditional electric hot water heater.

One measure that has been used by other US utilities to promote solar hot water heating as a demand side measure is to provide financing up to a fixed total amount per unit that would allow the customer a combination of energy and loan payments that are lower than their current water heating costs. This kind of a measure not only eases the customer's cost, and provides the utility with a cost effective demand-side management measure, but provides a control mechanism on the market price of solar hot water heaters.

Of course, the solar water heater only provides savings to the customer and the utility if it continues to function properly. A low cost inspection and maintenance program would ensure satisfactory results for both the utility and its customers.

COST AND PERFORMANCE

| <i>Criteria</i> | <i>Value</i> |
|--------------------------|---------------|
| Capital Cost (\$): | 3,500 - 4,000 |
| Operating Cost (\$/yr): | 30 - 50 |
| Energy Savings (kWh/yr): | 3,400 - 3,600 |

REFERENCES

1. Cliff Murley, Sacramento Municipal Utility District, Solar Water Heating Programs.
2. Pacific Energy Group.

SOLAR DESALINATION / DISTILLATION

Depending on the amount of pure water desired, there are a variety of renewable energy technologies that can be used. For very small water demands the simplest is direct solar distillation of water. Larger centralized systems may use direct solar techniques, reverse osmosis using electrical power input from renewable energy sources, or may stand alone as in the case of an ocean thermal energy conversion facility operated to produce fresh water

Cost and performance information is given below for one small scale system (residential drinking water) utilizing a simple and proven technology that could be implemented with no additional load to the electric utility system.

COST AND PERFORMANCE

| <i>Criteria</i> | <i>Solar Distillation</i> |
|-----------------------|---------------------------|
| Capital Cost (\$): | 350.00 |
| Operating Cost: | |
| fixed (\$/yr) | minimal |
| variable (\$/gal) | minimal |
| Performance (gal/yr): | 730 |

REFERENCES

1. McCracken Solar Company, Alturas, California.

SOLAR THERMAL INDUSTRIAL HEAT

Among a variety of methods for converting solar energy to useful heat, solar thermal parabolic troughs can supply heat at temperatures of 100 - 350°C for a variety of industrial processes such as food processing, although current utilization of this technology is not widespread. The system consists of reflective parabolic troughs which track the path of the sun and concentrate the rays on a working fluid in an insulated collector tube, and heat exchangers to transfer the heat to the industrial process system as required. Depending on the application, a backup source of heat may also be utilized.

Current heating applications are more likely to be cogeneration or fuel based, so rather than displacing electricity, solar industrial heat systems would offset fuel consumption. Solar thermal industrial heat systems have been shown to be cost effective when compared to mainland uses of natural gas, and may be even more competitive with alternatives in Hawaii.

COST AND PERFORMANCE

| <i>Criteria</i> | <i>Current</i> | <i>Future</i> |
|------------------------------------------------------|----------------|---------------|
| Capital Cost (\$/m ²): | 237 | 250 |
| Operating Cost (\$/m ² /yr): | 2.40 | 2.4 |
| Replacement Costs (\$/m ² , every 5 yrs): | 21.00 | 21.00 |
| Energy Savings (MBTU/m ² /yr): | 2.20 - 2.75 | 3.60 - 4.30 |

REFERENCES

1. *Economic Status and Prospects of Solar Thermal Industrial Heat*, Williams, T. and M. Hale, National Renewable Energy Laboratory. December 1992.

ALTERNATIVE OCEAN THERMAL RESOURCE APPLICATIONS

DESALINATION

In the open-cycle OTEC process, a small fraction of the warm water stream is vaporized or "flashed" under a partial vacuum. Flow of this water vapor towards the condenser is used to drive a low-pressure steam turbine. After exiting the turbine, the water vapor is condensed in a thin-walled plate heat exchanger by cold deep ocean water, and the condensate is collected as marketable fresh water. Cost and performance data for an open-cycle OTEC plant optimized for fresh water production are based on a 1992 paper by Luis Vega of the Pacific International Center for High Technology Research (PICHTR; Reference 1). This is a land-based plant with two condenser stages, having a net power output of 9 MWe and a fresh water production capacity of 35,000 m³/day. Cost and performance data are summarized in Table 1. Also presented in Table 1 are similar data for a conventional desalination plant using reverse osmosis (RO) technology. These data are based on a 1991 paper by Gordon Leitner (Reference 2), which describes the Las Palmas III RO plant in the Canary Islands.

Table 1. Desalination Cost and Performance Data

| Characteristic | Open-cycle OTEC | Conventional RO |
|---------------------------------------|----------------------------------------------------------|-------------------------------|
| Project location | unspecified site with $\Delta T = 20^{\circ}\text{C}$ | Las Palmas, Canary Islands |
| Fresh water production capacity | 35,000 m ³ /day | 36,000 m ³ /day |
| Capital cost | \$132,300,000 | \$55,000,000 |
| Non-energy O&M cost | \$1,984,500 | \$1,988,000 |
| Energy consumption per unit output | none | 5.8 kWh/m ³ |
| Energy production per unit output | 6.0 kWh/m ³ | none |
| Annual fresh water output | 10,500,000 m ³ | 10,200,000 m ³ |
| Annual energy consumption | none | 59,200 MWh |
| Annual energy production | 63,000 MWh | none |

Based on the data in Table 1, the levelized cost of energy (in constant dollars) at which fresh water from the open-cycle OTEC plant becomes economically competitive with that produced by a conventional reverse osmosis (RO) plant is estimated to be 6.5¢/kWh. This assumes a 20-year service life and 80% utilization factor for both plants, with all financial parameters the same as those used for utility financing of the electric power generating projects in the main body of the report.

DISTRICT COOLING

Deep cold ocean water can be used to provide district cooling for commercial building developments. The ocean water is passed through a heat exchanger, chilling fresh water on the other side of the heat exchanger plates. The deep naturally cold ocean water replaces conventional refrigeration equipment, which has much higher peak power and contributes substantially to the evening peak in the daily utility load profile. The deep seawater pumps have a much lower energy requirement and represent a continual rather than peaked load.

Cost and performance data for deep seawater and conventional district cooling systems are presented in Table 2, taken from a 1994 report prepared by Makai Ocean Engineering for the State of Hawaii (Reference 3). Data are presented for two system cooling loads: 2,500 tons and 5,300 tons (note that one ton of cooling represents a heat removal rate of 200 BTU per minute or 0.288 MBTU/day).

Table 2. District Cooling Cost and Performance Data

| Cooling Load | 2,500 tons | | 5,300 tons | |
|---------------------------|-------------------|-------------------|-------------------|-------------------|
| | Deep SW | Conventional | Deep SW | Conventional |
| Capital cost | \$10,577,000 | \$4,688,000 | \$16,253,000 | \$9,938,000 |
| Non-energy O&M cost | \$477,400 | \$395,000 | \$786,300 | \$879,000 |
| Unit energy consumption | 12.3 kWh per MBTU | 70.8 kWh per MBTU | 14.8 kWh per MBTU | 70.8 kWh per MBTU |
| Total annual heat removed | 157,680 MBTU | 157,680 MBTU | 334,280 MBTU | 334,280 MBTU |
| Annual energy consumption | 1,940 MWh | 11,160 MWh | 4,950 MWh | 23,670 MWh |

Based on the data in Table 2, the levelized cost of energy (in constant dollars) at which deep sea water district cooling becomes economically competitive with a conventional chiller system is estimated to be 7.9¢/kWh for the 2,500-ton load and 3.2 ¢/kWh for the 5,300-ton load. This assumes a 20-year service life and 60% utilization factor for both types of district cooling, with all financial parameters the same as those used for utility financing of the electric power generating projects in the main body of the report.

There are three potential locations for deep seawater district cooling projects in Hawaii: two larger systems (each approximately 10,000 tons) at West Beach, Oahu, and Kailua-Kona on the Big Island; and a smaller system (approximately 5,000 tons) on southern Kauai. Although the ability to develop projects in these areas would depend on anticipated load growth, local hotel owners expressed an interest and willingness to participate in such a system.

REFERENCES

1. Vega, L.A., 1992. Economics of ocean thermal energy conversion (OTEC). In *Ocean Energy Recovery: The State of the Art*, edited by R.J. Seymour, pp. 152-181. New York, New York: American Society of Civil Engineers.
2. Leitner, G.F., 1991. Total water costs on a standard basis for three large, operating, S.W.R.O. plants. *Desalination*, Vol. 81, pp. 39-48.
3. Makai Ocean Engineering, 1994. *Preliminary State Wide Assessment of Seawater Air Conditioning for Hawaii. Phase I: West Beach, Oahu*. Honolulu, Hawaii: Energy Division, Department of Business, Economic Development and Tourism.