

Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road
Waterford, CT 06385



DominionSM

Re:10 CFR 2.202

February 28, 2003

Secretary, Office of the Secretary of the Commission
U.S. Nuclear Regulatory Commission
ATTN: Rulemakings and Adjudications Staff
Washington, D.C. 20555

Serial No.: B18849
NL&OS/ETS
Docket No: 50-336
License No.:DPR-65

DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNIT 2
ANSWER TO ORDER FOR INTERIM INSPECTION REQUIREMENTS FOR
REACTOR PRESSURE VESSEL HEADS AT PRESSURIZED WATER REACTORS
DATED FEBRUARY 11, 2003

On February 11, 2003, the Nuclear Regulatory Commission (NRC) issued an Order for Interim Inspection Requirements for Reactor Pressure Vessel Heads at Pressurized Water Reactors licensees. The Order requires specific inspection of the reactor pressure vessel (RPV) head and associated penetration nozzles at pressurized water reactors (PWRs). The Commission stated that the actions in the Order are interim measures, necessary to ensure that licensees implement and maintain appropriate measures to inspect and, as necessary, repair RPV heads and associated penetration nozzles. The Order required that licensees immediately start implementation of the requirements of the Order and respond to specific actions within twenty (20) days of the date of the Order.

In accordance with Section V of the Order and 10 CFR 2.202, Dominion Nuclear Connecticut, Inc. (DNC) hereby submits its answer to the Order. DNC consents to the Order and does not request a hearing.

As provided for by Section IV.F of the Order, DNC will be seeking relaxation of the requirements in Section IV.C(1)(a) of the Order that require a bare metal visual examination of 100% of the RPV head surface. DNC's request for relaxation will be submitted to the NRC by separate letter.

If you have any questions, please contact Mr. Ravi G. Joshi at (860) 440-2080.

Very truly yours,

David A. Christian
Senior Vice President – Nuclear Operations and Chief Nuclear Officer

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Mr. Samuel J. Collins, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Assistant General Counsel for Materials Litigation and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. H. J. Miller, Region I Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. S. M. Schneider
NRC Senior Resident Inspector
Millstone Power Station

Mr. R. B. Ennis
NRC Senior Project Manager
Millstone Power Station Unit 2


Subject: Response to RPV Head and Penetration Nozzles Inspection Order (EA-03-009)

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by David A. Christian who is Senior Vice President – Nuclear Operations and Chief Nuclear Officer of Dominion Nuclear Connecticut, Inc. He has affirmed before me that he is duly authorized to execute and file the foregoing document in behalf of that Company, and that the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 28TH day of February, 2003.

My Commission Expires: May 31, 2006.


Notary Public

(SEAL)