



# MARATHON ASHLAND PIPE LINE ULSD TESTING

Wesley Neff  
November 20, 2002

# Distribution Concerns

- The distribution system has no experience in handling ultra low specification product in a batched system
  - Off-highway /heating oil <5000 ppm
  - Jet Fuel <3000 ppm
  - Low sulfur diesel <500 ppm
  - Kerosene <2000 ppm
  - Ultra low sulfur diesel ,15 ppm



# Goals for MAPL ULSD Testing

- Determine whether sulfur from other refined products will “trail-back” in the pipeline
- Determine what batch sequences will work and the amount of interface generated



# Goals for MAPL ULSD Testing (Con't)

- Determine sulfur degradation due to:
  - The originating tank and receipt manifold piping
  - The pipeline and its associated appurtenances
  - The delivery manifold, tank piping and transport loading equipment
- Determine an appropriate field test for sulfur



# ULSD Testing

- **Initial tests conducted with Premium Gasoline on 4 pipeline systems**
  - Many lessons about contamination learned
- **Precautions taken with ULSD tests**
  - Automatic sumps were locked out
  - Booster pump units along the pipeline were not started
  - Simple tank to tank movements
  - Pipeline shutdowns minimized
  - Tank lines and tanks emptied prior to ULSD
  - Special sampling procedures implemented



# ULSD Testing

- **ULSD tests were conducted on 4 pipeline systems**
  - **10", 12", 16" and 20" diameter - 70 to 250 miles long**
- **Garyville to Zachary test was the most recent**
  - **Test is representative of all tests**
  - **Test covered movement from Garyville refinery tankage to MAP's tankage at Zachary, La**
    - **70 miles of 20" pipeline**
  - **Second test on this system in April, 2002**




# ULSD Testing – Garyville to Zachary

- Garyville made 90,000 bbls of ULSD in mid-September, 2001
  - ULSD in tank had 10 ppm sulfur and API gravity of 38.7 degrees
  - ULSD from unit had 7 ppm sulfur
- 76,500 bbls lifted to Zachary
  - LSD at head end
  - Regular gasoline at tail end



# ULSD Testing – Garyville to Zachary Results (Con't)

Garyville to Zachary Head End Expanded Sulfur Profile  
(9/15/01 - 9/16/01) Chart 2




10/8/01  
rwn





# ULSD Testing – Garyville to Zachary Results (Con't)


Garyville to Zachary Expanded Tail End Sulfur Profile  
(9/16/01) Chart 3





# ULSD Testing – Garyville to Zachary Results (Con't)

Zachary Head End - Sulfur & Gravity Profile  
ULSD Batch - 9/16/01 - Chart 6





# ULSD Testing – Garyville to Zachary Results (Con't)

- **Zachary via 20" system wrapped with LSD and gasoline**
  - 73,034 bbls out of 76,588 bbls delivered to a clean tank at Zachary
  - 1-2 ppm sulfur degradation tank to tank
  - 4.6% loss to interface
  - Refinery tank line at Garyville contaminated head end 4000 bbls
  - No migration of sulfur at head end or tail end beyond the normal gravity interface zone
  - No degradation due to the pipeline and associated appurtenances
  - No sulfur degradation from delivery piping

# Testing Summary

- **MAPL results indicate:**
  - **Pipelines can transport ULSD and maintain the sulfur specification**
  - **Gravity changes correspond closely to sulfur changes; protective gravity cuts may be acceptable**
  - **The loss to interface should be the same as with current critical cuts**

# Testing Summary (Con't)

- **MAPL results indicate:**
  - **Contamination occurs from front end systems such as refinery piping and origin station piping**
  - **Little sulfur contamination occurs in the pipeline**
  - **Tankage and delivery system piping does not add significant sulfur contamination**

# Testing Conclusions

- **Must have in-line testing equipment**
  - **Control contamination that happens during transit**
  - **Define cut points**
  - **Suitable test equipment is not available**
- **Test equipment must be robust**
- **May need an indirect method for interface detection**

# Testing Conclusions (Con't)

- Each pipeline system will have its own “personality”
  - Anything which creates a product quality problem today will be exacerbated when handling ULSD
    - Slow actuating valves – leaking valves
    - Non-dedicated tank lines
    - Long dead-legs in stations – long suction/discharge piping at pump stations
    - Sumps that inject automatically – prover loops that are not flushed
    - Systems with frequent shutdowns or large elevation differences
  - May need to redesign facilities to minimize contamination

# Testing Conclusions (Con't)

- Pipeline ULSD sulfur specifications could vary by system or routing
  - Simple tank to tank movements could add only 1 ppm sulfur with a moderate interface loss
  - More complex network routings could add several ppm sulfur and have a large loss to interface



# DISCUSSION

---