

## Appendix O

### Analysis of Power and Energy Impacts to Glen Canyon Dam, Shortage Criteria EIS

---

1

2

3

4 This appendix includes the methodology and analysis conducted by the Western regarding  
5 energy resources at Glen Canyon Dam Powerplant. The analysis in Section 4.11 uses Western's  
6 analysis of generation capacity and its associated economic value.

7



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33

## Table of Contents

O.1	Methodology Overview .....	O-1
O.1.1	CRSS Model .....	O-3
O.1.2	Hydrological Conditions Studied.....	O-4
O.1.3	Glen Canyon Dam Record of Decision .....	O-4
O.1.4	GTMax-Lite Data Processor .....	O-5
O.1.5	Market Prices .....	O-7
O.1.6	Market Price Processor .....	O-8
O.1.7	GTMax-Lite Model.....	O-11
O.1.8	Economic Calculations .....	O-16
O.2	Results of Western’s Analysis .....	O-16
O.2.1	Glen Canyon Dam Energy Generation .....	O-17
O.2.2	Glen Canyon Dam Capacity Generation.....	O-18
O.2.3	Present Value of Energy .....	O-19
O.2.4	Present Value of Capacity and Energy and Capacity Combined.....	O-20
O.2.5	Impact to Western Area Power Administration’s SLCA/IP Firm Power Rate .....	O-21
O.3	Customer Rates .....	O-22
O.4	Discussion of Results .....	O-23
O.5	References Cited .....	O-24

## List of Figures

Figure O-1	Diagram Depicting Major Modeling Components and Processes.....	O-2
Figure O-2	Average Market Prices for 2004 Based on the Dow Jones Index.....	O-8
Figure O-3	December AURORA Prices Scaled to the Dow Jones Monthly Average.....	O-10
Figure O-4	July AURORA Prices Scaled to the Dow Jones Monthly Average.....	O-10
Figure O-5	Glen Canyon Powerplant Operations under Median Winter Conditions.....	O-14
Figure O-6	Glen Canyon Powerplant Operations under Median Summer Conditions .....	O-15
Figure O-7	Glen Canyon Powerplant Operations under Dry Winter Condition .....	O-15
Figure O-8	Lake Powell End-of-March Elevations.....	O-24

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

## List of Tables

Table O-1	Equations for Converting ROD Operating Criteria and CRSS Output.....	O-6
Table O-2	GTMax-Lite Equations .....	O-13
Table O-3	Daily Generation Fractions for Weekend Days .....	O-14
Table O-4	Energy Generation .....	O-17
Table O-5	Change in Energy Generation.....	O-17
Table O-6	Percent Change in Energy.....	O-17
Table O-7	Capacity Generation.....	O-18
Table O-8	Change in Capacity Generation .....	O-18
Table O-9	Percent Change in Capacity .....	O-18
Table O-10	PV of Energy.....	O-19
Table O-11	Dollar Change in PV of Energy .....	O-19
Table O-12	Percent Change in PV of Energy .....	O-19
Table O-13	Change in PV, Energy & Capacity .....	O-20
Table O-14	Percent Change in PV of Capacity.....	O-20
Table O-15	Dollar Change in PV of Capacity .....	O-20
Table O-16	Percent Change in PV of Capacity.....	O-21
Table O-17	SLIP Firm Power Rate .....	O-21
Table O-18	Change in SLIP Firm Power Rate.....	O-22

## 1 O.1 Methodology Overview

2 The methodology used by the Western Area Power Administration (Western) to estimate the  
3 economics of Shortage Criteria Environmental Impact Statement (EIS) alternatives is a multi-  
4 step procedure of data processing and computer simulations. A flow diagram depicting the major  
5 components of this procedure and component interactions is displayed in Figure O-1. The  
6 procedure uses monthly results produced by the Colorado River Simulation System (CRSS) for  
7 each of the five EIS alternatives. This includes monthly values of turbine-water releases, power  
8 conversion factors, and the physical production capability of the Glen Canyon Dam (GCD)  
9 hydropower plant. The CRSS model also simulates operations for other Colorado River System  
10 Project (CRSP) reservoirs. However, EIS alternatives only impact the Glen Canyon Dam and are  
11 therefore the focus of this analysis.

12 CRSS results along with operating constraints mandated by the Glen Canyon Dam EIS Record of  
13 Decision (ROD) are input into an Excel spreadsheet that prepares input data for a customized  
14 variation of the Generation and Transmission Maximization (GTMax) model. To distinguish this  
15 customized version from the original model, it is referred to as GTMax-Lite in this document.  
16 The Data Processor spreadsheet uses power conversion factors to translate CRSS releases and  
17 ROD constraints from water units into a power equivalent. For example, monthly turbine water  
18 releases specified in terms of acre-feet (af) in CRSS output tables are converted into an  
19 equivalent electricity production in units of Mega-Watt-hours (MWh). The spreadsheet also  
20 selects a subset of CRSS results and calculates statistics that are analyzed in more detail by other  
21 processes.

22 Physical monthly operating limits for capacity and energy along with ROD operational  
23 constraints are used by the GTMax-Lite model to simulate hourly Glen Canyon Dam power plant  
24 generation levels. The model determines the hourly operation schedule over a one-week period  
25 (i.e., 168 hours) that maximizes the economic value of the hydropower resource. The operation  
26 schedule produced by the model is within the physical limitations of the power plant and it  
27 complies with all environmental and institutional regulations.


28 The GTMax-Lite model uses a projection of market prices as a measure of the future economic  
29 value of hydropower generation. These prices heavily influence the generation schedule  
30 produced by the model when it optimizes the hydropower plant resource. Future hourly price  
31 signals are estimated over the study period by a second Excel spreadsheet referred to as the Spot  
32 Price Processor. It uses 2004 hourly spot market price patterns produced by the AURORA model  
33 (Electric Power Information Solutions, Inc. 2005), an estimate of historical 2004 market prices  
34 for the Palo-Verde market hub as reported in the Dow-Jones index, and a nominal inflation rate.

35 GTMax results include an estimate of the economic value of Glen Canyon power plant capacity  
36 and energy production over the simulation period. It also includes an estimate of the hydropower  
37 plant maximum production capability taking into account ROD operational constraints. This  
38 measure of capacity is mostly, but not always, substantially less than the physical capability of  
39 the plant based only on hydrological head; that is, the physical capability estimated by CRSS.

1 Western customer power rates are calculated using a power repayment study (PRS) spreadsheet-  
2 based computer program that contains both general and specific repayment rules associated with  
3 a particular hydropower project. This spreadsheet uses GTMax-Lite results for Glen Canyon and  
4 from the full-scale GTMax model for all other Salt Lake City Area Integrated Project  
5 (SLCA/IP) plants.

6 A more detailed explanation of the methodology used for the Shortage Criteria EIS is provided  
7 in the following sections. This includes both data processing algorithms and the GTMax-Lite  
8 simulation model. Detailed explanations of other models, such as CRSS that feed into the  
9 process, but are not run by Western, are provided elsewhere.

10 Figure O-1  
12 Diagram Depicting Major Modeling Components and Processes



1       **O.1.1 CRSS Model**

2       The CRSS model mimics operational decisions that are made for CRSP reservoirs. Since EIS  
3       alternatives have unique criteria, each simulation contains alternative-specific operating rules  
4       that affect monthly and annual water releases. Monthly release patterns affect the economic  
5       value of the hydropower resource since the value of power is highly sensitive to seasonal and  
6       hourly variations in market prices. Typically market prices are the highest in the summer and  
7       winter seasons. Therefore, from a myopic power viewpoint, water releases would ideally be  
8       concentrated during these two seasons. However, from a broader perspective power benefits  
9       must be weighted against other operational objectives such as flood control, irrigation,  
10       municipal and industrial water supplies, recreation, and the environment.

11       Shortage Criteria alternatives also affect reservoir forebay elevations and the amount of water  
12       that bypass turbines. The forebay elevation determines the hydraulic head and is the primary  
13       factor that influences the amount of power that is produced per volume of water released  
14       through the turbines. High forebay elevations typically translate into more power production  
15       per af of turbine water releases as compared to lower forebay elevations. However,  
16       maintaining full or nearly full reservoirs increases the risk of releasing water through bypass  
17       tubes and spillways. Sudden unexpected inflows under a full reservoir condition may require  
18       reservoir releases that exceed maximum turbine flow rates. Maintaining lower reservoir  
19       levels on the other hand will reduce the risk of non-turbine water releases during flood  
20       conditions, but it will also increase the risk of lowering the forebay elevation below turbine  
21       inlet tubes during droughts. When this occurs, both power production and the plant capacity  
22       is zero. Operating rules must therefore balance the risks associated with either having too  
23       much or not enough water stored in Lake Powell.

24       Balancing risks in a basin with large variations of water inflows, such as CRSP, require a  
25       full-spectrum examination of hydrological conditions. Therefore, the CRSS model produces  
26       numerous simulation results for each month. These results represent a range of plausible  
27       futures from which probability distributions of future hydropower conditions are constructed.  
28       Distributions are influenced by initial reservoir conditions such that distributions are  
29       relatively narrow for near-term projections. This represents a relatively low level of  
30       uncertainty about the future. However, as the projection period extends further into the  
31       future, the distribution widens as uncertainty grows.

32       CRSS results include scenario-specific estimates of monthly energy production and physical  
33       capability for 99 possible futures throughout the analysis period which extends from the  
34       beginning of January 2008 through the end of December 2060. For the Shortage Criteria EIS,  
35       forecasts are made by simulating reservoir operations with 99 different sequences of inflows.  
36       Each sequence is based on a chronological inflow pattern that has occurred in the past, and is  
37       referred to as a trace. Refer to Appendix A for a detailed explanation of CRSS reservoir  
38       operating rules and traces.

### 1       **O.1.2 Hydrological Conditions Studied**

2       Ideally detailed simulations of hourly operations at the Glen Canyon Dam hydropower plant  
3       would be performed for each of the 99 traces over the 53 year analysis period. However, it is  
4       computationally impractical. Therefore, a simplified approach was used to measure  
5       differences among alternatives. This involves analyzing only selected points from the  
6       monthly distributions produced by CRSS. The Data Processor spreadsheet computes  
7       statistics and extracts pertinent information from the CRSS output.

8       Western chose four hydrological conditions to study to ensure a representative look at the  
9       differences between the alternatives. The four conditions are: Mean, Median, 90%  
10      Exceedence, and Trace 94, and are explained below.

11      *Mean:* An average value of the 99 CRSS traces was computed for each month of the study  
12      period, for each alternative.

13      *Median:* The 50<sup>th</sup> percentile value of the 99 CRSS traces was computed for each month of  
14      the study period, for each alternative.

15      *90% Exceedence:* The 10<sup>th</sup> percentile value of the 99 CRSS traces was computed for each  
16      month of the study period. 90% exceedence is often referred to as 10<sup>th</sup> percentile in Western  
17      and Reclamation hydrological studies; the two terms are synonymous.

18      *Trace 94:* Individual traces of the CRSS output were examined. Trace 94 was selected by  
19      Western as representing especially poor conditions for generation at GCD, with periods of no  
20      generation due to low Lake Powell reservoir elevations (below 3490'). Trace 94 was selected  
21      to examine the difference in performance of the five alternatives under conditions of  
22      complete loss of GCD generation for an extended period of time. Trace 94 also allows for  
23      examination of a time-connected series of potential GCD operations, showing drops and  
24      recoveries of Lake Powell elevation over time. The other three hydrological conditions  
25      studied are not time-connected in the same manner that a single trace is.

26      Mean, median and 90% exceedance values for capability and energy are computed  
27      separately. Furthermore, capability statistics are based only on hydrologic head as computed  
28      by CRSS. However, under current operating constraints imposed on Glen Canyon,  
29      sustainable capability is a function of both the physical powerplant capability and the  
30      monthly water release volume (refer to the next section for more details). Although it may be  
31      more accurate to compute capacity statistics using both the hydrologic head and monthly  
32      water releases, this process would have been very computationally intensive with only a  
33      marginal increase in precision. As a simplification, statistical values for physical capability  
34      and energy are first calculated and then sustainable capacity is estimated by the GTMax-Lite  
35      model using these statistical values.

### 36      **O.1.3 Glen Canyon Dam Record of Decision**

37      The economics of Shortage Criteria Alternatives is not only a function of monthly water  
38      release volumes, but also of physical and institutional limitations on daily and hourly  
39      operations. Of particular importance is the Glen Canyon Dam Record of Decision (ROD)  
40      that affirmed the selection of the Modified Low Fluctuating Flow Alternative as the preferred



1 operating alternative. The Bureau of Reclamation (Reclamation) issued the operating criteria  
2 for Glen Canyon Dam early in 1997. The ROD criteria expanded on the operational rules  
3 contained in the Glen Canyon Dam Operation EIS and ROD. It also provided Western and  
4 Reclamation staff with guidance on the operation of the dam and the Salt Lake City Area  
5 Integrated Projects (SLCA/IP) power system.

6 The ROD imposed a limit on the maximum allowable release from Glen Canyon Dam to  
7 25,000 cubic feet of water per second (cfs) and included exceptions to the maximum release  
8 for Beach/Habitat Building Flows and Habitat Maintenance Flows such as occurred in March  
9 1996. Exceptions were also made to avoid spills or flood flow releases during high runoff  
10 years. During high hydropower conditions when the total monthly water release volume is  
11 greater than a constant 25,000 cfs release rate throughout the month, the maximum release  
12 rate is relaxed. However, releases are restricted to a flat-flow operating regime.

13 Releases must also be at least 8,000 cfs between the daytime hours of 7:00 a.m. to 7:00 p.m.,  
14 and 5,000 cfs or more at night. The ROD also set limits on the allowable release fluctuations  
15 in any continuous 24-hour period. The amounts vary depending on the volume of water  
16 scheduled to be released in a given month. For example, the allowable daily change is 5,000  
17 cfs/24 hours for months in which scheduled water releases through the dam are less than 600  
18 thousand acre feet (kaf). Fluctuations will be held at 6,000 cfs/24 hours for months of  
19 scheduled releases between 600 and 800 kaf, and at 8,000 cfs/24 hours for months of  
20 scheduled releases greater than 800 kaf/month. Finally, the limits the rate at which the  
21 generators may ramp up or down during a one-hour time period. The maximum power plant  
22 ramp rates are set at 4,000 cfs per hour increasing and 1,500 cfs per hour decreasing.

#### 23 **O.1.4 GTMax-Lite Data Processor**

24 The Data Processor spreadsheet prepares input data for the GTMax-Lite model by translating  
25 CRSS and ROD information from water units into equivalent power and energy units.  
26 Equations that are used by the spreadsheet are summarized in Table O-1. For example, the  
27 processor multiplies a power conversion factor by the ROD allowable maximum flow rate to  
28 compute the maximum power plant output. Power factors are approximated by CRSS for  
29 each trace in all study months. The maximum output level computed by the data processor is  
30 not always achieved since the maximum daily change restriction and hourly up and down  
31 ramp rate limits further constrain operations.

32 It should be noted that the monthly water releases in table are scaled to represent the amount  
33 of water that is released in a typical week. GTMax-Lite model is executed for only one week  
34 per study period month. Total generation during this “typical” week is based on CRSS  
35 monthly water release volumes times a scaling factor. This factor is equal to the number of  
36 days in the week (i.e., 7) divided by the number of days in a simulated month. For example,  
37 the scaling factor for January equals 7 divided by 31. The inverse of this factor is used to  
38 obtain monthly values by scaling-up weekly results.

1

Table O-1  
Equations for Converting ROD Operating Criteria and CRSS Output

CRSS/ROD Criteria	Power Equivalent for GTMax-Lite Input
Monthly Water Release	$E_w^{pow} = \frac{TR_m^{wat} \times CF_m^{w-p}}{1000} \times \frac{7}{ND_m} \quad \forall m   m = 1, \dots, NM$
Maximum Release	$C_w^{pow} = \text{Max} \left( C_m^{CRSS}, \frac{MR_m^{wat} \times CF_m^{w-p}}{1000} \times 0.082644 \right) \quad \forall m   m = 1, \dots, NM$
Maximum Daily Change	$DC_w^{pow} = \frac{DC_m^{wat} \times CF_m^{w-p}}{1000} \times 0.082644 \quad \forall m   m = 1, \dots, NM$
Hourly Up-Ramp Rate Limit	$HU_w^{pow} = \frac{HU_m^{wat} \times CF_m^{w-p}}{1000} \times 0.082644 \quad \forall m   m = 1, \dots, NM$
Hourly Down-Ramp Rate Limit	$HD_w^{pow} = \frac{HD_m^{wat} \times CF_m^{w-p}}{1000} \times 0.082644 \quad \forall m   m = 1, \dots, NM$
Minimum Daytime Release	$DM_w^{pow} = \frac{DM_m^{wat} \times CF_m^{w-p}}{1000} \times 0.082644 \quad \forall m   m = 1, \dots, NM$
Minimum Nighttime Release	$MN_w^{pow} = \frac{MN_m^{wat} \times CF_m^{w-p}}{1000} \times 0.082644 \quad \forall m   m = 1, \dots, NM$

where,

$m$  = Simulation month index

$w$  = Simulation week index with one representative week per month

$ND_m$  = Number of simulation days in month  $m$

$NM$  = Number of simulation months;  $636 = 12 \times 53$

$E_w^{pow}$  = Weekly generation (MWh) during week  $w$

$TR_m^{wat}$  = Total water volume (AF) released during month  $m$

$C_w^{pow}$  = Weekly capability (MW) during week  $w$

$C_m^{CRSS}$  = CRSS physical capability (MW) during month  $m$

$MR_m^{wat}$  = Maximum release rate (cfs) during month  $m$ ; dependent on  $TR_w^{wat}$

$DC_w^{pow}$  = Maximum daily change (MW/day) during week  $w$

$DC_m^{wat}$  = Maximum daily change (cfs/day) during month  $m$ ; dependent on  $TR_w^{wat}$

$HU_w^{pow}$  = Maximum hourly power increase (MW/h) during week  $w$

$HU_m^{wat}$  = Maximum hourly up-ramp rate (cfs/hr) during month  $m$

$HD_w^{pow}$  = Maximum hourly power decrease (MW/h) during week  $w$

$HD_m^{wat}$  = Maximum hourly down-ramp rate (cfs/hr) during month  $m$

$MD_w^{pow}$  = Minimum daytime hourly generation (MWh) during week  $w$

$MD_m^{wat}$  = Minimum daytime release rate (cfs) during month  $m$

$MN_w^{pow}$  = Minimum nighttime hourly generation (MWh) during week  $w$

$MN_m^{wat}$  = Minimum nighttime release rate (cfs) during month  $m$

1       **O.1.5 Market Prices**

2       Representative energy and capacity prices are essential for an economic evaluation of  
3       Shortage Criteria Alternatives. Pricing assumptions tend to be controversial because there are  
4       many sources of information, and because the price assumed can make a large difference in  
5       the resulting valuation of energy and capacity. Some analysts prefer using historical energy  
6       and capacity prices because they can be tied to a specific set of purchase transactions. Others  
7       prefer to use estimates of future costs under the assumption that historical costs do not  
8       necessarily predict future prices. Prices for historical or future energy can be obtained fairly  
9       easily from a variety of sources. However, prices for capacity are more difficult to obtain  
10       since they are more closely identified to a particular utility or power generation facility and  
11       usually are considered proprietary information by the facility owner.

12       Western coordinated energy prices with Reclamation to ensure that both agencies were using  
13       the same data. The two agencies agree upon a method that combined two types of energy  
14       prices. These data include a historical price index for the Palo-Verde market hub contained  
15       in a Dow Jones, Inc. database and hourly market price patterns produced by the AURORA  
16       model. Both the historical and modeled data are for the year 2004. Prices for 2005 were  
17       rejected from consideration due to the anomalies caused by fuel supply disruptions resulting  
18       from hurricane damage that occurred in the summer and autumn.


19       A review of hourly 2004 Dow Jones price data identified numerous anomalies such as  
20       atypically high prices on several Sundays over the course of the year. There were also long  
21       and frequent periods of missing data. Although the Dow Jones month average prices, shown  
22       in Figure O-2, are representative and would suffice for Reclamation’s monthly energy  
23       modeling, the quality of the hourly price data was inadequate for Western’s hourly modeling.  
24       To eliminate the hourly energy price problems, Reclamation provided Western with  
25       AURORA model simulated market prices for 2004. The Aurora model results had hourly and  
26       weekly prices that represented typical weekly price profiles, but average price levels were  
27       significantly less than historical levels. To match the Dow Jones index prices, the AURORA  
28       hourly model output was scaled such that the average monthly values matched the Dow  
29       Jones monthly average values. A more detailed description of the scaling process is provided  
30       in the next section.

31       Some of the anomalies associated the Dow Jones, Inc. price index may be a reflection of the  
32       energy market that is currently functioning in the WECC and small number of reported  
33       transactions that is used to calculate the index. For any given hour the Dow index is the  
34       weighted average price for all reported bilateral exchanges. A bilateral exchange is a private  
35       transaction between two parties at a negotiated price. It should also be noted that only a small  
36       percentage of bilateral contracts are reported to the Dow Jones. Although monthly average  
37       prices follow a typical pattern, the extent to which the Dow Jones prices reflect the broader  
38       WECC electricity market is not known. This method of price discovery differs from a market  
39       price that is determined through a central clearinghouse whereby individual buyers and  
40       sellers do not directly communicate with each other. Instead a price is determined by the  
41       intersection of supply and demand bid curves.

1 AURORA model simulations used in this analysis were developed for and used in the  
2 Northwest Power and Conservation Council’s *Fifth Northwest Electric Power and*  
3 *Conservation Plan* (NWPCC 2005). The Northwest Power and Conservation Council is  
4 primarily interested in Northwestern electricity markets. Relatively less attention is devoted  
5 to characterizing market conditions in other parts of the WECC region. Consequently, the  
6 Palo Verde forecast described in this analysis primarily reflects the default data supplied with  
7 the AURORA model.

8  
9

Figure O-2  
Average Market Prices for 2004 Based on the Dow Jones Index



10

11 **O.1.6 Market Price Processor**

12 The GTMax-Lite model uses a projection of market prices as a measure of the future  
13 economic value of hydropower generation. This assumption implies that market prices reflect  
14 the marginal economic cost of serving the last megawatts-hour (MWh) of load in the system  
15 (i.e., system lambda). Furthermore, Glen Canyon power injections into the grid are  
16 minuscule relative to the entire power system in which it operates. Therefore, its operations  
17 do not influence the marginal value of energy. Given the size and complexity of the Western  
18 Electricity Coordinating Council (WECC) power grid and the markets that it functions in,  
19 these assumptions are reasonable. It should also be noted that the relative economic  
20 differences among alternatives are of importance, rather than the absolute economic value of  
21 a specific alternative.

Appendix O

1 The Spot Price Processor prepares typical energy price profiles for GTMax based on the  
2 AURORA model results. Instead of using each hourly price, typical spot price patterns were  
3 computed for three different day types in each month. These include Sunday, weekday, and  
4 Saturday. A daily price pattern is obtained by computing an average hourly price for each  
5 similar hour. For example, the weekday price at 1:00 AM is the average of AURORA prices  
6 at 1:00 AM for all days in a month that are between Monday and Friday, inclusive. Each day  
7 of the month is then assigned hourly prices depending on the month and type of day. For  
8 example, every weekday in January is assigned the average price pattern for January  
9 weekdays.

10 The final step of the process scales monthly prices to match the simple (i.e., unweighted)  
11 mean of hourly Palo-Verde prices contained in the Dow Jones database. These monthly  
12 average prices follow a typical seasonal pattern for the Southwestern United States. Prices  
13 are the highest during the summer months reflecting an elevated demand for air conditioning.  
14 On the other hand, prices during the spring and autumn seasons are relatively low. Winter  
15 prices are somewhat higher than these shoulder seasons as loads are elevated by more  
16 lighting and heating demands. Prices are inflated to approximate hourly prices for future  
17 years. For this analysis, the annual inflation rate is assumed to be 2.2 percent.


18 The use of typical (i.e., average) hourly price profiles to estimate Glen Canyon power plant  
19 generation patterns is more realistic than estimating generation patterns based on individual  
20 hourly prices. This is in part due to the recognition that power marketers have excellent  
21 foresight regarding overall daily price patterns over the upcoming week, but the magnitude  
22 and individual hourly variations from the typical pattern cannot be accurately predicted. In  
23 contrast, the GTMax model has perfect foresight and if provided with the detailed price  
24 profile it will react to each individual “perfectly predicted” price. When GTMax is provided  
25 with the typical or average pattern, it produces a generation pattern that more closely  
26 emulates actual energy scheduling practices.

27 Market prices have a profound influence on generation schedules prepared by power  
28 marketers as well as those produced by optimization models. Figures O-3 and O-4 show  
29 hourly used by GTMax for a winter month, December, and for a summer month, July. The  
30 hourly price pattern for weekdays in December follows a typical winter profile with two  
31 separate daily peaks. The first peak occurs in the morning followed by a midday price slump.  
32 Prices rise again in the evening reaching a high between 6 PM to 8 PM. The lowest prices  
33 hours are in the middle of the night, bottoming out at 2 AM to 4 AM. Prices are somewhat  
34 lower during the weekends, especially on Sunday. Also weekend hourly price patterns  
35 deviate somewhat from weekday price profiles.

36 While winter prices exhibit a two-hump price pattern, prices during the summer months peak  
37 only once during the day – typically in the late afternoon between 4 PM to 6 PM during the  
38 hottest part of the day. Similar to the wintertime, prices are at a minimum in the middle of  
39 the night.


1  
2

Figure O-3  
December AURORA Prices Scaled to the Dow Jones Monthly Average



3  
4  
5

Figure O-4  
July AURORA Prices Scaled to the Dow Jones Monthly Average



6

1       **O.1.7 GTMax-Lite Model**

2       Western and Argonne National Laboratory simulated Glen Canyon hydropower plant  
3       operations on an hourly time step with the GTMax-Lite modeling software. GTMax-Lite  
4       is similar to the full version of the GTMax model except it only contains those features that  
5       are required to perform an economic evaluation of Shortage Criteria Alternatives. Model run  
6       time and data transfers are significantly shorter, while a level of simulation accuracy  
7       equivalent to the full version is retained.

8       The GTMax-Lite objective function is to produce an hourly generation schedule over a one-  
9       week time period that maximizes the economic value of the hydropower resource. Market  
10      prices input into the model convey the economic value of hydropower generation. These  
11      prices heavily influence the generation schedule produced by the model when optimizing the  
12      hydropower plant resource. To the extent possible the GTMax-Lite model uses its limited  
13      energy resource to first generate electricity during on-peak hours when it has the highest  
14      economic value. Any remaining energy is scheduled during lower-priced hours.

15      Glen Canyon power plant operations are subject to a set of constraints. These include a  
16      physical operating capability and a limit on the total weekly electricity production. As  
17      described in previous sections, these constraints are consistent with CRSS model results. In  
18      addition to physical operating constraints, the GTMax-Lite model also complies with the  
19      ROD Criteria. Table O-2 contains the GTMax-Lite mathematical formulations consisting of  
20      an objective function and a set of operating constraints.

21      In practice, hydropower plant operations do not always strictly follow an economic  
22      optimization regime as suggested by mathematical models. This occurs because models are a  
23      simplification of reality and typically only include those elements that can be described in the  
24      form of mathematical equations. In GTMax-Lite, equations are used to model the power  
25      plant based on an economic maximization function subject to physical and legal operating  
26      limits. However, marketers must often include other important factors which result in  
27      operations that often deviate from the simplified mathematical optimal. Some of these factors  
28      include individual risk tolerance levels and intricacies associated with bilateral contracts,  
29      block spot purchase patterns, grid limitations, and power exchanges and interchanges. Other  
30      factors not included in GTMax-Lite are general agreements that have been made with  
31      affected parties, but that are not contained in a legally binding decree.

1 Despite its limitations, the GTMax-Lite model usually simulates daily and hourly generation  
2 patterns that are similar to actual operations. However, compared typical operations, the  
3 GTMax-Lite model will at times schedule less power during the weekend when market prices  
4 are low, shifting more power to higher-priced weekdays. Although operations comply with  
5 ROD constraints, the GTMax-Lite schedule may have some detrimental implications for the  
6 environment. Therefore, additional constraints that specify a minimum allocation of daily  
7 generation among the days of the weeks are incorporated into the GTMax-Lite mathematical  
8 formulation.

9 Daily minimums are specified as the ratio of daily generation during a weekend day relative  
10 to the average daily generation during a weekday. For example, a value of 0.9 assigned to  
11 Saturday requires that the total generation during that day must be at least 90 percent of a  
12 weekday's generation. Values assigned to the daily generation restrictions are based on  
13 historical operations and vary by month as shown in Table O-3. Minimum daily generation  
14 levels are often not binding in the model and water releases scheduled by GTMax-Lite on  
15 Saturday and Sunday frequently are more than the minimum.

16 Glen Canyon power plant operations simulated by GTMax-Lite under median hydrological  
17 conditions for a typical week in the wintertime, 2<sup>nd</sup> week in December, 2010, are depicted in  
18 Figure O-5. To maximize the economic value of the hydropower resource, the model  
19 generates as much power as possible during hours when market prices are the highest.  
20 Generation tends to drop as the spot price decreases; for example, during the midday price  
21 valley. Generation during on-peak hours are constrained by the ROD daily change, reaching  
22 a peak of about 610 megawatts (MW). That is substantially less than (approximately half) the  
23 median capability of 1,205 megawatts (MW) estimated by CRSS based on the Powell  
24 Reservoir forebay elevation.

25 Simulated operations during the summertime also tend to follow prices. As shown in Figure  
26 O-6, Glen Canyon generation exhibits a one-hump pattern that has a shape similar to the  
27 market price profile. Simulated operations are for July 2010 under median conditions.  
28 Comparable to the wintertime, peak generation levels are constrained to slightly more than  
29 600 megawatts (MW) despite a hydrological head that is capable of supporting generation  
30 levels of approximately 1,232 MW.

31 Under dry hydrological conditions, maximum generation levels simulated by GTMax-Lite  
32 drop even further. Figure O-7 shows that on-peak production levels are less than 475 MW.  
33 Under the driest conditions, forebay elevations dip below turbine water inlet tubes resulting  
34 in zero monthly electricity generation and zero power plant capacity.



1

Table O-2  
GTMax-Lite Equations

Description	GTMax-Lite Equation
Objective Function	$Maximize: SP_h \times Gen_h \quad \forall h   h = 1, \dots, 168$
Maximum Hourly Generation	$Gen_h \leq C_w^{pow} \quad \forall h   h = 1, \dots, 168$
Weekly Generation	$WGen_w = \sum_{h=1}^{168} Gen_h$
Maximum Daily Change	$DC_w^{pow} \geq Gen_{j+k-wrap} - Gen_j \quad \forall j   j = 1, \dots, 168$ and for each $j, k = 1, \dots, 23$ when $j + k > 168, wrap = j + k - 168$ else $wrap = 0$
Hourly Up-Ramp Rate Limit	$HU_w^{pow} \geq Gen_h - Gen_{h-1+wrap} \quad \forall h   h = 1, \dots, 168$ when $h > 1$ $wrap = 0$ else $wrap = 168$
Hourly Down-Ramp Rate Limit	$HD_w^{pow} \geq Gen_{h-1+wrap} - Gen_h \quad \forall h   h = 1, \dots, 168$ when $h > 1$ $wrap = 0$ else $wrap = 168$
Minimum Daytime Release	$MD_w^{pow} \leq Gen_h \quad \forall h   h = 1, \dots, 7, 20, \dots, 31, 44, \dots, 55, 68, \dots, 79, 92, \dots, 103,$ $116, \dots, 127, 140, \dots, 151, 164, \dots, 168$
Minimum Nighttime Release	$MN_w^{pow} \leq Gen_h \quad \forall h   h = 8, \dots, 19, 32, \dots, 43, 56, \dots, 67, 80, \dots, 91, 104, \dots, 115,$ $128, \dots, 139, 152, \dots, 163$
Daily Generation	$DGen_d = \sum_{i=1}^{24} Gen_{(d-1) \times 24 + i} \quad \forall d   d = 1, \dots, 7$
Minimum Daily Generation for Weekend Days	$DGen_d \geq DGen_2 \times DMin_d \quad \forall d   d = 1, 7$
Identical Weekday Total Generation Levels	$DGen_2 = DGen_d \quad \forall d   d = 3, 4, 5$

where,

$h$  = Simulation hour index

$d$  = Simulation day index where 1=Sun, 2= Mon, etc.

$wrap$  = index parameter to address temporal boundary conditions

$Gen_h$  = Average generation level (MWh) during hour  $h$

$SP_h$  = Spot market price index (\$/MWh) for hour  $h$

$WGen_w$  = Total generation (MWh) during week  $w$

$DGen_d$  = Total generation (MWh) during day  $d$

$DMin_d$  = Minimum daily generation fraction for day  $d$  (see Table X)

2


Table O-3  
Daily Generation Fractions for Weekend Days

Month	Sunday	Saturday
January	0.86349	0.88511
February	0.86861	0.94269
March	0.90666	0.94367
April	0.91358	0.98481
May	0.93182	0.95657
June	0.86247	0.89126
July	0.94368	0.96479
August	0.92117	0.94085
September	0.95205	0.96890
October	0.97621	0.97621
November	0.94810	0.98237
December	0.90623	0.96419

1

2  
3


Figure O-5  
Glen Canyon Powerplant Operations under Median Winter Conditions



4


1  
2

Figure O-6  
Glen Canyon Powerplant Operations under Median Summer Conditions



3  
4  
5  
6

Figure O-7  
Glen Canyon Powerplant Operations under Dry Winter Conditions



7

### 1       **O.1.8 Economic Calculations**

2       The economic value of the Glen Canyon Dam energy is computed by multiplying power  
3       plant generation estimated by GTMax-Lite by the market price. Since the model only  
4       simulates operations for one representative week in each month, economic values are scaled.  
5       This scaling factor equals the number of days in a projection month divided by 7. A net  
6       present value (NPV) of the monthly economic values over the study period was calculated by  
7       discounting monthly values at an annual rate of 4.875%. When discounting, it was assumed  
8       that the stream of hourly economic benefits in a month occurred mid-month as a single lump-  
9       sum value.

10       Differences in annual energy and capacity generation were calculated between the No Action  
11       Alternative and each Action Alternative. The annual capacity difference in terms of  
12       megawatts was assigned a value using a capacity price of \$6.32/kilowatt-month. That price  
13       represents the market value of generation in 2007 dollars. For valuing capacity, Western  
14       obtained a cost of constructing a new combined cycle natural gas power plant. Capacity was  
15       valued at the replacement cost identified by some SLCA/IP customer utilities who have  
16       recently constructed facilities which provide load following capacity. These customer data  
17       were collected in order to get information regarding the construction cost per megawatt of a  
18       recently built facility that provides electrical services similar to the GCD power plant.

19       This value is higher than the average cost of capacity from existing facilities on the system,  
20       but was selected for two reasons. 1) Over the 53 year study period, available capacity from  
21       existing sources will not be adequate to serve growing loads. New capacity will have to be  
22       built. 2) Renewable resource requirements in states such as California could cause new  
23       capacity costs to escalate at a rate faster than the 2.2% assumed in this analysis.

24       The two Western offices performing analyses coordinated capacity values, so the same  
25       capacity values were used for GCD and for the Lower Basin power plants.

26       Capacity values were converted to a present value using the same method as for energy, and  
27       were then added to the energy present value to obtain a total value of the difference in  
28       generation between the No Action alternative and each Action alternative. Reclamation did  
29       not value capacity differences in their analysis.

## 30       **O.2 Results of Western's Analysis**

31       Western Area Power Administration's financial analysis of the alternatives concentrated on the  
32       effect each alternative has on energy generation and capacity generation at Glen Canyon Dam  
33       (GCD). The effects are measured by the difference in generation in gigawatthours (GWh) of  
34       energy and megawatts (MW) of capacity between the No Action alternative and each of the  
35       Action alternatives, for the four representative hydrological conditions outlined above. The  
36       analysis includes the economic effect of changes to capacity and energy calculated by applying  
37       energy and capacity costs to the changes in generation. Finally, a NPV calculation was  
38       performed to develop a single value to compare each Action alternative to No Action. The  
39       sections below break down the results of the analysis into each of the aspects studied.

**O.2.1 Glen Canyon Dam Energy Generation**

The energy generation at GCD for each alternative was summed over the 53-year study (2008-2060) period and is displayed in Table O-4 below in GWh. (One GWh is equal to 1 million kilowatt hours.) The difference in generation of the Action alternatives as compared to No Action is shown in Table O-5. Table O-6 has those same differences as percentages.

Table O-4  
Energy Generation

Alternatives	Generation Mean GWh	Generation Median GWh	Generation 90% Exceed GWh	Generation Trace 94 GWh
No Action	4,261.89	3,747.44	3,159.31	4,319.24
Basin States	4,249.67	3,799.02	3,081.67	4,623.61
Conservation Before Shortage	4,251.35	3,799.67	3,089.61	4,423.55
Water Supply	4,149.86	3,784.11	2,956.92	4,391.75
Reservoir Storage	4,291.84	3,768.42	3,160.89	4,389.03

Table O-5  
Change in Energy Generation

Alternatives	Change in Generation Mean GWh	Change in Generation Median GWh	Change in Generation 90% Exceed GWh	Change in Generation Trace 94 GWh
No Action	0.00	0.00	0.00	0.00
Basin States	(12.21)	51.57	(77.64)	304.37
Conservation Before Shortage	(10.54)	52.23	(69.70)	104.31
Water Supply	(112.03)	36.67	(202.39)	72.51
Reservoir Storage	29.96	20.98	1.57	69.79

Table O-6  
Percent Change in Energy

Alternatives	Change in Generation Mean Percent	Change in Generation Median Percent	Change in Generation 90% Exceed Percent	Change in Generation Trace 94 Percent
No Action	0.00%	0.00%	0.00%	0.00%
Basin States	(0.21%)	0.98%	(1.74%)	5.17%
Conservation Before Shortage	(0.18%)	0.99%	(1.56%)	1.77%
Water Supply	(1.89%)	0.70%	(4.54%)	1.23%
Reservoir Storage	0.51%	0.40%	0.04%	1.19%

1 **O.2.2 Glen Canyon Dam Capacity Generation**  
 2 Generation of capacity at GCD was calculated and averaged over the same study period as  
 3 shown in Table O-7. The numbers in the table represent the average peak capacity output of  
 4 GCD in megawatts, and is much lower than the power plant capability based on lake  
 5 elevation. Table O-8 displays the difference between each alternative and the No Action  
 6 alternative. Table O-9 has those same differences as percentages.

Table O-7  
Capacity Generation

Alternatives	Average Capacity Mean Megawatts	Average Capacity Median Megawatts	Average Capacity 90% Exceed Megawatts	Average Capacity Trace 94 Megawatts
No Action	602.98	546.23	455.22	605.14
Basin States	606.42	552.41	442.55	647.20
Conservation Before Shortage	606.61	552.42	443.77	620.07
Water Supply	591.77	550.31	425.11	615.60
Reservoir Storage	612.57	549.08	452.74	614.20

7

Table O-8  
Change in Capacity Generation

Alternatives	Change in Capacity Mean Megawatts	Change in Capacity Median Megawatts	Change in Capacity 90% Exceed Megawatts	Change in Capacity Trace 94 Megawatts
No Action	0.00	0.00	0.00	0.00
Basin States	3.44	6.18	(12.67)	42.06
Conservation Before Shortage	3.63	6.20	(11.45)	14.93
Water Supply	(11.21)	4.08	(30.11)	10.47
Reservoir Storage	9.59	2.85	(2.48)	9.06

8

Table O-9  
Percent Change in Capacity

Alternatives	Change in Capacity Mean Percent	Change in Capacity Median Percent	Change in Capacity 90% Exceed Percent	Change in Capacity Trace 94 Percent
No Action	0.00%	0.00%	0.00%	0.00%
Basin States	0.06%	0.12%	(0.28%)	0.71%
Conservation Before Shortage	0.06%	0.12%	(0.26%)	0.25%
Water Supply	(0.19%)	0.08%	(0.68%)	0.18%
Reservoir Storage	0.16%	0.05%	(0.06%)	0.15%

9

**O.2.3 Present Value of Energy**

The NPV of energy generation at GCD was calculated for each Alternative at each hydrological condition. Each of the Action alternatives was compared to the No Action alternative to determine the difference in NPV of energy generation in GWh over the study period. Table O-10 shows the NPV of each alternative studied. Table O-11 displays the difference between each of the Action alternatives and the No Action alternative. Table O-12 has those same differences as percentages.

Table O-10  
PV of Energy

Alternatives	NPV Mean \$ Million	NPV Median \$ Million	NPV 90% Exceed \$ Million	NPV Trace 94 \$ Million
No Action	\$5,913.18	\$5,263.89	\$4,458.09	\$5,887.55
Basin States	\$5,979.28	\$5,368.44	\$4,309.47	\$6,647.15
Conservation Before Shortage	\$5,981.13	\$5,369.32	\$4,323.33	\$6,107.39
Water Supply	\$5,855.53	\$5,352.21	\$4,154.08	\$6,062.79
Reservoir Storage	\$6,039.16	\$5,298.89	\$4,428.16	\$6,032.95

8

Table O-11  
Dollar Change in PV of Energy

Alternatives	Change in NPV Mean \$ Million	Change in NPV Median \$ Million	Change in NPV 90% Exceed \$ Million	Change in NPV Trace 94 \$ Million
No Action	\$0.00	\$0.00	\$0.00	\$0.00
Basin States	\$66.10	\$104.55	(\$148.62)	\$759.60
Conservation Before Shortage	\$67.95	\$105.43	(\$134.75)	\$219.84
Water Supply	(\$57.65)	\$88.32	(\$304.01)	\$175.23
Reservoir Storage	\$125.98	\$35.00	(\$29.93)	\$145.39

9

Table O-12.  
Percent Change in PV of Energy

Alternatives	Change in NPV Mean Percent	Change in NPV Median Percent	Change in NPV 90% Exceed Percent	Change in NPV Trace 94 Percent
No Action	0.00%	0.00%	0.00%	0.00%
Basin States	1.12%	1.99%	(3.33%)	12.90%
Conservation Before Shortage	1.15%	2.00%	(3.02%)	3.73%
Water Supply	(0.97%)	1.68%	(6.82%)	2.98%
Reservoir Storage	2.13%	0.66%	(0.67%)	2.47%

10

**O.2.4 Present Value of Capacity and Energy and Capacity Combined**

Table O-13 displays the combined change in NPV of energy in Table O-11 above and capacity in Table O-15 below. The difference values shown in Tables O-11, O-13, and O-15 all refer back to the No Action values shown in Table O-10. Tables O-14 and O-16 are the differences in Table O-13 and O-15 shown as percentages.

Table O-13  
Change in PV, Energy & Capacity

Alternatives	Change in NPV Mean \$ Million	Change in NPV Median \$ Million	Change in NPV 90% Exceed \$ Million	Change in NPV Trace 94 \$ Million
No Action	\$0.00	\$0.00	\$0.00	\$0.00
Basin States	\$75.96	\$125.59	(\$183.66)	\$927.22
Conservation Before Shortage	\$78.11	\$126.43	(\$166.36)	\$272.03
Water Supply	(\$78.86)	\$105.23	(\$374.12)	\$213.56
Reservoir Storage	\$148.67	\$42.48	(\$41.53)	\$176.72

Table O-14  
Percent Change in PV of Capacity

Alternatives	Change in NPV Mean Percent	Change in NPV Median Percent	Change in NPV 90% Exceed Percent	Change in NPV Trace 94 Percent
No Action	0.00%	0.00%	0.00%	0.00%
Basin States	1.28%	2.39%	(4.12%)	15.75%
Conservation Before Shortage	1.32%	2.40%	(3.73%)	4.62%
Water Supply	(1.33%)	2.00%	(8.39%)	3.63%
Reservoir Storage	2.51%	0.81%	(0.93)	3.00%

Table O-15  
Dollar Change in PV of Capacity

Alternatives	Change in NPV Mean \$ Million	Change in NPV Median \$ Million	Change in NPV 90% Exceed \$ Million	Change in NPV Trace 94 \$ Million
No Action	\$0.00	\$0.00	\$0.00	\$0.00
Basin States	\$9.87	\$21.04	(\$35.04)	\$167.62
Conservation Before Shortage	\$10.15	\$21.00	(\$31.61)	\$52.19
Water Supply	(\$21.22)	\$16.91	(\$70.11)	\$38.32
Reservoir Storage	\$22.68	\$7.48	(\$11.61)	\$31.33



1

Table O-16  
Percent Change in PV of Capacity

Alternatives	Change in NPV Mean Percent	Change in NPV Median Percent	Change in NPV 90% Exceed Percent	Change in NPV Trace 94 Percent
No Action	0.00%	0.00%	0.00%	0.00%
Basin States	0.17%	0.40%	(0.79%)	2.85%
Conservation Before Shortage	0.17%	0.40%	(0.71%)	0.89%
Water Supply	(0.36%)	0.32%	(1.57%)	0.65%
Reservoir Storage	0.38%	0.14%	(0.26%)	0.53%

2

**O.2.5 Impact to Western Area Power Administration’s SLCA/IP Firm Power Rate**

3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

Western performed a rate analysis of the present value results summarized in Table O-13 above. Table O-17 shows the results of the analysis on the SLCA/IP firm power rate, while Table O-18 shows the difference of each alternative as compared to the No Action alternative, both in mills/kWh and in percent change. Because of time constraints, the rate analysis was confined to the Median and 90% exceedence hydrological conditions (The 90% exceedence No Action SLCA/IP rate is a cursory study meant to illustrate the higher rate at low hydrologic levels. It shouldn’t be interpreted as the result of a thorough rate PRS.) An explanation of the methodology Western used to perform the rate analysis is presented below Tables O-17 and O-18.

Table O-17  
SLIP Firm Power Rate

Alternatives	Mill/kWh SLIP Rate Median	Mill/kWh SLIP Rate 90% Exceed
No Action	25.28	27.34
Basin States	23.43	29.15
Conservation Before Shortage	23.43	29.13
Water Supply	23.36	28.86
Reservoir Storage	24.89	29.64

14

1

Table O-18  
Change in SLIP Firm Power Rate

Alternatives	Mill/kWh Change in SLIP Rate Median	Percent Change in SLIP Rate Median	Mill/kWh Change in SLIP Rate 90% Exceed	Percent Change in SLIP Rate 90% Exceed
No Action	0.00	0.00%	0.00	0.00%
Basin States	(1.85)	(7.32%)	1.81	6.62%
Conservation Before Shortage	(1.85)	(7.32%)	1.79	6.55%
Water Supply	(1.92)	(7.59%)	1.52	5.56%
Reservoir Storage	(0.39)	(1.54%)	2.30	8.41%

2

### 3 O.3 Customer Rates

4 Western sets rates for firm electric service from Federal hydropower projects in its marketing  
5 territory based on Department of Energy regulations and applicable Federal statutes. Power rates  
6 are calculated using what is referred to as a power repayment study. The PRS is a special  
7 spreadsheet-based computer program that contains the general and any specific repayment rules  
8 associated with a particular hydro project such as the SLCA/IP. [The SLCA/IP comprises the  
9 Colorado River Storage Project (CRSP), Rio Grande, Collbran, Dolores, and Seedskadee  
10 Projects, consolidated for marketing and ratemaking purposes.] When coupled with pertinent  
11 project historical data and future projections, the PRS calculates the power rate that is charged to  
12 customers who receive SLCA/IP power. The PRS ensures that all identified project costs are  
13 repaid within the time frames established by law and regulation.

14 For the rate analysis work done for this report, two base case PRS's were developed. There two  
15 base cases correspond to the power rates for the No Action alternatives at Median and 90%  
16 Exceedence hydrological conditions. The first is basically the same as the PRS Western used for  
17 its current firm power rate. This case is based on Median hydrological conditions, meaning that it  
18 includes firming purchase cost estimates for future years based on Median generation estimates.  
19 The second base case is the same as the first, except that future firming purchase estimates are  
20 based on 90% exceedence (10<sup>th</sup> percentile) estimates of future generation, and firming purchases.

21 These two base case PRS's produce a rate of 25.28 mills per KWh (Median) and 27.34 mills per  
22 KWh (90% Exceedence). Once the base case PRS's are done, the difference in NPV dollars of  
23 each Action alternative as compared to the No Action alternative is inserted into the PRS's and a  
24 change in the power rate is computed. These PRS results are what are displayed in Tables 5 and  
25 5a above.

## 1 O.4 Discussion of Results

2 Overall, at all hydrological conditions, the Reservoir Storage alternative provides the most  
3 favorable conditions for power at GCD, while the Water Supply alternative provides the worst  
4 results for power generation, based on the above financial analysis. The Basin States and  
5 Conservation Before Shortage alternatives show similar results and are ranked between the  
6 Reservoir Storage alternative and the Water Supply alternative in their effect on power resources  
7 at GCD.


8 One result is common to Table 5a as well in the preceding tables. At 90% exceedence level, the  
9 Action alternatives show consistently worse results (lower energy and capacity generation, lower  
10 NPV, higher SLCA/IP rate) than the No Action alternative. Likewise, at Median conditions, the  
11 Action alternatives show better results than the No Action alternative. Results at the Mean  
12 conditions are more mixed, with some results being better under No Action, and others at one or  
13 more of Action alternatives. Trace 94 shows consistent improvement in results of the Action  
14 alternatives as compared to No Action.

15 The practical effect of Action alternatives is to produce a widening effect on power generation,  
16 revenues, and rates as hydrological conditions range from wet to dry and back to wet. As  
17 conditions get drier, generation drops more under the Action alternatives as compared to No  
18 Action. Conversely, as conditions go from drier to wetter, generation improves more under the  
19 Action alternatives as compared to No Action. This could result in more variation in the CRSP  
20 Basin Fund cash reserves, and could lead to additional actions, such as power rate adjustments,  
21 rate surcharges, or reductions to customer allocations to respond to shortfalls in revenue under  
22 dry conditions. Under the Action alternatives, Western and its power customers would need to  
23 quickly respond to changing hydrological conditions to forestall financial problems.

24 Notwithstanding the financial analysis discussed above, the most important aspect of any of the  
25 Action alternatives to Western and the firm power customers is whether and how much the  
26 alternative reduces the probability of a total loss of generation from GCD. Loss of GCD  
27 generation would result in a huge loss of revenue to Western, Reclamation and various  
28 environmental programs in the Upper Basin; loss of generation and replacement costs for power  
29 customers; and degradation to power system reliability.

30 Figure O-8 below is a graph showing the percentage of trace monthly elevations from  
31 Reclamation's CRSS modeling output that are less than or equal to elevation 3490'. This graph is  
32 an indicator of how well each alternative is able to forestall a shutdown of GCD generation as  
33 compared to the No Action alternative.

Figure O-8  
Lake Powell End-of-March Elevations  
Comparison of Action Alternatives to No Action Alternative  
Percent of Values Less Than or Equal to Elevation 3490 feet msl



1  
2 Using this measure, the Water Supply alternative is much worse than the No Action alternative,  
3 while the Reservoir Storage, Basin States, and Conservation before Shortage alternatives are  
4 equal to or slightly better than No Action.

## 5 O.5 References Cited

- 6 Electric Power Information Solutions, Inc. *AURORA—Software for Forecasting Electric Market*  
7 *Price and Value*. West Linn, Oregon: EPIS, Inc. 2005.
- 8 Northwest Power and Conservation Council. *Fifth Northwest Electric Power and Conservation*  
9 *Plan*. Portland, Oregon: Northwest Power and Conservation Council. May 2005. Available  
10 from <http://www.nwcouncil.org/energy/powerplan/plan/Default.htm> .
- 11 Ouarda, Taha B.M.J. John W. Labadie and Darrell G. Fontane. “Indexed Sequential Hydrologic  
12 Modeling for Hydropower Capacity Estimation.” *Journal of the American Water Resources*  
13 *Association*. 33 No. 6 (December 1997):1337-1349.