

accordance with 18 CFR 4.34(b), and 385.2010.

**Magalie R. Salas,**  
Secretary.

[FR Doc. E3-00244 Filed 11-14-03; 8:45 am]

BILLING CODE 6717-01-P

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

#### Notice of Application Accepted for Filing and Soliciting Motions to Intervene and Protest

November 7, 2003.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

a. *Type of Application:* New Major License.

b. *Project No.:* 2114-116.

c. *Date Filed:* October 29, 2003.

d. *Applicant:* Public Utility District No. 2 of Grant County, WA.

e. *Name of Project:* Priest Rapids Hydroelectric Project.

f. *Location:* On the Columbia River in portions of Grant, Yakima, Kittitas, Douglas, Benton, and Chelan counties, Washington. The project occupies federal lands managed by the U.S. Bureau of Land Management, U.S. Bureau of Reclamation, U.S. Department of Energy, U.S. Department of the Army, and U.S. Fish and Wildlife Service.

g. *Filed Pursuant to:* Federal Power Act 16 U.S.C. 791(a)-825(r).

h. *Applicant Contact:* Ms. Laurel Heacock, Licensing Manager, Public Utility District No. 2 of Grant County, 30 C Street S.W., Ephrata, Washington 98823, telephone (509) 754-6622.

i. *FERC Contact:* Charles Hall, telephone (202) 502-6853, e-mail [Charles.Hall@ferc.gov](mailto:Charles.Hall@ferc.gov).

j. *Deadline for filing motions to intervene and protests:* 60 days from the issuance date of this notice.

All documents (original and eight copies) should be filed with: Magalie R. Salas, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426.

The Commission's Rules of Practice require all intervenors filing documents with the Commission to serve a copy of that document on each person on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

Motions to intervene and protests may be filed electronically via the Internet in lieu of paper. The Commission strongly encourages electronic filings. See 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site (<http://www.ferc.gov>) under the "e-Filing" link.

k. This application has been accepted, but is not ready for environmental analysis at this time.

l. The project includes two developments with a total authorized capacity of 1,755 megawatts (MW) as follows:

(a) The Wanapum development consisting of a dam 186.5 feet high and 8,637 feet long with upstream fish passage facilities, a reservoir with an approximate surface area of 14,680 acres, a powerhouse with ten turbine-generator units with a total nameplate capacity of 900 MW, transmission lines, and appurtenant facilities.

(b) The Priest Rapids development consisting of a dam 179.5 feet high and 10,103 feet long with upstream fish passage facilities, a reservoir with an approximate surface area of 7,725 acres, a powerhouse with ten turbine-generator units with a total nameplate capacity of 855 MW, transmission lines, and appurtenant facilities.

m. A copy of the application is available for review at the Commission in the Public Reference Room or may be viewed on the Commission's Web site at <http://www.ferc.gov> using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov) or toll-free at 1-866-208-3676, or for TTY, (202) 502-8659. A copy is also available for inspection and reproduction at the address in item h above.

You may also register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via e-mail of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

n. Anyone may submit a protest or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210, 385.211, and 385.214. In determining the appropriate action to take, the Commission will consider all protests filed, but only those who file a motion to intervene in accordance with the Commission's Rules may become a party to the proceeding. Any protests or motions to intervene must be received on or before the specified deadline date for the particular application.

All filings must (1) bear in all capital letters the title "PROTEST" or "MOTION TO INTERVENE;" (2) set forth in the heading the name of the applicant and the project number of the application to which the filing responds; (3) furnish the name, address, and telephone number of the person protesting or intervening; and (4) otherwise comply with the requirements of 18 CFR 385.2001 through 385.2005. Agencies may obtain copies of the application directly from the applicant. A copy of any protest or motion to intervene must be served upon each representative of the applicant specified in the particular application.

**Magalie R. Salas,**  
Secretary.

[FR Doc. E3-00245 Filed 11-14-03; 8:45 am]

BILLING CODE 6717-01-P

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

#### Notice of Application Accepted for Filing and Soliciting Motions To Intervene and Protests

November 7, 2003.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

a. *Type of Application:* New Minor License.

b. *Project No.:* 2601-007.

c. *Date filed:* July 22, 2003.

d. *Applicant:* Duke Power.

e. *Name of Project:* Bryson Hydroelectric Project.

f. *Location:* The Bryson Project is located on the Oconaluftee River in Swain County, North Carolina. The project does not affect federal lands.

g. *Filed Pursuant to:* Federal Power Act, 16 U.S.C. 791(a)-825(r).

h. *Applicant Contact:* Mr. Jeffrey G. Lineberger; Manager, Hydro Licensing, Duke Power, 526 South Church Street, PO Box 1006, Charlotte, NC 28201-1006.

i. *FERC Contacts:* Lee Emery at (202) 502-8379 or [lee.emery@ferc.gov](mailto:lee.emery@ferc.gov); and Carolyn Holsopple at (202) 502-6407 or [carolyn.holsopple@ferc.gov](mailto:carolyn.holsopple@ferc.gov).

j. *Deadline for filing motions to intervene and protests:* 60 days from the issuance date of this notice.

All documents (original and eight copies) should be filed with: Magalie R. Salas, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426.

The Commission's Rules of Practice require all intervenors filing documents

with the Commission to serve a copy of that document on each person on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

Motions to intervene and protests may be filed electronically via the Internet in lieu of paper. The Commission strongly encourages electronic filings. See 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site (<http://www.ferc.gov>) under the "e-Filing" link.

k. This application has been accepted for filing, but is not ready for environmental analysis at this time.

l. The existing Bryson Hydroelectric Project operates in a run-of-river mode, within a 6-inch tolerance band. Project operation is dependent on available flow in the Oconaluftee River. The project consists of the following features: (1) A 341-foot-long, 36-foot-high concrete multiple arch dam, consisting of, from left to right facing downstream, (a) a concrete, non-overflow section, (b) two gravity spillway sections, each surmounted by a 16.5-foot-wide by 16-foot-high Tainter gate, and (c) an uncontrolled multiple-arch spillway with four bays; (2) a 1.5-mile-long, 38-acre impoundment at elevation 1828.41 mean sea level (msl); (3) two intake bays, each consisting of an 8.5-foot-diameter steel intake pipe with a grated trashrack having a clear bar spacing of between 2.25 to 2.5 inches; (4) a powerhouse having a brick and concrete superstructure and concrete substructure, containing two turbine/generating units, having a total installed capacity of 980 kilowatts (kW); (5) a switchyard, with three single-phased transformers; and (6) appurtenant facilities.

Duke Power estimates that the average annual generation is 5,534,230 kilowatt hours (kWh). Duke Power uses the Bryson Project facilities to generate electricity for use by retail customers living in the Duke Power-Nantahala Area.

m. A copy of the application is available for review at the Commission in the Public Reference Room or may be viewed on the Commission's Web site at <http://www.ferc.gov> using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov) or toll-free at 1-866-208-3676, or for TTY,

(202) 502-8659. A copy is also available for inspection and reproduction at the address in item h above.

You may also register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via e-mail of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

n. Anyone may submit a protest or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210, 385.211, and 385.214. In determining the appropriate action to take, the Commission will consider all protests filed, but only those who file a motion to intervene in accordance with the Commission's Rules may become a party to the proceeding. Any protests or motions to intervene must be received on or before the specified deadline date for the particular application.

When the application is ready for environmental analysis, the Commission will issue a public notice requesting comments, recommendations, terms and conditions, or prescriptions.

All filings must (1) bear in all capital letters the title "PROTEST" or "MOTION TO INTERVENE"; (2) set forth in the heading the name of the applicant and the project number of the application to which the filing responds; (3) furnish the name, address, and telephone number of the person protesting or intervening; and (4) otherwise comply with the requirements of 18 CFR 385.2001 through 385.2005. Agencies may obtain copies of the application directly from the applicant. A copy of any protest or motion to intervene must be served upon each representative of the applicant specified in the particular application.

**Magalie R. Salas,**  
Secretary.

[FR Doc. E3-00246 Filed 11-14-03;8:45 am]

**BILLING CODE 6717-01-P**

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

#### Notice of Application Accepted for Filing and Soliciting Motions To Intervene and Protests

November 7, 2003.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

a. *Type of Application:* New Minor License.

b. *Project No.:* 2602-005.

c. *Date filed:* July 22, 2003.

d. *Applicant:* Duke Power.

e. *Name of Project:* Dillsboro Hydroelectric Project.

f. *Location:* The Dillsboro Project is located on the Tuckasegee River in Jackson County, North Carolina. The project does not affect federal lands.

g. *Filed Pursuant to:* Federal Power Act, 16 U.S.C. 791(a)—825(r).

h. *Applicant Contact:* Mr. Jeffrey G. Lineberger; Manager, Hydro Licensing, Duke Power, 526 South Church Street, P.O. Box 1006, Charlotte, NC 28201-1006.

i. *FERC Contacts:* Lee Emery at (202) 502-8379 or [lee.emery@ferc.gov](mailto:lee.emery@ferc.gov); and Carolyn Holsopple at (202) 502-6407 or [carolyn.holsopple@ferc.gov](mailto:carolyn.holsopple@ferc.gov).

j. *Deadline for filing motions to intervene and protests:* 60 days from the issuance date of this notice.

All documents (original and eight copies) should be filed with: Magalie R. Salas, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426.

The Commission's Rules of Practice require all intervenors filing documents with the Commission to serve a copy of that document on each person on the official service list for the project.

Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

Motions to intervene and protests may be filed electronically via the Internet in lieu of paper. The Commission strongly encourages electronic filings. See 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site (<http://www.ferc.gov>) under the "e-Filing" link.

k. This application has been accepted for filing, but is not ready for environmental analysis at this time.

l. The existing Dillsboro Hydroelectric Project operates in a run-of-river mode, within a 6-inch tolerance band. Project operation is dependent on available flow in the Tuckasegee River, which is dependent on Duke Power's East Fork (FERC No. 2698) and West Fork (FERC No. 2686) Tuckasegee River projects. The Dillsboro Project consists of the following features: (1) A 310-foot-long, 12-foot-high concrete masonry dam, consisting of, from left to right facing downstream, (a) a concrete, non-overflow section, (b) a 14-foot-long uncontrolled spillway section, (c) a 20-foot-long spillway section with two 6-foot-wide spill gates, (d) a 197-foot-long uncontrolled spillway section, (e)