November 19, 2001

LICENSEE: FirstEnergy Nuclear Operating Company

FACILITY: Davis-Besse Nuclear Power Station, Unit 1

SUBJECT: MEETING SUMMARY OF NOVEMBER 14, 2001, TO DISCUSS THE

LICENSEE'S RESPONSE TO BULLETIN 2001-01

On November 14, 2001, Nuclear Regulatory Commission (NRC) management and staff met in Rockville, Maryland, with representatives of FirstEnergy Nuclear Operating Company and their contractors. The meeting was requested by the licensee in order to supplement their response to NRC Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles." The licensee has proposed deferring inspections recommended by the bulletin to their 13th refueling outage which is scheduled to begin in March 2002. The bulletin recommends that inspections be performed prior to December 31, 2001. A list of the meeting participants is included as Enclosure 1. The meeting handouts are included as Enclosure 2.

As described in the licensee's handouts, the purpose of the meeting was to (1) discuss the licensee's revised probabilistic safety assessment based upon comments received from the staff during the meeting of November 9, 2001, (2) discuss comparisons between plant-specific allowable flaw size and flaw size as calculated by NRC (EMC2) and Electric Power Research Institute MRP-44, and (3) answer NRC questions concerning the licensee's responses to the staff's requests for additional information and other submittals.

At the conclusion of the meeting, the licensee offered to docket any additional information that the staff considered necessary to complete their review. In addition, the licensee requested their desire to obtain a copy of the staff's proprietary technical assessment report and suggested that a confidentiality agreement be prepared to expedite its release.

/RA/

Stephen P. Sands, Project Manager, Section 2 Project Directorate III Division of Licensing Projects Management Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosures: 1. List of Meeting Participants

2. Meeting Handout

cc w/encls: See next page

LICENSEE: FirstEnergy Nuclear Operating Company November 19, 2001

FACILITY: Davis-Besse Nuclear Power Station, Unit 1

SUBJECT: MEETING SUMMARY OF NOVEMBER 14, 2001, TO DISCUSS THE

LICENSEE'S RESPONSE TO BULLETIN 2001-01

On November 14, 2001, Nuclear Regulatory Commission (NRC) management and staff met in Rockville, Maryland, with representatives of FirstEnergy Nuclear Operating Company and their contractors. The meeting was requested by the licensee in order to supplement their response to NRC Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles." The licensee has proposed deferring inspections recommended by the bulletin to their 13th refueling outage which is scheduled to begin in March 2002. The bulletin recommends that inspections be performed prior to December 31, 2001. A list of the meeting participants is included as Enclosure 1. The meeting handouts are included as Enclosure 2.

As described in the licensee's handouts, the purpose of the meeting was to (1) discuss the licensee's revised probabilistic safety assessment based upon comments received from the staff during the meeting of November 9, 2001, (2) discuss comparisons between plant-specific allowable flaw size and flaw size as calculated by NRC (EMC2) and Electric Power Research Institute MRP-44, and (3) answer NRC questions concerning the licensee's responses to the staff's requests for additional information and other submittals.

At the conclusion of the meeting, the licensee offered to docket any additional information that the staff considered necessary to complete their review. In addition, the licensee requested their desire to obtain a copy of the staff's proprietary technical assessment report and suggested that a confidentiality agreement be prepared to expedite its release.

/RA/

Stephen P. Sands, Project Manager, Section 2 Project Directorate III Division of Licensing Projects Management Office of Nuclear Reactor Regulation

Docket No. 50-346 **DISTRIBUTION:**

PUBLIC PD3-2 r/f SSands
Enclosures: 1. List of Meeting Participants
2. Meeting Handout

PUBLIC PD3-2 r/f SSands
OGC ACRS SBajwa
JZwolinski/TMarsh AMendiola
THarris TBergman GGrant, RIII

cc w/encls: See next page WBateman RBarrett KWichman

AHiser GLongo ALee

ADAMS ACCESSION NO. ML013190336 SRosenberg JChung DLoveless

LBurkhart DPickett

OFFICE	PM:PDIII-2		LA:PDIII-2		SC:EMCB		SC:PDIII-2	
NAME	S Sands/ DVP for /		T Harris		K Wichman		A Mendiola	
DATE	11/16/01		11/16/01		11/19/01		11/19/01	

Mr. Guy G. Campbell FirstEnergy Nuclear Operating Company

Davis-Besse Nuclear Power Station, Unit 1

CC:

Mary E. O'Reilly FirstEnergy 76 South Main Street Akron, OH 44308

Manager - Regulatory Affairs FirstEnergy Nuclear Operating Company Davis-Besse Nuclear Power Station 5501 North State - Route 2 Oak Harbor, OH 43449-9760

Jay E. Silberg, Esq. Shaw, Pittman, Potts and Trowbridge 2300 N Street, NW. Washington, DC 20037

Regional Administrator U.S. Nuclear Regulatory Commission 801 Warrenville Road Lisle, IL 60523-4351

Michael A. Schoppman Framatome ANP 1700 Rockville Pike, Suite 525 Rockville, MD 20852

Resident Inspector U.S. Nuclear Regulatory Commission 5503 North State Route 2 Oak Harbor, OH 43449-9760

Plant Manager
FirstEnergy Nuclear Operating Company
Davis-Besse Nuclear Power Station
5501 North State - Route 2
Oak Harbor, OH 43449-9760

Dennis Clum
Radiological Assistance Section Supervisor
Bureau of Radiation Protection
Ohio Department of Health
P.O. Box 118
Columbus, OH 43266-0118

Carol O'Claire, Chief, Radiological Branch Ohio Emergency Management Agency 2855 West Dublin Granville Road Columbus, OH 43235-2206

Director
Ohio Department of Commerce
Division of Industrial Compliance
Bureau of Operations & Maintenance
6606 Tussing Road
P.O. Box 4009
Reynoldsburg, OH 43068-9009

Ohio Environmental Protection Agency DERR--Compliance Unit ATTN: Zack A. Clayton P.O. Box 1049 Columbus, OH 43266-0149

State of Ohio Public Utilities Commission 180 East Broad Street Columbus, OH 43266-0573

Attorney General
Department of Attorney
30 East Broad Street
Columbus, OH 43216

President, Board of County Commissioners of Ottawa County Port Clinton, OH 43252

LIST OF MEETING PARTICIPANTS

NOVEMBER 14, 2001

NRC FirstEnergy Nuclear Operating Company

Bill Bateman Steve Moffitt
Richard Barrett Dave Geisen
Keith Wichman Kendall Byrd
Allen Hiser David Lockwood
Giovanna Longo Gerald Wolf

Andrea Lee Andrew Siemaozkio

Stacey Rosenberg

Jin Chung
David Loveless
Larry Burkart
Doug Pickett

Framatome ANP Akin, Gump, Strauss, Hauer, & Feld, L.L.P.

Bob Enzinna Roy Lessy

Ken Yoon Steve Fyhtitch

Stephen Mazurkiewicz