

November 29, 2001

LICENSEE: Indiana Michigan Power Company

FACILITY: Donald C. Cook mNuclear Plant , Unit 2

SUBJECT: MEETING SUMMARY OF NOVEMBER 20, 2001, TO DISCUSS THE LICENSEE'S RESPONSE TO BULLETIN 2001-01 (TAC NOS. MB2624 AND MB2625)

On November 20, 2001, Nuclear Regulatory Commission (NRC) management and staff met in Rockville, Maryland, with representatives of Indiana Michigan Power Company and their contractors. The meeting was to allow the licensee to provide additional information to supplement their response to NRC Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles." The licensee has proposed deferring inspections recommended by the bulletin for Unit 2 until their next refueling outage which is scheduled to begin on January 19, 2002. The bulletin recommends that inspections be performed prior to December 31, 2001. A list of the meeting participants is included as Enclosure 1. The meeting handouts are included as Enclosure 2.

As described in the licensee's handouts, the licensee provided information concerning (1) comparisons between plant-specific allowable flaw size and flaw size as calculated by NRC (EMC2) and Electric Power Research Institute MRP-44, (2) the licensee's probabilistic safety assessment and (3) the proposed inspection scope.

At the conclusion of the meeting, the licensee offered to docket any additional information that the staff considered necessary to complete their review.

/RA/

John F. Stang , Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Projects Management
Office of Nuclear Reactor Regulation

Docket No. 50-316

Enclosures: 1. List of Meeting Participants
2. Meeting Handout

cc w/encls: See next page

LICENSEE: Indiana Michigan Power Company November 29, 2001

FACILITY: Donald C. Cook mNuclear Plant , Unit 2

SUBJECT: MEETING SUMMARY OF NOVEMBER 20, 2001, TO DISCUSS THE LICENSEE'S RESPONSE TO BULLETIN 2001-01 (TAC NOS. MB2624 AND MB2625)

On November 20, 2001, Nuclear Regulatory Commission (NRC) management and staff met in Rockville, Maryland, with representatives of Indiana Michigan Power Company and their contractors. The meeting was to allow the licensee to provide additional information to supplement their response to NRC Bulletin 2001-01, "Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles." The licensee has proposed deferring inspections recommended by the bulletin for Unit 2 until their next refueling outage which is scheduled to begin on January 19, 2002. The bulletin recommends that inspections be performed prior to December 31, 2001. A list of the meeting participants is included as Enclosure 1. The meeting handouts are included as Enclosure 2.

As described in the licensee's handouts, the licensee provided information concerning (1) comparisons between plant-specific allowable flaw size and flaw size as calculated by NRC (EMC2) and Electric Power Research Institute MRP-44, (2) the licensee's probabilistic safety assessment and (3) the proposed inspection scope.

At the conclusion of the meeting, the licensee offered to docket any additional information that the staff considered necessary to complete their review.

/RA/

John F. Stang , Senior Project Manager, Section 1
Project Directorate III
Division of Licensing Projects Management
Office of Nuclear Reactor Regulation

Docket No. 50-316

Enclosures: 1. List of Meeting Participants
2. Meeting Handout

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	PD3-2 r/f	SSands
OGC	ACRS	SBajwa
JZwolinski/TMarsh		AMendiola
THarris	TBergman	GGrant, RIII
WBateman	RBarrett	KWichman
AHiser	GLongo	ALee
SRosenberg	JChung	LBurkhart

ADAMS ACCESSION NO. ML013310065

OFFICE	PM:PDIII-1	LA:PDIII-1	SC:EMCB	ASC:PDIII-1
NAME	J Stang	T Harris	K Wichman	W Reckley
DATE	11/28/01	11/28/01	11/29/01	11/29/01

OFFICIAL RECORD COPY

LIST OF MEETING PARTICIPANTS

NOVEMBER 20, 2001

NAMES

AFFILIATION

John Lamb	NRC
John Stang	NRC
Deann Raleigh	Lis. Science
Mike Rencheck	AEP
Chris Bakken	AEP
T. Satyan Shama	AEP
Robert Perdue	Westinghouse
Jim Hawley	AEP
Dan Garner	AEP
Warren Bamford	Westinghouse
Selim Sancaletar	Westinghouse
Scot Greenlee	AEP
Roger Huston	LSS
Toby Woods	AEP
Jay Collins	NRR
Matthew McConnell	NRR
Anne Passarelli	NRR
Andrea Lee	NRR
Allen Hiser	NRR
Steve Long	NRR
B. P. Jain	NRR
Rich Barrett	NRR
Bill Bateman	NRR
JStrosnider	NRR
S. Bajwa	NRR
L. Burkhart	NRR
W. Reckley	NRR
M. Young	NRC
D. Hood	NRR
B. Sheron	NRR
M. Rencheck	AEP
Daniel Horner	McGraw-Hill
J. Beall	NRC
Sam Collins	NRC
Mitz Young	NRC
Jin Chung	NRR

Donald C. Cook Nuclear Plant, Units 1 and 2

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, MI 48913

Township Supervisor
Lake Township Hall
P.O. Box 818
Bridgman, MI 49106

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
7700 Red Arrow Highway
Stevensville, MI 49127

David W. Jenkins, Esquire
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Mayor, City of Bridgman
P.O. Box 366
Bridgman, MI 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, MI 48909

Drinking Water and Radiological
Protection Division
Michigan Department of
Environmental Quality
3423 N. Martin Luther King Jr Blvd
P.O. Box 30630, CPH Mailroom
Lansing, MI 48909-8130

Ronald Gaston
Director, Regulatory Affairs
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

David A. Lochbaum
Union of Concerned Scientists
1616 P Street NW, Suite 310
Washington, DC 20036-1495

A. Christopher Bakken, Site Vice President
Indiana Michigan Power Company
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106

Michael W. Rencheck
Vice President, Nuclear Engineering
Indiana Michigan Power Company
Nuclear Generation Group
500 Circle Drive
Buchanan, MI 49107