

United States Department of the Interior

BUREAU OF RECLAMATION

Great Plains Region Montana Area Office P.O. Box 30137 Billings, Montana 59107-0137



REFER TO: MT-450

August 29, 2006

FAXOGRAM: Water Order Change

To: Chief, Power Supply and Billing Division, WAPA, Watertown, South Dakota

Attention: F-6001

Chief, Power Dispatching Branch, WAPA, Loveland, Colorado

Attention: J-4120

Facilities Manager, Hardin, Montana Attention: MT-300: Tom Tauscher Project Manager, Mills, Wyoming

Attention: WY-4000, WY-4100, WY-6400

Assistant Superintendent, National Park Service, Lovell, Wyoming

Attention: Jim Staebler

From: Reservoir and River Operations, Billings, Montana

Subject: Yellowtail Water Release Order - BHR No. 06-37

CURRENT RESERVOIR CONDITIONS:

Elevation: 3598.65; Storage: 737,181 acre-feet; River Release: 1,500 cfs; Inflow: 1,745 cfs;

GENERAL COMMENTS:

The BIA requested a reduction in diversions to the Bighorn Canal. In response, this FAXOGRAM confirms the actual operation change that was made at Yellowtail Dam and Powerplant on August 28, 2006.

NOTE: This is the time period when fish are more susceptible to high levels of nitrogen gas super-saturation. To provide a more desirable mixing flow of approximately 75% through the spillway gates and 25% through the sluice gates to maintain the total gas super-saturation levels at safe limits, the minimum Afterbay elevation should be maintained at or above elevation 3183 whenever possible. This is only a soft limit and may be deviated from during special or emergency operations.

TURBINE RELEASES:

Beginning at 1500 hour on Monday, August 28, 2006:

Decrease average daily turbine release to 1,880 cfs (\approx 1,050 MW-Hrs/day using 43.0 cfs/mw).

AFTERBAY RELEASE AND OPERATION:

Beginning at 1500 hour on Monday, August 28, 2006:

Increase diversions to the Bighorn Canal to 450 cfs (gage height at 74.41 using a shift of -0.28). Maintain river release at 1,500 cfs (gage height at 59.30 using shift of -0.23). Maintain total release from the Afterbay at 1,950 cfs.