



IN REPLY REFER TO: MT-450

United States Department of the Interior

BUREAU OF RECLAMATION

Great Plains Region

Montana Area Office

P.O. Box 30137

Billings, Montana 59107-0137



December 11, 2006

FAXOGRAM: Water Order Change

To: Chief, Power Supply and Billing Division, WAPA, Watertown, South Dakota
Attention: F-6001
Chief, Power Dispatching Branch, WAPA, Loveland, Colorado
Attention: J-4120
Facilities Manager, Hardin, Montana
Attention: MT-300: Tom Tauscher
Project Manager, Mills, Wyoming
Attention: WY-4000, WY-4100, WY-6400
Assistant Superintendent, National Park Service, Lovell, Wyoming
Attention: Jim Staebler

From: Reservoir and River Operations, Billings, Montana

Subject: **Yellowtail Water Release Order - BHR No. 07-08**

CURRENT RESERVOIR CONDITIONS:

Elevation: 3611.06; Storage: 810,002 acre-feet; River Release: 1,500 cfs; Inflow: 1,355 cfs;

GENERAL COMMENTS:

Power generation indicates actual river flows are higher than anticipated. In response, the following operation changes are required at Yellowtail Dam and Powerplant, applying a new shift to the river stage.

NOTE: This is the time period when fish are less affected by high levels of nitrogen gas super-saturation. Since mixing flows through the spillway gates and through the sluice gates is not required at this time, it is still desirable to provide a mixing flow of approximately 75% through the spillway gates and 25% through the sluice gates whenever the level of the Afterbay allows for the flows to be released through the spillway gates.

TURBINE RELEASES:

At 1600 hour on Monday, December 11, 2006:

Maintain average daily turbine release at 1,430 cfs (\approx 907 MW-Hrs/day using 37.8 cfs/mw).

AFTERBAY RELEASE AND OPERATION:

At 1600 hour on Monday, December 11, 2006:

Maintain diversions to the Bighorn Canal at 0 cfs.

Maintain river release at 1,500 cfs (decrease gage height to 60.05 and apply a shift of -0.98).

Maintain total release from the Afterbay at 1,500 cfs.

/S/ Tim H. Felchle