



IN REPLY REFER TO: MT-450

United States Department of the Interior

BUREAU OF RECLAMATION

Great Plains Region

Montana Area Office

P.O. Box 30137

Billings, Montana 59107-0137



June 2, 2006

FAXOGRAM: Water Order Change

To: Chief, Power Supply and Billing Division, WAPA, Watertown, South Dakota
Attention: F-6001
Chief, Power Dispatching Branch, WAPA, Loveland, Colorado
Attention: J-4120
Facilities Manager, Helena, Montana
Attention: MT-682, MT669
Project Manager, Mills, Wyoming
Attention: WY-4000, WY-4100, WY-6400
PPL Energy Plus, LLC, Butte, Montana
Attention: Resource Coordinator, Lance Elias

From: Reservoir and River Operations, Billings, Montana

Subject: **Canyon Ferry Water Release Order - CFR No. 06-24**

CURRENT RESERVOIR CONDITIONS:

Elevation: 3787.14; Storage: 1,573,059 acre-feet; River Release: 4,235 cfs; Inflow: 9,320 cfs;

GENERAL COMMENTS:

The snowmelt runoff into Canyon Ferry has peaked and is quickly receding. To conserve storage and allow Canyon Ferry to continue filling, the following operation change is required at Canyon Ferry Dam.

CANYON FERRY RELEASES AND OPERATIONS: All times are Mountain Daylight Savings Time (MDST)

At 0100 hour on Monday, June 5, 2006:

Maintain releases through the river outlet gates at 0 cfs.

Maintain releases through the spillway gates at 0 cfs.

Decrease turbine releases to 3,300 cfs (\approx 795 MW-Hrs/day using 99.7 cfs/mw).

Maintain releases for Helena Valley Project at 745 cfs (355 cfs pumped to Helena Valley and 390 cfs discharged to the Missouri River).

Decrease average daily release to the Missouri River to about 3,690 cfs.

Decrease average total release from Canyon Ferry to about 4,045 cfs.

/S/ Tim H. Felchle