1 Introduction

1.1 PURPOSE

The number of tornadoes that occurred on May 3, 1999, in Oklahoma and Kansas, their severity, and the level of devastation they caused have not been seen in a generation within the United States. One of the missions of the Federal Emergency Management Agency (FEMA) that directly supports the *National Mitigation Strategy* is:

to significantly reduce the risk of loss of life, injuries, economic costs and destruction of natural and cultural resources that result from natural hazards.

In response to the disasters caused by the May 3 tornadoes, FEMA deployed a Building Performance Assessment Team (BPAT), composed of national experts in engineering, architecture, meteorology, and planning, to Oklahoma and Kansas. The mission of the BPAT was to assess the performance of buildings affected by the tornadoes, investigate losses, and describe the lessons learned. This report presents the BPATs observations, conclusions, and recommendations, which are intended to help communities, businesses, and individuals reduce future injuries and the loss of life and property resulting from tornadoes and other high-wind events.

1.2 TEAM COMPOSITION

The BPAT included FEMA Headquarters and Regional Office engineers and staff; a meteorologist; planners; architects; wind engineers; structural engineers; and forensic engineers. The members of the BPAT are listed in the appendix of this report.

1.3 METHODOLOGY

The FEMA Mitigation Directorate deployed the BPAT to Oklahoma and Kansas on May 10, 1999. The team inspected both residential and non-residential buildings, as discussed below. By assessing the performance of these buildings, the team was able to develop technical guidance concerning new construction and post-tornado reconstruction for state and local governments, building owners, architects, engineers, and contractors.

In addition to assessing building performance, the BPAT:

• inspected shelter areas in public buildings (e.g., schools, churches, day care centers, nursing homes),

CHAPTER 1 PRELIMINARY REPORT

• investigated successes and failures of existing shelters during the tornadoes, and

 evaluated existing tornado response plans within buildings intended for high occupancy such as schools and private industry facilities.

Field investigations began on May 10 and were conducted through May 18. In Oklahoma, inspections were made in Bridge Creek (about 50 miles southwest of Oklahoma City); the Oklahoma City metroplex, including the suburbs of Moore, Del City, and Midwest City; the Project Impact community of Tulsa; and Stroud and Mulhall. In Kansas, inspections were made in unincorporated Sedgwick County, the City of Haysville, and Wichita, Kansas.

BPATs frequently conduct aerial assessments of damage areas to gather general data on damage sites, acquire aerial photographs of those sites, and determine the focus and final composition of the BPAT. For the May 3 tornado disasters, adequate information was provided to the team by the FEMA Disaster Field Offices (DFOs) and by state and local government agencies. Therefore, the BPAT did not conduct an aerial assessment of the damage areas.

The BPAT inspected the following types of residential buildings:

- single- and multi-family, one- to two-story wood-frame houses
- manufactured and modular homes
- accessory structures

Many of the houses inspected in Kansas were constructed on basement or crawlspace foundations; most of the houses inspected in Oklahoma were constructed on slab-on-grade foundations. From its observations, the BPAT formed conclusions concerning the structural performance of residential buildings exposed to the May 3 tornadoes. The BPAT also formed conclusions regarding exterior architectural systems; those conclusions focus on roof coverings, brick veneer and other siding materials, windows, garage doors, and masonry chimneys.

The non-residential building types observed included the following:

- tilt-up pre-cast concrete walls with steel joists
- load-bearing masonry walls with steel joists
- load-bearing masonry with pre-cast concrete hollow-core floor and roof slabs
- pre-engineered metal buildings (light steel frames)
- buildings constructed of laminated wood arches with wood framing
- buildings with masonry veneer and pre-cast concrete floors

PRELIMINARY REPORT INTRODUCTION CHAPTER 1

- industrial plants
- a regional shopping outlet mall
- public use buildings inspected include a hospital, nursing homes, day care centers, hotels, schools

Other important issues such as windborne debris (missiles), personal protection, and sheltering were investigated and are discussed in individual sections of this report.

FEMA encouraged the participation of state and county government officials and locally based experts in the assessment process. Their involvement was critical because it helped to:

- ensure that state and local building code and other requirements were properly interpreted,
- increase the likelihood that local construction practices were fully appreciated and understood,
- establish positive relationships among Federal, state, and local governments and the private sector, and
- encourage the development of recommendations that were both economically and technically realistic.

Under this premise, the BPAT met with local government officials upon arriving in Oklahoma and Kansas to "partner" in the overview and identification of damage areas. Team members were briefed by staff members of the FEMA regional DFOs and representatives of state, county, and local government agencies on the extent and types of damage. GIS maps were provided and reviewed in order to select field investigation sites and establish an itinerary (Figure 1-1).

CHAPTER 1 PRELIMINARY REPORT

FIGURE 1-1: BPAT meeting with State of Kansas and local government officials in Wichita, Kansas.



FIGURE 1-2: Meeting with local fire official in Midwest City, Oklahoma. Photo to be added later.

PRELIMINARY REPORT INTRODUCTION CHAPTER 1

Collectively, the team spent over 2,000 hours in the field conducting site investigations and inspecting damage. Documentation of observations made during the site visits included field notes and photographs. The BPAT's mission did not include recording the numbers of buildings damaged by the tornadoes, determining the frequency of specific types of damage, or collecting data that could serve as the basis of statistical analysis.

1.4 PRESENTATION OF FINDINGS

The observations, conclusions, and recommendations in this report are grouped to address issues concerning (1) residential property protection, (2) non-residential property protection, and (3) personal protection and sheltering.

Table 1-1 correlates the BPAT's findings with the Fujita damage scale (which ranks tornadoes according to the damage they cause) and general tornado intensity in terms that will be used throughout this report. For the purposes of this report, tornado intensity is referred to by the three categories listed in Table 1-1: moderate, severe, and violent. When appropriate, damage observations in this report are presented in terms of the Fujita scale ratings. Table 1-1 is intended to help the reader better understand tornadoes, the damage associated with them, and how mitigation efforts can be made to reduce the property damage and loss of life caused by tornadoes. Further discussions regarding the makeup of a tornado, the damage associated with the winds of a tornadic event and the Fujita scale are presented in Chapter 2.

This report is intended to provide information related to mitigation efforts that communities, businesses, and individuals can undertake to reduce future injuries and the loss of life and property. It is not the intent of this report to re-classify the strength of the May 3 tornadoes or the ratings of the damage observed, or to debate the magnitude of the wind speeds associated with those tornadoes. The Fujita scale ratings mentioned in this report are based on preliminary ratings issued by the local National Weather Service (NWS) offices in Oklahoma and Kansas after the tornado outbreaks. The National Severe Storms Laboratory (NSSL) in Norman, Oklahoma, provided additional preliminary information regarding the tornadoes.

TABLE 1-1

The BPAT Damage Assessment Table

9	SU	ale)S	ale alemain	cinal	peris polection	ening longer long
TOTAL TOTAL		Enite of the	adold mogalily	Wades .	pasala	Shelte
(5		large, medium, and	Protecting entire	Must have a structure or	To attain near
)	VIOLENT	small air-	buildings is	room specifically	absolute
	ļ		rolling debris	al and	engineered for	a shelter
VIOLENT	Z.		١	impractical.	extreme wind protection.	should be constructed
						within or
	9		medium and	Voluntary	Additional	adjacent to a
	?		small air-	retrofits	strengthening	home, office,
			borne and	strengthen	of building	or business
N'		SEVERE	rolling debris	homes and	structure and	that is built
)	£			sbullalina	roduco riek	
	7			with existing	leduce HSN.	accordance
OCVERE.				technology.		With FEMA
The State of the S	Ì		small air-	Constructing	Constructing	or the
			borne and	to newer	puilding	National
			rolling debris	building	envelope to	Performance
		MODERATE		codes and	newer building	Criteria for
() ()	Ç			standards	codes and	Tornado
	2			strengthens	standards	Shelters.
₽ MODERA IE				buildings.	minimizes risk	