

**POTENTIAL INTERFERENCE FROM
BROADBAND OVER POWER LINE (BPL)
SYSTEMS TO FEDERAL GOVERNMENT
RADIOCOMMUNICATION SYSTEMS
AT 1.7 - 80 MHz**

Phase 2 Study

VOLUME II



technical report

NTIA Report 08-450

**POTENTIAL INTERFERENCE FROM BROADBAND OVER
POWER LINE (BPL) SYSTEMS TO FEDERAL GOVERNMENT
RADIOCOMMUNICATION SYSTEMS AT 1.7 - 80 MHz**

Phase 2 Study

VOLUME II

**James C. Richards
Jonathan V. Williams**



**U.S. Department of Commerce
Carlos M. Gutierrez, Secretary**

John M. R. Kneuer, Assistant Secretary
for Communications and Information

October 2007

VOLUME II
TABLE OF CONTENTS

TECHNICAL APPENDICES

TABLE OF CONTENTS	iii	
GLOSSARY	iv	
APPENDIX A	ANTENNA MEASUREMENT HEIGHT	
A.1	Introduction	A-1
A.2	Height of Peak Field Strength	A-1
A.3	Compliance Measurement Height for Operation Between 1.7 – 30 MHz	A-10
A.4	Compliance Measurement Height for Operation at 30 MHz and Above	A-53
A.5	Height Correction Factor Above 30 MHz	A-62
APPENDIX B	MEASUREMENT DISTANCE ALONG THE POWER LINE	
B.1	Introduction	B-1
B.2	Simulation Results	B-1
APPENDIX C	MEASUREMENT DISTANCE EXTRAPOLATION	
C.1	Introduction	C-1
C.2	BPL Field Strength Simulation Results	C-1
C.2.1	Extrapolated Field Strength Levels Meeting the Part 15 Limits ...	C-1
C.2.2	Simulation Results	C-2
APPENDIX D	SPECIAL PROTECTION PROVISIONS	
D.1	Excluded Frequency Bands	D-1
D.2	Exclusion Zones	D-2
D.2.1	Coast Stations	D-2
D.2.2	Radioastronomy Observatories	D-5
D.3	Consultation Areas	D-7

GLOSSARY

AWG	American Wire Gauge
BPL	Broadband over Power Line(s)
BW	Bandwidth
CISPR	International Special Committee on Radio Interference
CONUS	Continental United States
COTHEN	Customs Over The Horizon Enforcement Network
dB	Decibel
dBi	Decibel referenced to an isotropic radiator
dBm	Decibel referenced to 1 milliwatt
dB μ V	Decibel referenced to 1 microvolt
dBW	Decibels referenced to 1 Watt
E	Electric Field Strength
EMC	Electromagnetic Compatibility
EUT	Equipment Under Test
FCC	Federal Communications Commission
G	Gain
GHz	Gigahertz
H	Magnetic Field Strength
HF	High Frequency
Hz	Hertz
I	Interference Power
ICAO	International Civil Aviation Organization
IRAC	Interdepartment Radio Advisory Committee
ITM	Irregular Terrain Model
ITS	Institute for Telecommunication Sciences
ITU	International Telecommunication Union
ITU-R	International Telecommunication Union Radiocommunication Sector
kHz	Kilohertz
km	Kilometer
LV	Low Voltage
m	Meter
MHz	Megahertz
mm	millimeter
mS	Siemens/meter
ms	Millisecond
MV	Medium Voltage
N	Noise Power
NEC	Numerical Electromagnetic Code
NOI	Notice of Inquiry
NPRM	Notice of Proposed Rulemaking
NTIA	National Telecommunications and Information Administration
OR	Off-Route

OTH	Over the Horizon
PFD	Power Flux Density
PLC	Power Line Communications
PLT	Power Line Telecommunications
R	Route
RF	Radio Frequency
RMS	Root Mean Square
RSMS	Radio Spectrum Measurement System
S	Signal Power
SNR	Signal-to-Noise Ratio
SSB	Single Sideband
SSN	Smoothed Sunspot Number
URD	Underground Residential Distribution
US&P	United States and Possessions
UTC	Universal Coordinated Time
VHF	Very High Frequency
VLA	Very Large Array
VOA	Voice of America
VOACAP	Voice of America Coverage Analysis Program
W	Watt
μA	Microampere
μV	Microvolt

APPENDIX A

MEASUREMENT ANTENNA HEIGHT

A.1 INTRODUCTION

Section A.2 describes NTIA's Numerical Electromagnetics Code (NEC) simulation results showing the height where the peak field strength is expected in close proximity to an Access Broadband over Power Line (BPL) system operating on overhead Medium Voltage (MV) power lines. Section A.3 shows the effectiveness of the 1 meter measurement height in estimating the peak field strength at frequencies between 1.7 and 30 MHz. Section A.4 provides results from simulations performed in the 30 – 50 MHz range, using the 1 to 4 meter measurement height range defined in the compliance measurement guidelines for Access BPL systems operating above 30 MHz. In Section A.5, the optional 5-dB height correction factor for measurements at a 1 meter height is compared to the use of the 1 to 4 meter measurement height for the various power line simulations at frequencies above 30 MHz.

A.2 HEIGHT OF PEAK FIELD STRENGTH

Figures A-1 through A-18 show the heights where the peak electric field strength occurred over the frequency range of 2 to 50 MHz for the NEC power line models described in Section 2.2. The height of the modeled power lines was 12 meters. These results assume field strength values are calculated at a horizontal distance of 10 meters.




Figure A-1: Height corresponding to peak electric field strength as a function of frequency




Figure A-2: Height corresponding to peak electric field strength as a function of frequency




Figure A-3: Height corresponding to peak electric field strength as a function of frequency




Figure A-4: Height corresponding to peak electric field strength as a function of frequency




Figure A-5: Height corresponding to peak electric field strength as a function of frequency




Figure A-6: Height corresponding to peak electric field strength as a function of frequency




Figure A-7: Height corresponding to peak electric field strength as a function of frequency




Figure A-8: Height corresponding to peak electric field strength as a function of frequency




Figure A-9: Height corresponding to peak electric field strength as a function of frequency




Figure A-10: Height corresponding to peak electric field strength as a function of frequency




Figure A-11: Height corresponding to peak electric field strength as a function of frequency




Figure A-12: Height corresponding to peak electric field strength as a function of frequency




Figure A-13: Height corresponding to peak electric field strength as a function of frequency




Figure A-14: Height corresponding to peak electric field strength as a function of frequency




Figure A-15: Height corresponding to peak electric field strength as a function of frequency




Figure A-16: Height corresponding to peak electric field strength as a function of frequency




Figure A-17: Height corresponding to peak electric field strength as a function of frequency




Figure A-18: Height corresponding to peak electric field strength as a function of frequency

A.3 COMPLIANCE MEASUREMENT HEIGHT FOR OPERATION BETWEEN 1.7 - 30 MHz

The Federal Communication Commission (Commission or FCC) Part 15 measurement guidelines specify that below 30 MHz, measurements are to be made with the antenna positioned at a height of 1 meter. In Section A.2, the height corresponding to the peak field strength was often located well above the 1 meter measurement height. The following plots show a comparison between the peak field strength determined from the measurement guidelines and the 80th percentile of peak electric field strength at any height along the length of the power line. The 80th percentile values eliminate the localized peaks that are unlikely to be encountered by a radio receiver randomly located in close proximity to an Access BPL power line.¹ The plots are shown for a number of NEC power line models at frequencies from 2 to 28 MHz.

¹ See NTIA Comments, at Technical Appendix, pp. 2-18.

2 MHz Plots




Figure A-19: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-20: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-21: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-22: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-23: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-24: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

4 MHz Plots




Figure A-25: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-26: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-27: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-28: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-29: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-30: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

6 MHz Plots




Figure A-31: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-32: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-33: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-34: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-35: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-36: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

8 MHz Plots




Figure A-37: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-38: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-39: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-40: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-41: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-42: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

10 MHz Plots




Figure A-43: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-44: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-45: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-46: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-47: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-48: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

12 MHz Plots




Figure A-49: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-50: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-51: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-52: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-53: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-54: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

14 MHz Plots




Figure A-55: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-56: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-57: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-58: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-59: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-60: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

16 MHz Plots




Figure A-61: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-62: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-63: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-64: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-65: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-66: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

18 MHz Plots




Figure A-67: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-68: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-69: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-70: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-71: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-72: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

20 MHz Plots




Figure A-73: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-74: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-75: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-76: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-77: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-78: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

22 MHz Plots




Figure A-79: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-80: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-81: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-82: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-83: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-84: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

24 MHz Plots




Figure A-85: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-86: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-87: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-88: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-89: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-90: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

26 MHz Plots




Figure A-91: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-92: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-93: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-94: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-95: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-96: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

28 MHz Plots




Figure A-97: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-98: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-99: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-100: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-101: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height




Figure A-102: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at a 1 meter measurement height

A.4 COMPLIANCE MEASUREMENT HEIGHT FOR OPERATION AT 30 MHz AND ABOVE

The Commission's Part 15 measurement guidelines specify that at or above 30 MHz, measurements are to be made with the antenna positioned at a height ranging from 1 to 4 meters. The electric field strength should be measured in both the horizontal and vertical planes. The following plots show a comparison between the peak field strength determined from applying the measurement guidelines to the power line simulations to compute the 80th percentile of peak field strength at any height along the length of the power line. The rationale for use of 80th percentile values was previously addressed in Section A.3. The plots are shown for a number of NEC power line models at the frequencies of 30, 40 and 50 MHz.

30 MHz Plots




Figure A-103: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-104: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-105: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-106: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-107: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-108: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height

40 MHz Plots




Figure A-109: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-110: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-111: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-112: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-113: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-114: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height

50 MHz Plots




Figure A-115: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-116: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-117: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-118: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height




Figure A-119: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height





Figure A-120: 80th percentile of peak electric field strength along the power line relative to the peak electric field strength at the 1 to 4 meter measurement height

A.5 HEIGHT CORRECTION FACTOR ABOVE 30 MHz


Above 30 MHz, the option to perform compliance measurements at a 1 meter measurement height coupled with a 5 dB height correction factor provides a much simpler measurement approach than to perform measurements over a 1 to 4 meter range of measurement antenna heights. Figures A-121 through A-138 show the comparison between use of a 1 to 4 meter measurement height and the optional use of a 1 meter measurement height.

The results shown in these figures indicate that use of the optional 1 meter measurement height tends to underestimate the peak electric field strength by 2.5 to 7.5 dB. Thus, the use of the optional 1 meter measurement height coupled with a 5 dB correction factor will, in general, provide similar results to measurements performed using a 1 to 4 meter measurement height.


30 MHz Plots




A-121: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-122: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-123: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters



A-124: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-125: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-126: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters


40 MHz Plots




A-127: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-128: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-129: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters



A-130: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-131: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-132: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters


50 MHz Plots




A-133: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-134: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters




A-135: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters



A-136: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters



A-137: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters



A-138: Comparison of electric field strength as a function of measurement height, if compliance measurements were performed at heights of 1 meter, or at 1 to 4 meters

APPENDIX B MEASUREMENT DISTANCE ALONG THE POWER LINE

B.1 INTRODUCTION

As noted in the NTIA Phase 1 Study, compliance measurement testing commissioned by BPL equipment vendors and service providers has generally focused on radiated emissions measured on radials from the BPL device under test. However, FCC rules state that Part 15 devices and all attached wiring should be considered when measuring radiated emissions.² The Commission's BPL measurement guidelines specify the locations along the power line away from a BPL device where field strength measurements are to be taken.³ This Appendix provides NTIA's results from evaluating the field strength along the length of the power line and comparing this to the field strength levels at the prescribed measurement locations.

B.2 SIMULATION RESULTS

Figures B-1 through B-84 show the electric field strength level along the power line for a variety of simulated power line configurations, and over the frequency range of 2 to 28 MHz. Each figure includes the Part 15 radiated emissions limit extrapolated to a measurement distance of 10 meters assuming the power line height is 12 meters.⁴ In addition, these figures show the measurement points specified in the measurement guidelines. The peak value of these points was used to scale the signal source level so that the power line model satisfies the Part 15 limit, as extrapolate to the 10 meter measurement distance. Electric field strength values were determined from NEC magnetic field strength simulations of the power line models using the methodology described in Section 2.2.

² See 47 C.F.R. §15.31(g)-(k).

³ See BPL Report and Order, at Appendix C ¶ 2.b.2 (“Testing shall be performed at distances of 0, ¼, ½, ¾, and 1 wavelength down the line from the BPL injection point on the power line. Wavelength spacing is based on the mid-band frequency...”).

⁴ *Id.* ¶ 2.b.4 (describing the slant range distance extrapolation methodology).

2 MHz Plots




Figure B-1: Vertical electric field strength along power line for tri36 topology




Figure B-2: Vertical electric field strength along power line for tri36n topology




Figure B-3: Vertical electric field strength along power line for tri26n topology




Figure B-4: Vertical electric field strength along power line for ver1n topology




Figure B-5: Vertical electric field strength along power line for ver26n topology




Figure B-6: Vertical electric field strength along power line for ver36n topology

4 MHz Plots




Figure B-7: Vertical electric field strength along power line for tri36 topology




Figure B-8: Vertical electric field strength along power line for tri36n topology




Figure B-9: Vertical electric field strength along power line for tri26n topology




Figure B-10: Vertical electric field strength along power line for ver1n topology




Figure B-11: Vertical electric field strength along power line for ver26n topology




Figure B-12: Vertical electric field strength along power line for ver36n topology

6 MHz Plots




Figure B-13: Vertical electric field strength along power line for tri36 topology




Figure B-14: Vertical electric field strength along power line for tri36n topology




Figure B-15: Vertical electric field strength along power line for tri26n topology




Figure B-16: Vertical electric field strength along power line for ver1n topology




Figure B-17: Vertical electric field strength along power line for ver26n topology




Figure B-18: Vertical electric field strength along power line for ver36n topology

8 MHz Plots




Figure B-19: Vertical electric field strength along power line for tri36 topology




Figure B-20: Vertical electric field strength along power line for tri36n topology




Figure B-21: Vertical electric field strength along power line for tri26n topology




Figure B-22: Vertical electric field strength along power line for ver1n topology




Figure B-23: Vertical electric field strength along power line for ver26n topology




Figure B-24: Vertical electric field strength along power line for ver36n topology

10 MHz Plots




Figure B-25: Vertical electric field strength along power line for tri36 topology




Figure B-26: Vertical electric field strength along power line for tri36n topology




Figure B-27: Vertical electric field strength along power line for tri26n topology




Figure B-28: Vertical electric field strength along power line for ver1n topology




Figure B-29: Vertical electric field strength along power line for ver26n topology




Figure B-30: Vertical electric field strength along power line for ver36n topology

12 MHz Plots




Figure B-31: Vertical electric field strength along power line for tri36 topology




Figure B-32: Vertical electric field strength along power line for tri36n topology




Figure B-33: Vertical electric field strength along power line for tri26n topology




Figure B-34: Vertical electric field strength along power line for ver1n topology




Figure B-35: Vertical electric field strength along power line for ver26n topology




Figure B-36: Vertical electric field strength along power line for ver36n topology

14 MHz Plots




Figure B-37: Vertical electric field strength along power line for tri36 topology




Figure B-38: Vertical electric field strength along power line for tri36n topology




Figure B-39: Vertical electric field strength along power line for tri26n topology




Figure B-40: Vertical electric field strength along power line for ver1n topology




Figure B-41: Vertical electric field strength along power line for ver26n topology




Figure B-42: Vertical electric field strength along power line for ver36n topology

16 MHz Plots




Figure B-43: Vertical electric field strength along power line for tri36 topology




Figure B-44: Vertical electric field strength along power line for tri36n topology




Figure B-45: Vertical electric field strength along power line for tri26n topology




Figure B-46: Vertical electric field strength along power line for ver1n topology




Figure B-47: Vertical electric field strength along power line for ver26n topology




Figure B-48: Vertical electric field strength along power line for ver36n topology

18 MHz Plots




Figure B-49: Vertical electric field strength along power line for tri36 topology




Figure B-50: Vertical electric field strength along power line for tri36n topology




Figure B-51: Vertical electric field strength along power line for tri26n topology




Figure B-52: Vertical electric field strength along power line for ver1n topology




Figure B-53: Vertical electric field strength along power line for ver26n topology




Figure B-54: Vertical electric field strength along power line for ver3n topology

20 MHz Plots




Figure B-55: Vertical electric field strength along power line for tri36 topology




Figure B-56: Vertical electric field strength along power line for tri36n topology




Figure B-57: Vertical electric field strength along power line for tri26n topology




Figure B-58: Vertical electric field strength along power line for ver1n topology




Figure B-59: Vertical electric field strength along power line for ver26n topology




Figure B-60: Vertical electric field strength along power line for ver36n topology

22 MHz Plots




Figure B-61: Vertical electric field strength along power line for tri36 topology




Figure B-62: Vertical electric field strength along power line for tri36n topology




Figure B-63: Vertical electric field strength along power line for tri26n topology




Figure B-64: Vertical electric field strength along power line for ver1n topology




Figure B-65: Vertical electric field strength along power line for ver26n topology




Figure B-66: Vertical electric field strength along power line for ver36n topology

24 MHz Plots




Figure B-67: Vertical electric field strength along power line for tri36 topology




Figure B-68: Vertical electric field strength along power line for tri36n topology




Figure B-69: Vertical electric field strength along power line for tri26n topology




Figure B-70: Vertical electric field strength along power line for ver1n topology




Figure B-71: Vertical electric field strength along power line for ver26n topology




Figure B-72: Vertical electric field strength along power line for ver36n topology

26 MHz Plots




Figure B-73: Vertical electric field strength along power line for tri36 topology




Figure B-74: Vertical electric field strength along power line for tri36n topology




Figure B-75: Vertical electric field strength along power line for tri26n topology




Figure B-76: Vertical electric field strength along power line for ver1n topology




Figure B-77: Vertical electric field strength along power line for ver26n topology




Figure B-78: Vertical electric field strength along power line for ver36n topology

28 MHz Plots




Figure B-79: Vertical electric field strength along power line for tri36 topology




Figure B-80: Vertical electric field strength along power line for tri36n topology




Figure B-81: Vertical electric field strength along power line for tri26 topology




Figure B-82: Vertical electric field strength along power line for ver1n topology




Figure B-83: Vertical electric field strength along power line for ver26n topology




Figure B-84: Vertical electric field strength along power line for ver36n topology

APPENDIX C

MEASUREMENT DISTANCE EXTRAPOLATION

C.1 INTRODUCTION

The distance extrapolation calculation based on use of the slant path distance from the BPL device and power lines under test and the measurement antenna was discussed in Section 2.5 of the report. Some of the resulting plots from NTIA's NEC power line model simulations were reported in that section. The remaining plots are included in this appendix.

C.2 BPL FIELD STRENGTH SIMULATION RESULTS

C.2.1 Extrapolated Field Strength Levels Meeting the Part 15 Limits

Figure C-1 shows the extrapolated electric field strength levels that satisfy the Part 15 limits using slant range distance extrapolation, assuming a power line height of 12 meters. The simulated measurement antenna height is assumed to be 1 meter.




Figure C.1 - Extrapolated field strength levels meeting Part 15 emissions limits based on slant-range distance to the BPL device under test

C.2.2 Simulation Results

Figures C-2 through C-15 shows the simulated electric field strength moving away from the power line for a number of power line structures that were previously defined in Section 2.2 of the BPL Phase 2 Study. The extrapolated field strength levels meeting the Part 15 emissions limit below 30 MHz are displayed on each figure for comparison. The simulations determined the vertical electric field strength from the horizontal magnetic field strength using the methodology for compliance testing in the Part 15 rules for Access BPL and assuming the electric field strength is related to the magnetic field strength by $\eta = 377$ ohms (Ω). The peak field strength value was chosen from among the values calculated at points along the line, as defined in the measurement guidelines, at a distance of 10 meters away from the line. The plots of field strength relative to distance are taken from this corresponding location for each case.




Figure C-2: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 2 MHz




Figure C-3: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 4 MHz




Figure C-4: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 6 MHz




Figure C-5: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 8 MHz




Figure C-6: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 10 MHz




Figure C-7: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 12 MHz




Figure C-8: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 14 MHz




Figure C-9: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 16 MHz




Figure C-10: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 18 MHz




Figure C-11: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 20 MHz




Figure C-12: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 22 MHz




Figure C-13: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 24 MHz




Figure C-14: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 26 MHz




Figure C-15: Electric field strength compared to emissions limit based on slant-range extrapolation for various power line models – 28 MHz

APPENDIX D SPECIAL PROTECTION PROVISIONS

D.1 EXCLUDED FREQUENCY BANDS

As adopted in the BPL Report and Order, Access BPL emissions from overhead MV power lines are excluded from aeronautical (R) mobile allocations in the 1.7 – 30 MHz frequency range and the 74.8 – 75.2 MHz aeronautical radionavigation band, as delineated in Table D-1. Otherwise, with mature deployments of BPL devices: (1) reception of aeronautical safety communications by aeronautical (land or “base”) stations would be endangered; (2) reception of aeronautical safety communications by aircraft would be endangered; and (3) at some aeronautical station or aircraft locations, emissions from In-House BPL devices at these frequencies will increase receiver noise levels such that additional interfering signals from Access BPL devices cannot be risked. This exclusion amounts to less than 2.18 percent of national spectrum resource between 1.7 MHz and 80 MHz.

Table D-1: Bands in Which Access BPL Emissions Are Prohibited

Frequency Band	Total Spectrum (kHz)
2,850 – 3,025 kHz	175
3,400 – 3,500 kHz	100
4,650 – 4,700 kHz	50
5,450 – 5,680 kHz	230
6,525 – 6,685 kHz	160
8,815 – 8,965 kHz	150
10,005 – 10,100 kHz	95
11,275 – 11,400 kHz	100
13,260 – 13,360 kHz	100
17,900 – 17,970 kHz	70
21,924 – 22,000 kHz	76
74.8 – 75.2 MHz	400
TOTAL BANDWIDTH	1,706
U.S. AREA FACTOR	1.0
PORTION OF NATIONAL SPECTRUM RESOURCE AT 1.7 – 80 MHz	< 2.18% (area factor x bandwidth factor)

D.2 EXCLUSION ZONES

D.2.1 Coast Stations

The analytical results of Section 3.3.1 lead to a requirement to define exclusion zones in the 2,173.5-2,190.5 kHz band within 1 km of coast station facilities, whose coordinates are listed in Tables D-2 and D-3. This amounts to 0.022 percent of the

bandwidth between 1.7 MHz and 80 MHz and less than 0.004 percent of U.S. territorial area, or less than 0.0000008 percent of national spectrum resource between 1.7 MHz and 80 MHz. This special protection requirement will prevent substantial endangerment of distress alerting by ships and aircraft in oceanic areas. In the event that an Access BPL operator plans to deploy numerous Access BPL devices at these frequencies in areas near these exclusion zones, consult with the following point of contact may best ensure that harmful interference is prevented at these facilities:

Commandant (CG 622)
 U.S. Coast Guard
 2100 2nd Street, S.W.
 Washington, DC 20593 – 0001
 Telephone: (202) 267 – 2860
 E-Mail: cgcomms@comdt.uscg.mil

Table D-2: Exclusion zones for U.S. Coast Guard Coast Stations

Locale	Latitude	Longitude
Group Guam	13° 35' 23" N	144° 50' 24" E
GANTSEC	18° 18' 00" N	65° 46' 59" W
Puerto Rico	18° 28' 11" N	66° 07' 47" W
Honolulu	21° 18' 21" N	157° 53' 23" W
Group Key West	24° 33' 35" N	81° 47' 59" W
Trumbo Point CG Base	24° 33' 58" N	81° 47' 57" W
Miami	25° 37' 28" N	80° 23' 07" W
Everglades Park	25° 50' 10" N	81° 23' 13" W
Group Saint Petersburg (Everglades)	25° 51' 00" N	81° 23' 24" W
Station Ft. Lauderdale	26° 05' 21" N	80° 06' 40" W
Station Ft. Myers Beach	26° 27' 34" N	81° 57' 15" W
Group Miami (Ft. Pierce)	27° 27' 36" N	80° 18' 36" W
Station Ft. Pierce	27° 27' 50" N	80° 18' 27" W
Group Corpus Christi	27° 42' 01" N	97° 16' 11" W
Group Corpus Christi	27° 42' 06" N	97° 16' 45" W
ESD Saint Petersburg	27° 45' 21" N	82° 37' 32" W
Group Saint Petersburg	27° 46' 11" N	82° 37' 47" W
Station Port O'Connor	28° 26' 03" N	96° 25' 39" W
S. Padre Island	28° 26' 22" N	97° 09' 56" W
Freeport	28° 55' 59" N	95° 16' 59" W
Group Galveston (Freeport)	28° 56' 24" N	95° 17' 59" W
Station YANKEETOWN	29° 01' 51" N	82° 43' 39" W
Station Ponce De Leon Inlet	29° 03' 50" N	81° 55' 01" W
Group New Orleans (Grand Isle)	29° 15' 53" N	89° 57' 26" W
Galveston	29° 19' 59" N	94° 46' 18" W
Kapalan	29° 20' 04" N	94° 47' 17" W
Sabine	29° 43' 42" N	93° 52' 14" W
New Orleans	30° 01' 17" N	90° 07' 24" W
Panama City	30° 10' 01" N	85° 45' 04" W
Group Mobile (Panama City)	30° 10' 12" N	85° 45' 36" W

Locale	Latitude	Longitude
ANT Jacksonville Beach	30° 17' 16" N	81° 24' 10" W
Pensacola	30° 20' 24" N	87° 18' 17" W
Group Mayport	30° 23' 10" N	81° 26' 01" W
Group Mayport	30° 23' 24" N	81° 25' 48" W
Ft. Morgan	30° 39' 07" N	88° 03' 12" W
Tybee Lighthouse	32° 01' 15" N	80° 50' 39" W
Point Loma Lighthouse	32° 39' 56" N	117° 14' 34" W
Point Loma	32° 40' 07" N	117° 14' 14" W
Activities San Diego	32° 43' 59" N	117° 11' 13" W
Group Charleston (Sullivan's Island)	32° 45' 00" N	79° 49' 47" W
Sullivan's Island Lights	32° 45' 02" N	79° 50' 03" W
Group Charleston	32° 46' 25" N	79° 56' 37" W
Group San Diego	32° 52' 48" N	118° 26' 23" W
San Pedro	33° 45' 00" N	118° 15' 58" W
Group Fort Macon	33° 53' 24" N	78° 01' 48" W
Point Mugu	33° 59' 32" N	119° 07' 18" W
Group LA / Long Beach	34° 07' 11" N	119° 06' 35" W
Channel Island	34° 09' 17" N	119° 13' 11" W
Station Oxnard Channel Island	34° 09' 43" N	119° 13' 19" W
Group Ft. Macon	34° 41' 48" N	76° 40' 59" W
Group Cape Hatteras	35° 13' 59" N	75° 31' 59" W
Group Cape Hatteras	35° 15' 35" N	75° 31' 48" W
Morro Bay (Cambria)	35° 31' 21" N	121° 03' 21" W
San Clemente Island	32° 50' 24" N	118° 23' 15" W
Point Pinos	36° 38' 12" N	121° 56' 06" W
CAMSLANT	36° 43' 47" N	76° 01' 11" W
Group Hampton Roads	36° 53' 01" N	76° 21' 10" W
Point Montara	37° 31' 23" N	122° 30' 47" W
Point Montara Lighthouse	37° 32' 09" N	122° 31' 08" W
Group San Francisco	37° 32' 23" N	122° 31' 11" W
Group San Francisco	37° 48' 34" N	122° 21' 55" W
Point Bonita	37° 49' 00" N	122° 31' 41" W
Group Eastern Shores	37° 55' 47" N	75° 22' 47" W
Group Eastern Shore	37° 55' 50" N	75° 22' 58" W
CAMPSPAC	38° 06' 00" N	122° 55' 48" W
Point Arena Lighthouse	38° 57' 18" N	124° 44' 28" W
Point Arena	38° 57' 36" N	123° 44' 23" W
Group Atlantic City	39° 20' 59" N	74° 27' 42" W
Activities New York	40° 36' 06" N	74° 03' 36" W
Activities New York	40° 37' 11" N	74° 04' 11" W
ESD Moriches Hut	40° 47' 19" N	72° 44' 53" W
Group Moriches	40° 47' 23" N	72° 45' 00" W
Group Humboldt Bay	40° 58' 41" N	124° 06' 31" W
Group Humboldt Bay	40° 58' 47" N	124° 06' 35" W
Trinidad Head	41° 03' 15" N	124° 09' 02" W
Group Long Island Sound	41° 16' 12" N	72° 54' 00" W
Station New Haven	41° 16' 12" N	72° 54' 06" W

Locale	Latitude	Longitude
Station Brant Point	41° 17' 21" N	70° 05' 31" W
Group Woods Hole	41° 17' 23" N	70° 04' 47" W
Station Castle Hill	41° 27' 46" N	71° 21' 42" W
Group Woods Hole	41° 30' 30" N	70° 41' 42" W
Boston Area	41° 40' 12" N	70° 31' 48" W
Station Provincetown	42° 01' 48" N	70° 12' 42" W
Eastern Point	42° 36' 24" N	70° 39' 26" W
Cape Blanco	42° 50' 16" N	124° 33' 52" W
Group North Bend	43° 24' 16" N	124° 13' 22" W
Group North Bend	43° 24' 35" N	124° 14' 23" W
Cape Elizabeth	43° 33' 28" N	70° 12' 00" W
Group South Portland	43° 38' 24" N	70° 15' 00" W
Group South Portland	43° 38' 45" N	70° 14' 51" W
Group SW Harbor	44° 16' 19" N	68° 18' 27" W
Group Southwest Harbor	44° 16' 48" N	68° 18' 36" W
Fort Stevens, Oregon	46° 09' 14" N	123° 53' 07" W
Group Astoria	46° 09' 29" N	123° 31' 48" W
Group Astoria	46° 09' 35" N	123° 53' 24" W
La Push	47° 49' 00" N	124° 37' 59" W
Station Quillayute River	47° 54' 49" N	124° 38' 01" W
Port Angeles	48° 07' 59" N	123° 25' 59" W
Group Port Angeles	48° 08' 24" N	123° 24' 35" W
Juneau (Sitka)	57° 05' 24" N	135° 15' 35" W
Kodiak	57° 40' 47" N	152° 28' 47" W
Valdez (Cape Hinchinbrook)	60° 26' 23" N	146° 25' 48" W

Table D-3: Exclusion zones for Maritime Public Coast Stations

Licensee Name	Location	Latitude	Longitude
Shipcom LLC	Marina Del Ray, CA	33° 56' 21" N	118° 27' 14" W
Globe Wireless	Rio Vista, CA	38° 11' 55" N	121° 48' 34" W
Avalon Communications Corp	St. Thomas, VI	18° 21' 19" N	64° 56' 48" W
Globe Wireless	Bishopville, MD	38° 24' 10" N	75° 12' 59" W
Shipcom LLC	Mobile, AL	30° 40' 07" N	88° 10' 23" W
Shipcom, LLC	Coden, AL	30° 22' 35" N	88° 12' 20" W
Globe Wireless	Pearl River, LA	30° 22' 13" N	89° 47' 26" W
Globe Wireless	Kahalelani, HI	21° 10' 33" N	157° 10' 39" W
Globe Wireless	Palo Alto, CA	37° 26' 44" N	122° 06' 48" W
Globe Wireless	Agana, GU	13° 29' 22" N	144° 49' 39" E

D.2.2 Radioastronomy Observatories

Using correlation techniques, the Very Large Array (VLA) receivers operate with desired signal levels that are well below ambient noise levels and rely on the protection

criteria specified by the International Telecommunication Union Radiocommunication Sector (ITU-R) for radioastronomy observatories. Figure D-1 illustrates the antenna array at this facility near Socorro, New Mexico. The BPL Memorandum Opinion and Order defined an exclusion zone where Access BPL systems operating on overhead MV power lines in the 73.0 – 74.6 MHz band should be no closer than 65 km from the coordinates of the VLA facility.⁵ The coordinate at the center of the VLA is 34° 04' 43.50"N, 107° 37' 03.82"W. Figure D-2 shows the specified protection radii within the National Radio Astronomy Observatory. The BPL rules also state that Access BPL using LV power lines or underground power lines using the 73.0 – 74.6 MHz band should be excluded within 47 km from the coordinates of the VLA facility. The analyses in Section 3.3.3 confirmed that these exclusion zone radii are reasonable to limit the power flux density (PFD) to levels defined for this frequency band by the ITU-R. This amounts to 2.04 percent of the bandwidth between 1.7 MHz and 80 MHz and less than 0.028 percent of U.S. territorial area, or less than 0.0006 percent of national spectrum resource between 1.7 MHz and 80 MHz.



Figure D-1: Very Large Array (VLA) radioastronomy observatory

⁵ See Amendment of Part 15 regarding new requirements and measurement guidelines for Access Broadband over Power Line Systems, ET Docket No. 04-37, Memorandum Opinion and Order, released August 7, 2006, (“BPL Memorandum Opinion and Order”), at ¶¶ 57 - 59.




Figure D-2: VLA protection radii for overhead Access BPL shown within the National Radio Astronomy Observatory near Socorro, New Mexico.

D.3 CONSULTATION AREAS

Part 15 of the Commission’s rules for carrier current systems apply the same field strength limits for wanted and unwanted emissions, and so, consultation between BPL service providers and radio operators should not be limited to the fundamental frequencies intentionally used in Access BPL systems. Moreover, frequencies used by many communications receivers in the 1.7 – 30 MHz frequency range are subject to change in the long-term and over hourly or shorter time frames. In light of these factors and given that the consultation areas needed for BPL systems are small, consultation should be required for all planned Access BPL operations at all frequencies of potential concern in these consultation areas. These consultation areas are:

- For frequencies in the 1.7 – 30 MHz frequency range, the areas within 4 km of facilities located at the following coordinates:
 - the Commission’s protected field offices listed in 47 C.F.R. § 0.121, the point-of-contact for which is specified in that section;
 - the aeronautical stations listed in Tables D-4 and D-5;
 - the land stations listed in Tables D-6 and D-7;

- For frequencies in the 1.7 – 80 MHz frequency range, the areas within 4 km of facilities located at the coordinates specified for radio astronomy facilities in US 311.
- For frequencies in the 1.7 – 80 MHz frequency range, the area within 1 km of the Table Mountain Radio Receiving Zone, the coordinates and point of contact for which are specified in 47 C.F.R. § 21.113(b).
- For frequencies in the 1.7 – 30 MHz frequency range, the areas within 37 km of radar receiver facilities located at the coordinates specified in Table D-8.

Point of contact
 U.S. Coast Guard HQ
 Division of Spectrum Management CG-622
 2100 Second St., SW. Rm. 6611
 Washington, DC 20593
 Tel: 202-267-6036
 Fax: 202-267-4106
 Email: jtaboada@comdt.uscg.mil

Table D-4: Consultation Area Coordinates for Aeronautical (OR) Stations (1.7 – 30 MHz)

Command Name	Location	Latitude	Longitude
Washington	Arlington, VA	38° 51' 07" N	77° 02' 15" W
Cape Cod	Cape Cod, MA	41° 42' 00" N	70° 30' 00" W
Atlantic City	Atlantic City, NJ	39° 20' 59" N	74° 27' 42" W
Elizabeth City	Elizabeth City, NC	36° 15' 53" N	76° 10' 32" W
Savannah	Savannah, GA	32° 01' 30" N	81° 08' 30" W
Miami	Opa Locka, FL	25° 54' 22" N	80° 16' 01" W
Clearwater	Clearwater, FL	27° 54' 27" N	82° 41' 29" W
Borinquen	Aguadilla, PR	18° 18' 36" N	67° 04' 48" W
New Orleans	New Orleans, LA	29° 49' 31" N	90° 02' 06" W
Traverse City	Traverse City, MI	44° 44' 24" N	85° 34' 54" W
San Diego	San Diego, CA	32° 43' 33" N	117° 10' 15" W
Sacramento	McClellan AFB, CA	38° 40' 06" N	121° 24' 04" W
Astoria	Warrenton, OR	46° 25' 18" N	123° 47' 46" W
North Bend	North Bend, OR	43° 24' 39" N	124° 14' 35" W
Barbers Point	Kapolei, HI	21° 18' 01" N	158° 04' 15" W
Kodiak	Kodiak, AK	57° 44' 19" N	152° 30' 18" W
Houston	Houston, TX	29° 45' 00" N	95° 22' 00" W
Detroit	Mt. Clemens, MI	42° 36' 05" N	82° 50' 12" W
San Francisco	San Francisco, CA	37° 37' 58" N	122° 23' 20" W
Los Angeles	Los Angeles, CA	33° 56' 36" N	118° 23' 48" W

Command Name	Location	Latitude	Longitude
Humboldt Bay	McKinleyville, CA	40° 58' 39" N	124° 06' 45" W
Port Angeles	Port Angeles, WA	48° 08' 25" N	123° 24' 48" W
Sitka	Sitka, AK	57° 05' 50" N	135° 21' 58" W

Point of contact
 ARINC
 2551 Riva Road
 Annapolis, MD 21401
 Tel: 1-800-633-6882
 Fax: 410-266-2329
 Email: bplnotifications@arinc.com
www.arinc.com

Table D-5: Consultation Area Coordinates for Aeronautical Receive Stations (1.7 – 30 MHz)

Locale	Latitude	Longitude
Southampton, NY	40° 55' 15" N	72° 23' 41" W
Molokai, HI	21° 12' 23" N	157° 12' 30" W
Oahu, HI	21° 22' 27" N	158° 05' 56" W
Half Moon Bay, CA	37° 39' 64" N	122° 24' 44" W
Pt. Reyes, CA	38° 06' 00" N	122° 56' 00" W
Barrow, AK	71° 17' 24" N	156° 40' 12" W
Guam	13° 25' 12" N	144° 48' 00" E (note: Eastern Hemisphere)
NY Comm Center, NY	40° 46' 48" N	73° 05' 46" W
Cedar Rapids, IA	42° 02' 05.0" N	91° 38' 37.6" W
Beaumont, CA	33° 54' 27.1" N	116° 59' 49.1" W
Fairfield, TX	31° 47' 02.6" N	96° 47' 03.0" W
Houston, TX	29° 36' 35.8" N	95° 16' 54.8" W
Miami, FL	25° 49' 05" N	80° 18' 28" W

Point Of Contact
 U.S. Coast Guard HQ
 Division of Spectrum Management CG-622
 2100 Second St., SW. Rm. 6611
 Washington, DC 20593
 Tel: 202-267-6036
 Fax: 202-267-4106
 Email: jtaboada@comdt.uscg.mil

Table D-6: Consultation Area Coordinates for Land Stations, Set 1 (1.7–30 MHz)

Command Name	Location	Latitude	Longitude
COMMSTA Boston	Maspee, MA	41° 24' 00" N	70° 18' 57" W
Camlant	Chesapeake, VA	36° 33' 59" N	76° 15' 23" W
COMMSTA Miami	Miami, FL	25° 36' 58" N	80° 23' 04" W

Command Name	Location	Latitude	Longitude
COMMSTA New Orleans	Belle Chasse, IA	29° 52' 40" N	89° 54' 46" W
Campac	Pt. Reyes Sta, CA	38° 06' 00" N	122° 55' 48" W
COMMSTA Honolulu	Wahiawa, HI	21° 31' 08" N	157° 59' 28" W
COMMSTA Kodiak	Kodiak, AK	57° 04' 26" N	152° 28' 20" W
Guam	Finegayan, GU	13° 53' 08" N	144° 50' 20" E

Point of contact
 COTHEN Technical Support Center
 COTHEN Program Manager
 Tel: (800) 829-6336

Table D-7: Consultation Area Coordinates for Land Stations, Set 2 (1.7 – 30 MHz)

Site Name	Latitude	Longitude
Albuquerque, NM	35° 05' 02" N	105° 34' 23" W
Arecibo, PR	18° 17' 26" N	66° 22' 33" W
Atlanta, GA	32° 33' 06" N	84° 23' 35" W
Beaufort, SC	34° 34' 22" N	76° 09' 48" W
Cape Charles, VA	37° 05' 37" N	75° 58' 06" W
Cedar Rapids, IA	42° 00' 09" N	91° 17' 39" W
Denver, CO	39° 15' 45" N	103° 34' 23" W
Fort Myers, FL	81° 31' 20" N	26° 20' 01" W
Kansas City, MO	38° 22' 10" N	93° 21' 48" W
Las Vegas, NV	36° 21' 15" N	114° 17' 33" W
Lovelock, NV	40° 03' 07" N	118° 18' 56" W
Memphis, TN	34° 21' 57" N	90° 02' 43" W
Miami, FL	25° 46' 20" N	80° 28' 48" W
Morehead City, NC	34° 34' 50" N	78° 13' 59" W
Oklahoma City, OK	34° 30' 52" N	97° 30' 52" W
Orlando, FL	28° 31' 30" N	80° 48' 58" W
Reno, NV	38° 31' 12" N	119° 14' 37" W
Sarasota, FL	27° 12' 41" N	81° 31' 20" W
Wilmington, NC	34° 29' 24" N	78° 04' 31" W

Point Of Contact
 ROTH Deputy Program Manager
 (540) 653-3624

Table D-8: Consultation Area Coordinates for Radar Receiver Stations (1.7 – 30 MHz)

Latitude/Longitude
18° 01' N / 66° 30' W
28° 05' N / 98° 43' W
36° 34' N / 76° 18' W