

Regulatory Commission, Washington, DC 20555-0001, and it is requested that copies be transmitted either by means of facsimile transmission to 301-415-3725 or by e-mail to OGCMailCenter@nrc.gov. A copy of the request for hearing and petition for leave to intervene should also be sent to the licensee. The licensee's contact for this is Mr. P. Michael Whaley, Nuclear Reactor Manager, Kansas State University, 112 Ward Hall, Manhattan, KS 66506-2506.

Non-timely requests and/or petitions and contentions will not be entertained absent a determination by the Commission, the presiding officer, or the Atomic Safety and Licensing Board that the petition, request and/or contentions should be granted based on a balancing of the factors specified in 10 CFR 2.309(c)(1)(i)-(viii).

Detailed guidance which the NRC uses to review applications for the renewal of non-power reactor licenses can be found in the document NUREG-1537, entitled "Guidelines for Preparing and Reviewing Applications for the Licensing of Non-Power Reactors," can be obtained from the Commission's PDR. The NRC maintains an Agencywide Documents Access and Management System (ADAMS), which provides text and image files of NRC's public documents. The detailed review guidance (NUREG-1537) may be accessed through the NRC's Public Electronic Reading Room on the Internet at <http://www.nrc.gov/reading-rm/adams.html> under ADAMS accession number ML042430055 for part one and ML042430048 for part two. Copies of the application to renew the facility license for the KSU Research Reactor are available for public inspection at the Commission's PDR, located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland, 20855-2738. The initial application also may be accessed through the NRC's Public Electronic Reading Room, at the address mentioned above, under ADAMS accession number ML022630083. The revised application may be accessed under ADAMS accession number ML052620181. Persons who do not have access to ADAMS, or if there are problems in accessing the documents located in ADAMS, may contact the NRC Public Document Room Reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 28th day of September 2005.

For the Nuclear Regulatory Commission.

Brian E. Thomas,

Section Chief, Research and Test Reactors Section, New, Research and Test Reactors Program, Division of Regulatory Improvement Programs, Office of Nuclear Reactor Regulation.

[FR Doc. E5-5474 Filed 10-5-05; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-272 and 50-311]

PSEG Nuclear, LLC; Exelon Generation Company, LLC; Salem Nuclear Generating Station, Unit Nos. 1 and 2; Notice of Partial Withdrawal of Application for Amendment to Facility Operating License

The U.S. Nuclear Regulatory Commission (NRC or the Commission) has granted the request of PSEG Nuclear LLC (PSEG), on behalf of PSEG and Exelon Generation Company, LLC (the licensees) to withdraw a portion of its April 15, 2004, application and the August 11, 2004, and August 11, 2005, supplements for proposed amendments to Facility Operating License Nos. DPR-70 and DPR-75 for the Salem Nuclear Generating Station, Unit Nos. 1 and 2, located in Salem County, New Jersey.

One of the proposed changes would have permitted a modification to the Salem, Unit No. 1, containment cooling system. Specifically, PSEG proposed to install a new closed-loop chilled water system to supply cooling water to the containment fan cooling units during normal operation. The emergency containment cooling water system would remain the safety-related source of cooling water for postulated accidents. The request involved changes to the system configuration, revisions to the analysis of containment temperature and pressure following a design-basis event, and associated changes to the Technical Specifications. The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the **Federal Register** on October 12, 2004 (69 FR 60684). However, by letter dated August 11, 2005, PSEG withdrew the above-referenced proposed change.

For further details with respect to this action, see the application for amendment dated April 15, 2004, as supplemented by letters dated August 11, 2004, and August 11, 2005. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area 01 F21, 11555 Rockville Pike (first floor),

Rockville, Maryland. Publicly-available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams/html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 30th day of September 2005.

For the Nuclear Regulatory Commission.

Stewart N. Bailey,

Sr. Project Manager, Section 2, Project Directorate I, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. E5-5473 Filed 10-5-05; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-220 and 50-410]

Nine Mile Point Nuclear Station, LLC; Nine Mile Point Nuclear Station, Units 1 and 2; Notice of Availability of the Draft Supplement 24 to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants, and Public Meeting for the License Renewal of Nine Mile Point Nuclear Station, Units 1 and 2

Notice is hereby given that the U.S. Nuclear Regulatory Commission (NRC, Commission) has published a draft plant-specific supplement to the Generic Environmental Impact Statement for License Renewal of Nuclear Plants (GEIS), NUREG-1437, regarding the renewal of operating licenses DPR-63 and NPF-69 for an additional 20 years of operation for the Nine Mile Point Nuclear Station, Units 1 and 2 (Nine Mile Point). Nine Mile Point is located in northern New York on the shore of Lake Ontario, approximately 5 miles northeast of Oswego, New York, 36 miles north-northeast of Syracuse, New York, and 65 miles east of Rochester, New York. Possible alternatives to the proposed action (license renewal) include no action and reasonable alternative energy sources.

The draft Supplement 24 to the GEIS is publicly available at the NRC Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, or from the NRC's Agencywide Documents

Access and Management System (ADAMS). The ADAMS Public Electronic Reading Room is accessible at <http://www.nrc.gov/reading-rm/adams/web-based.html>. The accession number for the draft Supplement 24 to the GEIS is ML052720075. Persons who do not have access to ADAMS, or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's Public Document Room Reference staff by telephone at 1-800-397-4209, or 301-415-4737, or by e-mail at pdr@nrc.gov. In addition, the Penfield Library, located at State University of New York, Oswego, New York 13126, has agreed to make the draft supplement to the GEIS available for public inspection.

Any interested party may submit comments on the draft supplement to the GEIS for consideration by the NRC staff. To be certain of consideration, comments on the draft supplement to the GEIS and the proposed action must be received by December 22, 2005. Comments received after the due date will be considered if it is practical to do so, but the NRC staff is able to assure consideration only for comments received on or before this date. Written comments on the draft supplement to the GEIS should be sent to: Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, Mailstop T-6D59, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

Comments may be hand-delivered to the NRC at 11545 Rockville Pike, Room T-6D59, Rockville, Maryland, between 7:30 a.m. and 4:15 p.m. on Federal workdays. Electronic comments may be submitted to the NRC by e-mail at NineMilePointEIS@nrc.gov. All comments received by the Commission, including those made by Federal, State, local agencies, Native American Tribes, or other interested persons, will be made available electronically at the Commission's PDR in Rockville, Maryland, and through ADAMS.

The NRC staff will hold a public meeting to present an overview of the draft plant-specific supplement to the GEIS and to accept public comments on the document. The public meeting will be held on November 17, 2005, at the Town of Scriba Conference Room, 42 Creamery Road, Oswego, New York 13126. There will be two sessions to accommodate interested parties. The first session will commence at 1:30 p.m. and will continue until 4:30 p.m. The second session will commence at 7 p.m. and will continue until 10 p.m. Both meetings will be transcribed and will include: (1) A presentation of the contents of the draft plant-specific

supplement to the GEIS, and (2) the opportunity for interested government agencies, organizations, and individuals to provide comments on the draft report. Additionally, the NRC staff will host informal discussions one hour prior to the start of each session at the same location. No comments on the draft supplement to the GEIS will be accepted during the informal discussions. To be considered, comments must be provided either at the transcribed public meeting or in writing. Persons may pre-register to attend or present oral comments at the meeting by contacting Ms. Leslie C. Fields, the NRC Environmental Project Manager at 1-800-368-5642, extension 1186, or by e-mail at NineMilePointEIS@nrc.gov no later than November 8, 2005. Members of the public may also register to provide oral comments within 15 minutes of the start of each session. Individual, oral comments may be limited by the time available, depending on the number of persons who register. If special equipment or accommodations are needed to attend or present information at the public meeting, the need should be brought to Ms. Fields's attention no later than November 8, 2005, to provide the NRC staff adequate notice to determine whether the request can be accommodated.

FOR FURTHER INFORMATION, CONTACT: Ms. Leslie C. Fields, License Renewal and Environmental Impacts Program, Division of Regulatory Improvement Programs, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Mail Stop O-11F1, Washington, DC 20555-0001. Ms. Fields may be contacted at the aforementioned telephone number or e-mail address.

Dated at Rockville, Maryland, this 29th day of September, 2005.

For the Nuclear Regulatory Commission.

Jacob I. Zimmerman,

Acting Program Director, License Renewal and Environmental Impacts Program, Division of Regulatory Improvement Programs, Office of Nuclear Reactor Regulation.

[FR Doc. E5-5471 Filed 10-5-05; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Draft Regulatory Guide: Issuance, Availability

The U.S. Nuclear Regulatory Commission (NRC) has issued for public comment a draft revision of an existing guide in the agency's Regulatory Guide Series. This series has been developed to describe and make available to the

public such information as methods that are acceptable to the NRC staff for implementing specific parts of the NRC's regulations, techniques that the staff uses in evaluating specific problems or postulated accidents, and data that the staff needs in its review of applications for permits and licenses.

The draft Revision 1 of Regulatory Guide 8.38, entitled "Control of Access to High and Very High Radiation Areas in Nuclear Power Plants," is temporarily identified by its task number, DG-8028, which should be mentioned in all related correspondence. Like its predecessors, this proposed revision describes an acceptable program for implementing the requirements of Title 10, Part 20, of the *Code of Federal Regulations* (10 CFR Part 20), "Standards for Protection Against Radiation." In particular, 10 CFR 20.1101, "Radiation Protection Programs," requires licensees to develop and implement a radiation protection program appropriate to the scope of licensed activities and potential hazards. To augment that requirement, 10 CFR 20.2102, "Records of Radiation Protection Programs," requires licensees to document those radiation protection programs. An important aspect of such programs at nuclear power plants is the institution of a system of controls that includes procedures, training, audits, and physical barriers to protect workers against unplanned exposures in high and very high radiation areas. Toward that end, 10 CFR 20.1601 provides specific requirements applicable to controlling access to high radiation areas, while 10 CFR 20.1602 provides additional requirements to prevent unauthorized or inadvertent entry into very high radiation areas. Appendix A to the proposed revised guide augments this guidance with recommended procedures for good operating practices for underwater diving operations in high and very high radiation areas. In addition, Appendix B summarizes past experience with very high and potentially very high radiation areas, so that pertinent historical information is readily accessible.

Dose rates in areas of nuclear power plants that are accessible to individuals can vary over several orders of magnitude. High radiation areas, where personnel can receive doses in excess of the regulatory limits in a relatively short time, require special controls. Very high radiation areas require much stricter monitoring and controls, because failure to adequately implement effective radiological controls can result in radiation doses that result in a significant health risk. Thus, it is important that licensees have effective