



## Substitute Refrigerants Under SNAP as of June 12, 2008

SNAP Information: <http://www.epa.gov/ozone/snap>

EPA has created the Significant New Alternatives Policy (SNAP) Program under section 612 of the Clean Air Act Amendments. SNAP evaluates alternatives to ozone-depleting substances. Substitutes are reviewed on the basis of ozone depletion potential, global warming potential, toxicity, flammability, and exposure potential as described in the March 18, 1994, final SNAP rule (59 FR 13044). Lists of acceptable and unacceptable substitutes will be updated periodically in the Federal Register. The following SNAP notices and subsequent final rules are included in this list: August 26, 1994 (59 FR 44240), January 13, 1995 (60 FR 3318), June 13, 1995 (60 FR 31092), July 28, 1995 (60 FR 38729), February 8, 1996 (61 FR 4736), May 22, 1996 (61 FR 25585), September 5, 1996 (61 FR 47012), October 16, 1996 (61 FR 54030), March 10, 1997 (62 FR 10700), June 3, 1997 (62 FR 30275), February 24, 1998 (63 FR 9151), May 22, 1998 (63 FR 28251), January 26, 1999 (64 FR 3861), March 3, 1999 (64 FR 10374), April 28, 1999 (64 FR 22982), June 8, 1999 (64 FR 30410), December 6, 1999 (64 FR 68039), April 11, 2000 (65 FR 19327), June 19, 2000 (65 FR 37900), December 18, 2000 (65 FR 78977), May 23, 2001 (66 FR 28379), March 22, 2002 (67 FR 13272), December 20, 2002 (67 FR 77927), August 21, 2003 (68 FR 50533), and October 1, 2004 (69 FR 58903), March 29, 2006 (71 FR 15589), September 28, 2006 (71 FR 55884), October 4, 2007 (72 FR 56628), and June 12, 2008 (73 FR 33304).

### Acceptable Substitutes for Class I (CFCs) Substances in Air Conditioning under the Significant New Alternatives Policy (SNAP) Program as of June 12, 2008

Substitutes (Name Used in Federal Register)	Trade Name	CFC-11 Centrifugal Chillers	CFC-12, CFC-114, R-500 Centrifugal Chillers	CFC-12, R-500 Reciprocating Chillers	CFC-12 Motor Vehicle AC	CFC-12 Industrial Process AC	CFC-114 Industrial Process AC	CFC-12, R-500 Residential Dehumidifiers
HCFC-123	123	R, N	N					
HCFC-22	22	N	N	N	R, N* (buses only)		N (only <115F)	R, N
HCFC-124	124		R, N (CFC-114 only)				R, N	
HFC-134a	134a	N	R, N	R, N	R, N*		N (only <125F)	R, N
HFC-152a	152a				N*** (no R)			
HFC-227ea		N	N	N				
HFC-236fa			R, N (CFC-114 only)					
HFC-245fa	Genetron® 245fa	R,N	R,N (CFC-114 only)				R,N	
R-401A, R-401B	MP-39, MP-66			R, N			R, N	R, N
R-406A	GHG		R, N (R-500 only)		R, N**			R

Key: R = Retrofit Uses, N = New Uses

\*These refrigerants are actually "acceptable subject to use conditions." The conditions include 1)the use of unique fittings, 2)the use of descriptive labels, and 3) a prohibition against topping off one refrigerant with another. Details may be found in EPA's fact sheet titled "Choosing and Using Alternative Refrigerants for Motor Vehicle Air Conditioning."

\*\* In addition to the use conditions listed under (\*), these refrigerants must be used with barrier hoses.

\*\*\*See (73 FR 33303) for use conditions.



**Acceptable Substitutes for Class I (CFCs) Substances in Air Conditioning under the  
Significant New Alternatives Policy (SNAP) Program as of June 12, 2008 (continued)**

<b>Substitutes (Name Used in Federal Register)</b>	<b>Trade Name</b>	<b>CFC-11 Centrifugal Chillers</b>	<b>CFC-12, CFC-114, R-500 Centrifugal Chillers</b>	<b>CFC-12, R-500 Reciprocating Chillers</b>	<b>CFC-12 Motor Vehicle AC</b>	<b>CFC-12 Industrial Process AC</b>	<b>CFC-114 Industrial Process AC</b>	<b>CFC-12, R-500 Residential Dehumidifiers</b>
R-409A (HCFC Blend Gamma)	409A							R
R-411A, R-411B	411A, 411B			R, N				
FRIGC (HCFC Blend Beta)	FRIGC FR-12, 416A		R, N (CFC-12, R-500 only)	R, N	R, N*			R, N
Free Zone (HCFC Blend Delta)	Freezone / RB-276		R, N (CFC-12, R-500 only)	R, N	R, N*			R, N
Hot Shot (HCFC Blend Omicron)	Hot Shot, KarKool, 414B		R, N (CFC-12, R-500 only)	R, N	R, N**	R,N	R,N	R, N
GHG-X4 (HCFC Blend Xi)	GHG-X4, Autofrost, McCool Chill-it, 414A		R, N (CFC-12, R-500 only)	R, N	R, N**			R, N
GHG-X5	GHG-X5		R, N (CFC-12, R-500 only)	R, N	R, N**			R, N
GHG-HP (HCFC Blend Lambda)	GHG-HP				R, N**			R, N
Freeze 12	Freeze 12		R, N (CFC-12, R-500 only)	R, N	R, N*			R, N
411C	G2018C		R, N (CFC-12, R-500 only)	R, N				
THR-02	THR-02		N (CFC-12 only)	N (CFC-12 only)		R, N		
Ikon A, Ikon-12 (Blend Zeta)	Ikon A, Ikon-12		R, N (CFC-12 only)		R, N*	R, N		
Ikon B	Ikon B		R, N (CFC-12 only)	N (CFC-12 only)		R, N		R, N (CFC-12 only)
FOR12A, FOR12B	FOR12A, FOR12B		R, N (CFC-12 only)	R, N (CFC-12 only)		R, N		
SP34E	SP34E			R, N (CFC-12 only)	R, N*			
HCFC-22/HCFC-142b			R, N (CFC-12 only)	R, N (CFC-12 only)				R, N (CFC-12 only)
R-420A	Choice R-420A		R, N (CFC-12, R-500 only)	R, N	R**	R,N		R, N
ISCEON 39TC	ISCEON 39TC		R, N (CFC-12 only)			R,N		
RS-24 (2002 formulation)						R,N		R, N (CFC-12 only)
R-407C	SUVA 407C, KLEA 407C			R, N (R-502)		R, N (R- 502)		R, N (R-502)
R-422C	ICOR XLT1			R,N (R-502)		R, N (R- 502)		R, N (R-502)
R-426A	RS-24 (new formulation)				R,N*	R,N		R,N

Key: R = Retrofit Uses, N = New Uses

\*These refrigerants are actually "acceptable subject to use conditions." The conditions include 1)the use of unique fittings, 2)the use of descriptive labels, and 3) a prohibition against topping off one refrigerant with another. Details may be found in EPA's fact sheet titled "Choosing and Using Alternative Refrigerants for Motor Vehicle Air Conditioning."



\*\* In addition to the use conditions listed under (\*), these refrigerants must be used with barrier hoses.



**Acceptable Substitutes for Class I (CFCs) Substances in Air Conditioning under the  
Significant New Alternatives Policy (SNAP) Program as of June 12, 2008 (continued)**

Substitutes (Name Used in Federal Register)	Trade Name	CFC-11 Centrifugal Chillers	CFC-12, CFC-114, R-500 Centrifugal Chillers	CFC-12, R-500 Reciprocating Chillers	CFC-12 Motor Vehicle AC	CFC-12 Industrial Process AC	CFC-114 Industrial Process AC	CFC-12, R-500 Residential Dehumidifiers
Ammonia Vapor Compression		N	N					
Evaporative Cooling		N	N	N	N*			
Desiccant Cooling		N	N	N				
Ammonia / Water Absorption		N	N					
Water / Lithium Bromide Absorption		N	N					
Small Auxiliary Power Units in Tractor Trailers					R, N			

Key:

R = Retrofit Uses, N = New Uses

\*These refrigerants are actually "acceptable subject to use conditions." The conditions include 1)the use of unique fittings, 2)the use of descriptive labels, and 3) a prohibition against topping off one refrigerant with another. Details may be found in EPA's fact sheet titled "Choosing and Using Alternative Refrigerants for Motor Vehicle Air Conditioning."

\*\* In addition to the use conditions listed under (\*), these refrigerants must be used with barrier hoses.







**Acceptable Substitutes for Class I (CFCs) Substances in Commercial Refrigeration under the  
Significant New Alternatives Policy (SNAP) Program as of June 12, 2008 (continued)**

Substitutes (Name Used in Federal Register)	Trade Name	ODS Being Replaced	Cold Storage Ware- houses	Ref. Transport	Retail Food Ref.	Ice Machines	Vending Machines	Water Coolers	Non-Mecha- nical Heat Transfer	Very Low Temp. Ref.
HFE-7100, HFE-7200		11, 12, 113, 114, 115							R, N	
HFE-7100, HFE-7200 as a secondary heat transfer fluid in not-in-kind systems		12, 502, 13, 13B1, 503			N (12, 502)					N (13, 13B1, 503)
Ikon A, Ikon-12 (Blend Zeta)	Ikon A, Ikon-12	12	R, N	R, N	R, N	R, N	R, N	R, N		
Ikon B	Ikon B	12	R, N	R, N	R, N	R, N	R, N	R, N		
FOR12A, FOR12B	FOR12A, FOR12B	12	R, N	R, N	R, N	N	R, N	R, N		
SP34E	SP34E	12	R, N	R, N	R, N		R, N	R, N		
HFC-134a/HBr (92/8)		12, 502		N						
HFC-134a/HBr (92/8) as the primary heat transfer fluid in secondary-loop equipment		12, 502	N		N					
PFC-330ST, PFC-550HC, PFC- 660HC, PFC-1100HC, PFC- 1100LT, PGC-100, PGC-150, PFC-331ST, PFC-551HC, PFC- 661HC, PFC-1101HC, PGC-151	PFC-330ST, PFC- 550HC, PFC-660HC, PFC-1100HC, PFC- 1100LT, PGC-100, PGC-150, PFC- 331ST, PFC-551HC, PFC-661HC, PFC- 1101HC, PGC-151	13, 113, 114, blends thereof								R, N
PFC-1102HC, PFC-662HC, PFC-552HC and FLC-15	PFC-1102HC, PFC-662HC, PFC-552HC and FLC-15	13, 113, 114, blends thereof								N
Hydrofluoroether 7000	HFE-7000	CFC-11 and CFC- 113							R, N	
ISCEON 39TC	ISCEON 39TC	12	R, N							
RS-24 (2002 formulation)		12	R,N	R,N	R,N	R,N	R,N	R,N		
NU-22 [R-125/134a/600 (46.6/50.0/3.4)]	NU-22	502	R,N	R,N	R,N	R,N	R,N	R,N		
ISCEON 89	ISCEON 89	R-13B1								R,N
R-407C	SUVA 407C, KLEA 407C	502	R,N	R,N	R,N	R,N	R,N	R,N	R,N	
R-407D		12		R,N						

Key: R = Retrofit Uses, N = New Uses  
\*Acceptable only where no other alternatives are technically feasible due to safety or performance requirements.



**Acceptable Substitutes for Class I (CFCs) Substances in Non-Commercial Refrigeration under the Significant New Alternatives Policy (SNAP) Program as of June 12, 2008**

<b>Substitutes (Name Used in Federal Register)</b>	<b>Trade Name</b>	<b>ODS Being Replaced</b>	<b>Industrial Process Refrigeration</b>	<b>Ice Skating Rinks</b>	<b>Household Refrigerators</b>	<b>Household Freezers</b>
HCFC-123	123	11	R, N			
HCFC-22	22	12, 502	R, N	R, N	R, N	R, N
HFC-23		13, 13B1, 503	R, N			
HFC-134a	134a	12	R, N		R, N	R, N
HFC-152a		12			N	N
HFC-227ea		12	N			
HFC-236fa		114	R, N			
HFC-245fa	Genetron® 245fa	114	R, N			
R-401A, R-401B	MP-39, MP-66	12	R, N	R	R, N	R, N
R-402A, R-402B	HP-80, HP-81	502	R, N			R, N
R-403B	Isceon 69-L	13, 13B1, 503	R, N*			
R-404A	HP-62, 404A	502	R, N			R, N
R-406A	GHG	12, 500	R		R	R
R-407A, R-407B	Klea 407A, 407B	502	R, N	R, N		
R-408A (HCFC Blend Epsilon)	408A	502	R			
R-409A (HCFC Blend Gamma)	409A	12			R	R
R-411A, R-411B	411A, 411B	12, 500, 502	R, N			
R-428A	RS-52	502		R, N	R, N	R, N
R-507	AZ-50	502	R, N			
R-508A (PFC Blend Alpha)	KLEA 5R3	13, 13B1, 503	R, N			
R-508B	Suva 95	13, 13B1, 503	R, N			
FRIGC (HCFC Blend Beta)	FRIGC FR-12, 416A	12, 500	R, N		R, N	R, N
Free Zone (HCFC Blend Delta)	Free Zone / RB-276	12	R, N	R, N	R, N	R, N
Hot Shot (HCFC Blend Omicron)	Hot Shot, KarKool, 414B	12, 500	R, N	R, N	R, N	R, N
GHG-X4 (HCFC Blend Xi)	GHG-X4, Autofrost,	12, 500	R, N	R, N	R, N	R, N





McCool Chill-it, 414A

**Acceptable Substitutes for Class I (CFCs) Substances in Non-Commercial Refrigeration under the Significant New Alternatives Policy (SNAP) Program as of June 12, 2008 (continued)**

Substitutes (Name Used in Federal Register)	Trade Name	ODS Being Replaced	Industrial Process Refrigeration	Ice Skating Rinks	Household Refrigerators	Household Freezers
GHG-X5	GHG-X5	12, 500	R, N		R, N	R, N
R-420A	Choice R-420A	12, 500	R, N	R, N	R, N	R, N
(HCFC Blend Lambda)	GHG-HP	12	R, N		R, N	R, N
FREEZE 12	FREEZE 12	12	R, N	R, N	R, N	R, N
411C	G2018C	12, 500, 502	R, N	R, N		
NARM-502	NARM-502	13, 503	R, N			
THR-01	THR-01	12			N	N
THR-02	THR-02	12	R, N		N	N
THR-04	THR-04	502	R, N	R, N	R, N	
HCFC-22/HCFC-142b		12	R, N		R, N	R, N
Ikon A, Ikon-12 (Blend Zeta)	Ikon A, Ikon-12	12	R, N		N	N
Ikon B	Ikon B	12	R, N		N	N
FOR12A, FOR12B	FOR12A, FOR12B	12	R, N		R, N	R, N
SP34E	SP34E	12			R, N	R, N
HFE-7100, HFE-7200 as a secondary heat transfer fluid in not-in-kind systems		11, 12, 114, 115, 502	R, N			
HFC-134a/HBr (92/8)		12, 502	N			
Hydrofluoroether-7000	HFE-7000	11,113	R,N			
ISCEON 39TC	ISCEON 39TC	12	R,N			
RS-24 (2002 formulation)		12	R,N	R,N	R,N	R,N
R-407C	SUVA 407C, KLEA 407C	502	R, N	R, N	R, N	R, N
R-421B	Choice R-421B	12, 502	R, N	R, N	R, N	R, N
R-422C	ICOR XLT1	502	R,N			
R-426A	RS-24 (new formulation)	12	R,N	R,N	R,N	R,N



**Acceptable Substitutes for Class I (CFCs) Substances in Non-Commercial Refrigeration under the Significant New Alternatives Policy (SNAP) Program as of June 12, 2008 (continued)**

<b>Substitutes (Name Used in Federal Register)</b>	<b>Trade Name</b>	<b>ODS Being Replaced</b>	<b>Industrial Process Refrigeration</b>	<b>Ice Skating Rinks</b>	<b>Household Refrigerators</b>	<b>Household Freezers</b>
CO <sub>2</sub>		13, 13B1, 503	R, N			
Ammonia Vapor Compression		12, 502	R, N	R, N		
Ammonia Absorption		12			N	N
Propane, Propylene, Butane, HC Blend A, B	HC-12a, OZ-12	all	R, N*			
Self-chilling cans using CO <sub>2</sub>		12, 502			R, N	
Evaporative/Desiccant Cooling		all	N			

Key: R = Retrofit Uses, N = New Uses \*Prohibited for other end-uses. See the list of unacceptable refrigerants below.



**Unacceptable Substitute Refrigerants  
Significant New Alternatives Policy (SNAP) Program as of June 12, 2008**

<b>Substitutes (Name Used in Federal Register)</b>	<b>Trade Name</b>	<b>ODS Being Replaced</b>	<b>End-Uses</b>	<b>Reason</b>
<b>All flammable refrigerants, including OZ-12 (Hydrocarbon Blend A) and HC-12a (Hydrocarbon Blend B), except for HFC-152a in new MVAC equipment</b>		CFC-12	Motor Vehicle Air Conditioning, retrofit and new	lack of adequate risk assessment that characterizes incremental flammability risk
<b>OZ-12 (Hydrocarbon Blend A) and HC-12a (Hydrocarbon Blend B)</b>	OZ-12, HC-12a	CFC-12	All end-uses other than Industrial Process Refrigeration, retrofit and new	lack of adequate risk assessment that characterizes incremental flammability risk
<b>R-141b</b>		CFC-11	Centrifugal Chillers, new	high ODP, other substitutes with lower overall risk have been identified
<b>R-176*</b>		CFC-12	All end-uses, retrofit and new	contains CFC-12
<b>R-403B</b>		R-502	All end-uses other than Industrial Process Refrigeration, retrofit and new	contains a perfluorocarbon that exhibits extremely high GWP and very long lifetime
<b>R-405A</b>		CFC-12	All end-uses, retrofit and new	contains a perfluorocarbon that exhibits extremely high GWP and very long lifetime
<b>MT-31</b>		all CFCs and HCFCs	All end-uses, retrofit and new	a chemical contained in this blend presents an unacceptable toxicity risk
<b>Hexafluoropropylene (HFP) and all HFP-containing blends</b>		all CFCs and HCFCs	All end-uses, retrofit and new	presents an unacceptable toxicity risk
<b>Self-Chilling Cans using HFC-134a or HFC-152a</b>		CFC-12, HCFC-22, R-502	Household Refrigeration, Transport Refrigeration, Vending Machines, Cold Storage Warehouses and Retail Food Refrigeration; retrofit and new	unacceptably high greenhouse gas emissions from direct release of refrigerant to the atmosphere
<b>NARM-22</b>		HCFC-22	All end-uses, retrofit and new	contains HCFC-22

\*R-176 contains CFC-12, HCFC-22, and HCFC-142b. It is a different product from RB-276, typically sold under the name "Freezone."



**Environmental Protection Agency  
Air and Radiation Stratospheric Protection Division 6205J**

**Acceptable Substitutes for Class II (HCFCs) Substances in Air Conditioning and Refrigeration  
under the Significant New Alternatives Policy (SNAP) Program as of June 12, 2008**

Substitutes (Name Used in Federal Register)	Trade Name	Household and Light Commercial AC	Commercial Comfort Air Conditioning	Industrial Process Refriger- ation	Industrial Process Air Conditioning	Bus and Passenger Train AC	Cold Storage Warehouse Systems	Ice Skating Rinks	Refriger- ated Transport	Retail Food Refriger- ation	Ice Machines	Very Low Temp Refriger- ation	Household and other Refrigerated Appliances
R-410A	AZ-20	N	N	N	N	N	N	N	N	N	N	N	N
R-410B	Suva 9100	N	N	N	N		N	N	N	N	N		N
R-404A	HP62	R,N	R,N	R, N	R,N		R,N	R,N	R,N	R,N	R,N	R,N	R,N
R-407C	Suva 407C, KLEA 407C	R, N	R, N	R, N	R, N	R, N	R, N	R, N	R, N	R, N	R, N	R,N	R, N
R-421A	Choice R421A	R,N	R,N	R,N	R,N		R,N	R,N	R,N	R,N	R,N		R,N
R-421B	Choice R421B			R,N			R,N	R,N	R,N	R,N	R,N		R,N
R-422B	ICOR XAC1	R, N	R, N	R, N	R, N	R,N	R, N	R, N	R, N	R, N	R, N	R,N	R, N
R-422C	ICOR XLT1	R, N	R, N	R, N	R, N		R, N	R, N	R, N	R, N	R, N	R,N	R, N
R-422D	ISCEON MO29	R,N	R,N	R,N	R,N	R,N	R,N	R,N	R,N	R,N	R,N		R,N
R-424A	RS-44 (new formulation)	R,N	R,N	R,N	R,N		R,N	R,N	R,N	R,N	R,N		R,N
R-428A	RS-52			N			R,N	R,N	R,N	R,N	R,N		R,N
R-134a	HFC-134a	N	-	-	-	R, N	-	-	-	-	-		-
R-245fa	Genetron- 245fa		R, N (123)									N (141b)	
R-507A	AZ-50	R, N	R, N	R, N	R, N		R, N	-	R, N	R, N	R, N		R, N
R-417A	Isceon 59, NU- 22	R, N	R, N	R, N	R, N	R, N	R, N	R, N	R, N	R, N	R, N	R,N	R, N
R-125/134a/600a (28.1/70.0/1.9)		R, N	R, N	R, N	R, N	R, N			R, N				
Hydrofluoroether- 7000	HFE-7000											R, N	
RS-44 (2003 formulation)		R, N	R, N	R, N	R, N		R, N	R, N	R, N	R, N	R, N		R, N
RS-45 (proposed ASHRAE: R-434A)	RS-45	R,N	R,N	R,N	R,N		R,N	R,N	R,N	R,N	R,N		R,N
R- 125/290/134a/600a (55.0/1.0/42.5/1.5)	ICOR AT-22	R, N	R, N	R, N	R, N		R, N	R, N	R, N	R, N	R, N	R,N	R, N
ISCEON 79	ISCEON 79			R, N			R, N	R, N	R, N	R, N	R, N		R, N
KDD5	KDD5	R,N	R,N	R,N	R,N	R,N	R,N	R,N	R,N	R,N	R,N		R,N
Self-chilling cans using CO <sub>2</sub>		-	-	-	-		R, N	-	R, N	R, N	-		R, N
Ammonia		N <sup>1</sup>	N <sup>2</sup>	N <sup>3</sup>	N <sup>3</sup>		N <sup>3</sup>	N <sup>3</sup>	-	N <sup>4</sup>	N <sup>3</sup>		N <sup>1</sup>



**Acceptable Substitutes for Class II (HCFCs) Substances in Air Conditioning and Refrigeration  
under the Significant New Alternatives Policy (SNAP) Program as of June 12, 2008**

Substitutes (Name Used in Federal Register)	Trade Name	Household and Light Commercial AC	Commercial Comfort Air Conditioning	Industrial Process Refriger- ation	Industrial Process Air Conditioning	Bus and Passenger Train AC	Cold Storage Warehouse Systems	Ice Skating Rinks	Refriger- ated Transport	Retail Food Refriger- ation	Ice Machines	Very Low Temp Refriger- ation	Household and other Refrigerated Appliances
Evaporative Cooling		N	N	-	N		-	-	-	-	-	-	-
Desiccant Cooling		N	N	-	N		-	-	-	-	-	-	-
Water/Lithium bromide		-	N	-	-		-	-	-	-	-	-	-
THR-03	THR-03	N <sup>5</sup>	N	R, N	N		N	N	R, N	N	N		N
HFE-7100, HFE- 7200 for secondary heat transfer in NIK systems				N									

Key: R = Retrofit Uses, N = New Uses, (-) = Not submitted for review against this end use or not practical to use the substitute refrigerant in this end use.

1. Absorption systems; 2. Absorption chillers or vapor compression with secondary loop; 3. Vapor compression or absorption systems; 4. Vapor compression with a secondary loop; 5. Only approved for window air conditioning units.



<b>Description of Class II End Uses</b>		
<b>End Use</b>	<b>Air Conditioning and Refrigeration Systems or Applications</b>	<b>Ozone Depleting Substance</b>
Household and Light Commercial Air Conditioning	Heat pumps, central air conditioning, direct-expansion commercial air conditioners, packaged terminal air conditioners, room air conditioners, and split system air conditioners	HCFC-22
Commercial Comfort Air Conditioning	Reciprocating, centrifugal and screw chillers	HCFC-22, CFC-12, R-500, and CFC-11
Industrial Process Refrigeration	Refrigeration applications within the chemical, pharmaceutical and petrochemical industries, the oil and gas industry, the metallurgical industry, civil engineering, sports and leisure facilities, and food processing.	HCFC-22, CFC-12, R-500, and R-502
Industrial Process Air Conditioning	Air conditioning systems that perform a critical mission in a high-temperature industrial environment, such as cooling a control cab on a crane in a foundry or protecting a computer room in a steel mill.	HCFC-22, CFC-12, and CFC-114
Cold Storage Warehouse Systems	Public and private facilities used to store meat, produce, dairy products, frozen food, and other perishable goods.	HCFC-22, R-502 and CFC-12
Bus and Passenger Train Air Conditioning	Motor vehicle air conditioning systems for buses and passenger trains.	HCFC-22
Ice Skating Rinks	Ice Skating Rinks	HCFC-22, CFC-12, and R-502
Refrigerated Transport	Refrigeration systems in trucks, trailers, railcars, ships, internodal containers, on board ships, and air conditioning systems in buses and passenger trains.	CFC-12, R-500 and R-502
Retail Food Refrigeration	Stand alone refrigeration cases found in small markets, convenience stores, restaurants and other food establishments, large systems found in supermarkets, and HCFC-22 systems found in a wide variety of retail and service establishments.	HCFC-22, CFC-12, and R-502
Ice Machines	Small, medium, and large ice makers used by a number of entities including restaurants and hotels.	CFC-12
Household and Other Refrigerated Appliances	Refrigerators, freezers, water coolers, vending machines, and dehumidifiers.	CFC-12 and R-502

1. Substitution through retrofit is only applicable to HCFC-22 systems.

Refrigerant blends that contain Class II Ozone Depleting Substances include, but are not limited to, R-401A, R-401B, R-402A, R-402B, R-403B, R-406A, R-408A, R-409A, R-411A, R-411B, R-411C, R-414A, R-414B, and R-416A.





Alternative Refrigerant Manufacturers, con't																
Refrigerant	Arkema 800-343-7940	Dupont 800-235-7882	Greencool 703-643-2376	Honeywell 800-522-8001	ICI 800-275-5532	ICOR 800-357-4062	IKON 505-345-2707	CFC Refimax 800-406-2292	People's Welding Supply 800-382-9006	Refrigerant Solutions LTD	RMS of Georgia 800-347-5872	Rhodia Ltd.	Solpower 888-289-8866	Technical Chemical 800-527-0885	TechnoChem Co., Ltd. <sup>1</sup>	Tsinghua University of Beijing <sup>2</sup>
R-508B		Suva 95														
HCFC Blend Beta								FRIGC FR-12								
HCFC Blend Delta											Free Zone / RB-276					
GHG-X4									Autofrost / Chill-It							
GHG-X5									GHG-X5							
GHG-HP									GHG-HP							
Hot Shot						Hot Shot										
Blend Zeta							Ikon-12, Ikon A									
Ikon B							Ikon B									
Freeze 12														Freeze 12		
G2018C			R-411C													
THR-02, THR-03																THR-02, THR-03
Isceon 59/NU-22		Isceon 59				NU-22						Isceon 59				
Isceon 79		Isceon 79										Isceon 79				
Isceon 89		Isceon 89										Isceon 89				
FOR12A, FOR12B															FOR12A, FOR12B	
RS-45										RS-45						
SP34E													SP34E			

<sup>1</sup> and Inha University

<sup>2</sup> and the Beijing Inoue Qinghua Refrigeration Technology Company LTD