



Wind Integration Impacts: What Have We Learned?

Michael Milligan (Consultant)
Debbie Lew

National Wind Technology Center
National Renewable Energy Laboratory
Golden, Colorado USA

303-384-6900

michael_milligan@nrel.gov

debra_lew@nrel.gov





Acknowledgements

Thanks to:




Brian Parsons, NREL



J. Charles Smith, Utility Wind Integration Group



Edgar DeMeo, Renewable Energy Consulting Services



Brett Oakleaf, Xcel Energy



Kenneth Wolf, Minnesota Public Utilities Commission

Matt Schuerger, Energy Systems Consulting Services, LLC



Robert Zavadil, Enernex Corporation



Mark Ahlstrom, WindLogics



Dora Yen Nakafuji, California Energy Commission



Critical review/input from Nicholas Miller and Richard Piwko of GE Energy, Kevin Porter, Exeter Associates, and Henry Shiu, University of California, Davis on an earlier version of this presentation



Exeter Associates, Inc.

Presentation Outline

- Issues and time frames of importance
- What are wind's impacts, how are they measured?
- Principles of integration analysis
- Emerging best practices
- Stakeholder best practices
- Recent high-penetration studies
- Insights and remaining issues
- Ongoing work

Wind System Integration at NREL

- National Wind Technology Center
- Systems Integration Team
- Advising PUCs and the power industry as technical reviewers to integration studies
- Method development



Problem Introduction


- Reliable power system operation requires balance between load and generation *within acceptable statistical limits*
- Output of wind plants cannot be controlled and scheduled with high degree of accuracy
- Wind plants becoming large enough to have measurable impact on system operating cost
- System operators concerned that ***additional*** variability introduced by wind plants will increase system operating cost



Emerging Study Best-Practices

- Start by quantifying physical impacts
- Divide the impacts by time scale
 - Regulation
 - Load following and imbalance
 - Scheduling and unit commitment
 - Capacity value
- Analyze cost impact of wind in context of entire system in each time scale
 - Load variability
 - Wind variability
 - What is wind's impact on total variability and cost?
 - Allocation: recognize wind's positive and negative impacts


Time Frames of Wind Impact



- Typical U.S. terminology
 - Regulation -- seconds to a few minutes -- similar to variations in customer demand
 - Load-following -- tens of minutes to a few hours -- demand follows predictable patterns, wind less so
 - Scheduling and commitment of generating units -- hours to several days -- wind forecasting capability?
 - Capacity value (planning): based on reliability metric (ELCC=effective load carrying capability)


Decomposition of Control Area Loads

- Control area load & generation can be decomposed into three parts:
 - Base Load
 - Load Following
 - Regulation



Regulation & Load Following

	<i>REGULATION</i>	<i>LOAD FOLLOWING</i>
<i>Patterns</i>	<i>Random, uncorrelated</i>	<i>Largely correlated</i>
<i>Generator control</i>	<i>Requires AGC</i>	<i>Manual</i>
<i>Maximum swing (MW)</i>	<i>Small</i>	<i>10 – 20 times more</i>
<i>Ramp rate (MW/minute)</i>	<i>5 – 10 times more</i>	<i>Slow</i>
<i>Sign changes</i>	<i>20 – 50 times more</i>	<i>Few</i>



Impact of Variable Power Sources

- Power system is designed to handle tremendous variability in loads
- Wind adds to that variability
- System operator must balance loads=resources (within statistical tolerance)
- Key implication: ***It is not necessary or desirable to match wind's movements on a 1-1 basis***


Typical Objective of Integration Studies

- Determine the physical impact of wind on system operation across important time frames
 - Regulation (a capacity service; AGC)
 - Load following (ramp and energy components)
 - Unit commitment (scheduling)
 - Planning/capacity credit (same as capacity value)
- Use appropriate prices/costs to assess ancillary service cost impact of wind based on the measured physical impacts
- Not all studies focus on all time frames


Where Does Wind Data Come From?

- Meso-scale meteorological modeling that can “re-create” the weather at any space and time
- Model is run for the period of study and must match load time period
- Wind plant output simulation and fit to actual production of existing plants

Minnesota: Xcel



Colorado: Xcel



Challenges of Actual Data

- Power Information (PI) system
- Data storage error
 - Results from PI system data compression
- Old wind technology behavior does not reflect current-future performance



Comparison of Cost-Based U.S. Operational Impact Studies

Date	Study	Wind Capacity Penetration (%)	Regulation Cost (\$/MWh)	Load Following Cost (\$/MWh)	Unit Commitment Cost (\$/MWh)	Gas Supply Cost (\$/MWh)	Total Operating Cost Impact (\$/MWh)
May '03	Xcel-UWIG	3.5	0	0.41	1.44	na	1.85
Sep '04	Xcel-MNDOC	15	0.23	na	4.37	na	4.60
June '06	CA RPS Multi-year	4	0.45*	trace	na	na	0.45
Feb '07	GE/Pier/CAIAP	20	0-0.69	trace	na***	na	0-0.69***
June '03	We Energies	4	1.12	0.09	0.69	na	1.90
June '03	We Energies	29	1.02	0.15	1.75	na	2.92
2005	PacifiCorp	20	0	1.6	3.0	na	4.60
April '06	Xcel-PSCo	10	0.20	na	2.26	1.26	3.72
April '06	Xcel-PSCo	15	0.20	na	3.32	1.45	4.97
Dec '06	MN 20%	31**					4.41**

* 3-year average; total is non-market cost

** highest integration cost of 3 years; 30.7% capacity penetration corresponding to 25% energy penetration; 24.7% capacity penetration at 20% energy penetration

*** found \$4.37/MWh reduction in UC cost when wind forecasting is used in UC decision


Wind Capacity Value in the US

<u>Region/Utility</u>	<u>Method</u>	<u>Note</u>
CA/CEC	ELCC	Rank bid evaluations for RPS (mid 20s); 3-year near-match capacity factor for peak period
PJM	Peak Period	Jun-Aug HE 3 p.m. -7 p.m., capacity factor using 3-year rolling average (20%, fold in actual data when available)
Minnesota 20% Study	ELCC	Found significant variation in ELCC: 4%, 15%, 25% and variation based on year
ERCOT	10%	May change to capacity factor, 4 p.m. -6 p.m., Jul (2.8%)
MN/DOC/Xcel	ELCC	Sequential Monte Carlo (26-34%)
GE/NYSERDA	ELCC	Offshore/onshore (40%/10%)
CO PUC/Xcel	ELCC	Full ELCC study using 10-year data set; inaccuracies introduced by load forecasting algorithm. Average approximately 12.5%
RMATS	Rule of thumb	20% all sites in RMATS
PacifiCorp	ELCC	Sequential Monte Carlo (20%). New Z-method 2006
MAPP	Peak Period	Monthly 4-hour window, median
PGE		33% (method not stated)
Idaho Power	Peak Period	4 p.m. -8 p.m. capacity factor during July (5%)
PSE and Avista	Peak Period	PSE will revisit the issue (lesser of 20% or 2/3 Jan C.F.)
SPP	Peak Period	Top 10% loads/month; 85 th percentile

How Are Wind's Impacts Calculated?

How is Regulation Impact Calculated?


- Based on actual high-frequency (fast) system load data and wind data
- If wind data not available, use NREL high-resolution wind production data characteristics
- Impact of the wind variability is then compared to the load variability
- Preferred metric: ORNL regulation allocation approach
- Regulation cost impact of wind is based on physical impact and appropriate cost of regulation (market or internal)



–Realistic calculation of wind *plant* output (linear scaling from single anemometer is incorrect)

How is Load Following Impact Calculated?


- Based on actual system load data
- ...and wind data from *same* time period
 - Meteorological simulation to capture **realistic** wind profile, typically 10-minute periods and multiple simulated/actual measurement towers
 - Realistic calculation of wind **plant** output (linear scaling from single anemometer is incorrect)
- Wind variability added to **existing system variability** →



Implies no one-one backup for wind


How is Unit Commitment Impact Calculated?

- Requires a realistic system simulation for at least one year (more is better)
- Compare system costs with and without wind
- Use load and wind forecasts in the simulation
- Separate the impacts of variability from the impacts of uncertainty



How is Capacity Value Calculated?

- Uses similar data set as unit commitment modeling
 - Generation capacities, forced outage data
 - Hourly time-synchronized wind profile(s)
 - Several years' of data preferred
- Reliability model used to assess ELCC
- Wind capacity value is the increased load that wind can support at the same annual reliability as the no-wind case



High-Penetration Cases

- Minnesota PUC: 15-25% wind penetration (based on energy)
- Idaho Power: about 30% (peak)
- Avista: 30% peak

Minnesota 20% Wind Study

- Objective: Calculate ancillary service cost and capacity value of 20% wind penetration (by energy)
- Study analyzed 15, 20, 25% case
- Wind Capacity 5,689 MW on system peak of 18,527 MW (25% energy case; 30.7% capacity penetration)
- Connection with the MISO market






Figure 1: Location of "proxy towers" (model data extraction points) on inner grid.

Imbalance Across MISO Footprint



5-Minute Load/Net Load Changes: 25% Wind Case: Within-hour movement handled within MN



Key Innovation: Use of Variable Operating Reserve Dependent on Wind Generation




Figure 30: Illustration of time varying “operating reserve margin” developed from statistical analysis of hourly wind generation variations.

Wind Impact on Operating Reserves


Table 18: Estimated Operating Reserve Requirement for MN Balancing Authority – 2020 Load

Reserve Category	Base		15% Wind		20% Wind		25% Wind	
	MW	%	MW	%	MW	%	MW	%
Regulating	137	0.65%	149	0.71%	153	0.73%	157	0.75%
Spinning	330	1.57%	330	1.57%	330	1.57%	330	1.57%
Non-Spin	330	1.57%	330	1.57%	330	1.57%	330	1.57%
Load Following	100	0.48%	110	0.52%	114	0.54%	124	0.59%
Operating Reserve Margin	152	0.73%	310	1.48%	408	1.94%	538	2.56%
Total Operating Reserves	1049	5.00%	1229	5.86%	1335	6.36%	1479	7.05%

Notes on Table:

- Assumes 2020 MN Balancing Authority peak load of 20984 MW
- Requirements for load following and reserve margin based on two standard deviations of the five-minute variability and next hour forecast error, respectively.

Wind Integration Costs



Recent Studies in the Northwest

- Avista Utilities: Up to 30% wind penetration (peak)
- Idaho Power: Up to about 30% wind penetration (peak)
- BPA: analytical work in progress; integration cost is consistent with others
- Potential follow-on work to the NW Wind Integration Action Plan (NWIAP) on regional basis
- Northwest Wind Integration Action Plan:
<http://www.nwcouncil.org/energy/Wind/Default.asp>

Idaho Power


Table 15. Vista results using historical mid-C prices

Vista Results Using Historical Mid-C Prices					
study year	penetration level (MW)	cost per MWh wind	annual avg energy price		cost as % energy price
1998	300	\$3.19	\$27.61		11.6%
1998	600	\$4.73	\$27.61		17.1%
1998	900	\$6.06	\$27.61		21.9%
1998	1,200	\$6.92	\$27.61		25.1%
2000	300	\$21.89	\$132.17		16.6%
2000	600	\$30.30	\$132.17		22.9%
2000	900	\$39.06	\$132.17		29.6%
2000	1,200	\$39.40	\$132.17		29.8%
2005	300	\$10.69	\$58.19		18.4%
2005	600	\$9.32	\$58.19		16.0%
2005	900	\$10.58	\$58.19		18.2%
2005	1,200	\$8.12	\$58.19		14.0%

From Idaho Power Corp Wind Integration Study


Avista

Wind Integration Cost Components



From Avista Wind Integration Study: Kalich, UWIG

Impact of Forecast Error



From Avista Wind Integration Study: Kalich, UWIG

California Intermittency Analysis Project (from GE Energy, CEC Workshop)


Conclusions

- System operation with 12,500 MW of wind generation and 2,600 MW of solar is feasible with 2010X scenario infrastructure. 2020 scenario will be easier.
- An economically rational unit commitment must include intermittent resource forecasts.
- Such a commitment results in sufficient flexibility for successful operation.
- Some operating conditions will be more challenging:
 - Periods of high load rise, such as winter evening peak, may see an increased rate of rise.
 - Periods of light load will increase in frequency, and when combined with extremely high wind, may require mitigation (e.g., curtailment).
- Requirements for load following and regulation increase, resulting in increased duty for the balance of the generation portfolio. Possible additional cost for increased regulation ranges from 0 to 69 ¢ / MWhr of intermittent renewable.
- Changes in revenue are likely to affect economic viability of incumbent generators. It is possible that some will exit.
- Variable cost of production, wholesale load payments, total emissions and natural gas consumption drop substantially.
- Mitigation schemes examined in the study will be beneficial for challenging operating conditions, and can be pursued on an incremental and systemic basis.

Other Recent Studies



Minnesota Dept. of Commerce/ Enernex Study Framework

- 2010 scenario of 1500 MW of wind in 10 GW peak load system (< 700 MW wind currently)
- WindLogics: 10-minute power profiles from atmospheric modeling to capture geographic diversity
- Wind forecasting incorporated
- Extensive historic utility load and generator data available
- Monopoly market structure, no operating practice modification or change in conventional generation expansion plan



Minnesota Dept. of Commerce/ Enernex Study Results

- Incremental regulation due to wind $3\sigma = 8$ MW
- Incremental intra-hour load following burden increased 1-2 MW/min. (negligible cost)
- Hourly to daily wind variation and forecasting error impacts are largest costs
- Monthly total integration cost: \$2-\$11/MWh, with an average of \$4.50/MWh
- Capacity Credit (ELCC) of 26%




Completed September 2004 www.commerce.state.mn.us

(Industry Info and Services / Energy Utilities / Energy Policy / Wind Integration Study)


New York ISO and NYSEERDA/ GE Energy Study

- 2008 scenario of 3300 MW of wind in 33-GW peak load system (< 200 MW wind currently)
- AWS Truewind: wind power profiles from atmospheric modeling to capture statewide diversity
- Competitive market structure:
 - for ancillary services
 - allows determination of generator and consumer payment impacts
- Transmission examined: no delivery issues
- Post-fault grid stability improved with modern turbines



New York ISO and NYSERDA/ GE Energy Study Impacts

- Incremental regulation of 36 MW due to wind
- No additional spinning reserve needed
- Incremental intra-hour load following burden increased 1-2 MW/ 5 min.
- Hourly ramp increased from 858 MW to 910 MW
- All increased needs can be met by existing NY resources and market processes
- Capacity credit (UCAP) of 10% average onshore and 36% offshore
- Significant system cost savings of \$335- \$455 million on assumed 2008 natural gas prices of \$6.50-\$6.80 /MMBTU.




New York ISO and NYSERDA/ GE Energy Study

Forecasting and Price Impacts

- Day-ahead unit-commitment forecast error σ increased from 700-800 MW to 859-950 MW
- Total system variable cost savings increases from \$335 million to \$430 million when state of the art forecasting is considered in unit commitment (\$10.70/MWh of wind)
- Perfect forecasting increases savings an additional \$25 million


Standard Deviations of Day-Ahead Forecast Errors



http://www.nyserda.org/publications/wind_integration_report.pdf

Xcel Colorado/Enernex Study

- 10%, 15%, and 20%* penetration (wind nameplate to peak load) examined for ~7 GW peak load
- Gas storage & nominations
 - Gas imbalance
 - Extra gas burn for reserves
- Gas price sensitivity
- Transmission constraints
- O&M increase for increased start/stops
- Real-time market access



* 20% case is currently underway

Xcel Colorado/Enernex Study

Penetration Level	<u>10%</u>	<u>15%</u>
Hourly Analysis	\$2.26/MWh	\$3.32/MWh
Regulation	\$0.20/MWh	\$0.20/MWh
Gas Supply (1)	\$1.26/MWh	\$1.45/MWh
Total	\$3.72/MWh	\$4.97/MWh

(1) Costs includes the benefits of additional gas storage

Additional work is underway to analyze a 20% penetration case.

- **Without use of 300 MW pumped hydro unit, costs at 10% would be \$1.30/MWh higher**

Gas Storage Benefits/Results

- Summer/winter arbitrage
 - Cost savings in filling in summer and withdrawing in winter
- Reduction in need for financial hedge (call option)
 - Because the price of the gas in the storage field is known, there is no need to financially hedge the market price of the gas

Wind Penetration	10%	15%
\$/ MWH Gas Impact No Storage Benefits	\$2.17	\$2.52
\$/ MWH Gas Impact With Storage Benefits	\$1.26	\$1.45

Methods

Emerging Best Practices

- Capture system characteristics and response through operational simulations and modeling
- Capture wind deployment scenario geographic diversity through synchronized weather simulation
- Couple with actual historic utility load and load forecasts
- Use actual large wind farm power statistical data for short-term regulation and ramping
- Examine wind variation in combination with load variations
- Utilize wind forecasting best practice and combine wind forecast errors with load forecast errors
- Examine actual costs independent of tariff design structure

Stakeholder Review

Emerging Best Practices

- Technical review committee (TRC)
 - Bring in at beginning of study
 - Discuss assumptions, processes, methods, data
- Periodic TRC meetings with advance material for review
- Examples in Minnesota, Colorado, California, New Mexico, and interest by other states

Factors that Influence Integration Cost Results

- Wind penetration
- Balancing area size
 - Conventional generation mix
 - Load aggregation benefits
- Wind resource geographic diversity
- Market-based or self-provided ancillary services
- Size of interconnected electricity markets

Conclusions and Insights

- Additional operational costs are moderate for penetrations at or above portfolio standard levels
- For large, diverse electric balancing areas, existing regulation and load following resources and/or markets are adequate, accompanying costs are low
- Unit commitment and scheduling costs tend to dominate
- State of the art forecasting can reduce costs
 - majority of the value can be obtained with current state-of-the-art forecasting
 - additional incremental returns from increasingly accurate forecasts
- Realistic studies are data intensive and require sophisticated modeling of wind resource and power system operations

Conclusions and Insights

Data and Modeling Assumptions Matter

- Data from PI (Power Information) system
 - compression may artificially smooth high-resolution (fast) data
 - Missing data correction algorithm introduced artificial ramps in wind data
- Complex system influences wind capacity value and integration cost
 - Scheduled maintenance of conventional generation
 - Hydro dispatch (needs more systematic work)
 - Interchange schedules, markets

Some Remaining Issues

- Higher wind penetration impacts
- Effect of mitigation strategies
 - Balancing area consolidation and dynamic scheduling
 - Complementary generation acquisition (power system design; quick-response generation) and interruptible/price responsive load
 - Power system operations practices and wind farm control/curtailment
 - Hydro dispatch, pumped hydro, other storage and markets (plug-hybrid electric vehicles, hydrogen)
- Integration of wind forecasting and real time measurements into control room operations

In Process

(Enernex, WindLogics, Ariva, UWIG team)

- Xcel (MN) Renewable Development Fund:
Control Room Integration of Wind
 - Define, design, build and demonstrate a complete wind power forecasting system for use by Xcel system operators
 - Optimize the way that wind forecast information is integrated into the control room environment
 - R&D on defensive operating strategies: Value of off-site met towers, high wind warning system, rapid update cycle (RUC) model

In Process

- Smaller balancing authority projects



– Sacramento Municipal Utility District: high penetration, investigate value of pumped hydro



– Public Service of New Mexico: limited conventional resources, high ramping wind, export and minimum load issues



– Grant County projects: integrate with constrained existing hydro




Indicates NREL Systems Integration Participation

In Process

- Xcel Colorado 20% wind scenario (based on wind capacity to peak)
- BPA/Northwest Wind Integration Forum
- Western Governors' Clean and Diverse Energy Plan (CDEAC) recommendations and follow thru
 - Increased participation in transmission studies (SWAT, NTAC/BPA, MISO, etc.)
- Interest by Northwestern Energy (MT) in integration study
- Southwest Public Service (not yet started)
- Northern Tier Transmission Group (discussion)
- Western Wind Integration Study



Increasing Attention in North America



- IEEE Power Engineering Society Magazine, November/December 2005
- Planning update in Nov/Dec 2007
- Wind Power Coordinating Committee kickoff June 2006, Montreal PES meeting
- Utility Wind Integration Group (UWIG): Operating Impacts and Integration Studies User Group
- www.uwig.org




**Accelerating the Integration of Wind
Generation into Utility Power Systems**

New Study

Western Wind Integration Study

Western Wind Integration Study



Questions to address

- Is it cheaper to use local wind resources or import better class resources from out-of-state?
- How do out-of-state resources compare to local wind resources for matching load profiles? Does geographical diversity help reduce system variability?
- What are the benefits from long distance transmission that accesses multiple wind resources that are geographically diverse?
- Can the required transmission costs be covered by wind or other future generation sources?
- What additional aggregate system operational impacts or costs are imposed by wind variability? What kinds of mitigation measures help to manage that incremental variability?
- How does hydro help with wind integration?
- What is the role and value of wind forecasting?
- What benefit does Balancing Area cooperation or consolidation bring to wind variability management?
- Is there a benefit to aggregating regional wind demand instead of individual utility action?
- How does each wind area contribute to reliability and capacity value?

Key Tasks

- Stakeholder group
- Technical review committee
- Meso-scale modeling of wind
- Preliminary analysis
 - Examine load and wind profiles
 - Preliminary control area consolidation analysis
 - Build wind/transmission supply curves
- Design scenarios
- Evaluate scenarios for cost and operational impacts
 - Production Simulation Analysis
 - Evaluate physical performance and limitations of power grid
 - Evaluate economic/financial performance
- Evaluate mitigation measures
 - Operational strategies
 - Technology options

