



# ENERGY STAR Qualified Homes Codes & Standards Information

## Insulation Requirements for the National Builder Option Package

The National Builder Option Package requires that the insulation levels of a home meet or exceed Sections N1102.1 and N1102.2 of the 2004 IRC. For example, compliance may be determined by meeting the prescriptive insulation requirements listed by component below. Compliance may also be determined using U-factor alternatives or a total UA alternative as defined in Section N1102.1.2 and Section N1102.1.3. In all cases, insulation shall be inspected to Grade I installation as defined in the RESNET Standards by a RESNET-certified rater. Note that the fenestration requirements of the 2004 IRC do not apply to the fenestration requirements of the National Builder Option Package.

<u>Climate Zone</u>	<u>Ceiling R-Value</u>	<u>Wood Frame Wall R-Value</u>	<u>Floor R-Value</u>	<u>Basement Wall R-Value</u>	<u>Slab R-Value &amp; Depth</u>	<u>Crawl Space R-Value</u>
1	30	13	13	0	0	0
2	30	13	13	0	0	0
3	30	13	19	0	0	5/13
4 except Marine	38	13	19	10/13	10, 2 ft.	10/13
5 and Marine 4	38	19 or 13+5	30	10/13	10, 2 ft.	10/13
6	49	19 or 13+5	30	10/13	10, 4 ft.	10/13
7 and 8	49	21	30	10/13	10, 4 ft.	10/13

Reference: 2004 International Supplement to the International Codes. Copyright 2004. Falls Church, Virginia: International Code Council, Inc. Reproduced with permission. All rights reserved. (Excerpted from 2004 IRC Table N1102.1)

## Best Practices for Sizing Air Conditioners and Heat Pumps

Best practices for sizing air conditioners and heat pumps include:

- Sizing to the manufacturers' performance data;
- Sizing the equipment for the total and latent load capacities;
- Determining the auxiliary heat balance point when sizing heat pumps; and
- Considering both the cooling and heating loads in different climates when sizing heat pumps.

## ENERGY STAR Products – Average Energy Savings & Key Product Criteria

<b>Product</b>	<b>Average Energy Savings</b>	<b>Key Product Criteria</b>
<b>Air Conditioner</b>	25%	SEER ≥ 14 ; EER ≥ 11.5
<b>Heat Pump</b>	20%	SEER ≥ 14 ; EER ≥ 11.5; HSPF ≥ 8.2
<b>Furnace</b>	15%	AFUE ≥ 90% (About 15% more efficient than the minimum federal efficiency standards)
<b>Dish Washers</b>	25%	Energy Factor ≥ 0.58: At least 25% more energy efficient than minimum Federal government standards
<b>Clothes Washers</b>	50%	Minimum Modified Energy Factor (MEF) of 1.42
<b>Refrigerator</b>	15%	At least 15% more energy efficient than the minimum Federal government standard (NAECA)



# ENERGY STAR Qualified Homes Codes & Standards Information

Product	Average Energy Savings	Key Product Criteria
Windows	ENERGY STAR Home Windows for IRC Climate Zones  If IRC Climate Zone is not 2 or 4, then refer to the ENERGY STAR Window Climate Zones below	<b>IRC Climate Zone 4:</b> U-Factor $\leq$ 0.40; SHGC $\leq$ 0.45 <b>IRC Climate Zone 2:</b> U-Factor $\leq$ 0.55; SHGC $\leq$ 0.35; or U-Factor $\leq$ 0.56; SHGC $\leq$ 0.33 U-Factor $\leq$ 0.57; SHGC $\leq$ 0.32 U-Factor $\leq$ 0.58; SHGC $\leq$ 0.31 U-Factor $\leq$ 0.59; SHGC $\leq$ 0.30 U-Factor $\leq$ 0.60; SHGC $\leq$ 0.29 U-Factor $\leq$ 0.61; SHGC $\leq$ 0.28 U-Factor $\leq$ 0.62; SHGC $\leq$ 0.27 U-Factor $\leq$ 0.63; SHGC $\leq$ 0.26 U-Factor $\leq$ 0.64; SHGC $\leq$ 0.25
	Savings vary by climate region (as defined by the ENERGY STAR windows program) and home characteristics  See web-site for correct selection of ENERGY STAR windows for building site	<b>Northern Climate Zone:</b> U-Factor $\leq$ 0.35; SHGC $\leq$ Any <b>North/Central Climate Zone:</b> U-Factor $\leq$ 0.40; SHGC $\leq$ 0.55 <b>South/Central Climate Zone:</b> U-Factor $\leq$ 0.40; SHGC $\leq$ 0.40; or U-Factor $\leq$ 0.41; SHGC $\leq$ 0.36 U-Factor $\leq$ 0.42; SHGC $\leq$ 0.31 U-Factor $\leq$ 0.43; SHGC $\leq$ 0.24 <b>Southern Climate Zone:</b> U-Factor $\leq$ 0.65; SHGC $\leq$ 0.40; or U-Factor $\leq$ 0.66; SHGC $\leq$ 0.39 U-Factor $\leq$ 0.67; SHGC $\leq$ 0.39 U-Factor $\leq$ 0.68; SHGC $\leq$ 0.38 U-Factor $\leq$ 0.69; SHGC $\leq$ 0.37 U-Factor $\leq$ 0.70; SHGC $\leq$ 0.37 U-Factor $\leq$ 0.71; SHGC $\leq$ 0.36 U-Factor $\leq$ 0.72; SHGC $\leq$ 0.35 U-Factor $\leq$ 0.73; SHGC $\leq$ 0.35 U-Factor $\leq$ 0.74; SHGC $\leq$ 0.34 U-Factor $\leq$ 0.75; SHGC $\leq$ 0.33  <a href="http://www.energystar.gov/index.cfm?c=windows_doors.pr_crit_windows">http://www.energystar.gov/index.cfm?c=windows_doors.pr_crit_windows</a>
Thermostat	Savings depend on homeowner use	Shipped with a default energy saving program that is capable of maintaining two separate programs and four temperature settings or more for each day
Ventilating Fans	65%	<b>Range hoods (up to 500 cfm):</b> maximum allowable sound level of 2.0 sones; minimum efficacy level of 2.8 cfm/Watt <b>Bathroom fans (10 to 80 cfm):</b> maximum allowable sound level of 2.0 sones; minimum efficacy level of 1.4 cfm/Watt; minimum rated airflow at 0.25 static w.g. 60% of 0.1 static w.g. airflow <b>Bathroom fans (90 to 130 cfm):</b> maximum allowable sound level of 2.0 sones; minimum efficacy level of 2.8 cfm/Watt; minimum rated airflow at 0.25 w.g. 70% of 0.1 static w.g. airflow <b>Bathroom fans (140 to 500 cfm):</b> maximum allowable sound level of 3.0 sones; minimum efficacy level of 2.8 cfm/Watt; minimum rated airflow at 0.25 w.g. 70% of 0.1 static w.g. airflow Light sources must use pin-based fluorescent technology Warranty provided must be a minimum of 1 year
Lighting	66%	<a href="http://www.energystar.gov/index.cfm?c=lighting.pr_lighting">http://www.energystar.gov/index.cfm?c=lighting.pr_lighting</a>
Ceiling Fans	Savings depend on homeowner use	<a href="http://www.energystar.gov/index.cfm?c=ceiling_fans.pr_ceiling_fans">http://www.energystar.gov/index.cfm?c=ceiling_fans.pr_ceiling_fans</a>