



## Trough Thermal Storage - Status Spring 2007 -

---

NREL/DLR Trough Workshop - Denver

March 2007

Paul Nava, Ulf Herrmann

*FLAGSOL GmbH*

# Trough Thermal Storage - Content

---

## 1. Storage incentive – Why storage

## 2. Trough thermal storage technology

- how does it look for a commercial plant designer –

a. 2 Tank Molten salt storage

b. PCM (Phase Change Material) storage

c. Cement storage

d. Thermocline

## 3. Final judgment


# Thermal Storage Incentive (1)

---

1. Solar at daylight, electricity demand also at dark night – Increasing the capacity factor of the plant
2. Shifting electricity production to peak demand
3. Fulfil firm capacity and dispatchability requirements

# Thermal Storage Incentive (2)


On planet earth surface, solar energy is on daylight with changing intensity, but the demand has a different distribution over the time; hence an energy storage is required for shifting energy



- Electrical storage is not implementable due to cost reasons
- Thermal storages technologies are available which increase power plant utilization
- Economical justification:
  - For a flat rate energy payment tariff and no capacity limit there is no economical justification
  - Adding enough storage to a plant with maximum capacity will reduce the generation cost as long as the storage is cheaper than a second power island

# Thermal Storage Incentive (3)

Shifting energy to peak demand necessitate a mean of storage



- Electrical storage is not implementable due to cost reasons
- Thermal storages technologies are available which can shift the electricity production to the desired demand
- Economical justification:
  - The higher electricity rates for the practical shift of energy should compensate for the additional storage costs

# Thermal Storage Incentive (4)

---

**Dispatchability upgrades solar energy to the utility desired power supply, necessitate a source of thermal energy storage**

- Thermal storages technologies are available which can delay and shift the electricity production in accordance with dispatcher instructions
- Economical justification:
  - Higher dispatchable electrical capacity value should compensate for the additional storage costs
  - In the extreme case of a fully dispatchable power plant, the plant utilization rate might be reduced, requiring higher compensation (for the energy waste due to “storage full” cases)
  - With a small amount of fossil backup full firm capacity can be achieved

# Two Tank Molten salt storage



Molten salt storage proven at Solar Two

# Widely used in Process Industry



a) Molten Salt system with an output of 14 MW at 430°C, England




b) Molten Salt system with an output of 88 MW at 400°C, Bauxite digestion plant in Germany




b) Molten Salt system with an output of 7.7 MW at 470°C, melamine plant in Germany

Heat Transfer plants. All photographs by Bertrams Heatec Ltd.






# Andasol HTF and molten salt storage systems arrangement



# Molten salt storage arrangement



# Andasol storage - Technical parameter

---

- **Type:** 2-Tank Molten Salt Storage
- **Storage Fluid:** Nitrate salt mixture (60%  $\text{NaNO}_3$  and 40%  $\text{KNO}_3$ )
- **Melting Point of Fluid:** 223°C
- **Storage Capacity:** 1,010 MWh (~7.5 hrs full load operation)
- **Storage Tank Size:** 14 m height  
37 m diameter
- **Salt Mass:** 27,500 tons
- **Flow Rate:** 953 kg/s
- **Cold Tank Temperature:** 292°C
- **Hot Tank Temperature:** 386°C


# Andasol storage - construction




# Andasol storage - Economical justification

## Simplified indication of thermal storage required costs

- Andasol, Spain power plants design incorporate about 1,000,000 kWh thermal storage for the 50MW power block
- Conventional steam turbine power island costs are at about \$1000 per kW
- The alternative to the thermal storage introduction would be about equivalent to the double of the power block
- Requiring an equivalent of below \$50 per kWh thermal storage



# Specific Cost of Storage Concepts




# Phase Change Material storage

---

- Originally attractive due to PCM high latent heat capacity
- Coat a tail wind from DSG (Direct Steam Generation) as DSG needs latent heat storage for evaporation
- **\$20/kWht target price**
- Re. cascading PCM's for sensible heat HTF; better wait for one PCM results, current molten salt storage almost reached cascaded PCM potential price

# PCM storage design; approach

- Composite (tested in laboratory)
- Encapsulation (tested in laboratory)
- Sandwich (Test in 2007)
- Inter-media (under investigation by Weizmann Institut Research)




- The composite and encapsulated feasibility have been both proven in laboratory, the Sandwich test will assess its lower costs potential




# Cement Storage

- Attractive due to its low costs potential
- Could serve both for oil as well as for DSG sensible heat portions (pre and super heating's)
- ~\$25/kWh target price
  - Tube register design found to be the best
  - Heat transfer enhancement is important:
    - Material: concrete with quartz aggregates
    - Fins and other structure not cost effective
  - Modular storage, SH and PH sections for example, enhance utilization and reduces size (costs)
  - Full scale storage test ITES 2007-8 (1MW for a 5MWe plant)



# Thermocline storage

- Saving potential with storage filler
  - ~\$20/kWht price potential
- 
- Filler is essential
  - No saving without filler (1 tank saving < +~1/4 nitrate salt dominant costs)
  - Test filler material selection: quartzite and silica sand
  - 2.3 MWh successful proof of concept test



# Final judgment

---

- Storage converts „as available energy“ to much more valuable „dispatchable energy“  
→ *Storage will be required in the future*
- Molten Salt: most promising, O&M will assess its costs and potential reduction
- Cement: Simple and therefore straightforward to evaluate but not proven up to now
- Thermocline: Clear potential with filler, needs full scale test
- PCM: potentially available for DSG (costs unclear), doubtful for sensible HTF