

## Table 9.7 – Environmental Compliance Equipment Costs

(Nominal Dollars)

	<u>1990</u>	<u>1995</u>	<u>2000</u>	<u>2001</u>	<u>2002</u>	<u>2003</u>	<u>2004</u>
Average Flue Gas Desulfurization Costs at Utilities							
Average Operation & Maintenance Costs (mills/kWh)	1.35	1.16	0.96	1.27	1.11	1.23	1.38
Average Installed Costs (\$/kW)	118	126	124	131	124	124	145

**Source:** *Electric Power Annual 2004*, Table 5.3., DOE/EIA-0348(04) (November 2005). EIA, *Electric Power Annual 2001*, DOE/EIA-0348(01) (March 2003), Table 5.3.

**Notes:**

Includes plants under the Clean Air Act that were monitored by the Environmental Protection Agency, even if sold to an unregulated entity.

These data are for plants with a fossil-fueled, steam-electric capacity of 100 megawatts or more.